Orifice Metering of Natural Gas and Other Related Hydrocarbon Fluids—Concentric, Square-edged Orifice Meters

Part 4—Background, Development, Implementation Procedure, and Example Calculations



AGA Report No. 3
Part 4



Manual of Petroleum
Measurement Standards
Chapter 14.3.4

American Gas Association
400 North Capitol Street, NW
Washington, DC 20001

American Petroleum Institute
200 Massachusetts Avenue, NW
Washington, DC 20001

FOURTH EDITION, OCTOBER 2019

REAFFIRMED, JANUARY 2026

Special Notes

This AGA/API publication necessarily addresses problems of a general nature. With respect to particular circumstances, local, state, and federal laws and regulations should be reviewed.

Neither AGA and API nor any of AGA's or API's employees, subcontractors, consultants, committees, or other assignees make any warranty or representation, either express or implied, with respect to the accuracy, completeness, or usefulness of the information contained herein, or assume any liability or responsibility for any use, or the results of such use, of any information or process disclosed in this publication. Neither AGA and API nor any of API's employees, subcontractors, consultants, or other assignees represent that use of this publication would not infringe upon privately owned rights.

This API publications may be used by anyone desiring to do so. Every effort has been made by AGA/API to ensure the accuracy and reliability of the data contained in them; however, AGA/API makes no representation, warranty, or guarantee in connection with this publication and hereby expressly disclaims any liability or responsibility for loss or damage resulting from its use or for the violation of any authorities having jurisdiction with which this publication may conflict.

This AGA/API publication is published to facilitate the broad availability of proven, sound engineering and operating practices. These publications are not intended to obviate the need for applying sound engineering judgment regarding when and where these publications should be utilized. The formulation and publication of this AGA/API publication is not intended in any way to inhibit anyone from using any other practices.

Any manufacturer marking equipment or materials in conformance with the marking requirements of an API standard is solely responsible for complying with all the applicable requirements of that standard. API does not represent, warrant, or guarantee that such products do in fact conform to the applicable API standard.

All rights reserved. No part of this work may be reproduced, translated, stored in a retrieval system, or transmitted by any means, electronic, mechanical, photocopying, recording, or otherwise, without prior written permission from either the American Gas Association, 400 N. Capitol Street, NW, Washington, DC 20001 or API Publishing Services, 200 Massachusetts Avenue, NW, Suite 1100, Washington, DC 20001.

Copyright © 2019 American Petroleum Institute

Foreword

Nothing contained in this AGA/API publication is to be construed as granting any right, by implication or otherwise, for the manufacture, sale, or use of any method, apparatus, or product covered by letters patent. Neither should anything contained in the publication be construed as insuring anyone against liability for infringement of letters patent.

The verbal forms used to express the provisions in this document are as follows.

Shall: As used in a standard, “shall” denotes a minimum requirement in order to conform to the standard.

Should: As used in a standard, “should” denotes a recommendation or that which is advised but not required in order to conform to the standard.

May: As used in a standard, “may” denotes a course of action permissible within the limits of a standard.

Can: As used in a standard, “can” denotes a statement of possibility or capability.

This document was produced under API standardization procedures that ensure appropriate notification and participation in the developmental process and is designated as API *Manual of Petroleum Measurement Standard* (MPMS) Chapter 14.3.3 and AGA Report No. 3, Part 3. Questions concerning the interpretation of the content of this publication or comments and questions concerning the procedures under which this publication was developed should be directed in writing to the Director of Standards, American Petroleum Institute, 200 Massachusetts Avenue, NW, Suite 1100, Washington, DC 20001. Requests for permission to reproduce or translate all or any part of the material published herein should also be addressed to the director.

This AGA/API publication is reviewed and revised, reaffirmed, or withdrawn at least every five years. A one-time extension of up to two years may be added to this review cycle. Status of the publication can be ascertained from the API Standards Department, telephone (202) 682-8000. A catalog of API publications and materials is published annually by API, 200 Massachusetts Avenue, NW, Suite 1100, Washington, DC 20001.

A catalog of AGA Operations and Engineering publications, which is published and updated as needed and can be obtained by contacting AGA Operations and Engineering Department, phone (202) 824-7000 or web site http://www.aga.org/knowledgecenter.

Suggested revisions are invited and should be submitted to the Standards Department, API, 200 Massachusetts Avenue, NW, Suite 1100, Washington, DC 20001, standards@api.org or Operations and Engineering Department, American Gas Association, 400 North Capitol Street, NW, Washington, DC 20001, http://www.aga.org/knowledgecenter.

Contents

Page

1 Scope . . . 1

2 Normative References . . . 1

3 Symbols, Units, and Terminology . . . 1
3.1 General . . . 1
3.2 Symbols and Units . . . 1

4 History and Development . . . 4
4.1 Background . . . 4
4.2 Historical Database . . . 6
4.3 Recent Data Collection Efforts . . . 6
4.4 Basis for Equation . . . 12
4.5 Reader-Harris/Gallagher Equation . . . 14
4.6 Expansion Factor Revision . . . 21
4.7 Rigorous Method for Calculation of Mass Flow Uncertainty . . . 24
4.8 Research on Installation Effects . . . 26

5 Implementation Procedures . . . 26
5.1 Introduction . . . 26
5.2 Solution for Mass or Volume Flow Rate . . . 27
5.3 Special Procedures and Example Calculations for Natural Gas Applications . . . 39
5.4 Example Calculations . . . 55

Annex A (informative) Development of Flow Equation Algorithm . . . 97

Bibliography . . . 104

Figures
1 Flange Tap Data Comparison-Mean Deviation (%) versus Nominal Beta Ratio . . . 17
2 Flange Tap Data Comparison-Mean Deviation (%) versus Nominal Pipe Diameter . . . 18
3 Flange Tap Data Comparison-Mean Deviation (%) versus Reynolds Number Ranges . . . 18
4 Corner Tap Data Comparison-Mean Deviation (%) versus Nominal Beta Ratio . . . 18
5 Corner Tap Data Comparison-Mean Deviation (%) versus Reynolds Number Ranges . . . 19
6 D-D/2 (Radius) Tap Data Comparison-Mean Deviation (%) versus Nominal Beta Ratios . . . 19
7 D-D/2 (Radius) Tap Data Comparison-Mean Deviation (%) versus Reynolds Number Ranges . . . 19
8 Scatter Diagram Based on Buckingham Equation . . . 20
9 Scatter Diagram Based on Reader-Harris/Gallagher Equation . . . 20
A.1 Number of Iterations Required to Solve for Orifice Plate Coefficient of Discharge-Direct Substitution Method . . . 102
A.2 Number of Iterations Required to Solve for Orifice Plate Coefficient of Discharge-Newton-Raphson Method . . . 103

Tables
1 Nominal Tube Diameters and Beta Ratios Included in API/GPA Discharge Coefficient Research . . . 8
2 Regression Data Points by Tapping Configuration . . . 10
3 Regression Database Point Distribution for Flange Taps . . . 10
4 Regression Database Point Distribution for Corner Taps . . . 11
5 Regression Database Point Distribution for D-D/2 (Radius Taps) . . . 11
6 Example Y_1 Calculated Values Where k = 1.1 . . . 22
7 Example Y_1 Calculated Values Where k = 1.3 . . . 23
8 Example Y_1 Calculated Values Where k = 1.5 . . . 23

Contents

Page

9 Typical Values of Linear Coefficients of Thermal Expansion 29
10 Units, Conversion Constants, and Universal Constants 30
11 Example Test Case Abbreviations 55

Introduction

This part of the standard for Concentric, Square-edged Orifice Meters provides the background and history of the development of the standard and recommends a method to solve the flow equations for mass and volumetric flow.

Orifice Metering of Natural Gas and Other Related Hydrocarbon Fluids—Concentric, Square-edged Orifice Meters Part 4—Background, Development, Implementation Procedures, and Example Calculations

1 Scope

Chapter 14.3, Part 4 describes the background and development of the equation for the coefficient of discharge of flange-tapped, square-edged, concentric orifice meters, and recommends a flow rate calculation procedure. The recommended procedures provide consistent computational results for the quantification of fluid flow under defined conditions, regardless of the point of origin or destination, or the units of measure required by governmental customs or statute. The procedures allow different users with different computer languages on different computing hardware to arrive at almost identical results using the same standardized input data.

2 Normative References

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

API *Manual of Petroleum Measurement Standards*

Chapter 12.2.1, *Calculation of Petroleum Quantities Using Dynamic Measurement Methods and Volume Correction Factors*, *Part 1—Introduction*

Chapter 14.2/AGA Report No. 8, *Compressibility Factors of Natural Gas and Other Related Hydrocarbon Gases*

Chapter 14.3.1/AGA Report No. 3, Part 1, *Orifice Metering of Natural Gas and Other Related Hydrocarbon Fluids—Concentric, Square-edged Orifice Meters, Part 1—General Equations and Uncertainty Guidelines*

Chapter 14.3.2/AGA Report No. 3, Part 2, *Orifice Metering of Natural Gas and Other Related Hydrocarbon Fluids—Concentric, Square-edged Orifice Meters, Part 2—Specification and Installation Requirements*

Chapter 14.3.3/AGA Report No. 3, Part 3, *Orifice Metering of Natural Gas and Other Related Hydrocarbon Fluids—Concentric, Square-edged Orifice Meters, Part 3—Natural Gas Applications*

3 Symbols, Units, and Terminology

3.1 General

The symbols and units used are specific to API *MPMS* Chapter 14.3.3/AGA Report No. 3, Part 3 and were developed based on the USC inch—pound system of units. Regular conversion factors can be used where applicable; however, if SI units are used, the more generic equations in API *MPMS* Chapter 14.3.1/AGA Report No. 3, Part 1 should be used for consistent results.

3.2 Symbols and Units

C_d	orifice plate coefficient of discharge
$C_d(FT)$	coefficient of discharge at a specified pipe Reynolds number for flange-tapped orifice meter
C_{d_o}	first flange-tapped orifice meter coefficient of discharge constant within iteration scheme
C_{d_1}	second flange-tapped orifice meter coefficient of discharge constant within iteration scheme