ASCE STANDARD

ANSI/ ASCE/EWRI 56-10

ANSI/ ASCE/EWRI 57-10

Guidelines for the Physical Security of Water Utilities

ANSI/ASCE/EWRI 56-10

Guidelines for the Physical Security of Wastewater/ Stormwater Utilities

ANSI/ASCE/EWRI 57-10

This document uses both the International System of Units (SI) and customary units

ASCE

Approved American National Standard ANSI

EWRI ASCE

ENVIRONMENTAL & WATER RESOURCES INSTITUTE

ASCE STANDARD ANSI/ASCE/EWRI 56-10
ANSI/ASCE/EWRI 57-10

American Society of Civil Engineers

Guidelines for the Physical Security of Water Utilities

ANSI/ASCE/EWRI 56-10

Guidelines for the Physical Security of Wastewater/ Stormwater Utilities

ANSI/ASCE/EWRI 57-10

This document uses both the International System of Units (SI) and customary units.

ASCE
AMERICAN SOCIETY OF CIVIL ENGINEERS

Approved American National Standard
ANSI

EWRI
ASCE
ENVIRONMENTAL & WATER RESOURCES INSTITUTE

Published by the American Society of Civil Engineers

Library of Congress Cataloging-in-Publication Data

Guidelines for the physical security of water utilities, ASCE/EWRI 56-10. Guidelines for the physical security of wastewater-stormwater utilities ASCE/EWRI 57-10.
p. cm.
Includes bibliographical references and index.
ISBN 978-0-7844-1126-1 (alk. paper)
1. Water treatment plants–Security measures–Standards. 2. Storm sewers–Security measures–Standards. I. American Society of Civil Engineers. II. Environmental and Water Resources Institute (U.S.) III. Guidelines for the physical security of wastewater-stormwater utilities ASCE/EWRI 57-10
TD434.G85 2010
363.6'10684–dc22
2010047168

Published by American Society of Civil Engineers
1801 Alexander Bell Drive
Reston, Virginia 20191
www.pubs.asce.org

This standard was developed by a consensus standards development process which has been accredited by the American National Standards Institute (ANSI). Accreditation by ANSI, a voluntary accreditation body representing public and private sector standards development organizations in the U.S. and abroad, signifies that the standards development process used by ASCE has met the ANSI requirements for openness, balance, consensus, and due process.

While ASCE's process is designed to promote standards that reflect a fair and reasoned consensus among all interested participants, while preserving the public health, safety, and welfare that is paramount to its mission, it has not made an independent assessment of and does not warrant the accuracy, completeness, suitability, or utility of any information, apparatus, product, or process discussed herein. ASCE does not intend, nor should anyone interpret, ASCE's standards to replace the sound judgment of a competent professional, having knowledge and experience in the appropriate field(s) of practice, nor to substitute for the standard of care required of such professionals in interpreting and applying the contents of this standard.

ASCE has no authority to enforce compliance with its standards and does not undertake to certify products for compliance or to render any professional services to any person or entity.

ASCE disclaims any and all liability for any personal injury, property damage, financial loss or other damages of any nature whatsoever, including without limitation any direct, indirect, special, exemplary, or consequential damages, resulting from any person's use of, or reliance on, this standard. Any individual who relies on this standard assumes full responsibility for such use.

ASCE and American Society of Civil Engineers—Registered in U.S. Patent and Trademark Office.

Photocopies and reprints. You can obtain instant permission to photocopy ASCE publications by using ASCE's online permission service (http://pubs.asce.org/permissions/requests/). Requests for 100 copies or more should be submitted to the Reprints Department, Publications Division, ASCE (address above); e-mail: permissions@asce.org. A reprint order form can be found at http://pubs.asce.org/support/reprints/.

Copyright © 2011 by the American Society of Civil Engineers.
All Rights Reserved.
ISBN 978-0-7844-1126-1
Manufactured in the United States of America.

18 17 16 15 14 13 12 11 1 2 3 4 5

STANDARDS

In 2006, the Board of Direction approved the revision to the ASCE Rules for Standards Committees to govern the writing and maintenance of standards developed by the Society. All such standards are developed by a consensus standards process managed by the Society's Codes and Standards Committee (CSC). The consensus process includes balloting by a balanced standards committee made up of Society members and nonmembers, balloting by the membership of the Society as a whole, and balloting by the public. All standards are updated or reaffirmed by the same process at intervals not exceeding five years.

The following standards have been issued:

ANSI/ASCE 1-82 N-725 Guideline for Design and Analysis of Nuclear Safety Related Earth Structures

ASCE/EWRI 2-06 Measurement of Oxygen Transfer in Clean Water

ANSI/ASCE 3-91 Standard for the Structural Design of Composite Slabs and ANSI/ASCE 9-91 Standard Practice for the Construction and Inspection of Composite Slabs

ASCE 4-98 Seismic Analysis of Safety-Related Nuclear Structures

Building Code Requirements for Masonry Structures (ACI 530-02/ASCE 5-02/TMS 402-02) and Specifications for Masonry Structures (ACI 530.1-02/ASCE 6-02/TMS 602-02)

ASCE/SEI 7-10 Minimum Design Loads for Buildings and Other Structures

SEI/ASCE 8-02 Standard Specification for the Design of Cold-Formed Stainless Steel Structural Members

ANSI/ASCE 9-91 listed with ASCE 3-91

ASCE 10-97 Design of Latticed Steel Transmission Structures

SEI/ASCE 11-99 Guideline for Structural Condition Assessment of Existing Buildings

ASCE/EWRI 12-05 Guideline for the Design of Urban Subsurface Drainage

ASCE/EWRI 13-05 Standard Guidelines for Installation of Urban Subsurface Drainage

ASCE/EWRI 14-05 Standard Guidelines for Operation and Maintenance of Urban Subsurface Drainage

ASCE 15-98 Standard Practice for Direct Design of Buried Precast Concrete Pipe Using Standard Installations (SIDD)

ASCE 16-95 Standard for Load Resistance Factor Design (LRFD) of Engineered Wood Construction

ASCE 17-96 Air-Supported Structures

ASCE 18-96 Standard Guidelines for In-Process Oxygen Transfer Testing

ASCE/SEI 19-10 Structural Applications of Steel Cables for Buildings

ASCE 20-96 Standard Guidelines for the Design and Installation of Pile Foundations

ANSI/ASCE/T&DI 21-05 Automated People Mover Standards—Part 1

ANSI/ASCE/T&DI 21.2-08 Automated People Mover Standards—Part 2

ANSI/ASCE/T&DI 21.3-08 Automated People Mover Standards—Part 3

ANSI/ASCE/T&DI 21.4-08 Automated People Mover Standards—Part 4

SEI/ASCE 23-97 Specification for Structural Steel Beams with Web Openings

ASCE/SEI 24-05 Flood Resistant Design and Construction

ASCE/SEI 25-06 Earthquake-Actuated Automatic Gas Shutoff Devices

ASCE 26-97 Standard Practice for Design of Buried Precast Concrete Box Sections

ASCE 27-00 Standard Practice for Direct Design of Precast Concrete Pipe for Jacking in Trenchless Construction

ASCE 28-00 Standard Practice for Direct Design of Precast Concrete Box Sections for Jacking in Trenchless Construction

ASCE/SEI/SFPE 29-05 Standard Calculation Methods for Structural Fire Protection

SEI/ASCE 30-00 Guideline for Condition Assessment of the Building Envelope

SEI/ASCE 31-03 Seismic Evaluation of Existing Buildings

SEI/ASCE 32-01 Design and Construction of Frost-Protected Shallow Foundations

EWRI/ASCE 33-09 Comprehensive Transboundary International Water Quality Management Agreement

EWRI/ASCE 34-01 Standard Guidelines for Artificial Recharge of Ground Water

EWRI/ASCE 35-01 Guidelines for Quality Assurance of Installed Fine-Pore Aeration Equipment

CI/ASCE 36-01 Standard Construction Guidelines for Microtunneling

SEI/ASCE 37-02 Design Loads on Structures during Construction

CI/ASCE 38-02 Standard Guideline for the Collection and Depiction of Existing Subsurface Utility Data

EWRI/ASCE 39-03 Standard Practice for the Design and Operation of Hail Suppression Projects

ASCE/EWRI 40-03 Regulated Riparian Model Water Code

ASCE/SEI 41-06 Seismic Rehabilitation of Existing Buildings

ASCE/EWRI 42-04 Standard Practice for the Design and Operation of Precipitation Enhancement Projects

ASCE/SEI 43-05 Seismic Design Criteria for Structures, Systems, and Components in Nuclear Facilities

ASCE/EWRI 44-05 Standard Practice for the Design and Operation of Supercooled Fog Dispersal Projects

ASCE/EWRI 45-05 Standard Guidelines for the Design of Urban Stormwater Systems

ASCE/EWRI 46-05 Standard Guidelines for the Installation of Urban Stormwater Systems

ASCE/EWRI 47-05 Standard Guidelines for the Operation and Maintenance of Urban Stormwater Systems

ASCE/SEI 48-06 Design of Steel Transmission Pole Structures

ASCE/EWRI 50-08 Standard Guideline for Fitting Saturated Hydraulic Conductivity Using Probability Density Functions

ASCE/EWRI 51-08 Standard Guideline for Calculating the Effective Saturated Hydraulic Conductivity

ASCE/SEI 52-10 Design of Fiberglass-Reinforced Plastic (FRP) Stacks

ASCE/G-I 53-10 Compaction Grouting Consensus Guide
ASCE/EWRI 54-10 Standard Guideline for the Geostatistical Estimation and Block-Averaging of Homogeneous and Isotropic Saturated Hydraulic Conductivity
ASCE/SEI 55-10 Tensile Membrane Structures
ANSI/ASCE/EWRI 56-10 Guidelines for the Physical Security of Water Utilities
ANSI/ASCE/EWRI 57-10 Guidelines for the Physical Security of Wastewater/Stormwater Utilities
ASCE/T&DI/ICPI 58-10 Structural Design of Interlocking Concrete Pavement for Municipal Streets and Roadways

CONTENTS

Page

FOREWORD ix
ACKNOWLEDGMENTS xi

GUIDELINES FOR THE PHYSICAL SECURITY OF WATER UTILITIES

1 Application of Guidelines 1
1.1 Introduction 1
1.1.1 Elements of a Physical Protection System 1
1.1.1.1 Deterrence 1
1.1.1.2 Detection 1
1.1.1.3 Delay 1
1.1.1.4 Response 1
1.1.2 Design Basis Threat 1
1.1.2.1 Vandal 1
1.1.2.2 Criminal 1
1.1.2.3 Saboteur 2
1.1.2.4 Insider 2
1.2 Methodology for Applying These Guidelines 4
1.2.1 Instructions for Applying These Guidelines 4
1.2.1.1 Step 1: Vulnerability Assessment 4
1.2.1.2 Step 2: Characterize Design Basis Threat 5
1.2.1.3 Step 3: Identify Security Measures 5
1.2.1.4 Step 4: Consider Consequence Mitigation 5
1.2.2 Additional Information to Assist in Applying 6
1.2.2.1 New and Existing Facilities 6
1.2.2.2 Local Codes and Required Aesthetics 6
1.2.2.3 Assets Not Under Utility Control 6
1.2.2.4 Balance of the System 6
1.2.2.5 Value of the Asset 6
1.2.2.6 Levels of Security Measures 6
1.2.2.7 Response Time and Capabilities 6

2 Raw Water Facilities 7
2.1 Scope 7
2.2 Facility Mission 7
2.3 Philosophy of Security Approach 7
2.4 Benchmark Security Measures 7

3 Wells and Pumping Stations 13
3.1 Scope 13
3.2 Facility Mission 13
3.3 Philosophy of Security Approach 13
3.4 Benchmark Security Measures 13

4 Water Treatment Plants 19
4.1 Scope 19
4.2 Facility Mission 19
4.3 Philosophy of Security Approach 19
4.4 Benchmark Security Measures 19

5 Finished Water Storage Facilities 25
5.1 Scope 25
5.2 Facility Mission 25

5.3 Philosophy of Security Approach . . . 25
5.4 Benchmark Security Measures . . . 25

6 Water Distribution Systems . . . 31
6.1 Scope . . . 31
6.2 System Mission . . . 31
6.3 Philosophy of Security Approach . . . 31
6.4 Benchmark Security Measures . . . 31

7 Water System Support Facilities . . . 35
7.1 Scope . . . 35
7.2 Facility Mission . . . 35
7.3 Philosophy of Security Approach . . . 35
7.4 Benchmark Security Measures . . . 35

Appendix A Physical Security Elements . . . 41
A.1.0 Fencing and Perimeter Walls . . . 41
A.1.1 Chain-Link Fencing . . . 41
A.1.2 Anti-Climb/Anti-Cut Fencing . . . 41
A.1.3 Ornamental Fencing . . . 41
A.1.4 Perimeter Wall . . . 42
A.1.5 Fencing Topping . . . 42
A.1.6 Perimeter Line . . . 42
A.1.7 Fence Foundation Enhancements . . . 42
A.2.0 Gates . . . 42
A.2.1 Chain-Link Gates . . . 42
A.2.2 Electronic Gate Opening . . . 42
A.2.3 Electronic Gate Control System . . . 43
A.3.0 Site Areas . . . 43
A.3.1 Clear Zones . . . 43
A.3.2 Site Utilities . . . 43
A.4.0 Facility Entrances . . . 43
A.4.1 Sallyport Entrances . . . 43
A.4.2 Building Entrances . . . 44
A.5.0 Bollards and other Vehicle Barriers . . . 44
A.6.0 Exterior Surfaces . . . 44
A.7.0 Outdoor Security Lighting . . . 44
A.8.0 Signage . . . 44
A.8.1 Fence Signage . . . 44
A.8.2 Primary Site Entrance Signage . . . 44
A.8.3 Water Intake Delineation . . . 45
A.9.0 Electronic Security Systems . . . 45
A.9.1 Intrusion Detection Sensors: General . . . 45
A.9.2 Exterior Intrusion Detection . . . 45
A.9.2.1 Active Infrared Sensors . . . 45
A.9.2.2 Microwave Sensors . . . 45
A.9.2.3 Dual-Technology Sensors . . . 45
A.9.2.4 Buried Line Sensors . . . 45
A.9.2.5 Fence-Mounted Sensors . . . 45
A.9.3 Interior Intrusion Detection . . . 46
A.9.3.1 Dual-Technology Motion Sensors . . . 46
A.9.3.2 Linear Beam Sensors . . . 46
A.9.3.3 Glass-Break Sensors . . . 46
A.9.4 Door and Hatch Contact Alarm Switches . . . 46
A.9.5 Pipeline Vibration Detection . . . 46
A.10.0 Access Control Systems . . . 46
A.10.1 Access Control Systems: General . . . 46
A.10.2 Locks and Padlocks . . . 46
A.10.3 Numeric Keypad Locks . . . 46
A.10.4 Card Reader Systems . . . 46
A.11.0 Closed-Circuit Television (CCTV) Surveillance . . . 47
A.11.1 General Considerations . . . 47

A.11.2 Field of View . . . 47
A.11.3 CCTV Housings and Mounts . . . 47
A.11.4 Video Network Servers . . . 47
A.11.5 Digital Video Recorders . . . 47
A.11.6 CCTV Computer Application Software . . . 48
A.12.0 Security, Controls, and SCADA Wiring . . . 48
A.12.1 SCADA and Electrical Control Panel Enclosures . . . 48
A.13.0 Building Elements . . . 48
A.13.1 General . . . 48
A.13.2 Doors . . . 48
A.13.3 Security Grilles . . . 48
A.13.4 Security Cages . . . 48
A.14.0 Hatches, Vaults, and Vents . . . 48
A.14.1 Hatch, Vault, and Vent Alarms: General . . . 48
A.14.2 Roof or Sidewalk Hatches . . . 48
A.14.3 Roof Vents . . . 49
A.14.4 Vault Hatch with Elevated Curb . . . 49
A.14.5 Vault Door Hatch Set Flush with Top of a Structural Slab . . . 49
A.15.0 Online Water Quality Monitoring . . . 49
A.16.0 Operator Devices . . . 49
A.16.1 Man-Down Transmitter . . . 49
A.17.0 Chemical Fill-Line Locking Devices . . . 49
A.18.0 Hydrants . . . 49
A.19.0 Manholes . . . 49

GLOSSARY AND ABBREVIATIONS . . . 51
REFERENCES . . . 55

GUIDELINES FOR THE PHYSICAL SECURITY OF WASTEWATER/STORMWATER UTILITIES . . . 67

INDEX . . . 111

FOREWORD

These guidelines were developed as a joint effort between the American Society of Civil Engineers (ASCE) and the American Water Works Association (AWWA) with technical input from the Water Environment Federation (WEF), in accordance with ASCE Rules for Standards Committees, and were published initially as a proposed draft, *Guidelines for the Physical Security of Water Utilities* (ASCE/AWWA/WEF 2006). That consensus process included balloting by a balanced Standards Committee and reviewing during a public comment period. The provisions of this document have been written in permissive language and, as such, offer to the user a series of options or instructions but do not prescribe a specific course of action. Significant judgment is left to the user of these documents.

These guidelines use customary units with the International System of Units (SI) in parentheses. This approach was in the best interest of ASCE, AWWA, and WEF at the time of development of the initial Draft of these guidelines.

PURPOSE OF THE GUIDELINES

These guidelines apply to physical security for facilities used in potable water source, treatment, and distribution systems.

BACKGROUND OF THE DEVELOPMENT

Highlights related to the creation of all the Water Infrastructure Security Enhancements (WISE) guidance documents and/or standards in the early years of the twenty-first century are summarized below:

1. Under the U.S. Public Health Security and Bioterrorism Preparedness and Response Act of 2002 (PL 107–188), drinking water utilities serving more than 3,300 customers were required to conduct vulnerability assessments (VAs) of their water systems. The VAs often recommended security improvements to reduce the risk of malevolent acts (such improvements may also reduce the risk associated with natural events). Similar requirements for wastewater utilities have yet to be promulgated, but the protection of wastewater utility facilities using similar approaches has been promoted by the U.S. Environmental Protection Agency (USEPA) and various industry organizations. In addition, ASCE, AWWA, and WEF agreed to work together to develop materials to assist in the implementation of security recommendations and the overall improvement of water and wastewater infrastructure security. The project was funded by USEPA under a cooperative agreement to foster public/private partnership in water and wastewater security. This project was known as the USEPA Water Infrastructure Security Enhancements (WISE) Project.
2. The three organizations each became responsible for a portion of the project: AWWA led the drinking water supply, treatment, and distribution systems effort; WEF led the wastewater and stormwater collection, treatment, and disposal systems effort; and ASCE led the effort concerning the methodology and characteristics pertinent to design of contaminant detection and monitoring systems for both water and wastewater systems.
3. Phase 1 of the USEPA WISE project focused on the creation of Interim Voluntary Security Guidance documents (ASCE/AWWA/WEF 2004a, 2004b, 2004c). The purpose of these documents was to provide a centralized starting point for utilities as they integrate modern security practices into the management, operation, construction, or retrofit of their water, wastewater, and stormwater systems. Training materials were developed in Phase 2 to disseminate the information contained in the Phase 1 guidance documents.
4. Under the direction of USEPA, Phase 3 focused solely on the development of physical security guidelines for water, wastewater, and stormwater facilities. These voluntary consensus guidelines were first developed as the Draft and were published initially as *Guidelines for Physical Security for Water Utilities* (ASCE/AWWA/WEF 2006). The primary reviewers were members of the Water Supply Subcommittee of the ASCE WISE Standards Committee (SC), and the USEPA/ASCE/AWWA/WEF WISE Project Phase 3 Team.
5. The sections compiled in these guidelines are intended to provide direction to water utilities on how to design or retrofit their infrastructure, with consideration given to their unique circumstances and threats. A discussion of the various security threats and incidents that have occurred at water and wastewater utilities is provided in an American Water Works Association Research Foundation report by Welter (2003). This document can provide additional information in the assessment of security measures for utilities.
6. The USEPA Water Security Working Group presented its report *Recommendations of the National Drinking Water Advisory Council to the U.S. Environmental Protection Agency on Water Security Practices, Incentives, and Measures* to the National Drinking Water Advisory Council (NDWAC) on May 18, 2005 (WSWG 2005). Those findings included 18 features of an "active and effective" security program. These guidelines address the following NDWAC recommendations, which discuss physical security:
   a. Establish physical and procedural controls to restrict access to utility infrastructure to only those conducting authorized, official business and to detect unauthorized physical intrusions.
   b. Incorporate security considerations into decisions about acquisition, repair, major maintenance, and replacement of physical infrastructure; this should include consideration of opportunities to reduce risk through physical hardening and the adoption of inherently lower-risk design and technology options.
7. These guidelines should be implemented in concert with the other features and approaches described in the NDWAC report (WSWG 2005).

USE OF THESE GUIDELINES

The major points for the use of this document imply:

1. It is the responsibility of the user of an ASCE/EWRI standard or guideline to determine that the products and approaches described in the standard or guideline are suitable for use in the particular application being considered.
2. To effectively use these guidelines, a water utility should first complete a VA of its system. This VA should be completed in accordance with a generally accepted methodology such as the Risk Assessment Methodology for Water (RAM-W; Sandia Corporation 2002), the Vulnerability Self-Assessment Tool (VSAT; NACWA 2005), or other acceptable method. The resulting information will guide the utility in defining the capabilities and motives of its design basis threat (DBT) and in ranking each asset's criticality within the facility's system. The VA will also help to define the anticipated response time and response capability that, given the capabilities of the DBT, will characterize the robustness required for an effective security system.
3. The selection and recommendation of the physical protection approaches and measures contained in these guidelines are best engineering practices based on the collective experience and judgment of the WISE Standards Committee members. The physical security measures should be combined with management policies, operational procedures, and network security systems to form a comprehensive security system that provides multiple layers of protection or "protection in depth" for critical assets.
4. These guidelines contain information that utilities should consider when applying specific security technologies and methods to individual facilities or assets. These are described in Sections 2.0 through 7.0 (called "Guideline" in each section), which, in conjunction with the Foreword, Section 1.1 Introduction and its subsections, and the Appendices in this document, can be used as standalone documents. Most of the tables and figures of these guidelines were taken directly from ASCE/AWWA/WEF (2006) as cited herein, but Table 6-1 was adapted from that source due to public comments during the development process during the first six months of 2007 and the ASCE/EWRI Standards Committee ballots of 2008 and 2009.
5. It is important to recognize that a physical protection system should be designed as a site-specific system integrated into facility operations, response force capabilities, and the overall utility's security system to ensure that there are no gaps in protection. Furthermore, simply implementing the recommendations contained herein is no guarantee that an adversary cannot compromise a specific facility or critical asset.

SPECIAL ISSUES

1. These guidelines describe physical security approaches to delay or detect malevolent parties whose actions may otherwise defeat the mission of the utility. Enterprise-wide security approaches, while extremely important to any balanced security system, are beyond the scope of these guidelines. These approaches include management policies, administrative procedures, operational practices, and network security approaches, including supervisory control and data acquisition (SCADA) networks. Contaminant detection and monitoring systems, although briefly referenced in these guidelines, are also best employed as an integrated, enterprise-wide system. Guidance on enterprise-wide security approaches is provided in the USEPA WISE Phase 1 Interim Voluntary Security Guidance documents (ASCE/AWWA/WEF 2004a, 2004b, 2004c).
2. Added water security is beneficial for continuity of business, protection of water quality, provision of sufficient water quantity, ensuring public confidence, and protection of public health and safety. Thus, when implementing the security measures provided in these guidelines, the multiple benefits should be taken into account by utility staff and other stakeholders.
3. Within the scope of this document, domestic and international terrorists have been considered a special category of DBTs. With significantly enhanced tool and weapon capabilities, terrorists may be politically or ideologically motivated to cause maximum human casualties, often without regard for the terrorist's personal survival. Effectively protecting a facility from such a threat requires specialized security knowledge and equipment, and response forces typically not available to utilities. A utility that concludes that it is facing such a threat should seek guidance from specialized security experts and/or enhance its emergency response planning and execution to mitigate the consequences of such a terrorist attack. Strategies to counter such a defined threat may require higher-level measures than described in these guidelines.

DISCLAIMER

The information presented in these guidelines is intended to assist water utilities as they strive to improve the safety and security of their facilities, their employees, and the public. While the strategies and methods described here can reduce risk and enhance response and recovery actions, they cannot guarantee that any possible act of vandalism, violence, or terrorism will be prevented or stopped. As such, those responsible for the content and publication of this document can provide no guarantees for the performance of any actions taken in response to this guidance.

This document has been prepared in accordance with recognized engineering principles and should not be used without the user's competent knowledge for a given application. The publication of this document does not intend to warrant that the information contained herein is suitable for any general or specific use, and those responsible for the content and publication of this document take no position respecting the validity of patent rights. The user is advised that the determination of patent rights or risk of infringement is entirely their own responsibility.

ACKNOWLEDGMENTS

These voluntary guidelines were developed during the USEPA WISE Project, Phase 3 under the direction of the ASCE/EWRI WISE Standards Committee (ASCE/AWWA/WEF 2006). This committee consisted of the individuals listed below through the end of the Committee balloting process of August 2007. The members of the WISE Water Supply Subcommittee, which was the primary review group before the first ASCE/EWRI WISE SC pilot sections ballot, are also provided below. The CH2M HILL WISE Project Phase 3 Team members listed below drafted the document and assisted in the resolution reporting during the balloting process. The USEPA personnel listed with the Project Team reviewed material during the monthly WISE Project Partners conference calls of the USEPA WISE Project that ended around October 1, 2008.

Clifford L. Bowen, P.E.
William C. Boyle, Ph.D., P.E., B.C.E.E.
Erica M. Brown
Jeanette A. Brown, P.E., B.C.E.E.
Jonathan W. Bulkley, Ph.D., P.E.
Ivan Burrowes
James B. Conboy, P.E., B.C.E.E.
Joseph W. Dellapenna, Esq.
Clyde R. Dugan
John H. Easton, Ph.D.
Findlay G. Edwards, Ph.D., P.E., Vice Chair
Wayne Einfeld
Jorge A. Garcia, Ph.D., P.E.
Neil S. Grigg, Ph.D., P.E.
Yakir J. Hasit, Ph.D., P.E.
Todd Humphrey, P.E.
C. Dale Jacobson, P.E., B.C.E.E.
Jyung Seok Jeong
Conrad G. Keyes, Jr., Sc.D., P.E., P.S., D.W.R.E., Dist.M.ASCE, Chair
M. Patricia Lamb, C.U.S.A.
Thomas J. Lane, P.E.
Srinivasa Lingireddy, Ph.D., P.E.
Thomas J. Linville, P.E.
Daniel L. Lynch, P.E., B.C.E.E.
John W. McLaughlin, P.E.
Brian M. Murphy, P.E.
Irwin M. Pikus, Ph.D., Esq.
J. Alan Roberson, P.E.
Kyle E. Schilling, P.E., B.C.E.E, D.W.R.E.
Charles R. Stack, M.P.H.
C. Wesley Strickland, Esq.
Lloyd V. Urban, Ph.D., P.E.
James Van Norman
Gregory J. Welter, P.E., B.C.E.E.
James F. Wheeler, P.E.
Harold F. Wiedeman, P.E.
Robert C. Williams, P.E., B.C.E.E.

Water Supply Subcommittee

Edward E. Baruth (AWWA)
Beth Behner (AWWA)
Clifford L. Bowen, P.E.
Scott Brooks
Erica M. Brown
Clyde R. Dugan
Neil S. Grigg, Ph.D., P.E.
Todd Humphrey, P.E.
M. Patricia Lamb, C.U.S.A., Vice Chair
Thomas J. Lane, P.E.
Thomas J. Linville, P.E.
John W. McLaughlin, P.E., Chair
Brian M. Murphy, P.E.
James A. Roberson, P.E.
Roy Robinson, Past Chair
James S. Wailes, P.E. (AWWA)

The USEPA ASCE/AWWA/WEF WISE Project Team that worked with the CH2M HILL and its subconsultant Richard Brady and Associates, Inc. team members listed below organized and carried out the Phase 3 plan during June 2005 through the end of 2006 (ASCE/AWWA/WEF 2006). They included:

L. Christian Hanson, C.A.E. (ASCE), WISE Project Manager and Recording Secretary for the WISE SC
Conrad G. Keyes, Jr., Sc.D., P.E., P.S., D.W.R.E., WISE Standards Committee Chair
Findlay G. Edwards, Ph.D., P.E., WISE Standards Committee Vice Chair
John W. Mc Laughlin, P.E., Water Supply Subcommittee Chair
M. Patricia Lamb, C.U.S.A., Water Supply Subcommittee Vice Chair
Irwin M. Pikus, Ph.D., Esq., Methodology and Characteristics Subcommittee Chair
Yakir J. Hasit, Ph.D., P.E., Methodology and Characteristics Subcommittee Vice Chair
Jeanette A. Brown, P.E., B.C.E.E., Wastewater Stormwater Subcommittee Chair
William C. Boyle, Ph.D., P.E., B.C.E.E., Wastewater Stormwater Subcommittee Vice Chair
Stacy Passaro, P.E., B.C.E.E. (WEF), WISE Project Manager
James S. Wailes, P.E. (AWWA), WISE Project Manager

CH2M HILL Team

Jason M. Assouline
Paul A. Berg, P.E.
Richard D. Brady, P.E., B.C.E.E. (Richard Brady and Associates, Inc.)
Dale D. Gabel, P.E.
Forrest M. Gist, P.E.
Kristine K. Hargreaves, AIA
Yakir J. Hasit, Ph.D., P.E.
Sam Irrinki, P.E.
Alan B. Ispass, P.E., B.C.E.E.
Jacqueline T. Kepke, P.E.
M. Jane Mailand
Lena Perkins

USEPA

Gregory Spraul

Guidelines for the Physical Security of Water Utilities

Chapter 1
APPLICATION OF GUIDELINES

1.1 INTRODUCTION

These water utility guidelines recommend physical and electronic security measures for physical protection systems to protect against identified adversaries, referred to as design basis threats (DBTs), with specified motivations, tools, equipment, and weapons. Additional requirements and security equipment may be necessary to defend against threats with greater capabilities.

1.1.1 Elements of a Physical Protection System. Effective physical and electronic protection systems balance four elements (ASCE/AWWA/WEF 2004c): deterrence, detection, delay, and response.

1.1.1.1 Deterrence. Security measures such as lighting, the presence of closed-circuit television (CCTV), a clearly visible facility with no visual obstructions, or people in the area may deter an adversary from attacking a facility. Deterrence is not generally considered a part of a physical protection system with a predictable level of effectiveness; however, it can reduce the occurrence of crime or low-level vandal attacks.

1.1.1.2 Detection. Security measures such as sensors are intended to detect the presence of an intruder. An effective detection system should include electronic features such as sensors as well as cameras or visual observation for assessment of alarm validity. Depending on the types of sensors, a detection system may include lighting systems, motion detectors, monitoring cameras, access control equipment, or other devices.

1.1.1.3 Delay. Security features such as physical barriers are designed to delay an adversary until a response force can interrupt the adversary's actions. Delay features consist primarily of physical hardening devices often employed in multiple layers to provide protection in depth. Delay features are only effective when placed within a layer of detection.

1.1.1.4 Response. "Response" refers to actions taken to interrupt the adversary's task. Utility staff, the utility's security response force, or law enforcement may carry out the response, with the appropriate responder dependent on the threat and policy of the utility.

The capabilities of the responders to a security event, including number, authority, and weaponry, should be greater than the capabilities of the perceived threat to the facility. The appropriate response force should be identified during the facility's vulnerability assessment (VA) with notification, communication, and protocol requirements established in the utility's emergency response plan or a similar plan.

Figure 1-1 illustrates the interaction of detection (at the perimeter fence and exterior door), delay (fence, exterior door, and interior door), and the response time to an adversary's sequence of actions. This figure was originally developed by Mary Lynn Garcia of Sandia National Laboratories and uses a thief (that is, a criminal) as the DBT to illustrate the time required for delay. Utilities should develop their own time sequence as part of their vulnerability assessment process.

1.1.2 Design Basis Threat. DBTs considered in these guidelines address persons who intend to interrupt the water treatment or delivery processes, contaminate the water, or trespass on the water utility property in order to commit a malevolent act. The following subsections summarize the objectives, motives, and fundamental security approaches for each DBT used in this guideline. Table 1-1 contains additional information on the objectives, motives, and capabilities of DBT levels. The table also elaborates on the differences between base and enhanced DBT levels.

1.1.2.1 Vandal. Vandals are intent on defacing, damaging, or destroying property. They primarily seek targets of opportunity, using stealth to avoid detection. Adversaries in this group do not intend to injure or kill people (although such may occur as an accidental result of their actions), and are assumed to be unarmed.

Security approaches for a base-level vandal threat generally consist of placing physical barriers between the assets and public areas, and visual detection of intruders by utility staff or the general public. Use of appropriate perimeter fences and gates, adequate perimeter and area lighting, and hardened locks often provides sufficient deterrence from all but the most motivated vandals. Where the damage that could be caused by vandals is of relatively low cost to repair, utilities should consider whether it is more cost-effective to focus on consequence mitigation (i.e., the repair or replacement of assets) rather than on investing in expensive security systems and protective measures.

An enhanced threat created by a more intense or invasive vandal (one consisting of a greater number of individuals who plan the activities or who have access to larger or more capable tools) requires security approaches that detect and delay the intruder until the appropriate response force can stop the threat. These measures are generally only appropriate when the value of the assets is sufficient that consequence mitigation is a more costly or an unacceptable approach. Liability issues should also be considered.

1.1.2.2 Criminal. The primary motivation for a criminal is the desire to obtain equipment, tools, or components that have inherent value and can be sold. Criminals typically use stealth to avoid apprehension, and response times should focus on the time required for the adversary to obtain the asset. Depending on their level of desperation or sophistication, criminals may be armed and willing to injure or kill to accomplish their objectives.

Protective approaches against the base-level criminal threat with limited hand tools are focused on deterrence and delay. Visual barriers act as a deterrent to prevent the detection of assets by an opportunistic criminal. Prevention or delay of the removal of equipment and other targets can result from physical separation from public areas, adequate lighting, and physical barriers