© ASHRAE. Per international copyright law, additional reproduction, distribution, or transmission in either print or digital form is not permitted without ASHRAE's prior written permission.

CONTENTS

ANSI/ASHRAE Standard 190-2020
Method of Testing for Rating Indoor Pool Dehumidifiers

SECTION		PAGE
Foreword		2
1	Purpose	2
2	Scope	2
3	Instruments	2
4	Methods of Testing and Calculation	3
5	Test Procedures	5
6	Data to be Recorded	7
7	Test Results	7
8	Symbols Used in Equations	9
9	Reference Properties and Data	10
10	References	10

NOTE

Approved addenda, errata, or interpretations for this standard can be downloaded free of charge from the ASHRAE website at www.ashrae.org/technology.

© 2020 ASHRAE

1791 Tullie Circle NE · Atlanta, GA 30329 · www.ashrae.org · All rights reserved.

ASHRAE is a registered trademark of the American Society of Heating, Refrigerating and Air-Conditioning Engineers, Inc.
ANSI is a registered trademark of the American National Standards Institute.

© ASHRAE. Per international copyright law, additional reproduction, distribution, or transmission in either print or digital form is not permitted without ASHRAE's prior written permission.

(This foreword is not part of this standard. It is merely informative and does not contain requirements necessary for conformance to the standard. It has not been processed according to the ANSI requirements for a standard and may contain material that has not been subject to public review or a consensus process. Unresolved objectors on informative material are not offered the right to appeal at ASHRAE or ANSI.)

FOREWORD

This standard was prepared under the auspices of ASHRAE. It may be used, in whole or in part, by an association or government agency with due credit to ASHRAE. Adherence is strictly on a voluntary basis and merely in the interests of obtaining uniform standards throughout the industry.

1. PURPOSE

The purpose of this standard is to prescribe test methods for determining the moisture removal capacity and efficiency, pool heating capacity, and sensible and total cooling capacity for indoor pool dehumidifiers.

2. SCOPE

2.1 This standard applies to indoor pool dehumidifiers using electrically driven, mechanical vapor-compression refrigeration systems consisting of one or more factory-made assemblies that dehumidify and circulate air and may include pool water heating, air reheating, cooling, filtering, and heat recovery.

2.2 Systems other than those stated in Section 2.1 (e.g., cooling-only equipment) are excluded.

3. INSTRUMENTS

3.1 Temperature Measuring Instruments

3.1.1 All temperature measurements shall be made in accordance with ANSI/ASHRAE Standard 41.1, *Standard Method for Temperature Measurement* [1].

3.2 Pressure Measuring Instruments

3.2.1 Pressure measurements shall be made in accordance with ANSI/ASHRAE Standard 41.3, *Standard Method for Pressure Measurement* [2].

3.3 Air Velocity and Airflow Measurements

3.3.1 The static pressure difference across nozzles and velocity pressures at nozzle throats shall be measured according to ANSI/ASHRAE Standard 41.2, *Standard Method for Air Velocity and Airflow Measurement* [3].

3.4 Power Measurements

3.4.1 Power measurements shall be made in accordance with ANSI/ASHRAE Standard 41.11 *Standard Methods for Power Measurements* [4].

3.5 Liquid Flow Measurement

3.5.1 Water flow rates shall be measured with a liquid flowmeter or quantity meter having an accuracy of ±1.0% of the indicated value in accordance with ANSI/ASHRAE Standard 41.8 *Standard Methods of Measurement for Liquid Flow Measurements* [5].

3.5.2 Condensate collection rates shall be determined using a liquid quantity meter having an accuracy of ±1.0% of the indicated value in accordance with ASHRAE Standard 41.8.

3.6 Time and Mass Measurements

3.6.1 Time interval measurements shall be made with an instrument having an accuracy of ±0.2% of the indicated value.

3.6.2 Mass measurements shall be made with an instrument having an accuracy of ±1.0% of the indicated value.

3.7 Humidity Measurements

3.7.1 Humidity measurements shall be made in accordance with ANSI/ASHRAE Standard 41.6 *Standard for Humidity Measurement* [6].