ANSI/AWWA **C519-25**

(Revision of ANSI/AWWA C519-18)

AWWA Standard

High-Performance Waterworks Butterfly Valves—3 In. (75 mm) Through 60 In. (1,500 mm)

Effective date: Dec. 1, 2025.
First edition approved by Board of Directors June 9, 2018.
This edition approved June 7, 2025.
Approved by American National Standards Institute May 15, 2025.

American Water Works Association

Approved American National Standard ANSI

STANDARD Since 1881

AWWA Standard

This document is an American Water Works Association (AWWA) standard. It is not a specification. AWWA standards describe minimum requirements and do not contain all of the engineering and administrative information normally contained in specifications. The AWWA standards usually contain options that must be evaluated by the user of the standard. Until each optional feature is specified by the user, the product or service is not fully defined. AWWA publication of a standard does not constitute endorsement of any product or product type, nor does AWWA test, certify, or approve any product. The use of AWWA standards is entirely voluntary. This standard does not supersede or take precedence over or displace any applicable law, regulation, or code of any governmental authority. AWWA standards are intended to represent a consensus of the water industry that the product described will provide satisfactory service. When AWWA revises or withdraws this standard, an official notice of action will be placed in the Official Notice section of *Journal AWWA*. The action becomes effective on the first day of the month following the month of *Journal AWWA* publication of the official notice.

American National Standard

An American National Standard implies a consensus of those substantially concerned with its scope and provisions. An American National Standard is intended as a guide to aid the manufacturer, the consumer, and the general public. The existence of an American National Standard does not in any respect preclude anyone, whether that person has approved the standard or not, from manufacturing, marketing, purchasing, or using products, processes, or procedures not conforming to the standard. American National Standards are subject to periodic review, and users are cautioned to obtain the latest editions. Producers of goods made in conformity with an American National Standard are encouraged to state on their own responsibility in advertising and promotional materials or on tags or labels that the goods are produced in conformity with particular American National Standards.

Caution Notice: The American National Standards Institute (ANSI) approval date on the front cover of this standard indicates completion of the ANSI approval process. This American National Standard may be revised or withdrawn at any time. ANSI procedures require that action be taken to reaffirm, revise, or withdraw this standard no later than five years from the date of ANSI approval. Purchasers of American National Standards may receive current information on all standards by writing the American National Standards Institute, 1180 Avenue of the Americas, 10th Floor, New York, NY 10036; calling 212.642.4900; or emailing info@ansi.org.

All rights reserved. No part of this publication may be reproduced or transmitted in any form or by any means, electronic or mechanical, including scanning, recording, or any information or retrieval system. Reproduction and commercial use of this material is prohibited, except with written permission from the publisher. Please send any requests or questions to permissions@awwa.org.

ISBN-13, print: 978-1-64717-284-8

ISBN-13, electronic: 978-1-61300-804-1

DOI: http://dx.doi.org/10.12999/AWWA.C519.25

All rights reserved. No part of this publication may be reproduced or transmitted in any form or by any means, electronic or mechanical, including scanning, recording, or any information or retrieval system. Reproduction and commercial use of this material is prohibited, except with written permission from the publisher.

Copyright © 2025 by American Water Works Association
Printed in USA

Copyright © 2025 by American Water Works Association
Printed in USA

Committee Personnel

The AWWA Standards Subcommittee for High-Performance Waterworks Butterfly Valves, which prepared and reviewed this standard, had the following personnel at the time of approval:

Steve Carpenter, *Chair*

General Interest Members

J. Hrdlicka (*liaison, nonvoting*), Standards Engineer Liaison, AWWA, Denver, Colo.

Producer Members

S. Carpenter, B&K Valves and Equipment, Ramona, Calif.
T. Fallon, Mueller Water Products, Geneva, Ill.
J.D. Grant, DeZURIK Inc., Sartell, Minn.
H. Herold, VAG, Mannheim, Germany
J.R. Holstrom, Val-Matic Valve & Manufacturing Corp., Addison, Ill.
R. Larkin (*alternate*), J&S Valve, Gardendale, Ala.
A. Le, Emerson, Houston, Tex.
T. O'Shea (*alternate*), Val-Matic Valve & Manufacturing Corp., Elmhurst, Ill.
K. Scott (*alternate*), DeZURIK Inc., Sartell, Minn.
D. Swartzentruber, J&S Valve, Niles, Mich.

User Members

M. Chung, Metro Water District of Southern California, Los Angeles, Calif.
D. Erickson, Metro Vancouver, Burnaby, B.C.

The AWWA Standards Committee on Butterfly Valves, which reviewed and approved this standard, had the following personnel at the time of approval:

Shelly Hattan, *Chair*
Jeremy N. Nakashima, *Vice-Chair*
Paul J. Ries, *Vice-Chair*

General Interest Members

M.D. Bennett, Stantec, Cleveland, Ohio
B.E. Bosserman, Consultant, Mission Viejo, Calif.

Copyright © 2025 by American Water Works Association
Printed in USA

E. Engelskirchen, Freese and Nichols, Jersey Village, Tex.
J. Hebenstreit, Underwriters Laboratories Inc., Northbrook, Ill.
F.L. Hinker, Consultant, Santa Rosa, N.M.
J. Hrdlicka (*liaison, nonvoting*), Standards Engineer Liaison, AWWA, Denver, Colo.
M.C. Johnson, Utah State University, Water Research Laboratory, Logan, Utah
J. Kercho, Kimley-Horn, Fort Worth, Tex.
J.C. Limke, HDR Inc., Denver, Colo.
J.N. Nakashima, Lockwood, Andrews & Newnam Inc., Oakbrook Terrace, Ill.
U. Sant, Brown and Caldwell, Rancho Cordova, Calif.
R. Venis, AECOM, Kelowna, B.C.
R.A. Ward, Tighe & Bond, Westfield, Mass.

Producer Members

M. Bissauge, Vahn-Tech, Toronto, Ont.
J. Clifton (*alternate*), McWane, Columbiana, Ala.
D. Douro, Olsen Technologies, Allentown, Penn.
J.D. Grant, DeZURIK Inc., Sartell, Minn.
A.C. Granzow, NIBCO Inc., Elkhart, Ind.
H. Herold, VAG, Mannheim, Germany
J.R. Holstrom, Val-Matic Valve & Manufacturing Corp., Addison, Ill.
K. Johnson, M&H Valve Company, Anniston, Ala.
C. Keeling, US Valve, Linthicum, Md.
R. Larkin (*alternate*), J&S Valve, Gardendale, Ala.
T. O'Shea (*alternate*), Val-Matic Valve & Manufacturing Corp., Elmhurst, Ill.
K. Scott (*alternate*), DeZURIK Inc., Sartell, Minn.
D. Swartzentruber, J&S Valve, Niles, Mich.
J.H. Wilber, American AVK, Littleton, Colo.

User Members

L. Adams, US Bureau of Reclamation, Arvada, Colo.
B. Beck, Charlotte Water, Charlotte, N.C.
M. Chung, Metropolitan Water District of Southern California, Los Angeles, Calif.
D.W. Coppes, Massachusetts Water Resources Authority, Boston, Mass.
D. Erickson, Metro Vancouver, Burnaby, B.C.

Copyright © 2025 by American Water Works Association
Printed in USA

S. Hattan, Tarrant Regional Water District, Fort Worth, Tex.

R. Kilborn, EPCOR, Taylor, Tex.

V.Q. Le, Los Angeles Water and Power, Los Angeles, Calif.

J. Logan (*alternate*), Tarrant Regional Water District, Fort Worth, Tex.

S.E. Metzler, San Antonio River Authority, Weatherford, Tex.

P.J. Ries, Denver Water, Denver, Colo.

S.Y. Tung, City of Houston, Houston, Tex.

Copyright © 2025 by American Water Works Association
Printed in USA

This page intentionally blank.

Copyright © 2025 by American Water Works Association
Printed in USA

Contents

All AWWA standards follow the general format indicated subsequently. Some variations from this format may be found in a particular standard.

SEC. PAGE

Foreword

I Introduction ix
I.A Background ix
I.B History ix
I.C Acceptance ix
II Special Issues xi
II.A General xi
II.B Advisory Information on Product Application xii
II.C Valve Discs and Piping Design xiv
II.D Flange Bolt Patterns xv
II.E Permeation xv
II.F Chloramines xv
III Use of This Standard xvi
III.A Purchaser Options and Alternatives xvi
III.B Modification to Standard xx
IV Major Revisions xxi
V Comments xxi

Standard

1 General

1.1 Scope 1
1.2 Purpose 2
1.3 Application 2

SEC. PAGE

2 References

2.1 Industry Standards 2
2.2 Material Specifications 4

3 Definitions 5

4 Requirements

4.1 Materials 8
4.2 General Design 8
4.3 Workmanship and Coating 22

5 Verification

5.1 Testing by the Manufacturer 23
5.2 Notice of Nonconformance 27

6 Delivery

6.1 Marking 27
6.2 Shipping 27
6.3 Affidavit of Compliance 27

Appendix

A Installation, Operation, and Maintenance of High-Performance Butterfly Valves 29
A.1 General 29
A.2 Unloading 29
A.3 Storage 29
A.4 Inspection Prior to Installation 30
A.5 Installation 30
A.6 Field Testing 32

Copyright © 2025 by American Water Works Association
Printed in USA

SEC. PAGE
A.7 Operation 33
A.8 Maintenance 33

Tables

1-A Laying Length Dimensions: 3–24 in. (75–600 mm), Wafer and Lugged-Wafer Body Valves 9
1-B Laying Length Dimensions: 30–60 in. (750–1,500 mm), Wafer and Lugged-Wafer Body Valves 9
1-C Laying Length Dimensions: 3–60 in. (75–1,500 mm), Flanged Valves 10
1-D Wafer and Lugged-Wafer Body Minimum Wall Thickness 11
1-E Flanged Body Minimum Wall Thickness 11
1-F Standards for Flange Drilling Patterns, Dimensions, and Minimum Thickness 12
2 Actuator Application Factors (AF) ... 19
3 Valve Test Cycles Required 25
4 Prototype Actuator Proof-of-Design Test Cycles Required 26

Copyright © 2025 by American Water Works Association
Printed in USA

Foreword

This foreword is for information only and is not a part of ANSI/AWWA C519.*

I. Introduction.

I.A. *Background*. Butterfly valves are generally used for isolating and/or modulating flow in pipelines carrying liquids and gases. Manufacturers of steel butterfly valves developed tight-closing, polymeric-seated, and metal-seated valve options for cooling water systems and power stations and other industrial applications.

Since the 1990s, high-performance butterfly valves have gained increased acceptance for use in water treatment plants, water reuse, and water supply and distribution lines because they (1) provide higher pressure and fluid velocity ratings than rubber-seated butterfly valves; (2) provide tight shutoff; (3) are relatively easy to operate, even with large pressure differentials across the valves; and (4) require relatively little space for installation.

I.B. *History*. The need for standardization of high-performance butterfly valves for waterworks service was recognized by AWWA in 2010.

The 2018 standard was written to describe the then-available types of standard high-performance butterfly valves that had been in successful operation for at least 10 years. The standard established three pressure classifications, three fluid velocity classifications, standards for materials, laying lengths, minimum body and disc designs, and actuator requirements for high-performance butterfly valves.

Generally, modern high-performance butterfly-valve designs for water service include cast or welded body construction in 150-psi (1,034-kPa), 275-psi (1,896-kPa), and 500-psi (3,447-kPa) pressure ratings; flanged, lugged-wafer, and wafer bodies; seats in valve bodies or on the valve discs; and operating conditions (limited by the materials, design shutoff pressure, and velocities of water flow) that may produce torques considered maximum for the shaft size used.

The first edition of ANSI/AWWA C519 was approved by the AWWA Board of Directors on June 9, 2018. This edition was approved on June 7, 2025.

I.C. *Acceptance.* In May 1985, the US Environmental Protection Agency (USEPA) entered into a cooperative agreement with a consortium led by NSF International (NSF) to develop voluntary third-party consensus standards and a certification program for direct and indirect drinking water additives. Other members of

* American National Standards Institute, 1180 Avenue of the Americas, 10th Floor, New York, NY 10036.

Copyright © 2025 by American Water Works Association
Printed in USA

the original consortium included the Water Research Foundation (formerly AwwaRF), and the Conference of State Health and Environmental Managers (COSHEM). The American Water Works Association (AWWA) and the Association of State Drinking Water Administrators (ASDWA) joined later.

In the United States, authority to regulate products for use in, or in contact with, drinking water rests with individual states.[†] Local agencies may choose to impose requirements more stringent than those required by the state. To evaluate the health effects of products and drinking water additives from such products, state and local agencies may use various references, including

1. Specific policies of the state or local agency.

2. Four standards developed under the direction of NSF[‡]: NSF/ANSI/CAN[§] 60, Drinking Water Treatment Chemicals—Health Effects; NSF/ANSI/CAN 61, Drinking Water System Components—Health Effects; NSF/ANSI/CAN 372—Drinking Water System Components—Lead Content; and NSF/ANSI/CAN 600, Health Effects Evaluation and Criteria for Chemicals in Drinking Water.

3. Other references, including AWWA standards, *Food Chemicals Codex*, *Water Chemicals Codex,*[¶] and other standards considered appropriate by the state or local agency.

Various certification organizations may be involved in certifying products in accordance with NSF/ANSI/CAN 61. Individual states, provinces, or local agencies have authority to accept or accredit certification organizations within their jurisdiction. Accreditation of certification organizations may vary from jurisdiction to jurisdiction.

NSF/ANSI/CAN 600 (which formerly appeared in NSF/ANSI/CAN 60 and 61 as Annex A, "Toxicology Review and Evaluation Procedures") does not stipulate a maximum allowable level (MAL) of a contaminant for substances not regulated by a USEPA final maximum contaminant level (MCL). The MALs of an unspecified list of "unregulated contaminants" are based on toxicity testing guidelines (noncarcinogens) and risk characterization methodology (carcinogens). Use of NSF/ANSI/CAN 600 procedures may not always be identical, depending on the certifier.

ANSI/AWWA C519 does not address additives requirements. Thus, users of this standard should consult the appropriate state or local agency having jurisdiction in order to

---

[†] Persons outside the United States should contact the appropriate authority having jurisdiction.

[‡] NSF International, 789 North Dixboro Road, Ann Arbor, MI 48105.

[§] Standards Council of Canada, 55 Metcalfe Street, Suite 600, Ottawa, ON K1P 6L5 Canada.

[¶] Both publications available from National Academies Press, 500 Fifth Street NW, Washington, DC 20001.

Copyright © 2025 by American Water Works Association
Printed in USA

1. Determine additives requirements, including applicable standards.

2. Determine the status of certifications by parties offering to certify products for contact with, or treatment of, drinking water.

3. Determine current information on product certification.

II. Special Issues.

II.A. *General*. The purchaser should carefully evaluate conditions under which a valve is to be operated. The evaluations must include the determination of the hydraulic characteristics of the system in which the valve will be installed and the operation of the valve (open–closed, throttling, or modulating service), including (1) the maximum transient and static differential pressure across the valve disc and (2) flow through the valve under the most adverse operating conditions.

Torque requirements for valve operation vary considerably with the seat design or type, differential pressure across the valve, fluid velocity, fluid temperature, and upstream piping conditions.

Flow direction is important in the installation and use of a butterfly valve. Performance and sealing characteristics of some valves vary with direction of flow. Flow direction can affect the torque requirements and throttling characteristics of valves with offset discs or discs that do not have identical surface configurations on each side. Many offset seat-type butterfly valves have different sealing characteristics on one side versus the other. A manufacturer may have a recommended high-pressure sealing side for long-term reliability.

Hydraulic testing, flow capacities, and valve torques are based on the flow upstream of a valve being uniform and undisturbed, such as the flow produced by a long length of constant-diameter straight pipe. Piping configurations that produce a nonuniform or turbulent flow pattern upstream of the valve can increase torque requirements, create damaging vibrations, increase head loss, and increase stresses in valve components.

Some hydraulic systems can produce fluid velocities higher than the maximum of 35 ft/s (10.7 m/s) described in this standard. These design conditions should be clearly specified by the purchaser so that the valve supplier can address materials and actuator issues. Typically, high fluid velocities can result from flow control and pressure-reducing applications, from pipeline breaks, during firefighting, or in surge-relief applications. The effects of high fluid velocities and asymmetrical turbulent-flow conditions can result in high component stresses and high torque requirements such that the actuator(s) may not be able to hold valve position or control valve opening and closing. These flow conditions are not within the scope of this standard.

Copyright © 2025 by American Water Works Association
Printed in USA

II.B. *Advisory Information on Product Application.* This standard does not describe all possible applications or manufacturing technologies. The purchaser should identify special requirements and required deviations from this standard and include appropriate language in purchase documents. Refer to Sec. III.A in this foreword. Other advisory information is provided as follows:

1. The maximum anticipated fluid velocity through the valve, maximum nonshock shutoff and differential pressure, water temperature range, and valve classification are used by manufacturers to calculate torque requirements through methods found in AWWA Manual M49—*Quarter-Turn Valves: Head Loss, Torque, and Cavitation Analysis,* which then may determine valve operating-component design and actuator sizing. This information should be provided according to items 5, 6, 7, 23, and 24 of Sec. III.A in this foreword. If this information is not provided, a maximum fluid velocity of 35 ft/s (10.7 m/s) and maximum pressure classification of 500 psi (3,447 kPa) will be provided with actuators sized for the most severe conditions listed in this standard, which may result in a significant unwarranted expense.

Turbulence is also a factor that may affect torque requirements. Turbulence will be considered only if information on piping conditions is provided according to item 27 of Sec. III.A in this foreword.

2. This standard limits handwheel rim pull but not handwheel diameter. A smaller handwheel may require a more expensive actuator requiring more turns. If a large-diameter handwheel is of concern because of clearance or other limitations, the diameter should be limited to an acceptable dimension according to item 14 of Sec. III.A in this foreword.

3. This standard refers to ANSI/AWWA C541, Hydraulic and Pneumatic Cylinder and Vane-Type Actuators for Valves and Slide Gates, which permits the use of some plated components in metallic water-hydraulic cylinder actuators. The purchaser should be aware of the possibility of plating failure, particularly when the operating water is unusually corrosive, resulting in the promotion of material degradation. The purchaser may limit acceptability to cylinders having components that do not depend on plating to resist corrosion according to item 15 of Sec. III.A in this foreword.

4. This standard permits polymer and metal seating-surface materials. This standard recommends seating surfaces of reinforced polymer or stainless steel or nickel-copper alloy in cases where valves are to be operated more frequently than once a month. The purchaser may require these materials for specific applications according to item 11 of Sec. III.A in this foreword.

Copyright © 2025 by American Water Works Association
Printed in USA

5. This standard also accepts sprayed mating-seat surfaces when the surfaces are applied under certain conditions. The suitability of this type of surface depends, to a large extent, on the quality of the manufactured product. The purchaser should be aware of the manufacturer's previous experience with similar applications. The purchaser may limit acceptability to a specific product or application according to item 11 of Sec. III.A in this foreword.

6. The material references for metals in Sec. 4.2 and Sec. 4.3 of this standard are based on successful experience. There may be instances where the water is corrosive, resulting in the promotion of material degradation, and the listed materials may not be suitable for both the valve and, if applicable, the hydraulic cylinder. If the materials are not appropriate for the application, the purchaser should identify in the purchase documents which materials are acceptable and identify any other allowable materials.

7. High-performance butterfly valves were developed as steel products and typically mate with steel and ductile-iron flanges. They generally do not mate to cast-iron flanges. Flanges conforming to standards noted in Sec. 4.2.2.1 (Table 1-F) mate with valves described in this standard and are dimensionally interchangeable. The purchaser should review pressure ratings of the valves and mating flanges, and dimensional compatibility of mating pipeline flanges.

8. This standard does not require a minimum waterway area, nor does it limit head loss across the valve. If a minimum waterway or head loss is of concern, limitations should be provided. Refer to item 26 of Sec. III.A of this foreword.

9. This standard allows a party other than the valve manufacturer to mount an actuator to a valve. Sec. 5.1.1 and Sec. 5.1.2.1 require that the valve and actuator assembly be performance- and leak-tested as an assembly. The purchaser is cautioned that the valve manufacturer cannot assume responsibility for the valve's sealing and operating performance if the actuator is mounted by a party other than the valve manufacturer. If actuator mounting by another party is a concern, requirements on actuator mounting should be included in the purchase documents.

10. Electric actuators meeting the requirements of ANSI/AWWA C542, Electric Motor Actuators for Valves and Slide Gates, can be supplied with or without an intermediate quarter-turn mechanism. If desired, the purchaser should specify a multiturn actuator coupled to an intermediate mechanism according to ANSI/AWWA C504, Rubber-Seated Butterfly Valves.

11. High-performance butterfly valves can vary in their seat design, and typically are of single-, double-, and triple-offset seat configurations. The purchaser should be aware that not all high-performance butterfly valve seat designs are required to create

Copyright © 2025 by American Water Works Association
Printed in USA

a positive drop-tight seal between the valve disc and seat, and that these seat designs can also vary in their leakage rates. Should the purchaser specify a high-performance butterfly valve, an associated acceptable leakage rate should also be specified. This information can be obtained from the manufacturer or supplier. Acceptable leakage rates may vary considerably depending on application, operational requirements, and applicable safety standards. Valve testing standards such as ISO 5208, Industrial Valves—Pressure Testing of Metallic Valves, or API 598, Valve Inspection and Testing, have permissible leakage rates that would be applicable for these seat designs and could assist the purchaser in determining an appropriate leakage rate.

II.C. *Valve Discs and Piping Design.* The discs of butterfly valves, when in the fully open position, intrude into the adjacent upstream and downstream piping or other adjacent devices. This intrusion can be an issue especially with adjacent pipe interior linings, polyethylene transmission pipe, and mating flanges. The piping system designer should check the valve manufacturer's recommendations for minimum pipe internal diameter for disc clearance and be sure that the adjacent pipe internal diameters are sufficient to accommodate the fully open valve discs.

The installation of butterfly valves downstream of turbulence-inducing devices or pieces of equipment, such as pumps, check valves, and pipe fittings, requires some consideration to avoid various mechanical and hydraulic issues. Turbulence can cause premature wearing of seats, unequal hydrodynamic loads on the discs with associated increase in torque loadings on valve actuators, unanticipated higher loadings and stresses on shaft bearings with resulting decrease in bearing longevity, and higher stresses on the valve shafts. These issues can be especially significant with butterfly valves installed directly on the discharge flanges of pumps. In some cases, valve-shaft orientation downstream of piping elbows can have a significant effect on the previously described valve mechanical and hydraulic issues. Piping system designers should review with the butterfly valve manufacturers the requirements or recommendations for minimum upstream pipe runs to provide reasonably smooth flow patterns approaching the valve discs, as well as the recommendations regarding shaft orientation. Such recommendations regarding minimum upstream pipe runs should be the result of hydraulic tests or based on relevant experience. If no test data or results are available or if no relevant experience is available, refer to the section "Effects of Pipe Installations" in AWWA Manual M49. If such installation is considered, the user should consult with the valve manufacturer regarding recommendations for minimum upstream straight pipe length and shaft orientation to reduce or eliminate such hydraulic or mechanical issues.

Copyright © 2025 by American Water Works Association
Printed in USA

The installation of butterfly valves upstream of certain equipment requires some consideration to avoid various mechanical and hydraulic issues, especially if the butterfly valve disc is partially open. For example, if butterfly valves are installed directly on the upstream or downstream flanges of other valves (such as check valves), then the open butterfly valve disc will intrude into the body of the adjacent valve. A partially open butterfly valve disc, or even a partially open butterfly valve installed a short distance upstream of equipment, can result in issues such as increased wear on check valve hinges and shaft supports and oscillation ("chattering") of the check valve discs. The turbulence caused by a partially open butterfly valve disc can also affect the performance and accuracy of other downstream devices such as flowmeters and pressure-measuring devices. Sufficient pipe spacing between the butterfly valve and the downstream piece of equipment should be provided to address these issues. Note that the situation of a partially open disc can occur with valves in throttling or modulating service. If any such conditions exist in the piping system, the user should consult the valve manufacturer for recommendations.

II.D. *Flange Bolt Patterns.* The ASME and AWWA flange bolt patterns in sizes 42 in. (1,050 mm) through 60 in. (1,500 mm) are not compatible. Additionally, the ASME B16.47 flanges are generally designed for outside nominal diameter pipe and may not be compatible with inside nominal diameter pipe or cement mortar–lined pipe. System designers should review the compatibility and mating conditions of the flanges in this size range.

II.E. *Permeation.* The selection of materials is critical for potable water, wastewater, and reclaimed water service and distribution piping systems in locations where there is the likelihood the valve will be exposed to significant concentrations of pollutants such as low-molecular-weight petroleum products or organic solvents or their vapors. Documented research has shown that piping system materials such as polyethylene, polybutylene, polyvinyl chloride, asbestos cement, and elastomers used in gaskets and packing glands are subject to permeation by lower-molecular-weight organic solvents or petroleum products. If a valve is buried in such a contaminated area or an area subject to contamination, consult the manufacturer regarding permeation of valve components and jointing materials *before* selecting materials for use in that area.

II.F. *Chloramines*. The selection of materials is critical for water service and distribution piping in locations where there is a possibility that elastomers will be in contact with specific water treatment disinfection agents. Documented research has shown that elastomers such as gaskets, seals, valve seats, and encapsulations may be degraded when exposed to certain disinfection agents. This standard does not include

Copyright © 2025 by American Water Works Association
Printed in USA

elastomer test requirements for chemical resistance to water treatment disinfection agents such as, but not limited to, chlorine and chloramines. If resistance to such agents is required, careful selection of and specifications for elastomeric materials and the specifics of their application for each water system component should be considered to provide long-term usefulness and minimal degradation (swelling, loss of elasticity, softening) of each elastomeric valve component. The 2007 publication, *Performance of Elastomeric Components in Contact With Potable Water,* sponsored by the former AWWA Research Foundation (now The Water Research Foundation) and USEPA, presents data on commonly used elastomeric materials and may serve as a reference for reviewing alternate materials in specific applications. System designers, valve manufacturers, and material producers may also have knowledge and experience with elastomeric materials in specific applications that could provide the purchaser with additional information.

III. Use of This Standard. It is the responsibility of the user of an AWWA standard to determine that the products described in that standard are suitable for use in the particular application being considered.

III.A. *Purchaser Options and Alternatives*. The following information should be provided by the purchaser.

1. Standard to be used—that is, ANSI/AWWA C519, High-Performance Waterworks Butterfly Valves—3 In. (75 mm) Through 60 In. (1,500 mm) of latest edition.
2. Whether compliance or certification with NSF/ANSI/CAN 61, Drinking Water System Components—Health Effects, is required.
3. Size of valve.
4. Quantity required.
5. Type of body:
    a. Wafer or lugged-wafer (Type 1 or Type 2) or flanged.
    b. Wafer or flange facing, either flat or raised face.
    c. The F1, F2, or F3 laying length required for flanged Class 150 and Class 275 valves.
6. Minimum acceptable valve classification.
7. Maximum nonshock shutoff pressure and maximum nonshock line pressure.
8. Required flow rate through valve.
    a. Under normal conditions.
    b. Under maximum-flow conditions.
        - When opening (consider factors such as fire flow).

Copyright © 2025 by American Water Works Association
Printed in USA

- When closing or opening (consider factors such as pipeline break).

9. Description of connecting pipe: material, outside diameter (OD), inside diameter (ID), and flange type, classification, and dimensions.

10. Information or data required from the valve manufacturer or supplier. This information can include the following:

    a. Valve port diameter.
    b. Clearances required for the actuator and clearances required to remove the actuator.
    c. Seating/unseating torque and dynamic torque at specified flow and pressure.
    d. The number of turns to open and close for manual actuators.
    e. Assembled weight.
    f. Preferred-flow direction, if applicable (foreword, Sec. II Special Issues).
    g. Valve component materials (Sec. 4.2).
    h. Principal dimensions, including laying length (Tables 1-A thru 1-E).
    i. Actuator manufacturer, model, and torque capability (Sec. 4.2.8).
    j. Interior and exterior coating materials (Sec. 4.3.2).
    k. Clearance beyond the valve body required for the valve disc to open fully (Sec. A.5.8).
    l. Other materials used for the tested and certified valve.

11. Materials.

    a. For valves certified to the requirements of NSF 61, if the purchaser specifies a wetted component that is not part of the certification, the certification of the valve is no longer valid. NOTE: As of the publication date of this edition, no manufacturers are known to have obtained an NSF certification for this type of valve.
    b. If one or more of the materials included in this standard are unacceptable, specify the acceptable materials that are included in this standard.
    c. If materials included in the standard are not suitable for exposure to pipeline contents or are otherwise unacceptable, specify materials that are suitable and acceptable. (Refer to item 6, Sec. II.B of this foreword.)
    d. Metallic mating seats: Specify any limitations on acceptability of seat materials or sprayed seats for specific applications or specific products. Refer to items 4 and 5, Sec. II.B of this foreword.

12. Type of installation: in-plant, outdoor, buried, or submerged.

Copyright © 2025 by American Water Works Association
Printed in USA

13. Actuator type and service conditions.
    a. Type: manual, pneumatic, hydraulic, or electric.
    b. Service: open–close or modulating.
14. Manual actuator.
    a. Type: handwheel, chainwheel, or wrench nut.
    b. Direction to turn the handwheel, chainwheel, or wrench nut to open valves. (Unless otherwise specified, the valve will open by turning counterclockwise.)
    c. Position indicator:
        - If required.
        - Configuration for buried, submerged, or in-plant service.
    d. Special devices or features if required: extension shaft, floor stand, handwheel diameter, or position transmitter.
    e. Actuator handwheel or chainwheel pull requirements. Maximum pull requirements have been found by some operators to be a high exertion of effort, and lesser pulls of 40–60 lb (18.1–27.2 kg) on handwheels and chainwheels have sometimes been found to be beneficial (Sec. 4.2.8.9.2).
15. Pneumatic or hydraulic actuator (cylinder or vane).
    a. Operating medium: air, water, or oil.
    b. Operating medium pressure: maximum and minimum.
    c. Characteristics: control scheme, opening and closing speed ranges if different from the 30–60 s required by ANSI/AWWA C541, and accuracy.
    d. Position indicator:
        - If required.
        - Configuration.
    e. Special requirements:
        - Specify any limitations on acceptability or any special construction required.
16. Electric actuator (Sec. 4.2.8.10).
    a. Type: multiturn actuator coupled to an intermediate mechanism or integral quarter-turn unit.
    b. Characteristics: operating voltage, control scheme, requirements, and time of operation (i.e., fully open to fully closed from 0° to 90°).
    c. Position indicator: configuration.
    d. Special considerations: Type of service environment should be stated and appurtenances required.

Copyright © 2025 by American Water Works Association
Printed in USA

17. Other actuators: Actuators other than those described in this standard or ANSI/AWWA C541 or ANSI/AWWA C542 shall be specified in detail by the purchaser.

18. Valve and actuator arrangement and position. The purchaser may indicate a desired shaft orientation. Typically, butterfly valves are constructed so that the shaft may be horizontal or vertical in horizontal piping. The purchaser should also consider the application or service conditions of the valve. For example, valves used in raw (untreated) water and reuse water service should generally be installed with the shafts horizontal so that solids do not accumulate in the shaft sealing areas. Shaft orientation of valves installed upstream of pump suction intake can affect the performance of some types of pumps. Shaft orientation can affect valve head loss and dynamic torque when the valve is installed downstream of pumps and pipe fittings, which create an asymmetric approach velocity pattern at the valve. The user should consider the installation and orientation limitations given in Appendix A, Sec. A.5, and in AWWA Manual M49. Horizontal shaft orientation in horizontal piping will increase opening or closing torque because of hydrostatic torque if the pipe on one side of a closed valve is allowed to empty.

19. If an affidavit of compliance is required with the provisions of ANSI/AWWA C541 or ANSI/AWWA C542 signed by the actuator manufacturer.

20. If the flow resistance coefficient for a fully open valve calculated in accordance with AWWA Manual M49 is required.

21. If valve position versus flow resistance or coefficient curves are required, they should be referenced to procedures described in AWWA Manual M49.

22. If shop inspection and performance witness testing by the purchaser is required.

23. Maximum transient pressure and characteristics, if known.

24. Water temperature range.

25. If a leakage test in both directions is required.

26. If a maximum head loss is required. This information should be provided for each size and class of valve. NOTE: Not all manufacturers may use the same test methods for measuring head loss. Maximum head loss and testing requirements should be discussed by the purchaser and the manufacturer. It is recommended that the purchaser reference AWWA Manual M49 if a maximum head loss is specified.

27. A drawing or description of the piping arrangement sufficient to describe significant turbulent line flow conditions to which the valve disc may be subjected.

Copyright © 2025 by American Water Works Association
Printed in USA

28. Considerations relating to anticipated issues with components exposed to pipeline content containing chlorine, chloramines, chloride, or other chemicals. If these conditions are anticipated, the purchaser should identify the maximum expected concentrations of these chemicals and other factors, such as pH and temperature ranges, that may affect the corrosivity of these chemicals. The purchaser should consult with the manufacturers and, if appropriate, specify special requirements for these components.

29. Type of flange facing: This standard requires raised-face or flat-face flanges. Facings must be defined by the purchaser.

30. If purchase documents require shop inspection or test observations to be performed by the purchaser, the extent of such inspections and observations should be defined.

31. Details of federal, state, provincial, territorial, and local requirements (Sec. 4.1.1).

32. The provision of test records that are specified according to Sections 5.1.1, 5.1.2, 5.1.3, and 5.1.4 of this standard. Test records required for power actuators under ANSI/AWWA C541 or ANSI/AWWA C542 may also be requested. The purchaser may require all records or may stipulate a breakdown of production test records or proof-of-design test records.

33. Detailed description of nonstandard end connections (Sec. 4.2.2).

34. Type of shaft seal (Sec. 4.2.7). This standard does not require that seal materials be resistant to permeation by organic compounds such as organic solvents or petroleum-based products. If the purchaser's application involves such source conditions (usually in buried applications), then the purchaser should consult with the valve manufacturer to require the proper shaft seals.

35. Protective coatings if other than specified in Sec. 4.3.2 of this standard.

36. If an affidavit of compliance is required with the provisions of this standard signed by the valve manufacturer (Sec. 6.3).

37. If a material certification is required identifying the origin of materials and certifying that they comply with the material standards outlined in this standard.

38. Specify any special control applications, operating conditions, special allowable leakage rates, and bidirectional test requirements.

III.B. *Modification to Standard.* Any modification to the provisions, definitions, or terminology in this standard must be provided by the purchaser.

Copyright © 2025 by American Water Works Association
Printed in USA

IV. Major Revisions.

1. Revise and clarify definitions of single-, double-, and triple-offset butterfly valves in Section 3.
2. Revise and clarify standard references for flange requirements in Sec. 4.2.
3. Revisions to leakage test and hydrostatic test requirements in Sec. 5.1.

V. Comments. If you have any comments or questions about this standard, please call the AWWA Engineering and Technical Services at 303.794.7711; write to the department at 6666 West Quincy Avenue, Denver, CO 80235-3098; or email standards@awwa.org.

Copyright © 2025 by American Water Works Association
Printed in USA

This page intentionally blank.

Copyright © 2025 by American Water Works Association
Printed in USA

American Water Works Association

ANSI/AWWA C519-25
(Revision of ANSI/AWWA C519-18)

AWWA Standard

High-Performance Waterworks Butterfly Valves—3 In. (75 mm) Through 60 In. (1,500 mm)

SECTION 1: GENERAL

Sec. 1.1 Scope

This standard establishes minimum requirements for high-performance butterfly valves, 3 in. (75 mm) through 60 in. (1,500 mm) in diameter, with various body and end types, for raw water, potable water, reclaimed water, and wastewater having a pH range from 6 to 12 and a temperature range from 33–125°F (0.6–51.6°C). This standard covers three pressure ratings for high-performance butterfly valves suitable for maximum steady-state fluid working and differential pressures of 150 psig (1,034 kPa), 275 psig (1,896 kPa), and 500 psig (3,447 kPa), and maximum pipeline fluid velocity ranges of 16 ft/s (4.9 m/s), 24 ft/s (7.3 m/s), and 35 ft/s (10.7 m/s). The scope of carbon-steel and stainless-steel valves includes all sizes, classes, and body styles. The scope of ductile-iron valves includes all sizes in wafer and lugged-wafer bodies. The flanged ductile-iron body scope includes 3 in. (75 mm) through 60 in. (1,500) for Classes 150B, 150C, and 150D; 3 in. (75 mm) through 48 in. (1,200) for Classes 275B, 275C, and 275D; and 3 in. (75 mm) through 24 in. (600 mm) for Classes 500B, 500C, and 500D.

1.1.1 *Body types.* Valves described in this standard are provided in wafer, lugged-wafer, and double-flanged body patterns.

Copyright © 2025 by American Water Works Association
Printed in USA