ANSI/AWWA **F102-25**

(Revision of ANSI/AWWA F102-19)

AWWA Standard

Matched-Die-Molded, Fiberglass-Reinforced Plastic Weir Plates, Scum Baffles, and Mounting Brackets

Effective date: Aug. 1, 2025.
First edition approved by Board of Directors Jan. 27, 1991.
This edition approved Jan. 23, 2025.
Approved by American National Standards Institute Jan. 27, 2025.

American Water Works Association

Approved American National Standard ANSI

STANDARD Since 1881

AWWA Standard

This document is an American Water Works Association (AWWA) standard. It is not a specification. AWWA standards describe minimum requirements and do not contain all of the engineering and administrative information normally contained in specifications. AWWA standards usually contain options that must be evaluated by the user of the standard. Until each optional feature is specified by the user, the product or service is not fully defined. AWWA publication of a standard does not constitute endorsement of any product or product type, nor does AWWA test, certify, or approve any product. The use of AWWA standards is entirely voluntary. This standard does not supersede or take precedence over or displace any applicable law, regulation, or code of any governmental authority. AWWA standards are intended to represent a consensus of the water industry that the product described will provide satisfactory service. When AWWA revises or withdraws this standard, an official notice of action will be placed in the Official Notice section of *Journal AWWA.* The action becomes effective on the first day of the month following the month of *Journal AWWA* publication of the official notice.

American National Standard

An American National Standard implies a consensus of those substantially concerned with its scope and provisions. An American National Standard is intended as a guide to aid the manufacturer, the consumer, and the general public. The existence of an American National Standard does not in any respect preclude anyone, whether that person has approved the standard or not, from manufacturing, marketing, purchasing, or using products, processes, or procedures not conforming to the standard. American National Standards are subject to periodic review, and users are cautioned to obtain the latest editions. Producers of goods made in conformity with an American National Standard are encouraged to state on their own responsibility in advertising and promotional materials or on tags or labels that the goods are produced in conformity with particular American National Standards.

Caution Notice: The American National Standards Institute (ANSI) approval date on the front cover of this standard indicates completion of the ANSI approval process. This American National Standard may be revised or withdrawn at any time. ANSI procedures require that action be taken to reaffirm, revise, or withdraw this standard no later than five years from the date of ANSI approval. Purchasers of American National Standards may receive current information on all standards by calling or writing the American National Standards Institute, 1180 Avenue of the Americas, Tenth Floor, New York, NY 10036; 212.642.4900; or emailing info@ansi.org.

All rights reserved. No part of this publication may be reproduced or transmitted in any form or by any means, electronic or mechanical, including scanning, recording, or any information or retrieval system. Reproduction and commercial use of this material is prohibited, except with written permission from the publisher. Please send any requests or questions to permissions@awwa.org.

ISBN-13, print: 978-1-64717-264-0

ISBN-13, electronic: 978-1-61300-785-3

DOI: http://dx.doi.org/10.12999/AWWA.F102.25

All rights reserved. No part of this publication may be reproduced or transmitted in any form or by any means, electronic or mechanical, including scanning, recording, or any information or retrieval system. Reproduction and commercial use of this material is prohibited, except with written permission from the publisher.

Copyright © 2025 by American Water Works Association
Printed in USA

Copyright © 2025 by American Water Works Association. All Rights Reserved

Committee Personnel

The AWWA Standards Committee on Fiberglass Weirs, Troughs, and Baffles, which reviewed and approved this standard, had the following personnel at the time of approval:

Justin C. Reeves, *Chair*

General Interest Members

P. Banschbach, Garver, Fort Worth, Tex.
A. Dail (*liaison, nonvoting*), Standards Engineer Liaison, AWWA, Denver, Colo.
J.W. Green (*liaison, nonvoting*), Standards Council Liaison, Lockwood, Andrews & Newnam Inc., Oakbrook Terrace, Ill.
J.C. Reeves, Lockwood, Andrews & Newnam Inc., Fort Worth, Tex.

Producer Members

P.A. Merimee, MFG Construction and Water Treatment Products, Union City, Pa.
D. Vorse (*alternate*), National Composites, Troy, Mich.

User Members

S. Ali, Detroit Water and Sewerage Department, Capital Management Group, Detroit, Mich.
J.B. Pagenkopp, Metropolitan Water District of Southern California, La Verne, Calif.
J.S. Taylor, City of Fort Worth, Wichita Falls, Tex.
M. Toner (*alternate*), Metropolitan Water District of Southern California, La Verne, Calif.

Copyright © 2025 by American Water Works Association. All Rights Reserved

This page intentionally blank.

Copyright © 2025 by American Water Works Association. All Rights Reserved

Contents

All AWWA standards follow the general format indicated subsequently. Some variations from this format may be found in a particular standard.

SEC. PAGE

Foreword

I Introduction vii
I.A Background vii
I.B History vii
I.C Acceptance vii
II Special Issues ix
III Use of This Standard ix
III.A Purchaser Options and Alternatives ix
III.B Modification to Standard x
IV Major Revisions x
V Comments xi

Standard

1 General

1.1 Scope 1
1.2 Purpose 2
1.3 Application 2

2 References 2

3 Definitions 3

SEC. PAGE

4 Requirements

4.1 Information to Be Supplied by the Manufacturer 4
4.2 Materials 5
4.3 General and Detailed Design 7
4.4 Chemical and Physical Requirements 10

5 Verification

5.1 Sample Specimens 10
5.2 Production Testing 10
5.3 Inspection 10
5.4 Notice of Nonconformance 11

6 Delivery

6.1 Marking 11
6.2 Packing and Shipping 11
6.3 Affidavit of Compliance 11

Tables

1 Minimum Physical Properties of Laminates 6
2 Allowable Cosmetic Defects of Fiberglass Components 9

Copyright © 2025 by American Water Works Association. All Rights Reserved

This page intentionally blank.

Copyright © 2025 by American Water Works Association. All Rights Reserved

Foreword

This foreword is for information only and is not a part of ANSI/AWWA F102.*

I. Introduction.

I.A. *Background*. The purpose of this standard is to establish the minimum quality requirements for matched-die-molded, fiberglass-reinforced thermoset resin weir plates, scum baffles, and mounting brackets for use in municipal and industrial water treatment plants. The weirs, baffles, and brackets are intended for use in treatment basins or tanks. However, the specific application must consider the limitations specified under Sec. 1.1, and information must be provided by the purchaser to completely describe the fabrication requirements. Purchaser-specific information that should be considered is summarized in the foreword, Sec. III. The purchaser should review these recommendations and other appropriate data and make provisions in the purchaser's documents to describe the specific service requirements.

I.B. *History*. In 1986, the AWWA Standards Council authorized the development of AWWA standards to describe matched-die-molded, fiberglass-reinforced, thermoset resin weir plates, scum baffles, and mounting brackets. Beginning in 1987 with preliminary, but unfinished, standards developed by an earlier American Society for Testing and Materials (ASTM, now ASTM International) group, the AWWA Standards Committee on Fiberglass Weirs, Troughs, and Baffles formulated and reviewed several drafts of this final standard. The AWWA Standards Committee on Fiberglass Weirs, Troughs, and Baffles prepared ANSI/AWWA F102 and completed work on the first edition of this standard titled "AWWA Standard for Matched-Die-Molded, Fiberglass-Reinforced Plastic Weir Plates, Scum Baffles, and Mounting Brackets." The final draft was submitted to the committee for letter ballot voting on Aug. 23, 1990, and a consensus for acceptance was received. The first edition of this standard was approved by the AWWA Board of Directors on Jan. 27, 1991. Subsequent editions were approved on June 23, 1996; Jan. 20, 2002; Jan. 21, 2007; Jan. 20, 2013; and Jan. 24, 2019. This edition was approved on Jan. 23, 2025.

I.C. *Acceptance.* In May 1985, the US Environmental Protection Agency (USEPA) entered into a cooperative agreement with a consortium led by NSF International (NSF) to develop voluntary third-party consensus standards and a

* American National Standards Institute, 1180 Avenue of the Americas, 10th Floor, New York, NY 10036.

Copyright © 2025 by American Water Works Association. All Rights Reserved

certification program for direct and indirect drinking water additives. Other members of the original consortium included the Water Research Foundation (formerly AwwaRF) and the Conference of State Health and Environmental Managers (COSHEM). AWWA and the Association of State Drinking Water Administrators (ASDWA) joined later.

In the United States, authority to regulate products for use in, or in contact with, drinking water rests with individual states.[†] Local agencies may choose to impose requirements more stringent than those required by the state. To evaluate the health effects of products and drinking water additives from such products, state and local agencies may use various references, including

1. Specific policies of the state or local agency.

2. Four standards developed under the direction of NSF:[‡] NSF/ANSI/CAN[§] 60, Drinking Water Treatment Chemicals—Health Effects; NSF/ANSI/CAN 61, Drinking Water System Components—Health Effects; NSF/ANSI/CAN 372, Drinking Water System Components—Lead Content; and NSF/ANSI/CAN 600, Health Effects Evaluation and Criteria for Chemicals in Drinking Water.

3. Other references, including AWWA standards, *Food Chemicals Codex*, *Water Chemicals Codex,*[¶] and other standards considered appropriate by the state or local agency.

Various certification organizations may be involved in certifying products in accordance with NSF/ANSI/CAN 61. Individual states or local agencies have authority to accept or accredit certification organizations within their jurisdictions. Accreditation of certification organizations may vary from jurisdiction to jurisdiction.

NSF/ANSI/CAN 600 (which formerly appeared in NSF/ANSI/CAN 60 and 61 as Annex A, "Toxicology Review and Evaluation Procedures") does not stipulate a maximum allowable level (MAL) of a contaminant for substances not regulated by a USEPA final maximum contaminant level (MCL). The MALs of an unspecified list of "unregulated contaminants" are based on toxicity testing guidelines (noncarcinogens) and risk characterization methodology (carcinogens). Use of NSF/ANSI/CAN 600 procedures may not always be identical, depending on the certifier.

[†] Persons outside the United States should contact the appropriate authority having jurisdiction.

[‡] NSF International, 789 North Dixboro Road, Ann Arbor, MI 48105.

[§] Standards Council of Canada, 55 Metcalfe Street, Suite 600, Ottawa, ON K1P 6L5 Canada.

[¶] Both publications available from National Academies Press, 500 Fifth Street, NW, Washington, DC 20001.

Copyright © 2025 by American Water Works Association. All Rights Reserved

ANSI/AWWA F102 does not address additives requirements. Thus, users of this standard should consult the appropriate state or local agency having jurisdiction in order to

1. Determine additives requirements, including applicable standards.
2. Determine the status of certifications by parties offering to certify products for contact with, or treatment of, drinking water.
3. Determine current information on product certification.

II. Special Issues. This standard has no applicable information for this section.

III. Use of This Standard. It is the responsibility of the user of an AWWA standard to determine that the products described in that standard are suitable for use in the particular application being considered.

III.A. *Purchaser Options and Alternatives*. The following information should be provided by the purchaser:

1. Standard used—that is, ANSI/AWWA F102, Matched-Die-Molded, Fiberglass-Reinforced Plastic Weir Plates, Scum Baffles, and Mounting Brackets, of latest revision.
2. Whether compliance with NSF/ANSI/CAN 61, Drinking Water System Components—Health Effects, is required.
3. Whether a fire-retardant additive is required. The purchaser may desire plastic fabrications that include a fire-retardant additive to protect against flame spread and smoke propagation during storage, plant construction, and other conditions when basins are dewatered. The purchaser should recognize that such fabrications may be more costly, availability may be more limited, and certification to NSF/ANSI/CAN 61 or other health effects standards for products in contact with drinking water may not be possible.
4. Weir flow capacity.
5. Dimensional and weight limitations.
6. Materials present in the water to be treated with which the fabrications will be in contact.
7. Range of normal operating and extreme ambient temperatures anticipated during storage, project construction, maintenance, or other dewatered conditions.
8. Fittings, clearances, and attachment methods to be used and their requirements.
9. Type of installation.

Copyright © 2025 by American Water Works Association. All Rights Reserved

10. Operating conditions.

11. Fabrication classification (Sec. 1.1.2).

12. Whether certified drawings are to be provided (Sec. 4.1).

13. Details of federal, state, provincial, territorial, and local requirements (Sec. 4.2).

14. Whether ultraviolet stabilizers are required (Sec. 4.2.4).

15. Color and aesthetic treatments (Sec. 4.2.6).

16. Weir notch type and spacing (Sec. 4.3.1).

17. Specimens to be provided by the manufacturer (Sec. 5.1).

18. Tests to be performed by the manufacturer (Sec. 5.2).

19. Retest agreement requirements (Sec. 5.2.3).

20. Whether plant inspection is required, the conditions under which the inspection is to be carried out, and whether specific test equipment and testing assistance are required (Sec. 5.3).

21. Corrective action requirements if materials or products fail to conform to this standard, including assignment of cost for repair/replacement (Sec. 5.4).

22. Whether a guarantee statement is to be placed on the final product (Sec. 6.1.2).

23. Whether an affidavit of compliance is to be provided (Sec. 6.3).

III.B. *Modification to Standard*. Any modifications to the provisions, definitions, or terminology in this standard must be provided by the purchaser.

IV. Major Revisions. Major revisions made to the standard in this edition include the following:

1. Clarified Sec. III.A *Purchaser Options and Alternatives* to include the conditions under which the inspection is to be carried out and whether specific test equipment and testing assistance are required (foreword III.A, item 20).

2. Added potential repair option in cases of nonconformance (foreword III.A, item 21).

3. Removed clause to specify inspection conditions and replaced with a reference to the purchaser's documents (Sec. 5.3.1).

4. Revised Sec. 5.3.2 *Access to work* to refer to the purchaser's documents for agreements on access and assistance with test equipment.

5. Added other potential nonconformance resolutions besides replacement. Deleted affidavit of compliance from the nonconformance section (Sec. 5.4) since it is covered in Sec. 6.3.

Copyright © 2025 by American Water Works Association. All Rights Reserved

6. Removed manufacturer or supplier as provider of affidavit of compliance because an affidavit may be requested from a party other than the manufacturer (Sec. 6.3).

V. Comments. If you have any comments or questions about this standard, please call AWWA Engineering and Technical Services at 303.794.7711; write to the department at 6666 West Quincy Avenue, Denver, CO 80235-3098; or email at standards@awwa.org.

Copyright © 2025 by American Water Works Association. All Rights Reserved

This page intentionally blank.

Copyright © 2025 by American Water Works Association. All Rights Reserved

American Water Works Association

ANSI/AWWA F102-25
(Revision of ANSI/AWWA F102-19)

AWWA Standard

Matched-Die-Molded, Fiberglass-Reinforced Plastic Weir Plates, Scum Baffles, and Mounting Brackets

SECTION 1: GENERAL

Sec. 1.1 Scope

This standard describes the minimum requirements for fiberglass-reinforced plastic (FRP) weir plates, scum baffles, mounting brackets, lap plates, cover washers, and weir pans fabricated with the matched-die molding process. Included are requirements for design, construction, dimensions, tolerances, physical properties, work quality, appearance, and installation. This standard contains the requirements for using general-purpose and chemical-resistant resins. These fabrications are generally used in municipal water supply service and industrial water supply service applications.

1.1.1 *Exceptions*. This standard does not cover weir plates, scum baffles, mounting brackets, lap plates, and cover washers fabricated with the hand layup, sprayup, or flat-sheet machine-cut methods.

1.1.2 *Classification*. Resistance to the corrosive or chemical environment shall be determined prior to molding either Type I or Type II fabrications. Typically, municipal water supply service applications use Type I, and industrial water supply

Copyright © 2025 by American Water Works Association. All Rights Reserved