PD IEC TR 63401-3:2023



BSI Standards Publication

Dynamic characteristics of inverter-based resources in bulk power systems

Part 3: Fast frequency response and frequency ride-through from inverter-based resources during severe frequency disturbances

bsi.

National foreword

This British Standard is the UK implementation of IEC TR 63401-3:2023.

The UK participation in its preparation was entrusted to Technical Committee GEL/8/1.

A list of organizations represented on this committee can be obtained on request to its committee manager.

Contractual and legal considerations

This publication has been prepared in good faith, however no representation, warranty, assurance or undertaking (express or implied) is or will be made, and no responsibility or liability is or will be accepted by BSI in relation to the adequacy, accuracy, completeness or reasonableness of this publication. All and any such responsibility and liability is expressly disclaimed to the full extent permitted by the law.

This publication is provided as is, and is to be used at the recipient's own risk.

The recipient is advised to consider seeking professional guidance with respect to its use of this publication.

This publication is not intended to constitute a contract. Users are responsible for its correct application.

© The British Standards Institution 2023
Published by BSI Standards Limited 2023

ISBN 978 0 539 29338 8

ICS 27.160; 27.180; 29.020

Compliance with a British Standard cannot confer immunity from legal obligations.

This British Standard was published under the authority of the Standards Policy and Strategy Committee on 31 December 2023.

Amendments/corrigenda issued since publication

Date	Text affected

IEC TR 63401-3

Edition 1.0 2023-12

TECHNICAL REPORT

colour inside

Dynamic characteristics of inverter-based resources in bulk power systems – Part 3: Fast frequency response and frequency ride-through from inverter-based resources during severe frequency disturbances

INTERNATIONAL ELECTROTECHNICAL COMMISSION

ICS 27.160; 27.180; 29.020

ISBN 978-2-8322-8000-3

Warning! Make sure that you obtained this publication from an authorized distributor.

® Registered trademark of the International Electrotechnical Commission

CONTENTS

FOREWORD 6
INTRODUCTION 8
1 Scope 9
2 Normative references 9
3 Terms, definitions and abbreviated terms 9
3.1 Terms and definitions 9
3.2 Abbreviated terms 9
4 Definition of fast frequency response (FFR) 11
4.1 General 11
4.2 Existing usage of term FFR 11
4.2.1 FFR in Australia and Texas 11
4.2.2 FFR and synthetic inertia in European Network of Transmission System Operators for Electricity (ENTSO-E) 15
4.2.3 FFR and synthetic inertia in EirGrid/SONI 16
4.2.4 The enhanced frequency response and enhanced frequency control capability in the UK 18
4.2.5 FFR in North American Electric Reliability Council (NERC) and North America 18
4.3 Definition of FFR given by CIGRE JWG C2/C4.41 18
4.4 Recommended definition of fast frequency response (FFR) 19
4.4.1 Clear definition 19
4.4.2 Impact mechanism on system frequency 19
4.5 Description of the relationship among synchronous inertia response, fast frequency response, and primary frequency response 20
4.5.1 Relationship between synchronous inertia response and fast frequency response 20
4.5.2 Relationship between fast frequency response and primary frequency response 21
4.5.3 Relationship between synchronous inertia response and primary frequency response 21
5 System needs and conditions where fast frequency response is warranted 22
5.1 Higher ROCOF and lower nadir 22
5.1.1 General 22
5.1.2 Higher ROCOF 23
5.1.3 Worse nadir 24
5.1.4 Simulation study 25
5.1.5 Blackout in Great Britain power grid on 9 August 2019 26
5.2 Large fluctuation of system frequency in power system operation 29
5.2.1 General 29
5.2.2 Frequency regulation scheme 29
5.2.3 Relatively large load fluctuation 30
5.2.4 Relatively weak and slow PFR 30
6 Performance objectives for fast frequency response from inverter-based resources 31
6.1 The response time of FFR 31
6.2 The response characteristics and maximum response capacity of FFR 32
6.3 Test performance for renewable generator equipped with fast frequency response in China 34
6.3.1 General 34

6.3.2 Engineering construction 34
6.3.3 Test practice and performance 35
7 Available technologies, controls, and tuning considerations for fast frequency response and primary frequency response 35
7.1 Available technologies for fast frequency response 35
7.1.1 Technology capabilities for FFR service 35
7.1.2 Wind turbines 36
7.1.3 Solar PV 37
7.1.4 Battery energy storage 38
7.1.5 HVDC 40
7.2 Available controls for fast frequency response 41
7.2.1 General 41
7.2.2 Additional FFR control for grid-following converter 41
7.2.3 Grid-forming converter control 42
7.3 Tuning considerations for fast frequency response and primary frequency response 44
8 Test methods for verifying turbine-level or plant-level fast frequency response capability 45
8.1 General 45
8.2 Selection of test equipment 45
8.3 Test wiring method 45
8.4 Selection of measuring conditions 46
8.5 Step frequency disturbance test 47
8.6 Slope frequency disturbance test 47
8.7 Actual frequency disturbance simulation test 48
8.8 Actual frequency disturbance simulation test 48
9 Rate-of-change-of-frequency (ROCOF) definition and withstand capability for high ROCOF conditions 49
9.1 Definition of rate of change of frequency (ROCOF) 49
9.2 Ride-through (withstand) capability for high ROCOF conditions 51
10 Test specifications for high ROCOF conditions 53
10.1 Performance specification 53
10.1.1 Effective and operating ranges 53
10.1.2 Accuracy related to the characteristic quantity 53
10.1.3 Start time for rate of change of frequency (ROCOF) function 54
10.1.4 Accuracy related to the operate time delay setting 54
10.1.5 Voltage input 54
10.2 Functional test methodology 55
10.2.1 General 55
10.2.2 Determination of steady-state errors related to the characteristic quantity 55
10.2.3 Determination of the start time 63
10.2.4 Determination of the accuracy of the operate time delay 65
10.2.5 Determination of disengaging time 66
11 Modelling capabilities and improvements to dynamic models for fast frequency response and related high ROCOF conditions 67
11.1 General 67
11.2 Dynamic models for fast frequency response and related high ROCOF conditions 68
11.2.1 Dynamic models of whole power systems 68

11.2.2 Simplification of dynamic models 73
11.3 Modelling improvements 75
Bibliography 77

Figure 1 – Proposed response times by ERCOT as of 2014 12
Figure 2 – Time elements of FFR 14
Figure 3 – Impact mechanism on system frequency by FFR 20
Figure 4 – System frequency in response to a large generation trip 22
Figure 5 – Frequency characteristics under the same disturbance with various inverter-based resources penetration 26
Figure 6 – Frequency response in blackout in Great Britain power grid on 9 August 2019 27
Figure 7 – System frequency fluctuation under secondary frequency regulation due to load fluctuation in a grid 29
Figure 8 – Assignment of different modulations for quasi-steady-state frequency fluctuation 30
Figure 9 – Controlled contribution of electrical power provided by ROCOF-based FFR 33
Figure 10 – The controlled contribution of electrical power provided by deviation-based FFR 34
Figure 11 – Scheme of the transfer function of ROCOF-based FFR for grid-following converters 41
Figure 12 – Scheme of the transfer function of deviation-based FFR for grid-following converters 42
Figure 13 – Schematic of the droop control of deviation-based FFR for grid-forming converters 43
Figure 14 – Time elements of FFR 44
Figure 15 – Test wiring diagram 46
Figure 16 – Test slope curve for ROCOF-based FFR 48
Figure 17 – Schematic of increased ROCOF with increased renewable generation 50
Figure 18 – The response of IBRs for frequency slope change (change from 45 Hz to 55 Hz in 1 s) 51
Figure 19 – The response of IBRs for frequency step change of 1 Hz 52
Figure 20 – Operate time and operate time delay setting 54
Figure 21 – Example of test method for positive ROCOF function 56
Figure 22 – Test method for measurement of reset value for ROCOF functions: example for positive ROCOF function 59
Figure 23 – Start time measurement of positive ROCOF function 63
Figure 24 – Operate time delay measurement of positive ROCOF 65
Figure 25 – Disengaging time measurement of ROCOF 66
Figure 26 – Second generation BPS renewable energy system (RES) modules 69
Figure 27 – Load modelling practices 70
Figure 28 – WECC CLM 72
Figure 29 – Electronically interfaced load model 72
Figure 30 – Distributed energy resource model 73
Figure 31 – The traditional SFR model 73
Figure 32 – Improved model in light of ROCOF-based FFR and deviation-based FFR 75

Figure 33 – Electrical power from wind turbines for different combinations of wind power control strategies under 20 % wind power penetration in system 76

Table 1 – Frequency response times of FFR 13
Table 2 – Frequency response in Great Britain power grid on 9 August 2019 29
Table 3 – Summary of response times in different countries and regions 31
Table 4 – Summary of response times for inverter-based resources 31
Table 5 – Typical ranges of control parameters of FFR 34
Table 6 – Inertia response and fast frequency regulation performance 35
Table 7 – Input and output of a data collection point 46
Table 8 – Test conditions for fast frequency response of renewable energy power plant 46
Table 9 – Stepped frequency disturbance test 47
Table 10 – Test conditions for actual frequency disturbance simulation 48
Table 11 – Example of effective and operating ranges for over- and under-frequency protection 53
Table 12 – Example of effective and operating ranges for ROCOF protection 53
Table 13 – Test points for ROCOF function 57
Table 14 – Reporting of ROCOF accuracy 58
Table 15 – Test points of reset value for ROCOF function 62
Table 16 – Reporting of the reset value for ROCOF function 63
Table 17 – Test points for minimum frequency protection function start time 64
Table 18 – Test points to measure operate time delay 65
Table 19 – Test points for accuracy of the operate time delay 66
Table 20 – Test points of disengaging time for ROCOF function 67

INTERNATIONAL ELECTROTECHNICAL COMMISSION

_____

DYNAMIC CHARACTERISTICS OF INVERTER-BASED RESOURCES IN BULK POWER SYSTEMS –

Part 3: Fast frequency response and frequency ride-through from inverter-based resources during severe frequency disturbances

FOREWORD

1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
6) All users should ensure that they have the latest edition of this publication.
7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
9) IEC draws attention to the possibility that the implementation of this document may involve the use of (a) patent(s). IEC takes no position concerning the evidence, validity or applicability of any claimed patent rights in respect thereof. As of the date of publication of this document, IEC had not received notice of (a) patent(s), which may be required to implement this document. However, implementers are cautioned that this may not represent the latest information, which may be obtained from the patent database available at https://patents.iec.ch. IEC shall not be held responsible for identifying any or all such patent rights.

IEC TR 63401-3 has been prepared by subcommittee 8A: Grid Integration of Renewable Energy Generation, of IEC technical committee 8: System aspects of electrical energy supply. It is a Technical Report.

The text of this Technical Report is based on the following documents:

Draft	Report on voting
8A/130/DTR	8A/150/RVDTR

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

The language used for the development of this Technical Report is English.

This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available at www.iec.ch/members_experts/refdocs. The main document types developed by IEC are described in greater detail at www.iec.ch/standardsdev/publications.

A list of all parts in the IEC 63401 series, published under the general title *Dynamic characteristics of inverter-based resources in bulk power systems*, can be found on the IEC website.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under webstore.iec.ch in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn, or
- revised.

IMPORTANT – The "colour inside" logo on the cover page of this document indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

INTRODUCTION

Primary frequency response (PFR) denotes the autonomous reaction of system resources to change in frequency. In most power systems, the main contributor to PFR is the governor response of synchronous generation. In the systems with less synchronous generators, the system inertia is relatively low and PFR capability is relatively weak and slow, so the system frequency tends to change dramatically in severe power imbalance disturbances, which will trigger under-frequency load shedding (UFLS) or OPC (over speed protection control) of synchronous generators possibly. Therefore, it is an effective coping method to introduce some new frequency responses in the systems with high penetration of inverter-based resources.

This document studies fast frequency response (FFR) as a potential mitigation option in maintaining grid security during severe frequency disturbances. Broadly, FFR is some kind of rapid injection of electrical power from inverter-based resources or relief of loads that helps arrest the decline of system frequency during severe disturbances.

DYNAMIC CHARACTERISTICS OF INVERTER-BASED RESOURCES IN BULK POWER SYSTEMS –

Part 3: Fast frequency response and frequency ride-through from inverter-based resources during severe frequency disturbances

1 Scope

This part of IEC 63401, which is a Technical Report, provides an insight into the various forms of fast frequency response and frequency ride-through techniques that involve inverter-based generation sources (mainly wind and PV) in a bulk electrical system.

This document first focuses on extracting the clear definition of FFR from different references around the world, while studying the mechanism of FFR acting on system frequency and the unique features of FFR. It then compares various kinds of frequency response and demonstrates the relationship among synchronous inertia response, fast frequency response, and primary frequency response. Several system needs and conditions where FFR is suitable are identified. This document also focuses on the performance objectives, practicality and capabilities of various non-synchronous resources, and discusses the test methods for verifying FFR capability at different levels. Finally, it focuses on the ROCOF issues and on the robust performances of FFR.

2 Normative references

There are no normative references in this document.

3 Terms, definitions and abbreviated terms

3.1 Terms and definitions

No terms and definitions are listed in this document.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- IEC Electropedia: available at http://www.electropedia.org/
- ISO Online browsing platform: available at http://www.iso.org/obp

3.2 Abbreviated terms

Abbreviated term	Description
AEMO	Australian Energy Market Operator
AGC	automatic generation control
BESS	battery energy storage systems
BMS	battery management system
BPS	bulk power system