PD IEC TS 60871-3:2015+A1:2023



BSI Standards Publication

Shunt capacitors for AC power systems having a rated voltage above 1 000 V

Part 3: Protection of shunt capacitors and shunt capacitor banks

bsi.

National foreword

This Published Document is the UK implementation of IEC TS 60871-3:2015+A1:2023. It supersedes PD IEC/TS 60871-3:2015, which is withdrawn.

The start and finish of text introduced or altered by amendment is indicated in the text by tags. Tags indicating changes to IEC text carry the number of the IEC amendment. For example, text altered by IEC amendment 1 is indicated by A1 A1.

The UK participation in its preparation was entrusted to Technical Committee W/-, Consumer Products and Services Sector Policy and Strategy Committee.

A list of organizations represented on this committee can be obtained on request to its committee manager.

Contractual and legal considerations

This publication has been prepared in good faith, however no representation, warranty, assurance or undertaking (express or implied) is or will be made, and no responsibility or liability is or will be accepted by BSI in relation to the adequacy, accuracy, completeness or reasonableness of this publication. All and any such responsibility and liability is expressly disclaimed to the full extent permitted by the law.

This publication is provided as is, and is to be used at the recipient's own risk.

The recipient is advised to consider seeking professional guidance with respect to its use of this publication.

This publication is not intended to constitute a contract. Users are responsible for its correct application.

This publication is not to be regarded as a British Standard.

© The British Standards Institution 2023
Published by BSI Standards Limited 2023

ISBN 978 0 539 28477 5

ICS 29.240.99; 31.060.70

Compliance with a Published Document cannot confer immunity from legal obligations.

This Published Document was published under the authority of the Standards Policy and Strategy Committee on 31 July 2015.

Amendments/corrigenda issued since publication

Date	Text affected
30 September 2023	Implementation of IEC amendment 1:2023

CONTENTS

FOREWORD 5
1 Scope 7
2 Normative references 7
3 Terms and definitions 7
4 Internal fuses 7
4.1 General 7
4.2 Fuse characteristics 8
4.2.1 Rated current 8
4.2.2 Rated discharge capability 8
4.2.3 Disconnecting capability 8
4.2.4 Voltage withstand capability after operation 8
4.3 Influence of capacitor element configuration on capacitor life 8
4.3.1 Capacitor with all elements connected in parallel 8
4.3.2 Capacitor with elements connected in series and parallel 8
5 External fuses 8
5.1 General 8
5.2 Fuse characteristics 9
5.2.1 Rated current 9
5.2.2 Rated voltage 9
5.2.3 Time-current characteristics 9
5.2.4 Discharge capability 10
5.3 Fuse types 10
5.3.1 General 10
5.3.2 Expulsion fuses 10
5.3.3 Current-limiting fuses 11
5.3.4 Combination current-limiting/expulsion fuses 11
5.4 Influence of capacitor bank configuration on fuse selection 11
5.4.1 Single series section grounded star and delta banks 11
5.4.2 Single series section ungrounded star banks 11
5.4.3 Multiple series section banks 11
5.5 Coordination with case rupture curves 11
6 Unbalance detection 12
6.1 Operation 12
6.2 Types of unbalance protection 12
6.2.1 Neutral current (Figure 3) 12
6.2.2 Neutral voltage (Figure 4) 12
6.2.3 Current unbalance between neutrals (Figure 5) 13
6.2.4 Phase voltage unbalance (Figure 6) 13
6.2.5 Voltage difference (Figure 7) 13
6.2.6 Current unbalance in bridge connection (Figure 8) 13
6.3 Current and voltage transformers 13
6.3.1 Current transformers 13
6.3.2 Voltage transformers 14
6.4 Relays and protection settings 14
6.5 Sensitivity 14
6.6 Initial unbalance 15

7 Overload current 15
7.1 Operation 15
7.2 Protective arrangement 15
7.3 Current transformers 15
7.4 Relays 15
7.5 Protective settings 16
8 Over and undervoltage 16
8.1 Operation 16
8.2 Overvoltage protection 16
8.3 Undervoltage protection 16
8.4 Reclosing 16
9 Other protection 17
9.1 Surge arresters 17
9.1.1 General 17
9.1.2 Operation 17
9.1.3 Lightning transients 17
9.1.4 Switching transients 17
9.1.5 Temporary overvoltages 17
9.1.6 Rated voltage 17
9.1.7 Energy absorption 18
9.2 Damping devices 18
9.2.1 Capacitor switching 18
9.2.2 Inrush currents 18
9.2.3 Voltage transients 19
9.2.4 Ratings 19
9.3 Synchronized switching 19
9.3.1 Operation 19
9.3.2 Breaker contacts delay 19
10 Safety 19
10.1 Discharging devices 19
10.1.1 General 19
10.1.2 Internal resistors 20
10.1.3 External discharge devices 20
10.1.4 Discharging after disconnection 20
10.2 Dead metallic parts 20
Bibliography 25

Figure 1 – Fuse types 10
Figure 2 – Typical case rupture curves for approximately 30 000 cm³ case volume 21
Figure 3 – Star connection with the neutral grounded through a current transformer 21
Figure 4 – Star connection with voltage transformer between neutral and ground 21
Figure 5 – Star connection with ungrounded neutral and voltage transformers connected in an open delta 22
Figure 6 – Double-star connection with ungrounded neutral 22
Figure 7 – Star connection with grounded neutral and voltage transformers connected in differential measurement 22
Figure 8 – Bridge connection 22

Figure 9 – Line overcurrent relays for capacitor bank, grounded 22
Figure 10 – Line overcurrent relays for capacitor bank, ungrounded 23

Table 1 – Melting currents for type-K (fast) fuse links, in amperes 23
Table 2 – Melting currents for type-T (slow) fuse links, in amperes 24

INTERNATIONAL ELECTROTECHNICAL COMMISSION

_____

SHUNT CAPACITORS FOR AC POWER SYSTEMS HAVING A RATED VOLTAGE ABOVE 1 000 V –

Part 3: Protection of shunt capacitors and shunt capacitor banks

FOREWORD

1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
6) All users should ensure that they have the latest edition of this publication.
7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

The main task of IEC technical committees is to prepare International Standards. In exceptional circumstances, a technical committee may propose the publication of a technical specification when

- the required support cannot be obtained for the publication of an International Standard, despite repeated efforts, or
- t he subject is still under technical development or where, for any other reason, there is the future but no immediate possibility of an agreement on an International Standard.

International Standard IEC 60871-3, which is a technical specification, has been prepared by IEC technical committee 33: Power capacitors and their applications.

This second edition cancels and replaces the first edition published in 1996. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

a) Clearer writing of formulas on energy limitation for expulsion fuses;

b) Updated normative references and bibliography;

c) A new clause for synchronized switching has been added.

The text of this technical specification is based on the following documents:

Enquiry draft	Report on voting
33/545/DTS	33/563/RVC

Full information on the voting for the approval of this technical specification can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all parts in the IEC 60871, published under the general title *Shunt capacitors for a.c. power systems having a rated voltage above 1 000 V*, can be found on the IEC website.

The committee has decided that the contents of this publication will remain unchanged until the stability date indicated on the IEC website under "http://webstore.iec.ch" in the data related to the specific publication. At this date, the publication will be

- transformed into an International standard,
- r econfirmed,
- w ithdrawn,
- replaced by a revised edition, or
- amended.

A bilingual version of this publication may be issued at a later date.

SHUNT CAPACITORS FOR AC POWER SYSTEMS HAVING A RATED VOLTAGE ABOVE 1 000 V –

Part 3: Protection of shunt capacitors and shunt capacitor banks

1 Scope

This part of IEC 60871, which is a technical specification, gives guidance on the protection of shunt capacitors and shunt capacitor banks. it applies to capacitors according to IEC 60871-1.

2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60549, *High-voltage fuses for the external protection of shunt capacitors*

IEC 60871-1, *Shunt capacitors for a.c. power systems having a rated voltage above 1 000 V –Part 1: General*

IEC 60871-4, *Shunt capacitors for AC power systems having a rated voltage above 1 000 V – Part 4: Internal fuses*

3 Terms and definitions

For the purposes of this document, the terms and definitions given in IEC 60549, IEC 60871-1 and IEC 60871-4 apply.

4 Internal fuses

4.1 General

Internal fuses for shunt capacitors are selective current-limiting fuses arranged inside a capacitor. As defined in IEC 60871-4, they are designed to isolate faulted capacitor elements or capacitor unit, to allow operation of the remaining parts of that capacitor unit and the bank in which the capacitor unit is connected.

The operation of an internal fuse is initiated by the breakdown of a capacitor element. The affected element is instantaneously disconnected by the operation of the element fuse without interruption in the operation of the capacitor.

The number of externally parallel connected capacitors and the available short-circuit current of the supply system should not affect the current-limiting of internal fuses.

It should be noted that internal fuses do not provide protection against a short circuit between internal connections or a short circuit between active parts and casing, both of which may lead to case rupture.