PD IEC TS 62344:2022



BSI Standards Publication

Design of earth electrode stations for high-voltage direct current (HVDC) links — General guidelines

bsi.

National foreword

This Published Document is the UK implementation of IEC TS 62344:2022. It supersedes PD IEC/TS 62344:2013, which is withdrawn.

The UK participation in its preparation was entrusted to Technical Committee PEL/22, Power electronics.

A list of organizations represented on this committee can be obtained on request to its committee manager.

Contractual and legal considerations

This publication has been prepared in good faith, however no representation, warranty, assurance or undertaking (express or implied) is or will be made, and no responsibility or liability is or will be accepted by BSI in relation to the adequacy, accuracy, completeness or reasonableness of this publication. All and any such responsibility and liability is expressly disclaimed to the full extent permitted by the law.

This publication is provided as is, and is to be used at the recipient's own risk.

The recipient is advised to consider seeking professional guidance with respect to its use of this publication.

This publication is not intended to constitute a contract. Users are responsible for its correct application.

This publication is not to be regarded as a British Standard.

© The British Standards Institution 2023
Published by BSI Standards Limited 2023

ISBN 978 0 580 51635 1

ICS 29.240.99

Compliance with a Published Document cannot confer immunity from legal obligations.

This Published Document was published under the authority of the Standards Policy and Strategy Committee on 31 January 2023.

Amendments/corrigenda issued since publication

Date	Text affected

IEC TS 62344

Edition 2.0 2022-05

TECHNICAL SPECIFICATION

colour inside

Design of earth electrode stations for high-voltage direct current (HVDC) links – General guidelines

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

ICS 29.240.99

ISBN 978-2-8322-1035-2

Warning! Make sure that you obtained this publication from an authorized distributor.

® Registered trademark of the International Electrotechnical Commission

This page is left deliberately blank.

CONTENTS

FOREWORD 9
INTRODUCTION 11
1 Scope 12
2 Normative references 12
3 Terms and definitions 12
4 System conditions 16
4.1 General principles 16
4.2 System parameters related to earth electrode design 16
4.2.1 Amplitude and duration of the current 16
4.2.2 Polarity 16
4.2.3 Designed lifespan 16
4.2.4 Common earth electrodes 17
5 Design of land electrode stations 17
5.1 Main technical parameters 17
5.1.1 General principles 17
5.1.2 Temperature rise 17
5.1.3 Earthing resistance 17
5.1.4 Step voltage 18
5.1.5 Touch voltage 19
5.1.6 Current density 19
5.1.7 Field intensity in fish ponds 19
5.2 Electrode site selection and parameter measurement 19
5.2.1 General principles 19
5.2.2 Data collection survey 20
5.2.3 Distance from converter station (substation) 20
5.2.4 Environment conditions, terrain and landform 20
5.2.5 Geophysical and geological surveys 20
5.2.6 Topographical map 20
5.2.7 Values selected during design 20
5.3 Earth electrode and associated components 21
5.3.1 General principles for material selection 21
5.3.2 Selection of electrode elements and characteristics 21
5.3.3 Chemical and physical properties of petroleum coke 22
5.3.4 Current-guiding system 22
5.3.5 Bus 22
5.3.6 Electrode line and its monitoring device 23
5.4 Electrode arrangement 23
5.4.1 General principles 23
5.4.2 Filling coke 23
5.4.3 Selection of earth electrode shape 23
5.4.4 Earth electrode corridor (right of way) 24
5.4.5 Distance between sub-electrodes in the arrangement 24
5.4.6 Burial depth of the earth electrodes 24
5.4.7 Segmentation of earth electrodes 25
5.5 Minimum size of earth electrode 25
5.5.1 General principles 25

5.5.2 Total earth electrode length 25
5.5.3 Area of the surface of the coke-soil interface 25
5.5.4 Diameter of electrode elements 26
5.6 Current guiding system 26
5.6.1 General principles 26
5.6.2 Placement of the current-guiding wire 26
5.6.3 Connection of current-guiding wire 27
5.6.4 Selection of current-guiding wire cross-section 27
5.6.5 Insulation of the current-guiding wire 27
5.6.6 Disconnecting switch 27
5.6.7 Connection of the feeding cable 28
5.6.8 Connection of jumper cables 28
5.6.9 Selection of cable structure 28
5.6.10 Selection of cable cross-section 28
5.6.11 Selection of cable insulation 29
5.6.12 Cable welding position 29
5.6.13 Welding 29
5.6.14 Mechanical protection for cable 29
5.7 Auxiliary facilities 29
5.7.1 Online monitoring 29
5.7.2 Moisture replenishment 29
5.7.3 Exhaust equipment 30
5.7.4 Fence 30
5.7.5 Marker 30
6 Design of sea electrode station and shore electrode station 30
6.1 Main technical parameters 30
6.1.1 General 30
6.1.2 Temperature rise 30
6.1.3 Earthing resistance 30
6.1.4 Step voltage 30
6.1.5 Touch voltage 30
6.1.6 Voltage gradient in water 30
6.1.7 Current density 31
6.2 Electrode site selection and parameter measurement 31
6.2.1 General principles 31
6.2.2 Data collection survey 31
6.2.3 Distance from converter station (substation) 31
6.2.4 Environment conditions 31
6.2.5 Measurement of ground/water parameters 32
6.3 Earth electrode and associated components 32
6.3.1 General principles for material selection 32
6.3.2 Common electrode elements and characteristics 32
6.3.3 Chemical properties of petroleum coke 33
6.3.4 Current-guiding system 33
6.3.5 Bus 33
6.3.6 Electrode line monitoring device 33
6.4 Electrode arrangement 33
6.4.1 General principles 33
6.4.2 Filling coke 33

6.4.3 Selection of earth electrode shape 33
6.4.4 Segmentation of earth electrodes 34
6.5 Current-guiding system 34
6.5.1 Placement of the current-guiding wire 34
6.5.2 Connection of current-guiding system 34
6.5.3 Selection of cable cross-section 35
6.5.4 Insulation of the current-guiding system 35
6.5.5 Selection of cable structure 35
6.5.6 Mechanical protection for cable 35
6.6 Auxiliary facilities 35
7 Impact on surrounding facilities and mitigation measures 35
7.1 Impact on insulated metallic structures and mitigation measures 35
7.1.1 General principles 35
7.1.2 Relevant limits 36
7.1.3 Mitigation measures 36
7.2 Impact on bare metallic structures 36
7.2.1 General principles 36
7.2.2 Relevant limits 36
7.2.3 Mitigation measures 36
7.3 Impact on the power system (power transformer, grounding network, and surrounding towers) 36
7.3.1 General principles 36
7.3.2 Relevant limits 37
7.3.3 Mitigation measures 37
7.4 Impact on electrified railway 37
7.5 Other facilities (such as greenhouses and water pipes) 37
Annex A (informative) Basic concepts of earth electrodes 38
A.1 Basic concepts 38
A.2 Operation mode 38
A.2.1 General 38
A.2.2 Monopolar system 38
A.2.3 Bipolar system 39
A.2.4 Symmetric unbalanced system 41
A.2.5 Back-to-back converter station 41
A.3 Dangerous impact and accumulated impact 41
A.3.1 General 41
A.3.2 Safety risks of DC earth electrode 41
A.3.3 Accumulated effect of DC earth electrodes 46
A.4 Impact on an AC grid 47
A.4.1 General 47
A.4.2 DC current path to AC system 48
A.4.3 DC magnetic bias of AC transformer 48
Annex B (informative) Earth electrode design process 50
B.1 Site selection process 50
B.2 Earth electrode design process 51
Annex C (informative) Test results of human body resistance 53
C.1 Basic information of test subjects 53
C.2 Test method 54
C.3 Test results 54

Annex D (informative) Soil parameter measurement method 57
D.1 General requirements 57
D.2 Measurement of resistivity of shallow ground 58
D.2.1 Measurement method of resistivity 58
D.2.2 Measurement requirements 60
D.2.3 Measurement range 61
D.2.4 Data accuracy 61
D.2.5 Seasonal coefficient 61
D.2.6 Processing of measurement data 61
D.3 Measurement of resistivity of deep soil (MT method) 61
D.4 Measurement of soil volume thermal capacity 62
D.5 Measurement of soil thermal conductivity 62
D.6 Measurement of maximum natural temperature of soil 63
D.7 Measurement of soil moisture and groundwater table 63
D.8 Measurement of soil chemical characteristics 63
D.9 Geological exploration 63
D.10 Topographical map 63
Annex E (informative) Electrode line design 64
E.1 Overview 64
E.2 Main design principles 64
E.3 Selection and layout of conductor and earth wire 65
E.3.1 Selection of conductor 65
E.3.2 Selection of earth wire 65
E.3.3 Layout of conductor and earth wire 65
E.4 Insulation coordination and earthing for lightning protection 65
E.4.1 Type and number of insulators 65
E.4.2 Arcing horn gap 65
E.4.3 Earthing for lightning protection 66
E.5 Other considerations 66
Annex F (informative) Assessment of measurement method 67
F.1 General guidance 67
F.2 Experiment (testing) items 67
F.2.1 Visual inspection of the earth electrode 67
F.2.2 Current guiding system current distribution measurement 67
F.2.3 Measurement of earthing resistance 68
F.2.4 Measurement of step voltage on the ground and potential gradient in water near the earth electrode 68
F.2.5 Measurement of touch voltage 69
F.2.6 Measurement of soil surface potential profile 69
F.2.7 Measurement of earth electrode temperature rise 70
Annex G (informative) Earth electrode electrical parameter calculation method 71
G.1 General 71
G.2 Network method calculation model for DC earth electrode 71
G.3 Moment method calculation model for DC earth electrodes 71
G.4 Finite element method calculation model for DC earth electrodes 76
G.5 Calculation of earthing resistance, step voltage, touch voltage, electric field intensity and current density 78
G.5.1 General 78
G.5.2 Calculation of earthing resistance 78

G.5.3 Calculation of step voltage 78
G.5.4 Calculation of touch voltage 78
G.5.5 Calculation of electric field intensity 78
G.5.6 Calculation of current density 79
G.6 Application description 79
G.6.1 Original parameters 79
G.6.2 Example using the moment method 79
Annex H (informative) Thermal time constant 82
Annex I (informative) Online monitoring system 84
I.1 Schematic diagram of online monitoring system 84
I.2 Composition of online monitoring system 84
Annex J (informative) Calculation method for corrosion of nearby metal structures caused by earth electrodes 86
J.1 Consumption of metal structure due to corrosion 86
J.2 Estimate of leakage current in metal pipes 86
J.3 Calculation of the leakage current of the metal pipe 87
Annex K (informative) Calculation method for DC current flowing through AC transformer neutral near earth electrodes 88
Annex L (informative) Chemical processes in sea electrodes 91
Annex M (informative) Simple introduction of shore electrodes 92
M.1 General 92
M.2 Beach electrodes 92
M.3 Pond electrodes 92
Bibliography 94

Figure 1 – Electrode cross-section 23
Figure 2 – Vertical arrangement 24
Figure 3 – Placement of the current-guiding wire 27
Figure 4 – Feeding cable 28
Figure 5 – Sea electrode 33
Figure 6 – Sea bottom electrode with titanium nets 34
Figure 7 – Titanium net 35
Figure 8 – Impact of earth electrodes on AC systems (transformer, grounding network, tower) 37
Figure A.1 – HVDC power transmission system structure 38
Figure A.2 – Schematic diagram of monopolar earth/sea water return system 39
Figure A.3 – Schematic diagram of monopolar dedicated metallic return system 39
Figure A.4 – Schematic diagram of bipolar earth/sea water system 39
Figure A.5 – Schematic diagram of rigid bipolar system 40
Figure A.6 – Schematic diagram of bipolar dedicated metallic return system 41
Figure A.7 – Schematic diagram of touch voltage and step voltage 42
Figure A.8 – Schematic diagram of single circular earth electrode 43
Figure A.9 – Axial distribution of step voltage of single circular earth electrode 43
Figure A.10 – 3-D distribution of step voltage of single circular earth electrode 44
Figure A.11 – Schematic diagram of double circular earth electrode 44
Figure A.12 – Axial distribution of step voltage of double circular earth electrode 44

Figure A.13 – 3-D distribution of step voltage of double circular earth electrode 45
Figure A.14 – Schematic diagram of triple circular earth electrode 45
Figure A.15 – Axial distribution of step voltage of triple circular earth electrode 46
Figure A.16 – 3-D distribution of step voltage of triple circular earth electrode 46
Figure B.1 – Flow chart of earth electrode site selection process 50
Figure B.2 – Flow chart of earth electrode process 52
Figure C.1 – Age distribution of test samples 53
Figure C.2 – Height distribution of test samples 53
Figure C.3 – Weight distribution of test samples 54
Figure C.4 – Schematic diagram of test circuit 54
Figure C.5 – Histogram of foot-to-foot human body resistance distribution 55
Figure C.6 – Cumulative probability distribution of foot-to-foot body resistance by occupation 56
Figure D.1 – Equivalent circuit of Wenner method 59
Figure D.2 – Equivalent circuit of Schlumberger method 59
Figure D.3 – Equivalent circuit of dipole-dipole method 60
Figure G.1 – π shape equivalent circuit of an individual earth electrode unit 71
Figure G.2 – Ohm's Law applied to cylinder conductor 72
Figure G.3 – Continuity of axial component of the electric field in the soil and in the conductor 72
Figure G.4 – Spatial division of the earth electrode 72
Figure G.5 – Network for solving axis current 73
Figure G.6 – Horizontally layered soil 74
Figure G.7 – Geometrical structure of a tetrahedron unit 76
Figure G.8 – Structure of a double-circle DC earth electrode 80
Figure G.9 – Ground potential and step voltage distribution of a double-circle earth electrode 81
Figure H.1 – Earth electrode temperature rise characteristics 82
Figure I.1 – Schematic diagram of earth electrode online monitoring system 84
Figure J.1 – Calculation of current flowing through a metal pipe 87
Figure K.1 – Schematic diagram of ground resistance network and underground voltage source 88
Figure K.2 – Circuit model for the analysis of DC distribution of AC systems 90
Figure M.1 – Top view of shore electrode, beach type 92
Figure M.2 – Shore electrode, pond type 92

Table 1 – Composition of iron-silicon alloy electrode 22
Table 2 – Chemical composition of the petroleum coke after calcination 22
Table 3 – Physical properties of petroleum coke used for earth electrodes 22
Table 4 – Electric corrosion characteristics of different materials 26
Table C.1 – Statistical test results (foot-to-foot body resistance) 55
Table C.2 – Cumulative probability distribution of foot-to-foot human body resistance 56
Table D.1 – Soil (rock) / Water resistivity 57
Table D.2 – Soil volume thermal capacity 58

Table D.3 – Soil thermal conductivity 58
Table D.4 – Number of measurement points with different potential probes spacing..... 61
Table G.1 – Model of soil with two layers 80

INTERNATIONAL ELECTROTECHNICAL COMMISSION

_____

DESIGN OF EARTH ELECTRODE STATIONS FOR HIGH-VOLTAGE DIRECT CURRENT (HVDC) LINKS – GENERAL GUIDELINES

FOREWORD

1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
6) All users should ensure that they have the latest edition of this publication.
7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

IEC TS 62344 has been prepared by IEC technical committee 115: High Voltage Direct Current (HVDC) transmission for DC voltages above 100 kV. It is a Technical Specification.

This second edition cancels and replaces the first edition published in 2013. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

– Changed the requirement of earthing resistance limit for short-time unipolar earth system in 5.1.3.
– Corrected the coefficient before ρ_s from 0,015 9 to 0,008 in touch voltage limit calculation formula (3) in 5.1.5.
– Deleted the analytical calculation formulas of earthing resistance for sea and shore electrodes in 6.1.3.
– Changed the current density limit from 100 A/m^2 to 40 A/m^2 ~ 50 A/m^2 for the sea electrodes that are not accessible to human beings or to marine fauna in 6.1.7.

– Extended some detailed technical requirements for the measurement of ground/water soil parameters in 6.2.5.

– Reformulated the types and characteristics of electrode element material for sea and shore electrodes in 6.3.2.

– Added an informative Annex B: Earth electrode design process.

– Added an informative Annex C: Test results of human body resistance.

– Deleted the formula for calculating the average soil resistivity using harmonic mean when processing the measurement data in D.2.6 of Annex D.

– Extended some detailed technical requirements of electrode online monitoring system in Annex H.

– CIGRE 675:2017 is added to the bibliography.

– Terminology and way of expressions are modified using more commonly used terms in the HVDC electrode design industries and English speaking countries, so as to make the readers understand the content more easily.

The text of this Technical Specification is based on the following documents:

Draft	Report on voting
115/276/DTS	115/293/RVDTS

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

The language used for the development of this Technical Specification is English.

This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available at www.iec.ch/members_experts/refdocs. The main document types developed by IEC are described in greater detail at www.iec.ch/standardsdev/publications.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under webstore.iec.ch in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

INTRODUCTION

The high-voltage DC earth electrode is an important part of the DC power transmission system. It takes on the task of guiding the current into the earth under the monopolar earth return operation mode, and the unbalanced current under the bipolar operation mode. Further, it secures and provides the reference potential of converter neutral point under the bipolar/ monopolar operation mode, to protect the safe operation of the valves.

DC earth electrodes include land electrodes, sea electrodes, and shore electrodes. Today, there are around tens of DC electrodes in the world. Their influence on the nearby and far away environment is produced when there is DC current continuously leaking into the earth through DC earth electrodes.

Their influence on the surrounding environment includes:

a) influence on humans, mainly due to step voltage, touch voltage and transferred voltage;

b) influence on the electrode itself, mainly reflected by ground temperature rise and corrosion on the electrode;

c) influence on nearby ponds and organisms in the sea;

d) influence on the AC power system, mainly reflected by the DC voltage excursion of transformer neutral point;

e) influence on buried metallic objects, mainly revealed by the corrosion of buried metallic pipelines, AC grounding grids, tower foundations for power transmission lines and armoured cables, etc.

A great deal of experience has been accumulated in the research and design work in many countries, and relevant national standards or enterprise standards have been developed. The aim of this document is to develop the design guide for DC earth electrodes, on the site selection, material selection, shape, buried depth, adoption of equipment and connection styles, etc. It can be referred to by the electrode design engineers in different countries, to ensure the safe operation of earth electrode under different modes, control the influence on the environment nearby and the environment far away to the acceptable level, and to reasonably decrease engineering costs.

To ensure this document is more scientific, precise and practical, some research results obtained in recent years are adopted.

DESIGN OF EARTH ELECTRODE STATIONS FOR HIGH-VOLTAGE DIRECT CURRENT (HVDC) LINKS – GENERAL GUIDELINES

1 Scope

This document applies to the design of earth electrode stations for high-voltage direct current (HVDC) links. It is intended to provide necessary guidelines, limits, and precautions to be followed during the design of earth electrodes to ensure safety of personnel and earth electrodes, and reduce any significant impacts on DC power transmission systems and the surrounding environment.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60479-1, *Effects of current on human beings and livestock – Part 1: General aspects*

IEC TS 61201, *Use of conventional touch voltage limits – Application guide*

IEC 61936-1, *Power installations exceeding 1 kV AC and 1,5 kV DC – Part 1:* AC

IEC TS 61936-2, *Power installations exceeding 1 kV a.c. and 1,5 kV d.c. – Part 2: d.c.*

3 Terms and definitions

For the purposes of this document, the following terms and definitions apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- IEC Electropedia: available at http://www.electropedia.org/
- ISO Online browsing platform: available at http://www.iso.org/obp

3.1
earth (ground) electrode
conductive part that is in electric contact with local earth, directly or through an intermediate conductive medium

[SOURCE: IEC 60050-195:2021, 195-02-01]

3.2
land electrode
earth electrode buried in the ground above the high tide water level and located away from the shore and not influenced by water bodies

3.3
shore electrode

3.3.1
beach electrode
electrode located on the shore above the low tide water level, where the active part of the electrode is in contact with the soil or with underground water, but not directly with seawater

Note 1 to entry: Compared with land electrode, beach electrode is relatively close to the shore and is influenced by water bodies.