PD IEC TS 62898-3-4:2023



BSI Standards Publication

Microgrids

Part 3-4: Technical requirements — Microgrid monitoring and control systems

bsi.

National foreword

This Published Document is the UK implementation of IEC TS 62898-3-4:2023.

The UK participation in its preparation was entrusted to Technical Committee GEL/8, Systems Aspects for Electrical Energy Supply.

A list of organizations represented on this committee can be obtained on request to its committee manager.

Contractual and legal considerations

This publication has been prepared in good faith, however no representation, warranty, assurance or undertaking (express or implied) is or will be made, and no responsibility or liability is or will be accepted by BSI in relation to the adequacy, accuracy, completeness or reasonableness of this publication. All and any such responsibility and liability is expressly disclaimed to the full extent permitted by the law.

This publication is provided as is, and is to be used at the recipient's own risk.

The recipient is advised to consider seeking professional guidance with respect to its use of this publication.

This publication is not intended to constitute a contract. Users are responsible for its correct application.

This publication is not to be regarded as a British Standard.

© The British Standards Institution 2023
Published by BSI Standards Limited 2023

ISBN 978 0 539 16866 2

ICS 29.240.01

Compliance with a Published Document cannot confer immunity from legal obligations.

This Published Document was published under the authority of the Standards Policy and Strategy Committee on 31 August 2023.

Amendments/corrigenda issued since publication

Date	Text affected



IEC TS 62898-3-4

Edition 1.0 2023-08

TECHNICAL SPECIFICATION

Microgrids –
Part 3-4: Technical requirements – Microgrid monitoring and control systems

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

ICS 29.240.01

ISBN 978-2-8322-7438-5

Warning! Make sure that you obtained this publication from an authorized distributor.

® Registered trademark of the International Electrotechnical Commission

CONTENTS

FOREWORD 4
INTRODUCTION 6
1 Scope 8
2 Normative references 9
3 Terms, definitions and abbreviated terms 10
3.1 Terms and definitions 10
3.2 Abbreviated terms 12
4 Overview 12
4.1 General 12
4.2 System architecture 13
4.2.1 Stand-alone MMCS 13
4.2.2 Integrated MMCS 14
4.3 Hardware and software architectures 14
4.3.1 Hardware 14
4.3.2 Software 15
4.3.3 Database 15
4.4 Communication and cyber security 15
4.4.1 Communication 15
4.4.2 Cyber security 16
5 Functional requirements 17
5.1 Data acquisition and processing 17
5.1.1 Data acquisition 17
5.1.2 Data processing 17
5.2 Database management 18
5.3 Human-machine interface 18
5.4 Anti-maloperation locking and alarm 19
5.5 Time synchronization 20
5.6 Local power quality control 20
5.7 Frequency/voltage regulation during steady state operation of isolated microgrid 20
5.8 Sequence of operations 21
5.9 Control of device switching 21
5.10 Operating mode transition 21
5.10.1 General 21
5.10.2 Transition from island mode to grid-connected mode 22
5.10.3 Transition from grid-connected mode to island mode 22
5.11 Active and reactive power control 22
5.11.1 General 22
5.11.2 Active power control 22
5.11.3 Reactive power control and voltage control 23
5.12 Islanding detection 23
5.13 Black start 24
Annex A (informative) Example of collected information of MMCS 25
A.1 Microgrid operating data 25
A.1.1 Status data 25
A.1.2 Measurement data 25

A.2 Microgrid equipment operating status data 26
A.2.1 Primary equipment operating status data 26
A.2.2 Secondary equipment operating status data 26
A.2.3 Auxiliary equipment operating status data 26
A.3 Microgrid forecast data 27
A.4 Distributed energy planning data 27
Annex B (informative) Examples of actual microgrid applications and the associated functions of MMCS 28
B.1 Application CN1: MMCS of microgrid with photovoltaic and battery compacted with monitoring and control system of intelligent office park 28
B.1.1 General 28
B.1.2 System structure of MMCS 29
B.1.3 Main functions of MMCS 29
B.1.4 Applications 30
B.2 Application CN2: MMCS of MV small hydropower microgrid for solving power supply problems in remote areas 30
B.2.1 General 30
B.2.2 System structure of MMCS 31
B.2.3 Main functions of MMCS 32
B.2.4 Applications 34
B.3 Application JP1: Power stabilization with combining high-speed ΔF and ΔP suppression control utilizing storage batteries connected to thermal generation: the IKI island demonstration project from Japan 36
B.3.1 General 36
B.3.2 Purpose 37
B.3.3 Main functions of MMCS 37
B.3.4 Applications 38
Bibliography 40

Figure 1 – Functional mapping for operation and control of microgrids 13
Figure 2 – Structure of MMCS 14
Figure 3 – Typical three-layer communication for structure 1 16
Figure 4 – Typical two-layer communication for structure 2 16
Figure B.1 – Primary structure of Chengchuang microgrid 28
Figure B.2 – System structure of MMCS 29
Figure B.3 – The main single line diagram of the small hydropower microgrid 31
Figure B.4 – The main structure of MMCS 32
Figure B.5 – Daily voltage curve along the common line and Fengshan line before the implementation of microgrid in flooding period and heavy load 34
Figure B.6 – Daily voltage curve along the common line and Fengshan line after the implementation of microgrid 35
Figure B.7 – Daily voltage curve along the common line and Fengshan line before the implementation of microgrid 35
Figure B.8 – Daily voltage curve along the common line and Fengshan line after the implementation of microgrid 36
Figure B.9 – Overview of Iki Island power system and battery 37
Figure B.10 – Overview of control flow 38
Figure B.11 – Example of stable frequency due to storage battery charge / discharge 39

INTERNATIONAL ELECTROTECHNICAL COMMISSION

_____

MICROGRIDS

Part 3-4: Technical requirements – Microgrid monitoring and control systems

FOREWORD

1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as “IEC Publication(s)”). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
6) All users should ensure that they have the latest edition of this publication.
7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
9) IEC draws attention to the possibility that the implementation of this document may involve the use of (a) patent(s). IEC takes no position concerning the evidence, validity or applicability of any claimed patent rights in respect thereof. As of the date of publication of this document, IEC had not received notice of (a) patent(s), which may be required to implement this document. However, implementers are cautioned that this may not represent the latest information, which may be obtained from the patent database available at https://patents.iec.ch. IEC shall not be held responsible for identifying any or all such patent rights.

IEC TS 62898-3-4 has been prepared by subcommittee 8B: Decentralized electrical energy systems, of IEC technical committee TC 8: System aspects of electrical energy supply. It is a Technical Specification.

The text of this Technical Specification is based on the following documents:

Draft	Report on voting
8B/154/DTS	8B/178/RVDTS

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

The language used for the development of this Technical Specification is English.

This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available at www.iec.ch/members_experts/refdocs. The main document types developed by IEC are described in greater detail at www.iec.ch/publications.

A list of all parts in the IEC 62898 series, published under the general title *Microgrids*, can be found on the IEC website.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under webstore.iec.ch in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

INTRODUCTION

Microgrids can serve different purposes depending on the primary objectives of their applications. They are usually seen as means to manage reliability of supply and local optimization of energy supply by controlling distributed energy resources (DER). Microgrids also present a way to provide electricity supply in remote areas and to use clean and renewable energy as a systemic approach for rural electrification.

At present, there are many types of microgrid, often composed of distributed generation, battery energy storage, load, and other equipment. To achieve the effective integration and cooperative operation of the above equipment, a set of computer systems is often required, which is normally named as microgrid monitoring and control system. With the popularization of microgrids, the industry urgently needs a standard to specify the system architecture, component composition and functional requirements of microgrid monitoring and control system.

There are also various types of microgrid monitoring and control systems. For large scale (installed power > 100 kW) microgrid, its monitoring system and control system is more complex, usually using independent servers, workstations, remote terminal units, and others. Its communication protocol and data model can be based on the IEC 61850 series, and the system consists of a master station level and a local equipment level. For small-scale microgrids below 100 kW level, such as household microgrids with photovoltaic power generation and battery storage, it is relatively expensive to configure a complex microgrid monitoring and control system. At this time, the microgrid will generally adopt lightweight and cheap technical solutions, and the microgrid monitoring, control and energy management function will often be combined into a single device. Sometimes, for the small microgrid in remote mountainous areas, microgrid monitoring and control system based on the Internet of Things and cloud computing architecture is often used to realize the local autonomy and remote monitoring of the micro grid.

IEC TS 62898 series is intended to provide general guidelines and technical requirements for microgrid projects.

IEC TS 62898-1 mainly covers the following issues:

- determination of microgrid purposes and application,
- preliminary study necessary for microgrid planning, including resource analysis, load forecast, DER planning and power system planning,
- principles of microgrid technical requirements that should be specified during planning stage,
- microgrid evaluation to select an optimal microgrid planning scheme.

IEC TS 62898-2 mainly covers the following issues:

- operation requirements and control targets of microgrids under various operation modes,
- the basic control strategies and methods under various operation modes,
- the requirements of electrical energy storage (EES), relay protection, monitoring and communication under various operation modes,
- power quality.

IEC TS 62898-3-XX subseries technical specifications deal with the technical requirements of microgrids.

IEC TS 62898-3-1 mainly covers the following issues:

- requirements for microgrid protection,
- protection systems for microgrids,
- dynamic control for transient and dynamic disturbances in microgrids.

IEC TS 62898-3-2[1] covers the energy management system of microgrids.

IEC TS 62898-3-3 covers the self-regulation of dispatchable loads of microgrids.

This document covers microgrid monitoring and control systems (MMCS). It aims to provide requirements to address state monitoring and operation control problems in microgrids.

[1] Under preparation.

MICROGRIDS

Part 3-4: Technical requirements – Microgrid monitoring and control systems

1 Scope

The purpose of this part of IEC 62898 is to provide technical requirements for the monitoring and control of microgrids. This document applies to non-isolated or isolated microgrids integrated with distributed energy resources. This document describes the specific recommendations for low-voltage (LV) and medium-voltage (MV) microgrids.

This document focuses on standardization of the architecture, functions, and operation of microgrid monitoring and control systems (MMCS). It teases out the general functions of MMCS and provides technical requirements for MMCS. This document includes the following aspects of MMCS:

- system architecture,
- information exchange with other devices/functions in microgrid,
- performance requirement,
- main function descriptions.

The system architecture for MMCS:

- For a large scale (installed power > 100 kW) microgrid, microgrid energy management system (MEMS) and MMCS are normally separated. MMCS normally contains data servers, application servers, workstations, routers, information safety devices, SCADA, communication system, distributed generation controller, microgrid central controller, load controller, grid connection interface device and other ancillary equipment.
- For a small user-side microgrid (normally less than 100 kW), MEMS and MMCS are normally merged into one embedded device with system on chip, which is named as microgrid controller.

Main functions of MMCS:

- Data acquisition and processing, including collecting real-time data from the distributed generation, load, switches, transformers and reactive power compensation devices, and calculation and analysis of the acquired data.
- Database management, including maintaining, synchronizing, backing up, restoring the acquired data, and providing the data interface with other internal and external applications.
- Human-machine interface, including the real-time monitor screen and interface which is capable of remote control, mode switching, manual data entry, etc.
- Anti-maloperation locking and alarm, to lock the maloperation based on the predefined rule and logic.
- Time synchronization, including receiving the time synchronization signal from Global Navigation Satellite System (GNSS) or network time protocol (NTP) and synchronizing the time of each device within the microgrid.
- Local power quality evaluation and control the ability to collect information of out-of-limit voltage, power factor, harmonic, etc. and carry out control to improve power quality accordingly.
- Frequency/voltage regulation during steady state operation of an isolated microgrid to provide voltage and frequency inside an accepted operation range.

- Sequence of operations, or steady transition from power-off to start-up and from start-up to power-off.
- Switch control of devices within microgrids, including turning on and off loads, generation units, transformers, reactive power compensation devices, etc.
- Islanding detection, including real-time detection on power outage of the upstream distribution system.
- Operation mode transition, including transition from grid-connected mode to island mode and transition from island mode to grid-connected mode.
- Active and reactive power control, including load shedding (if required), load sharing and controlling the active and reactive power in real time according to the MEMS or manual command.
- Black start, the ability to initiate power sources and loads to ensure the microgrid can initiate operation from a non-energized state.
- Interface with the protection system or earthing system when adaptations are required according to the microgrid operating modes.

2 Normative references

The following documents are referred to in the text in such a way that some or all their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60870-5-101, *Telecontrol equipment and systems – Part 5-101: Transmission protocols – Companion standard for basic telecontrol tasks*

IEC 60870-5-104, *Telecontrol equipment and systems – Part 5-104: Transmission protocols – Network access for IEC 60870-5-101 using standard transport profiles*

IEC 61850 (all parts), *Communication networks and systems for power utility automation*

IEC 62443 (all parts), *Security for industrial automation and control systems*

IEC 62586-1, *Power quality measurement in power supply systems – Part 1: Power quality instruments (PQI)*

IEC TS 62898-1, *Microgrids – Part 1: Guidelines for microgrid projects planning and specification*

IEC TS 62898-2, *Microgrids – Part 2: Guidelines for operation*

IEC TS 62898-3-1, *Microgrids – Part 3-1: Technical requirements – Protection and dynamic control*

IEC TS 62898-3-2:—[2], *Microgrids – Part 3-2: Technical requirements – Energy management systems*

IEC TS 62898-3-3, *Microgrids − Part 3-3: Technical requirements − Self-regulation of dispatchable loads*

———————

[2] Under preparation. Stage at the time of preparation: IEC DTS 62898-3-2:2023.