IEC 60079-2

Edition 6.0 2014-07

INTERNATIONAL STANDARD

NORME INTERNATIONALE

Explosive atmospheres –
Part 2: Equipment protection by pressurized enclosure "p"

Atmosphères explosives –
Partie 2: Protection du matériel par enveloppe à surpression interne "p"



IEC 60079-2:2014-07(en-fr)



THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2014 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

Droits de reproduction réservés. Sauf indication contraire, aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de l'IEC ou du Comité national de l'IEC du pays du demandeur. Si vous avez des questions sur le copyright de l'IEC ou si vous désirez obtenir des droits supplémentaires sur cette publication, utilisez les coordonnées ci-après ou contactez le Comité national de l'IEC de votre pays de résidence.

IEC Central Office
3, rue de Varembé
CH-1211 Geneva 20
Switzerland

Tel.: +41 22 919 02 11
Fax: +41 22 919 03 00
info@iec.ch
www.iec.ch

About the IEC
The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications
The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigenda or an amendment might have been published.

IEC Catalogue - webstore.iec.ch/catalogue
The stand-alone application for consulting the entire bibliographical information on IEC International Standards, Technical Specifications, Technical Reports and other documents. Available for PC, Mac OS, Android Tablets and iPad.

IEC publications search - www.iec.ch/searchpub
The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee,…). It also gives information on projects, replaced and withdrawn publications.

IEC Just Published - webstore.iec.ch/justpublished
Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and also once a month by email.

Electropedia - www.electropedia.org
The world's leading online dictionary of electronic and electrical terms containing more than 30 000 terms and definitions in English and French, with equivalent terms in 14 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

IEC Glossary - std.iec.ch/glossary
More than 55 000 electrotechnical terminology entries in English and French extracted from the Terms and Definitions clause of IEC publications issued since 2002. Some entries have been collected from earlier publications of IEC TC 37, 77, 86 and CISPR.

IEC Customer Service Centre - webstore.iec.ch/csc
If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: csc@iec.ch.

A propos de l'IEC
La Commission Electrotechnique Internationale (IEC) est la première organisation mondiale qui élabore et publie des Normes internationales pour tout ce qui a trait à l'électricité, à l'électronique et aux technologies apparentées.

A propos des publications IEC
Le contenu technique des publications IEC est constamment revu. Veuillez vous assurer que vous possédez l'édition la plus récente, un corrigendum ou amendement peut avoir été publié.

Catalogue IEC - webstore.iec.ch/catalogue
Application autonome pour consulter tous les renseignements bibliographiques sur les Normes internationales, Spécifications techniques, Rapports techniques et autres documents de l'IEC. Disponible pour PC, Mac OS, tablettes Android et iPad.

Recherche de publications IEC - www.iec.ch/searchpub
La recherche avancée permet de trouver des publications IEC en utilisant différents critères (numéro de référence, texte, comité d'études,…). Elle donne aussi des informations sur les projets et les publications remplacées ou retirées.

IEC Just Published - webstore.iec.ch/justpublished
Restez informé sur les nouvelles publications IEC. Just Published détaille les nouvelles publications parues. Disponible en ligne et aussi une fois par mois par email.

Electropedia - www.electropedia.org
Le premier dictionnaire en ligne de termes électroniques et électriques. Il contient plus de 30 000 termes et définitions en anglais et en français, ainsi que les termes équivalents dans 14 langues additionnelles. Egalement appelé Vocabulaire Electrotechnique International (IEV) en ligne.

Glossaire IEC - std.iec.ch/glossary
Plus de 55 000 entrées terminologiques électrotechniques, en anglais et en français, extraites des articles Termes et Définitions des publications IEC parues depuis 2002. Plus certaines entrées antérieures extraites des publications des CE 37, 77, 86 et CISPR de l'IEC.

Service Clients - webstore.iec.ch/csc
Si vous désirez nous donner des commentaires sur cette publication ou si vous avez des questions contactez-nous: csc@iec.ch.

IEC 60079-2

Edition 6.0 2014-07

INTERNATIONAL STANDARD

NORME INTERNATIONALE

Explosive atmospheres –
Part 2: Equipment protection by pressurized enclosure "p"

Atmosphères explosives –
Partie 2: Protection du matériel par enveloppe à surpression interne "p"

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

COMMISSION
ELECTROTECHNIQUE
INTERNATIONALE

PRICE CODE
CODE PRIX XB

ICS 29.260.20

ISBN 978-2-8322-1746-7

Warning! Make sure that you obtained this publication from an authorized distributor.
Attention! Veuillez vous assurer que vous avez obtenu cette publication via un distributeur agréé.

® Registered trademark of the International Electrotechnical Commission
Marque déposée de la Commission Electrotechnique Internationale

CONTENTS

FOREWORD 7
INTRODUCTION 16
1 Scope 17
2 Normative references 17
3 Terms and definitions 18
4 Protection levels 20
5 Constructional requirements for pressurized enclosures 23
5.1 Enclosure 23
5.2 Materials 23
5.3 Doors and covers 23
5.3.1 Group I pressurized enclosures 23
5.3.2 Group I pressurized enclosures with static pressurization 23
5.3.3 Group II and Group III pressurized enclosures 23
5.3.4 Group II and Group III pressurized enclosures with static pressurization 24
5.3.5 Group II and Group III Level of Protection “pxb” 24
5.3.6 Group II and Group III Door and Cover warning 24
5.4 Mechanical strength 24
5.5 Group I and Group II Apertures, partitions, compartments and internal components 24
5.6 Apertures for Static Pressurization 25
5.7 Insulating materials for Group I equipment 25
5.8 Sealing 25
5.9 Spark and particle barriers 25
5.10 Cells and batteries 26
6 Temperature limits 26
6.1 General 26
6.2 For Level of Protection “pxb” or Level of Protection “pyb” 26
6.3 For Level of Protection “pzc” 26
7 Safety provisions and safety devices (except for static pressurization) 26
7.1 Suitability of safety devices for hazardous area 26
7.2 Integrity of safety devices 26
7.3 Provider of safety devices 27
7.4 Pressurization System evaluated as associated equipment 27
7.4.1 Pressurization systems for Level of Protection ”pzc”. 27
7.4.2 Pressurization systems for Level of Protection ”pyb”. 28
7.4.3 Pressurization systems for Level of Protection ”pxb”. 28
7.5 Sequence diagram for Level of Protection “pxb” 28
7.6 Ratings for safety devices 28
7.7 Group I and Group II Purging automated for Level of Protection “pxb” 28
7.8 Group I or Group II – Purging criteria 29
7.9 Group III – Cleaning 29
7.10 Requirements when a minimum flow rate required 29
7.11 Safety devices to detect minimum overpressure 29
7.12 Value of minimum overpressure 30
7.13 Pressurizing multiple enclosures 31
7.14 Safety devices on doors and covers 31

7.15 Equipment that may remain energized 31
7.16 Equipment permitted within Level of Protection “pyb” 31
8 Safety provisions and safety devices for static pressurization 32
8.1 Suitability of safety devices for hazardous area 32
8.2 Protective gas 32
8.3 Internal sources of release 32
8.4 Group I and Group II Filling procedure 32
8.5 Group III Filling Procedure 32
8.6 Safety devices 32
8.7 Equipment that may remain energized 32
8.8 Overpressure 32
9 Supply of protective gas 33
9.1 Backup supply 33
9.2 Independent supplies 33
9.3 Type of gas 33
9.4 Temperature 33
10 Pressurized equipment with an internal source of release 33
11 Release conditions 33
11.1 No release 33
11.2 Limited release of a gas or vapour 34
11.3 Limited release of a liquid 34
12 Design requirements for the containment system 34
12.1 General design requirements 34
12.2 Infallible containment system 34
12.3 Containment system with a limited release 35
13 Protective gas and pressurizing techniques when there is an internal source of release 35
13.1 General 35
13.2 Pressurization with leakage compensation 36
13.2.1 No release 36
13.2.2 Limited release of a gas or liquid 36
13.3 Pressurization with dilution 36
13.3.1 General 36
13.3.2 No release 36
13.3.3 Limited release of a gas or vapour 37
13.3.4 Limited release of a liquid 37
14 Ignition-capable equipment 37
15 Internal hot surfaces 37
16 Type verification and tests 38
16.1 Determining the maximum overpressure rating 38
16.2 Maximum overpressure test 38
16.3 Leakage test 38
16.3.1 Other than static pressurization 38
16.3.2 Static pressurization 38
16.4 Purging test for pressurized enclosures with no internal source of release and filling procedure test for static pressurization 39
16.4.1 General 39
16.4.2 Pressurized enclosure where the protective gas is air 39

16.4.3 Pressurized enclosure where the protective gas is inert 39
16.4.4 Pressurized enclosure where the protective gas may be either air or an inert gas with a density equal to air ±10 % 39
16.4.5 Filling procedure test for a pressurized enclosure protected by static pressurization 39
16.5 Purging and dilution tests for a pressurized enclosure with an internal source of release 39
16.5.1 Test gas 39
16.5.2 Pressurized enclosure where the flammable substance has less than 2 % (V/V) oxygen and the protective gas is inert 40
16.5.3 Pressurized enclosure with pressurization by continuous flow, containment system with less than 21 % (V/V) oxygen and the protective gas is inert 40
16.5.4 Pressurized enclosure where the flammable substance is not a liquid, pressurization by continuous flow and the protective gas is air 41
16.6 Verification of minimum overpressure 41
16.7 Tests for an infallible containment system 42
16.7.1 Overpressure test 42
16.7.2 Infallibility test 42
16.8 Overpressure test for a containment system with a limited release 42
17 Routine tests 42
17.1 Functional test 42
17.2 Leakage test 42
17.3 Tests for an infallible containment system 42
17.4 Test for a containment system with a limited release 42
18 Marking 42
18.1 General 42
18.2 Identifying as pressurized 43
18.3 Supplementary marking 43
18.4 Internal source of release 43
18.5 Static pressurization 43
18.6 Pressurization systems 43
18.7 Warnings required in other clauses 44
18.8 Overpressure limited by user 44
18.9 Inert gas 44
19 Instructions 45
Annex A (normative) Purging and dilution tests 46
A.1 General 46
A.2 Criteria for compliance where the protective gas is air 46
A.3 Criteria for compliance where the protective gas is inert 46
Annex B (informative) Examples of functional sequence diagram 47
Annex C (informative) Examples of the changes in pressure in ducts and enclosures 49
Annex D (informative) Information to be provided to the user 54
D.1 General 54
D.2 Ducting of protective gas 54
D.2.1 Location of inlet 54
D.2.2 Ducting between pressurized enclosure and inlet 54
D.2.3 Outlets for protective gas 54
D.2.4 Additional purge time to account for ducting 55

D.2.5 Temperature of protective gas at the inlet 55
D.3 Power for protective gas supply 55
D.4 Static pressurization 55
D.5 Enclosures with a containment system 55
D.6 Enclosure maximum overpressure 55
Annex E (normative) Classification of the type of release within enclosures 56
E.1 General 56
E.2 No normal release, no abnormal release 56
E.3 No normal release, limited abnormal release 56
E.4 Limited normal release 56
Annex F (informative) Examples for the use of the dilution area concept 57
Annex G (normative) Internal Cells and Batteries for Level of Protection "pxb" and Level of Protection "pyb" 59
G.1 General Requirements 59
G.1.1 General 59
G.1.2 Accepted Electrochemical Systems 59
G.1.3 Secondary cells and secondary batteries 59
G.1.4 Mechanical Protection 59
G.2 Electrical Protection by energy limiting circuits 60
G.2.1 Assessing as energy limited 60
G.2.2 Protective Components 60
G.2.3 Preventing excessive gas pressure 60
G.3 Additional requirements for Primary batteries 61
G.3.1 Prevention of reverse charging. 61
G.3.2 Prevention of accidental charging of primary batteries 61
G.4 Additional requirements for secondary batteries 62
G.4.1 Charging of secondary batteries inside the pressurized housing 62
G.5 Specific requirements for Inherently Safe (IhS) cells and batteries 62
G.6 Equipment located inside a pressurized enclosure connected to a battery which is also located inside the pressurized enclosure and not disconnected in the event of loss of pressurization 63
G.6.1 General 63
G.6.2 Circuit Isolation 63
G.6.3 Intrinsically safe battery or inherently safe battery used with "Ex" equipment 63
G.6.4 Intrinsically Safe or Inherently Safe battery with non-"Ex" equipment. 63
G.7 Supplementary marking and constructional requirements for pressurized enclosures containing one or more cells or batteries 65
G.7.1 General 65
G.7.2 Battery removal warning 65
G.7.3 Batteries requiring routine maintenance 65
G.8 Type tests 65
G.8.1 Voltage 65
G.8.2 Short circuit test for an Inherently Safe Cell or Battery 65
G.8.3 Full load test for other than Inherently safe batteries 65
Annex H (normative) Internal Cells and Batteries for Level of Protection "pzc" 66
H.1 General Requirements 66
H.1.1 General 66
H.1.2 Accepted Electrochemical Systems 66

H.1.3 Secondary cells and secondary batteries 66
H.1.4 Mechanical Protection 66
H.2 Equipment located inside a pressurized enclosure connected to a battery which is also located inside the pressurized enclosure and is not disconnected when power is removed from the enclosure. 67
H.3 Supplementary marking and constructional requirements for pressurized enclosures containing one or more cells or batteries 67
H.3.1 General 67
H.3.2 Battery removal warning 67
H.3.3 Batteries requiring routine maintenance 67
Bibliography 68

Figure B.1 – State diagram of a leakage-compensation purge control system 47
Figure C.1 – Protective gas outlet 50
Figure C.2 – Pressurized enclosures with leakage compensation, enclosures without moving parts 51
Figure C.3 – Pressurized enclosures with leakage compensation, rotating electrical machine with an internal cooling fan 52
Figure C.4 – Pressurized enclosure with a leakage compensation, rotating electrical machine with an external cooling fan 53
Figure F.1 – Diagram showing the use of the dilution area concept to simplify the purge and dilution test requirements 57
Figure F.2 – Diagram showing the use of the infallible containment system concept to simplify the purging and dilution requirements around ICE 58
Figure F.3 – Diagram showing the use of internal partitions around the potential source of release to simplify the purging and dilution requirements around ICE located outside the partitions 58
Figure G.1 – Reverse charging protection 61
Figure G.2 – Accidental charging protection 61

Table 1 – Determination of protection level 21
Table 2 – Design criteria based upon level of protection 22
Table 3 – Safety devices based upon Level of Protection 27
Table 4 – Protective gas requirements for a pressurized enclosure with a containment system 36
Table 5 – Equipment Protection Levels permitted within the dilution area based upon the Level of Protection of the pressurized enclosure 37
Table 6 – Text of warning markings 44
Table B.1 – Truth table of a leakage-compensation purge control system 47

INTERNATIONAL ELECTROTECHNICAL COMMISSION

_____

EXPLOSIVE ATMOSPHERES –

Part 2: Equipment protection by pressurized enclosure "p"

FOREWORD

1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
6) All users should ensure that they have the latest edition of this publication.
7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 60079-2 has been prepared by technical committee 31: Explosive atmospheres.

This sixth edition cancels and replaces the fifth edition published in 2007. This sixth edition cancels and replaces the first edition of IEC 61241-4 published in 2001. This sixth edition constitutes a technical revision.

The significance of changes between IEC 60079-2, Edition 6.0, 2014 and IEC 60079-2, Edition 5.0, 2007 are as listed below:

		Type		
Changes	**Clause**	**Minor and Editorial Changes**	**Extension**	**Major Technical Changes**
Scope Expanded to include combustible dust	1		X	
Protective Gas Replaced “apparatus” with “equipment”	3			
Protective Gas Revised to show that purging is not required for explosive dust atmospheres	3.16	X		
Level of Protection “pxb” Term and definitions revised to reflect EPL and level of protection	3.21	X		
Level of Protection “pyb” Term and definitions revised to reflect EPL and level of protection	3.22	X		
Level of Protection “pzc” Term and definitions revised to reflect EPL and level of protection	3.23	X		
Lower Flammable Limit Term and definition revised to agree with 60079-0	3.26	X		
Upper Flammable Limit Term and definition revised to agree with 60079-0	3.27	X		
Table 1 – Determination of protection level Revised to use EPL terminology	Table 1	X		
Table 2 – Design Criteria based upon level of protection Revised to use EPL terminology	Table 2	X		
Enclosure Requirements relaxed for specific designs	5.1		X	
Group II and Group III pressurized enclosures Text revised to use EPL terminology	5.3.3	X		
Group II and Group III Level of Protection “pxb” Added that warning also applies for explosive dust atmospheres	5.3.5		X	
Group II and Group III door and cover warning Added that warning also applies for explosive dust atmospheres	5.3.6		X	
Group II and Group III door and cover warning Revised warning from atmosphere “may be present” to “is present”	5.3.6	X		
Mechanical Strength Removed reference to 60079-0 by clause number for “X” condition	5.4	X		
Spark and particle barriers Removed reference to 60079-0 by clause number for “X” condition	5.9	X		
Cells and batteries Added requirements for cells and batteries	5.10			C1
For Level of Protection “pxb” or Level of Protection “pyb” Revised Table to use terminology consistent with EPLs	6.2	X		

Changes	Clause	Type		
		Minor and Editorial Changes	Extension	Major Technical Changes
Suitability of safety devices for hazardous area Word “explosion” changed to “ignition” to reflect UFL/LFL terms	7.1	X		
Integrity of safety devices Added requirement for detecting fan failure	7.2			C2
Table 3 – Safety devices based upon Level of Protection Revised column labels to use Level of Protection terminology	Table 3	X		
Provider of safety devices Remove reference to 60079-0 by clause number for “X” condition	7.3	X		
Pressurization System evaluated as associated equipment Added requirements for pressurization systems	7.4			C3
Sequence diagram for Level of Protection “pxb” Revised text to use Level of Protection terminology	7.5	X		
Group I and Group II purging automated for Level of Protection “pxb” Revised text to use Level of Protection terminology	7.7	X		
Group I and Group II purging automated for Level of Protection “pxb” Added text specifying that for “pxb”, control must be automated	7.7			C4
Group I or Group II – purging criteria Revised text to use Level of Protection terminology	7.8	X		
Group III – cleaning Added text for cleaning enclosures used in explosive dust atmospheres	7.9		X	
Safety devices to detect minimum overpressure Add word “minimum” to clause title to be consistent with text	7.11	X		
Safety devices to detect minimum overpressure Revised text to use Level of Protection terminology	7.11 d)	X		
Value of minimum overpressure Added word “minimum” to clause title to be consistent with text	7.12	X		
Value of minimum overpressure Revised text to use Level of Protection terminology	7.12	X		
Value of minimum overpressure Added text to reflect a note in Annex C	7.12		X	
Pressurizing multiple enclosures Revised text to use Level of Protection terminology	7.13	X		
Safety devices on doors and covers Revised text to use Level of Protection terminology	7.14	X		
Equipment that may remain energized Revised text to use EPL and level of protection terminology	7.15	X		
Equipment permitted within Level of Protection “pyb” Revised text to use EPL and level of protection terminology	7.16	X		
Group I and Group II Filling procedure Allow filling in a hazardous location if tested as non-hazardous	8.4		X	

		Type		
Changes	**Clause**	**Minor and Editorial Changes**	**Extension**	**Major Technical Changes**
Group III Filling Procedure Added static pressurization filling procedure for combustible dust	8.5		X	
Safety devices Revised text to use Level of Protection terminology	8.6	X		
Equipment that may remain energized Revised text to use EPL terminology	8.7	X		
Overpressure Removed reference to 60079-0 by clause number	8.8	X		
Backup supply Added requirements for a backup supply of protective gas	9.1			C5
Independent supplies Provided requirements for independence of pressurization	9.2		X	C6
Release Conditions Removed reference to 60079-0 by clause number for “X” condition	11.1.2	X		
Containment system with a limited release Removed reference to 60079-0 by clause number for “X” condition	12.3	X		
13.3.3 Limited release of a gas or vapour Revised text to reflect UFL/LFL terms	13.3.3	X		
Ignition-capable equipment Revised text to use Level of Protection terminology	14	X		
Type verification and tests Edition 5 clauses 16.1 to 16.7 moved to Edition 6 clauses 16.2 to 16.8	16	X		
Determining the maximum overpressure rating Added requirements to determine maximum overpressure	16.1			C7
Maximum overpressure test Moved Maximum overpressure test to 16.2	16.2			C7
Leakage test Clarify the acceptance criteria for the test	16.3.2		X	
Tests for an infallible containment system Clarify the rating used for the test	16.7.1			C8
Tests for an infallible containment system Modified test for infallible containment	16.7.2			C9
Edition 5 – Verifying ability of the pressurized enclosure to limit internal pressure Eliminated test	16.8			C7
Functional test Clarified that applies only to safety devices provided with enclosures	17.1	X		
Tests for an infallible containment system Waived helium leak tests for liquid systems	17.3		X	

		Type		
Changes	**Clause**	**Minor and Editorial Changes**	**Extension**	**Major Technical Changes**
Supplementary marking Allowed continued use of type of protection marking	18.3			
Pressurization systems Clarified use of Ex [p] and [Ex p] marking	18.6	X		
Warnings required in other clauses Added table number	18.7	X		
Warnings required in other clauses Added warning from 7.9	18.7		X	
Warnings required in other clauses Added warnings from Annex G and Annex H	18.7			C1
Instructions Added requirements for Group III	19		X	
Edition 5 Annex G – Infallibility test for containment system Deleted and replaced	Annex G	X		
Edition 5 Annex H – Introduction of an alternative risk assessment method encompassing “equipment protection levels” Deleted and replaced	Annex H	X		
Annex G – Internal Cells and Batteries for Level of Protection “pxb” and Level of Protection “pyb” Added requirements for cells and Batteries			X	
Annex H – Internal Cells and Batteries for Level of Protection “pzc” Added requirements for cells and Batteries			X	

Explanations:

A) Definitions

Minor and editorial changes clarification decrease of technical requirements minor technical change editorial corrections

These are changes which modify requirements in an editorial or a minor technical way. They include changes of the wording to clarify technical requirements without any technical change, or a reduction in level of existing requirement.

Extension addition of technical options

These are changes which add new or modify existing technical requirements, in a way that new options are given, but without increasing requirements for equipment that was fully compliant with the previous standard. Therefore, these will not have to be considered for products in conformity with the preceding edition. 5.

Major technical changes addition of technical requirements increase of technical requirements

These are changes to technical requirements (addition, increase of the level or removal) made in a way that a product in conformity with the preceding edition will not always be able to fulfill the requirements given in the later edition. These changes have to be considered for products in conformity with the preceding edition. For these changes additional information is provided in clause B) below

B) Information about the background of ‘Major Technical Changes’

C1 – Added annexes with requirements for using cells and batteries.

C2 – Added requirement that fan failure cannot be based upon loss of power to the fan.

C3 – Added requirements for equipment evaluated as a pressurization system to provide uniformity in the testing of such equipment.

C4 – Although, in Edition 5, the title of clause 7.6 stated automated purging, the word automated was not in the requirement. It is intended that all “pxb” equipment have an automated purging system to prevent energizing of ignition capable circuits until the purge cycle has been properly completed. This requires verifying that the flow is at least the minimum required for the purge time as well as verifying that the minimum overpressure exists within the enclosure.

C5 – If a backup supply of protective gas is provided, then both the primary and the backup supply needs to be capable of maintaining the required pressurization.

C6 – If a pressurized enclosure is used within a larger pressurized enclosure the protective gas supplies need to be independent.

C7 – The previous text in 16.1 of Edition 5, assumed that the enclosures had a maximum overpressure rating, but this is rarely the case. Some test houses relied upon the test in 16.8 to determine the maximum overpressure. Various methods were used to simulate regulator failure such as removing the regulator, but this also removed the orifices that would limit the flow. Based upon test house experience, the danger of flying fragments from the enclosure is acceptably small as either the enclosure or the gaskets will deform to relieve the internal pressure. A decision was taken to eliminate the overpressure test based upon the failed regulator. In addition, the definition of maximum overpressure is now based upon the value obtained when the pressurized enclosure is operated within its ratings. This maximum overpressure will generally occur when the equipment is in rapid purge mode with the maximum rated pressure applied to the inlet of the regulator. The Edition 5 text of 16.1 was modified and moved to 16.2.

C8 – The term overpressure in most cases implies operation outside of the normal ratings. Text was clarified to use the term “maximum operating pressure” rather than maximum internal overpressure. Test was 16.6.1 in Edition 5.

C9 – The test was modified to use helium leak detection rather than rely on maintaining a vacuum since this would depend upon the capability of the vacuum system. Test was 16.6.2 in Edition 5.

The significance of changes between IEC 60079-2, Edition 6.0, 2014 and IEC 61241-4, Edition 5.0, 2007 are as listed below:

		Type		
Changes	**Clause in 61241-4**	**Minor and Editorial Changes**	**Extension**	**Major Technical Changes**
Removed type of protection “pD”. Included in 3.20, 3.21 and 3.22	3.1		X	
Definition of pressurization now accommodates both gas and dust	3.3		X	
Definition of protective gas now accommodates both gas and dust	3.4		X	
Removed definition for an enclosure. Defined in IEC 60079-0	3.5	X		
Removed note in definition for pressurized enclosure.	3.6	X		
Replaced definition of static pressurization with 60079-2 definition	3.7	X		
Removed definition for “pressurization with continuous flow of the protective gas”. Term not used in 61241-4	3.9	X		
Removed definition for “electrical apparatus”. Definition is covered in IEV	3.10	X		
Definition of ignition-capable apparatus now accommodates both gas and dust	3.11	X		
Removed definition for “self-revealing fault”. Term not used in 61241-4	3.12	X		
Removed definition for “opening”. Term not used in 61241-4	3.13	X		
Removed definition for “protective device”. These are mostly referred	3.14	X		

Changes	Clause in 61241-4	Type		
		Minor and Editorial Changes	Extension	Major Technical Changes
to as a “safety device” throughout 61241-4.				
Removed definition for “protected apparatus”. This was only used to address batteries which are now covered in Annex G and Annex H.	3.17	X		
Replaced definition of “pressurization system” with 60079-2 definition	3.18	X		
Removed definition for “alternate (or auxiliary) source of supply of protective gas”. Term used is “second source of Supply. This is now addressed in 60079-2, 9.1	3.19	X		
Removed definition for “zones in Area Classification” This definition is provided in 60079-10-2.	3.20	X		
Removed definition for “zone 20 in Area Classification”. See above	3.21	X		
Removed definition for “zone 21 in Area Classification”. See above	3.22	X		
Removed definition for “zone 22 in Area Classification”. See above	3.23	X		
Removed Clause on “Pressurization principle” including sub-clauses. This information is covered by the definition of “Pressurization”, see 3.13 and other clauses in the standard.	4	X		
Removed Clause on “Electrical performance of apparatus”. Safe performance of equipment is addressed by 60079-0, 6.1 b)	5.1	X		
Removed note about equipment with large surface areas subjected to pressures > 1kPa may be subject to pressure vessel legislation.	5.2	X		
Text on apertures is equivalently covered by 5.5 and 5.6	5.3	X		
Text on electrical connections is equivalently covered in 60079-0, clause 14.	5.4	X		
Text on delaying opening of an enclosure because of internal hot surface is equivalently covered in clause 15.	5.5	X		
Removed text on providing suitable amount of doors or covers to provide for effective removal of dust from the enclosure. The text in 61241-4 would not lend itself to consistent assessments from different CBs.	5.5	X		
Text on temperature limits is equivalently covered in clause 6 and 60079-0, 26.5.1.3.	6	X		
Removed text on the responsibility of the manufacturer. Addressed in 60079-0.	7.1	X		
Removed text on the responsibility of the user. Addressed in 60079-14.	7.1	X		
Removed text that manufacturer shall provide instructions for cleaning the enclosure. Addressed in 60079-14.	7.1	X		
Removed text requiring a safety device to operate when the pressure within the enclosure exceeds the permitted maximum pressure. It is the user responsibility to not exceed the rated maximum pressure.	7.2	X		
Removed text requiring the isolation of the neutral conductor. Addressed in 60079-14.	7.4	X		
Text on failure of pressurization is equivalently covered by clause 7 & 13.3.	7.5	X		
Removed text on location of visible or audible alarms. Addressed in 60079-14.	7.5.1	X		
Removed text requiring both disconnection and alarming for Zone 21 Db. Addressed in 60079-14.	7.5.1.1	X		
Text on warning marking on doors and covers is equivalently covered in 5.3.6.	7.5.1.2	X		
Removed text about providing means for removing oil or moisture. Addressed in 60079-14, 13.1.6.	9.1	X		
Removed text requiring the minimum overpressure be verified over a 5 minute period. It is not considered that this measurement is time dependent.	10.4.1	X		

		Type		
Changes	**Clause in 61241-4**	**Minor and Editorial Changes**	**Extension**	**Major Technical Changes**
Removed text requiring the minimum overpressure be verified with through-the-wall moving parts operating in normal use. It is not considered that operating such parts will affect the internal pressure.	10.4.2	X		
Removed text requiring that the Leakage Test be done at a minimum of 200 Pa. The Leakage Test is only applicable to maximum overpressure specified by the manufacturer for normal service.	10.5	X		
Text on conformity for Leakage Testing of Static Pressurization is equivalently covered in 16.3.2.	10.5	X		
60079-2, Ed 6 does not have an exception to the impact test for pressurized enclosures that are not subject to mechanical damage.	10.6			B1
Removed text on routine Overpressure test	10.7	X		
Added text for routine tests of containment systems. 61241-4 did not address enclosures which contained an internal release of a flammable substance.	10.7		X	
Text on Marking is equivalently covered in clause 60079-0, clause 29	11.1	X		
Removed text requiring that “limitations affecting the safe use of the apparatus” be marked. This is covered in the Instructions, see 60079-0, clause 30.	11.2	X		
Removed text requiring that “the position at which the pressure and flow are monitored” be marked.	11.2	X		
Removed text requiring that “the maximum wattage of the lamp for a light fitting” be marked.	11.2	X		
Removed text “As agreed upon between the certificate applicant and testing station if necessary.”	11.4	X		

Explanations:
A) Definitions

Minor and editorial changes clarification decrease of technical requirements minor technical change editorial corrections
These are changes which modify requirements in an editorial or a minor technical way. They include changes of the wording to clarify technical requirements without any technical change, or a reduction in level of existing requirement.

Extension addition of technical options
These are changes which add new or modify existing technical requirements, in a way that new options are given, but without increasing requirements for equipment that was fully compliant with the previous standard. Therefore, these will not have to be considered for products in conformity with the preceding edition. 5.

Major technical changes addition of technical requirements increase of technical requirements
These are changes to technical requirements (addition, increase of the level or removal) made in a way that a product in conformity with the preceding edition will not always be able to fulfill the requirements given in the later edition. These changes have to be considered for products in conformity with the preceding edition. For these changes additional information is provided in clause B) below

B) Information about the background of ‘Major Technical Changes’

B1 – Pressurized enclosure must be subjected to impact testing as shown in Table 2.

The text of this standard is based on the following documents:

FDIS	Report on voting
31/1119/FDIS	31/1131/RVD

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

This standard is to be read in conjunction with IEC 60079-0, *Explosive atmospheres – Part 0: Equipment – General requirements*.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all parts of IEC 60079 series, under the general title Explosive atmospheres can be found on the IEC website.

Future standards in this series will carry the new general title as cited above. Titles of existing standards in this series will be updated at the time of the new edition.

The committee has decided that the contents of this publication will remain unchanged until the stability date indicated on the IEC web site under "http://webstore.iec.ch" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

The contents of the corrigendum of July 2015 have been included in this copy.

INTRODUCTION

This part of IEC 60079 gives requirements for the design, construction, testing and marking of electrical equipment for use in explosive atmospheres in which

a) a protective gas maintained at a pressure above that of the external atmosphere is used to guard against the formation of an explosive gas atmosphere within enclosures which do not contain an internal source of release of flammable gas or vapour;

b) a protective gas maintained at a pressure above that of the external atmosphere is used to guard against the formation of an explosive gas atmosphere within enclosures and is supplied to an enclosure containing one or more internal sources of release in order to guard against the formation of an explosive gas atmosphere; or

c) a protective gas maintained at a pressure above that of the external atmosphere, is used to prevent the entry of combustible dust which might otherwise lead to the formation of an explosive dust atmosphere within enclosures, but only where there is no internal source of release of combustible dust.

This standard includes requirements for the equipment and its associated equipment including the inlet and exhaust ducts, and also for the auxiliary control equipment necessary to ensure that pressurization and/or dilution is established and maintained.

EXPLOSIVE ATMOSPHERES –

Part 2: Equipment protection by pressurized enclosure "p"

1 Scope

This part of IEC 60079 contains the specific requirements for the construction and testing of electrical equipment with pressurized enclosures, of type of protection “p”, intended for use in explosive gas atmospheres or explosive dust atmospheres. It also includes the requirements for pressurized enclosures containing a limited release of a flammable substance.

This standard supplements and modifies the general requirements of IEC 60079-0. Where a requirement of this standard conflicts with a requirement of IEC 60079-0, the requirements of this standard take precedence.

This standard does not include the requirements for:

- pressurized enclosures where the containment system may release
  a) air with an oxygen content greater than normal, or
  b) oxygen in combination with inert gas where the oxygen is in a proportion greater than 21 %.
- pressurized rooms or analyser houses; see IEC 60079-13;
- pressurized enclosures used where “explosives” or pyrotechnics are present;
- pressurized enclosures used where hybrid mixtures of gas/vapour and combustible dust are present;
- pressurized enclosures used where pyrophoric substances such as explosives or propellants containing their own oxidizers are present
- pressurized enclosures with an internal source of release of combustible dust.

NOTE When the user acts in the role of the manufacturer, it is typically the user’s responsibility to ensure that all relevant parts of this standard are applied to the manufacturing and testing of the equipment.

2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60034-5, *Rotating electrical machines – Part 5: Degrees of protection provided by the integral design of rotating electrical machines (IP code) – Classification*

IEC 60050 (all parts), *International Electrotechnical Vocabulary*

IEC 60079-0, *Explosive atmospheres – Part 0: Equipment – General requirements*

IEC 60079-11, *Explosive atmospheres – Part 11: Equipment protection by intrinsic safety "i"*

IEC 60079-15, *Explosive atmospheres – Part 15: Equipment protection by type of protection "n"*

IEC 60112, *Method for the determination of the proof and the comparative tracking indices of solid insulating materials*

IEC 60127, (All parts) *Miniature fuses*

IEC 60529, *Degrees of protection provided by enclosures (IP Code)*

IEC 60664-1, *Insulation coordination for equipment within low-voltage systems – Part 1: Principles, requirements and tests*

3 Terms and definitions

For the purposes of this document, the terms and definitions given in IEC 60050-151, IEC 60050-426 and IEC 60079-0, as well as the following apply.

NOTE Unless otherwise specified, the terms "voltage" and "current" mean the r.m.s. values of an alternating, direct or composite voltage or current.

3.1
alarm
piece of equipment that generates a visual or audible signal that is intended to attract attention

3.2
containment system
part of the equipment containing the flammable substance that may constitute an internal source of release

3.3
dilution
continuous supply of a protective gas, after purging, at such a rate that the concentration of a flammable substance inside the pressurized enclosure is maintained at a value outside the explosive limits at any potential ignition source (that is to say, outside the dilution area)

Note 1 to entry: Dilution of oxygen by inert gas may result in a concentration of flammable gas or vapour above the upper flammable limit (UFL).

3.4
dilution area
area in the vicinity of an internal source of release where the concentration of a flammable substance is not diluted to a safe concentration

3.5
enclosure volume
volume of the empty enclosure without internal equipment. For rotating electrical machines, the free internal volume plus the volume displaced by the rotor

3.6
flammable substance
gases, vapours, liquids or mixtures thereof that are capable of being ignited

3.7
hermetically sealed device
device which is so constructed that the external atmosphere cannot gain access to the interior and in which any seal is made by fusion

Note 1 to entry: Examples of fusion include brazing, welding or the fusion of glass to metal.

3.8
ignition-capable equipment
ICE
equipment which in normal operation constitutes a source of ignition for a specified explosive atmosphere.

3.9
indicator
piece of equipment that shows whether flow or pressure is adequate and which is intended to be monitored periodically, consistent with the requirement of the application

3.10
internal source of release
point or location from which a flammable substance in the form of a flammable gas or vapour or liquid may be released into the pressurized enclosure such that in the presence of air an explosive gas atmosphere could be formed

3.11
leakage compensation
provision of a flow of protective gas sufficient to compensate for any leakage from the pressurized enclosure and its ducts

3.12
overpressure
pressure above ambient pressure within a pressurized enclosure

3.13
pressurization
technique of guarding against the ingress of the external atmosphere into an enclosure by maintaining a protective gas therein at a pressure above that of the external atmosphere

3.14
pressurization system
grouping of safety devices and other components used to pressurize and monitor or control a pressurized enclosure

3.15
pressurized enclosure
enclosure in which a protective gas is maintained at a pressure greater than that of the external atmosphere

3.16
protective gas
air or inert gas used for maintaining an overpressure and, if required, dilution and purging

Note 1 to entry: For the purposes of this standard, inert gas means nitrogen, carbon dioxide, argon or any gas which, when mixed with oxygen in the ratio 4 parts inert to 1 part oxygen as found in air, does not make the ignition and flammability properties, such as explosive limits, more onerous.

3.17
protective gas supply
compressor, blower or compressed gas container that provides the protective gas at a positive pressure

Note 1 to entry: The protective gas supply includes inlet (suction) pipes or ducts, pressure regulators, outlet pipes, ducts, and supply valves.

Note 2 to entry: Components of the pressurization system other than the pressure regulator, are not included.

3.18
purging
in a pressurized enclosure, the operation of passing a quantity of protective gas through the enclosure and ducts, so that the concentration of the explosive gas atmosphere is brought to a safe level

3.19
static pressurization
maintenance of an overpressure within a pressurized enclosure without the addition of protective gas in a hazardous area

3.20
Level of Protection "pxb"
pressurized enclosure providing Equipment Protection Level Mb, Gb or Db

Note 1 to entry: This permits unprotected equipment to be installed within the pressurized enclosure except for safety devices, see 3.23.

3.21
Level of Protection "pyb"
pressurized enclosure providing Equipment Protection Level Gb or Db with Equipment Protection Level Gc or Dc internal to the pressurized enclosure

Note 1 to entry: This permits Equipment Protection Level Gc or Dc equipment to be installed within the pressurized enclosure, except for safety devices, see 3.23

3.22
Level of Protection "pzc"
pressurized enclosure providing Equipment Protection Level Gc or Dc

Note 1 to entry: This permits unprotected equipment to be installed within the pressurized enclosure except for safety devices, see 3.23.

3.23

safety device
device used to implement or maintain the integrity of the type of protection

3.24
lower flammable limit
LFL
volume fraction of flammable gas or vapour in air below which an explosive gas atmosphere will not form, expressed as a percentage (see IEC 60079-20-1)

Note 1 to entry: This is also known as Lower Explosive Limit (LEL).

3.25
upper flammable limit
UFL
volume fraction of flammable gas or vapour in air above which an explosive gas atmosphere will not form, expressed as a percentage (see IEC 60079-20-1)

Note 1 to entry: This is also known as Upper Explosive Limit (UEL).

4 Protection levels

Protection by pressurization is subdivided into three Levels of Protection ("pxb", "pyb" and "pzc") which are selected based upon the Equipment Protection Level required (Mb, Gb, Db, Gc or Dc), whether there is the potential for an internal release, and whether the equipment within the pressurized enclosure is ignition-capable; see Table 1. The Level of Protection then