IEC 60079-29-0

Edition 1.0 2025-11

INTERNATIONAL STANDARD

Explosive atmospheres -
Part 29-0: Gas detection equipment - General requirements and test methods

ICS 29.260.20

ISBN 978-2-8327-0860-6

IEC 60079-29-0:2025-11(en)

THIS PUBLICATION IS COPYRIGHT PROTECTED
Copyright © 2025 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

IEC Secretariat
3, rue de Varembé
CH-1211 Geneva 20
Switzerland

Tel.: +41 22 919 02 11
info@iec.ch
www.iec.ch

About the IEC
The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications
The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigendum or an amendment might have been published.

IEC publications search - webstore.iec.ch/advsearchform
The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee, …). It also gives information on projects, replaced and withdrawn publications.

IEC Just Published - webstore.iec.ch/justpublished
Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and once a month by email.

IEC Customer Service Centre - webstore.iec.ch/csc
If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: sales@iec.ch.

IEC Products & Services Portal - products.iec.ch
Discover our powerful search engine and read freely all the publications previews, graphical symbols and the glossary. With a subscription you will always have access to up to date content tailored to your needs.

Electropedia - www.electropedia.org
The world's leading online dictionary on electrotechnology, containing more than 22 500 terminological entries in English and French, with equivalent terms in 25 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

Warning! Make sure that you obtained this publication from an authorized distributor.

CONTENTS

FOREWORD 4
INTRODUCTION 6
1 Scope 7
2 Normative references 8
3 Terms and definitions 8
3.1 Gas properties 8
3.2 Structure (or composition) of gas detection equipment 9
3.3 Sensors 11
3.4 Supply of gas to equipment 11
3.5 Signals and alarms 12
3.6 Times 14
3.7 Type OP open path gas detection equipment and fixed point infrared detectors 15
4 General requirements 16
4.1 Overview 16
4.2 Design 17
4.2.1 General 17
4.2.2 Indicators and means of indication 17
4.2.3 Alarm signal(s) 19
4.2.4 Fault signals 20
4.2.5 Special state indication 20
4.2.6 Adjustments 21
4.2.7 Battery-powered equipment 21
4.2.8 Software-controlled equipment 21
4.3 Marking 22
4.4 Instructions 23
5 Test methods 26
5.1 General 26
5.2 General requirements for tests 26
5.2.1 Samples and sequence of tests 26
5.2.2 Preparation of equipment before testing (all Types excluding FL-OP and TX-OP) 28
5.2.3 Preparation of equipment before testing (Types FL-OP and TX-OP) 29
5.3 Normal conditions for test 31
5.3.1 General 31
5.3.2 Test gas(es) 31
5.3.3 Flow rate for test gases 33
5.3.4 Power supply 33
5.3.5 Temperature 33
5.3.6 Pressure 33
5.3.7 Humidity 33
5.3.8 Acclimation time 34
5.3.9 Orientation 34
5.3.10 Communications options 34
5.4 Tests 34
5.4.1 General 34
5.4.2 Unpowered storage 35

5.4.3 Vibration 35
5.4.4 Drop test 37
5.4.5 Calibration kit 37
5.4.6 Linearity 37
5.4.7 Alarm set-point(s) 38
5.4.8 Stability 39
5.4.9 Gas concentrations above the upper limit of indication 40
5.4.10 Poisons and other gases 41
5.4.11 Temperature 43
5.4.12 Pressure (equipment with sensors only) 44
5.4.13 Humidity of test gas 44
5.4.14 Air velocity (diffusion equipment only) 45
5.4.15 Flow rate (aspirated equipment only) 45
5.4.16 Warm-up time 46
5.4.17 Time of response 46
5.4.18 Time of recovery 47
5.4.19 Sampling probe 47
5.4.20 Operation at or below the lower limit of measurement (Type O2-DE only) 47
5.4.21 Extended operation in test gas (Type TX only) 47
5.4.22 Orientation 48
5.4.23 Battery capacity for battery-powered equipment 48
5.4.24 Power supply variations for externally powered equipment 49
5.4.25 Electromagnetic immunity 49
5.4.26 Fault signal tests 51
5.4.27 Software controlled equipment 53
5.4.28 Environmental protection 53
5.4.29 Beam block fault (Type FL-OP and TX-OP except for topographic reflection) 54
5.4.30 Water vapour interference (Open path only) 55
5.4.31 Alignment (Open path only except for topographic detectors) 55
5.4.32 Partial obscuration (Open path only) 56
5.4.33 Long range operation (Open path only) 56
5.4.34 Direct solar radiation (Open path only) 56
5.4.35 Signal intensity variation (Open path topographic reflection only) 57
5.4.36 Scanning performance (Open path topographic reflection only) 57
Annex A (normative) Acceptance criteria for Type FL 58
A.1 Type FL-Group I 58
A.2 Type FL-Group II 60
A.3 Type FL-Group II hydrogen 63
Annex B (normative) Acceptance criteria for Type O2 66
Annex C (normative) Acceptance criteria for Type TX 69
Annex D (normative) Acceptance criteria for Type FL-OP and Type TX-OP 71
Annex E (normative) Gas specific performance requirements 73
Annex F (normative) Determination of time of response and time of recovery 74
F.1 General 74
F.2 Calculation of times of response and times of recovery 74
F.3 Pressure, temperature and gas velocities 75
F.4 Time of response and time of recovery methods for diffusion equipment 75

F.4.1 Calibration mask method 1 ... 75
F.4.2 Calibration mask method 2 ... 76
F.4.3 Flow method ... 77
F.4.4 Injection method ... 78
F.5 Time of response and time of recovery methods for aspirated equipment ... 78
F.5.1 Test rig ... 78
F.5.2 Equipment without internal pump ... 78
F.5.3 Equipment with internal pump ... 79
F.6 Open path detection equipment (Types FL-OP and TX-OP) ... 80
Annex G (informative) Transient considerations ... 81
G.1 Underdamped time of response ... 81
G.2 Underdamped time of recovery ... 83
Annex H (informative) Open path gas detection equipment water vapour test apparatus ... 86
Bibliography ... 87

Figure 1 – Relationship between indication range and measuring range ... 13
Figure 2 – Warm-up time in clean air (typical) ... 15
Figure 3 – Warm-up time in standard test gas (typical) ... 15
Figure 4 – Example of functional components of gas detection equipment ... 16
Figure 5 – Gas cell for calibration and speed of response test ... 30
Figure F.1 – Test chamber for calibration mask method 1 ... 76
Figure F.2 – Test arrangement for calibration mask method 2 ... 77
Figure F.3 – Schematic example of test chamber for flow method ... 78
Figure F.4 – Schematic example of test rig for use with aspirated equipment ... 79
Figure G.1 – Monotonic characteristic of overdamped or critically damped time response ... 81
Figure G.2 – Underdamped time response ... 83
Figure G.3 – Determination of time of recovery for the normal case, the deadband case and the underdamped case ... 85
Figure H.1 – Example of water vapour test apparatus ... 86

Table 1 – Indicators ... 17
Table 2 – Test samples and sequence of tests ... 26
Table A.1 – Acceptance criteria for Type FL-Group I ... 58
Table A.2 – Acceptance criteria for Type FL-Group II ... 60
Table A.3 – Acceptance criteria for Type FL-Group II hydrogen ... 63
Table B.1 – Acceptance criteria for Type O2 equipment (Type O2-DE & Type O2-IN) ... 66
Table C.1 – Acceptance criteria for Type TX equipment (Type TX-SM & Type TX-HM) ... 69
Table D.1 – Acceptance criteria for Type FL-OP & Type TX-OP ... 71
Table E.1 – Gas specific performance requirements ... 73

INTERNATIONAL ELECTROTECHNICAL COMMISSION

_____

Explosive atmospheres - Part 29-0: Gas detection equipment - General requirements and test methods

FOREWORD

1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as “IEC Publication(s)”). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
6) All users should ensure that they have the latest edition of this publication.
7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
9) IEC draws attention to the possibility that the implementation of this document may involve the use of (a) patent(s). IEC takes no position concerning the evidence, validity or applicability of any claimed patent rights in respect thereof. As of the date of publication of this document, IEC had not received notice of (a) patent(s), which may be required to implement this document. However, implementers are cautioned that this may not represent the latest information, which may be obtained from the patent database available at https://patents.iec.ch. IEC shall not be held responsible for identifying any or all such patent rights.

IEC 60079-29-0 has been prepared by the IEC technical committee 31: Equipment for explosive atmospheres. It is an International Standard.

This first edition of IEC 60079-29-0 cancels and replaces the second edition of 60079-29-1 published in 2016 and its Amendment 1:2020, and the first edition of IEC 60079-29-4 published in 2009. In addition, IEC 60079-29-0 Type TX-SM cancels and replaces Type SM of the first edition of IEC 62990-1; however, Type TX-HM will remain within the standard.

The text of this International Standard is based on the following documents:

Draft	Report on voting
31/1889/FDIS	31/1935/RVD

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

The language used for the development of this International Standard is English.

This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available at www.iec.ch/members_experts/refdocs. The main document types developed by IEC are described in greater detail at www.iec.ch/publications.

Users of this document are advised that interpretation sheets clarifying the interpretation of this document can be published. Interpretation sheets are available from the IEC webstore and can be found in the "history" tab of the page for each document.

A list of all parts in the IEC 60079-29 series, published under the general title *Explosive atmospheres*, can be found on the IEC website.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under webstore.iec.ch in the data related to the specific document. At this date, the document will be

– reconfirmed,

– withdrawn, or

– revised.

INTRODUCTION

This part of IEC 60079-29 specifies general requirements, test methods and acceptance criteria that apply to flammable, oxygen and toxic gas detection equipment intended to detect gases and vapours and to provide an indication, alarm or other output function for personnel or property protection in industrial and commercial applications. This part of IEC 60079-29 was developed for the purpose of aligning requirements and test methods of gas detection equipment within a single consolidated document for consistency.

Although a wide range of conditions can be encountered in practice, this document specifies requirements to be fulfilled by gas detection equipment when tested under prescribed laboratory conditions.

General and performance requirements for Type TX-HM gas detection equipment intended for occupational exposure measurement in the region of Occupational Exposure Limit Values are set out in IEC 62990-1.

Consideration needs to also be given to the following relevant international standards:

IEC 60079-29-2, *Explosive atmospheres - Part 29-2: Gas detectors - Selection, installation, use and maintenance of detectors for flammable gases and oxygen*

IEC 62990-2, *Workplace atmospheres - Part 2: Gas detectors - Selection, installation, use and maintenance of detectors for toxic gases and vapours*

IEC 60079-29-3, *Explosive atmospheres - Part 29-3: Gas detectors - Guidance on functional safety of fixed gas detection systems*

1 Scope

This part of IEC 60079-29 specifies general requirements, test methods and acceptance criteria that apply to flammable, oxygen and toxic gas detection equipment intended to detect gases and vapours and to provide an indication, alarm or other output function for personnel or property protection in industrial and commercial applications.

NOTE 1 The term gas detection equipment is often referred to as the term gas detector.

NOTE 2 The terms 'gas' and 'gases' used in this document are also intended to include 'vapour' and 'vapours'.

This document applies to the following gas detection equipment:

– Gas detection equipment Type "FL" intended for the detection of flammable gases:
  - Type FL-Group I, in mines susceptible to firedamp;
  - Type FL-Group II, in locations other than mines susceptible to firedamp; and
  - Type FL-OP, open path gas detection equipment for flammable gases.
– Gas detection equipment Type "O2" intended for the detection of oxygen:
  - Type O2-DE, detection of oxygen deficiency or oxygen enrichment; and
  - Type O2-IN, inertisation as measuring function for explosion protection.

NOTE 3 Inertisation is an explosion protection technique where an explosive atmosphere is purged with inert gas.

– Gas detection equipment Type "TX" intended for the detection of toxic gases:
  - Type TX-SM, detection in areas for safety monitoring applications and typically using alarm signalling;
  - Type TX-HM, occupational exposure measurement in the region of occupational exposure limit values; and

NOTE 4 Type TX-HM gas detection equipment performance requirements reside in IEC 62990-1.

  - Type TX-OP, open path gas detection equipment for toxic gases.

NOTE 5 This document addresses equipment giving a level of performance suitable for general purpose applications. Specific applications might require particular tests or evaluations that are additional to and separate from the compliance with this document.

NOTE 6 Although the focus of this document is gas detection equipment for use in 'explosive atmospheres', this document can be applicable to detection in areas not formally classified as 'explosive atmospheres'.

NOTE 7 Refrigerant gas detection equipment used for life, health and safety area monitoring are within the scope of this document or IEC 62990-1.

This document is not applicable to equipment:

– used for medical applications;
– used only in laboratories for analysis or measurement;
– used only for process monitoring or control purposes (such as a gas analyser);
– used in the domestic environment;
– used in environmental air pollution monitoring;
– used for flue gas analysis;
– used for sampling systems external to the gas detection equipment;
– with samplers and concentrators such as sorbents or paper tape having an irreversible indication;
– consisting of a passive optical receiver without a dedicated optical source;
– equipment within the scope of IEC 60335-2-40 and IEC 60335-2-89.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60079-29-2, *Explosive atmospheres - Part 29-2: Gas detectors - Selection, installation, use and maintenance of detectors for flammable gases and oxygen*

IEC 62990-2, *Workplace atmospheres - Part 2: Gas detectors - Selection, installation, use and maintenance of detectors for toxic gases and vapours*

IEC 60068-2-6, *Environmental testing - Part 2-6: Tests - Test Fc: Vibration (sinusoidal)*

IEC 60079-0, *Explosive atmospheres - Part 0: Equipment - General requirements*

IEC 60529, *Degrees of protection provided by enclosures (IP Code)*

IEC 61000-4-29, *Electromagnetic compatibility (EMC) - Part 4-29: Testing and measurement techniques - Voltage dips, short interruptions and voltage variations on d.c. input power port immunity tests*

IEC 61326-1, *Electrical equipment for measurement, control and laboratory use - EMC requirements - Part 1: General requirements*

IEC 62990-1, *Workplace atmospheres - Part 1: Gas detectors - Performance requirements of detectors for toxic gases*

ISO/IEC 80079-20-1, *Explosive atmospheres - Part 20-1: Material characteristics for gas and vapour classification - Test methods and data*