IEC 60092-376

Edition 4.0 2025-04

INTERNATIONAL STANDARD

Electrical installations in ships –
Part 376: Cables for control and instrumentation circuits 150/250 V (300 V)

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

ICS 47.020.60

ISBN 978-2-8327-0372-4

Warning! Make sure that you obtained this publication from an authorized distributor.

® Registered trademark of the International Electrotechnical Commission

CONTENTS

FOREWORD 4
1 Scope 6
2 Normative references 6
3 Terms and definitions 7
4 General requirements 7
4.1 Rated voltage 7
4.2 Markings 8
4.2.1 Indication of origin and voltage identification 8
4.2.2 Continuity of marking 8
4.2.3 Core identification 8
5 Construction requirements 8
5.1 General description 8
5.1.1 Overview 8
5.1.2 Unarmoured single- or double-sheathed cable 9
5.1.3 Armoured single-sheathed cable with outer sheath only 9
5.1.4 Armoured double-sheathed cable with inner and outer sheath only 9
5.1.5 Armoured single-sheathed cable with inner sheath only 9
5.2 Conductors 10
5.3 Insulation 10
5.3.1 Material 10
5.3.2 Application 10
5.3.3 Thickness of insulation 10
5.4 Cabling 11
5.4.1 General 11
5.4.2 Core assembly 11
5.4.3 Forming pair, triple, or quad units 11
5.4.4 Fillers 12
5.4.5 Number of cores, pair, triple, or quad units 12
5.5 Inner covering 12
5.5.1 General 12
5.5.2 Thickness of inner covering 12
5.6 Screen 12
5.6.1 Individual screen 12
5.6.2 Collective electrostatic screen 14
5.7 Inner sheath 14
5.7.1 Material 14
5.7.2 Application 15
5.7.3 Thickness of inner sheath 15
5.8 Braid armour 15
5.8.1 General 15
5.8.2 Braid wire diameter 15
5.8.3 Coverage density 15
5.8.4 Application of the armour 16
5.9 Outer sheath 16
5.9.1 Material 16
5.9.2 Application 16
5.9.3 Thickness of outer sheath 16

5.9.4 Colour of outer sheath 16
5.10 Construction for special applications 16
5.10.1 Cables for installation in explosive atmosphere areas 16
5.10.2 Cables for installation between areas with and without explosive atmospheres 16
6 Tests – Methods and requirements 17
6.1 General 17
6.2 Tests on cables for installation in explosive atmospheres 19
6.3 Tests on cables for installation between areas with and without explosive atmospheres 19
Annex A (informative) Core identification 21
Annex B (informative) Identification of cores of multicore cables 22
B.1 Marking 22
B.2 Arrangement of the marks 22
B.3 Spacing and dimensions of the marks 22
B.4 Appearance of marking 23
Annex C (informative) Number of cores, pair, triple or quad units 24
C.1 Number of cores 24
C.2 Number of pair, triple, or quad units 24
Bibliography 25

Figure B.1 – Arrangement of the marks 22

Table 1 – Electrical resistance of conductors 10
Table 2 – Insulation thickness 11
Table 3 – Thickness of inner covering 12
Table 4 – Drain wire requirements 13
Table 5 – Tests applicable to all cables 17
Table 6 – Additional tests required for halogen-free cables 19
Table 7 – Additional test required for low smoke cables 19
Table 8 – Additional tests required for fire resistant cables 19
Table 9 – Additional tests required for specific performances 19
Table 10 – Additional test for cables for installation between areas with and without explosive atmospheres 20
Table A.1 – Preferred colour code for single unit cables 21
Table B.1 – Dimensions of the marks 23

INTERNATIONAL ELECTROTECHNICAL COMMISSION

_____

ELECTRICAL INSTALLATIONS IN SHIPS –

Part 376: Cables for control and instrumentation circuits 150/250 V (300 V)

FOREWORD

1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
6) All users should ensure that they have the latest edition of this publication.
7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
9) IEC draws attention to the possibility that the implementation of this document may involve the use of (a) patent(s). IEC takes no position concerning the evidence, validity or applicability of any claimed patent rights in respect thereof. As of the date of publication of this document, IEC had not received notice of (a) patent(s), which may be required to implement this document. However, implementers are cautioned that this may not represent the latest information, which may be obtained from the patent database available at https://patents.iec.ch. IEC shall not be held responsible for identifying any or all such patent rights.

IEC 60092-376 has been prepared by subcommittee 18A: Electric cables for ships and mobile and fixed offshore units, of IEC technical committee 18: Electrical installations of ships and of mobile and fixed offshore units. It is an International Standard.

This fourth edition cancels and replaces the third edition published in 2017. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

a) addition of a colour code for wires and tapes for unit identification;
b) addition of the core numbering for multicore cables;
c) addition of design and test requirements for cables to be installed in explosive atmosphere areas;

d) addition of the design and test requirements for cables to be installed between areas with and without explosive atmospheres.

The text of this International Standard is based on the following documents:

Draft	Report on voting
18A/496/FDIS	18A/502/RVD

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

The language used for the development of this International Standard is English.

A list of all parts in the IEC 60092 series, published under the general title *Electrical installations in ships*, can be found on the IEC website.

This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available at www.iec.ch/members_experts/refdocs. The main document types developed by IEC are described in greater detail at www.iec.ch/publications.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under webstore.iec.ch in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn, or
- revised.

ELECTRICAL INSTALLATIONS IN SHIPS –

Part 376: Cables for control and instrumentation circuits 150/250 V (300 V)

1 Scope

This part of IEC 60092 applies to screened and unscreened cables for control and instrumentation circuits on ships and offshore units. The cables have an extruded solid insulation with a voltage rating of 150/250 V (300 V) (see Clause 4) and are intended for fixed installations.

The various types of cables are given in Clause 5. The construction requirements and test methods are aligned with those indicated in IEC 60092-350, unless otherwise specified in this document.

This document

– standardizes cables when they are installed in compliance with the requirements specified in IEC 60092-352,

– lays down standard construction requirements and characteristics of such cables directly or indirectly bearing on safety, and

– specifies test methods for checking conformity with those requirements.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60050-461, *International Electrotechnical Vocabulary – Part 461: Electric cables*

IEC 60079-14:2013, *Explosive atmospheres – Part 14: Electrical installations design, selection and installation of equipment, including initial inspection*

IEC 60092-350:2020, *Electrical installations in ships – Part 350: General construction and test methods of power, control and instrumentation cables for shipboard and offshore applications*

IEC 60092-360:2021, *Electrical installations in ships – Part 360: Insulating and sheathing materials for shipboard and offshore units, power, control, instrumentation and telecommunication cables*

IEC 60331-1, *Tests for electric cables under fire conditions – Circuit integrity – Part 1: Test method for fire with shock at a temperature of at least 830 °C for cables of rated voltage up to and including 0,6/1,0 kV and with an overall diameter exceeding 20 mm*

IEC 60331-2, *Tests for electric cables under fire conditions – Circuit integrity – Part 2: Test method for fire with shock at a temperature of at least 830 °C for cables of rated voltage up to and including 0,6/1,0 kV and with an overall diameter not exceeding 20 mm*

IEC 60331-21, *Tests for electric cables under fire conditions – Circuit integrity – Part 21: Procedures and requirements – Cables of rated voltage up to and including 0,6/1,0 kV*

IEC 60332-1-2, *Tests on electric and optical fibre cables under fire conditions – Part 1-2: Test for vertical flame propagation for a single insulated wire or cable – Procedure for 1 kW pre-mixed flame*

IEC 60332-3-22, *Tests on electric and optical fibre cables under fire conditions – Part 3-22: Test for vertical flame spread of vertically-mounted bunched wires or cables – Category A*

IEC 60445, *Basic and safety principles for man-machine interface, marking and identification – Identification of equipment terminals, conductor terminations and conductors*

IEC 60684-2, *Flexible insulating sleeving – Part 2: Methods of test*

IEC 60754-1, *Test on gases evolved during combustion of materials from cables – Part 1: Determination of the halogen acid gas content*

IEC 60754-2, *Test on gases evolved during combustion of materials from cables – Part 2: Determination of acidity (by pH measurement) and conductivity*

IEC 61034-2, *Measurement of smoke density of cables burning under defined conditions – Part 2: Test procedure and requirements*