# IEC 60287-1-3

Edition 2.0 2023-05
COMMENTED VERSION

# INTERNATIONAL STANDARD

colour inside

## Electric cables – Calculation of the current rating – Part 1-3: Current rating equations (100 % load factor) and calculation of losses – Current sharing between parallel single-core cables and calculation of circulating current losses



IEC 60287-1-3:2023-05 CMV(en)



**THIS PUBLICATION IS COPYRIGHT PROTECTED**
**Copyright © 2023 IEC, Geneva, Switzerland**

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

IEC Secretariat
3, rue de Varembé
CH-1211 Geneva 20
Switzerland

Tel.: +41 22 919 02 11
info@iec.ch
www.iec.ch

**About the IEC**
The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

**About IEC publications**
The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigendum or an amendment might have been published.

**IEC publications search - webstore.iec.ch/advsearchform**
The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee, …). It also gives information on projects, replaced and withdrawn publications.

**IEC Just Published - webstore.iec.ch/justpublished**
Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and once a month by email.

**IEC Customer Service Centre - webstore.iec.ch/csc**
If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: sales@iec.ch.

**IEC Products & Services Portal - products.iec.ch**
Discover our powerful search engine and read freely all the publications previews. With a subscription you will always have access to up to date content tailored to your needs.

**Electropedia - www.electropedia.org**
The world's leading online dictionary on electrotechnology, containing more than 22 300 terminological entries in English and French, with equivalent terms in 19 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

# IEC 60287-1-3

Edition 2.0 2023-05
COMMENTED VERSION

# INTERNATIONAL STANDARD

colour inside

## Electric cables – Calculation of the current rating – Part 1-3: Current rating equations (100 % load factor) and calculation of losses – Current sharing between parallel single-core cables and calculation of circulating current losses

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

ICS 29.060.20

ISBN 978-2-8322-7060-8

**Warning! Make sure that you obtained this publication from an authorized distributor.**

® Registered trademark of the International Electrotechnical Commission

# CONTENTS

FOREWORD ..... 3
INTRODUCTION ..... 5

1 Scope ..... 6
2 Normative references ..... 6
3 Terms, definitions and symbols ..... 6
3.1 Terms and definitions ..... 6
3.2 Symbols ..... 6
4 Description of method ..... 7
4.1 General ..... 7
4.2 Outline of method ..... 8
4.3 Matrix solution ..... 12

Annex A (informative) Example calculations ..... 13
A.1 ~~Introduction~~ Overview ..... 13
A.2 Example 1 ..... 13
A.2.1 General ..... 13
A.2.2 Calculations ..... 14
A.3 Example 2 ..... 19
A.4 Example 3 ..... 19
A.5 Example 4 ..... 20
Annex B (informative) Example of the computation of the coefficient $\alpha$ for hollow core conductors ..... 21
Bibliography ..... 22
List of comments ..... 23

Figure B.1 – Representation of a hollow core conductor ..... 21

Table 1 – Values of $\alpha$ for conductors ..... 11
Table A.1 – Sheath loss factor calculation according to IEC 60287-1-1 ..... 14
Table A.2 – Sheath current and sheath loss factor calculation per phase ..... 16
Table A.3 – Calculated values of $d_{j\text{i,k}}$ ..... 17
Table A.4 – Calculated values of $zz$ ..... 17
Table A.5 – Array [$Z$] including coefficients for currents ..... 18
Table A.6 – Sheath current and sheath loss factor calculation per phase ..... 19
Table A.7 – Sheath current and sheath loss factor calculation per phase ..... 20
Table A.8 – Sheath current and sheath loss factor calculation per phase ..... 20

INTERNATIONAL ELECTROTECHNICAL COMMISSION

_____

# ELECTRIC CABLES – CALCULATION OF THE CURRENT RATING –

## Part 1-3: Current rating equations (100 % load factor) and calculation of losses – Current sharing between parallel single-core cables and calculation of circulating current losses

## FOREWORD

1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as “IEC Publication(s)”). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
6) All users should ensure that they have the latest edition of this publication.
7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

**This commented version (CMV) of the official standard IEC 60287-1-3:2023 edition 2.0 allows the user to identify the changes made to the previous IEC 60287-1-3:2002 edition 1.0. Furthermore, comments from IEC TC 20 experts are provided to explain the reasons of the most relevant changes, or to clarify any part of the content.**

**A vertical bar appears in the margin wherever a change has been made. Additions are in green text, deletions are in strikethrough red text. Experts' comments are identified by a blue-background number. Mouse over a number to display a pop-up note with the comment.**

**This publication contains the CMV and the official standard. The full list of comments is available at the end of the CMV.**

IEC 60287-1-3 has been prepared by IEC technical committee 20: Electric cables. It is an International Standard.

This second edition cancels and replaces the first edition published in 2002. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

a) Change and update of list of symbols. **1**

The text of this International Standard is based on the following documents:

| Draft | Report on voting |
|---|---|
| 20/2098/FDIS | 20/2105/RVD |

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

The language used for the development of this International Standard is English.

This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available at www.iec.ch/members_experts/refdocs. The main document types developed by IEC are described in greater detail at www.iec.ch/publications.

A list of all parts in the IEC 60287 series, published under the general title *Electric cables – Calculation of the current rating*, can be found on the IEC website.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under webstore.iec.ch in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

**IMPORTANT – The "colour inside" logo on the cover page of this document indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.**

# INTRODUCTION

When single-core cables are installed in parallel, it is possible that the load current ~~may~~ will not share equally between the parallel cables. The circulating currents in the sheaths of the parallel cables will also differ. This is because a significant proportion of the impedance of large conductors is due to self reactance and mutual reactance. Hence the spacing and relative location of each cable will have an effect on the current sharing and the circulating currents. The currents are also affected by phase rotation. The method described in this document can be used to calculate the current sharing between conductors as well as the circulating current losses.

There is no simple rule by which the circulating current losses of parallel cables can be estimated. Calculation for each cable configuration ~~is necessary~~ should be applied. The principles and impedance formulae involved are straightforward but the difficulty arises in solving the large number of simultaneous equations generated. The number of equations to be solved generally precludes the use of manual calculations and solution by computer is recommended. For $n_c$ cables per phase having metallic sheaths in a three-phase system there are 6~~$n$~~ $\cdot$ $n_c$ equations containing the same number of complex variables.

For simplicity the equations set out in this document assume that the parallel conductors all have the same cross-sectional area. If this is not the case, the equations ~~may~~ should be adapted to allow for different resistances for each conductor. The effect of neutral and earth conductors can also be calculated by including these conductors in the appropriate loops. The method set out in this document does not take account of any portion of the sheath circulating currents that ~~may~~ can flow through the earth or other extraneous paths. In this respect, the effect of earth return path has been excluded for the purposes of the methodology described in the following, as it is concluded that it can affect the magnitude of the resulting circulating currents only by a small extent on a limited number of cases, where both very low soil electrical resistivity values and low earthing conductor resistance values are simultaneously considered. **2**

The conductor currents and sheath circulating currents in parallel single-core cables are unlikely to be equal. Because of this, the external thermal resistance for buried parallel cables should be calculated using the method set out in IEC 60287-2-1:2023, 4.2.3.2. Because the external thermal resistance and sheath temperatures are functions of the power dissipation from each cable in the group ~~it is necessary to adopt~~ an iterative procedure to determine the circulating current losses and the external thermal resistance should be adopted.

# ELECTRIC CABLES – CALCULATION OF THE CURRENT RATING –

# Part 1-3: Current rating equations (100 % load factor) and calculation of losses – Current sharing between parallel single-core cables and calculation of circulating current losses

## 1 Scope

This part of IEC 60287 provides a method for calculating the phase currents and circulating current losses in single-core cables arranged in parallel.

The method described in this document can be used for any number of cables per phase in parallel in any physical layout. The phase currents can be calculated for any arrangement of sheath bonding. For the calculation of sheath losses, it is assumed that the sheaths are bonded at both ends. A method for calculating sheath eddy current losses in two circuits in flat formation is given in IEC 60287-1-2.

## 2 Normative references

~~The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.~~

~~IEC 60287-1-2:1993, *Electric cables – Calculation of the current rating – Part 1: Current rating equations (100 % load factor) and calculation of losses – Section 2: Sheath eddy current loss factors for two circuits in flat formation*~~

~~IEC 60287-2-1:1994, *Electric cables – Calculation of the current rating – Part 2: Thermal resistance – Section 1: Calculation of thermal resistance*~~

There are no normative references in this document.

## 3 Terms, definitions and symbols

### 3.1 Terms and definitions

No terms and definitions are listed in this document.

ISO and IEC maintain terminology databases for use in standardization at the following addresses:

- IEC Electropedia: available at https://www.electropedia.org/
- ISO Online browsing platform: available at https://www.iso.org/obp

### 3.2 Symbols

$d_c$ external diameter of the conductor, mm

$d_s$ mean diameter of sheath or screen, mm

$f$ system frequency, Hz

~~i, k elements in the series of conductors~~

~~m, n elements in the series of cables~~

~~p~~ $n_c$ number of cables per phase

$D_{mn}$ axial spacing between conductors, mm

$[I]$ support vector used in the calculation of current in 4.3

$I_{p nc}$ current in the conductor of cable ~~p~~ $n_c$, A

$I_{sp nc}$ circulating current in the sheath of cable ~~p~~ $n_c$, A

$[Q]$ support matrix used in the calculation of current in 4.3

$R$ resistance of a conducting element, Ω/m

$R_c$ AC resistance of conductor at maximum operating temperature, Ω/m

$R_s$ AC resistance of the cable sheath or screen at their maximum operating temperature, Ω/m

$X_{i,k}$ apparent mutual reactance of a pair of conductors

$[Z]$ support matrix used in the calculation of current in 4.3

$\Delta V$ conductor voltage drop, V

~~$\alpha A$~~ coefficient depending on the construction of the conductor

$\lambda'_{p nc}$ sheath loss factor of cable ~~p~~ $n_c$ due to circulating currents

~~$\omega \Omega$~~ angular frequency of system ($2\pi f$), $s^{-1}$

NOTE Subscripts m, n, i and k are used in the following only to denote rows and columns of matrices and therefore to identify specific matrix elements. They do not correspond to the respective symbols used in other parts of the IEC 60287 series for identifying physical quantities.

## 4 Description of method

### 4.1 General

The method calculates the proportion of the phase current carried by each parallel conductor and the circulating current in the sheath of each cable. The loss factor ($\lambda'$) for each case is then calculated as the ratio of the losses in a sheath caused by circulating currents to the losses in the conductor of that cable.

The method of calculation set out in 4.2 and 4.3 only considers voltage drop along the conductors. Any unbalance in the load which would lead to unbalanced phase currents is ignored.

The equations to be solved for the unknown currents in the parallel conductors and their sheaths are built up from a consideration of the basic formulae for the impedance associated with a loop consisting of two long conductors lying parallel to each other and the formulae for the mutual impedance between a loop and an adjacent conductor. Consideration of these equations leads to a system of simultaneous equations for the impedance voltage for all the conductors and sheaths in a three-phase parallel cable system. The impedance voltages for all conductors in parallel in the same phase are equal. Also for the conductors representing the bonded sheaths the voltages are equal. Hence the impedance voltages can be eliminated from the equations. The sum of the currents in the parallel conductors is equal to either the known phase current or zero for the sheaths. This provides the additional information ~~needed~~ required for the solution of the simultaneous equations.

It should be noted that all the currents are complex quantities containing both real and imaginary parts.

The mutual impedance between conductors is a function of their relative positions. Hence, if the relative positions of the cables vary along the route, or the sheaths are cross-bonded, then

the impedance for each section shall be calculated individually and the vector results summed in order to obtain the total impedance of each loop. If the route length is very short, then significant errors ~~may~~ can occur in the calculated result due to the change in the relative positions of the cables as they approach the terminations.

The equations set out in this document can also be used to calculate the current sharing between cables without a metallic sheath or armour and between cables with the sheaths connected together at one end only, single-point bonded. For such calculations, the circulating current in each sheath is zero. Where cable sheaths are bonded at one end only, the standing voltage at the open circuit end of the sheath can also be determined using this method of calculation.

For the method set out in this document, it is recommended that the solution of the equations is achieved by a process of matrix algebra. This has the advantage that the solution achieved is unique and not a function of an iterative process.

### 4.2 Outline of method

The loss factor for the sheath in a given cable in a parallel circuit is given by:

~~$$\lambda'_{\mathrm{p}} = \left(\frac{I_{\mathrm{sp}}}{I_{\mathrm{p}}}\right)^2 \frac{R_{\mathrm{s}}}{R_{\mathrm{c}}} \qquad (1)$$~~

~~where~~

~~$\lambda'_{\mathrm{p}}$ is the sheath loss factor of cable p due to circulating currents;~~

~~$I_{\mathrm{sp}}$ is the circulating current in the sheath of cable p, in A;~~

~~$I_{\mathrm{p}}$ is the current in the conductor of cable p, in A;~~

~~$R_{\mathrm{s}}$ is the resistance of sheath at operating temperature, in Ω/m;~~

~~$R_{\mathrm{c}}$ is the a.c. resistance of conductor at operating temperature, in Ω/m.~~

$$\lambda'_{n_{\mathrm{c}}} = \left(\frac{I_{\mathrm{s}n_{\mathrm{c}}}}{I_{n_{\mathrm{c}}}}\right)^2 \frac{R_{\mathrm{s}}}{R_{\mathrm{c}}} \qquad (1)$$

The currents $I_{\mathrm{s}}$~~$_{\mathrm{p}}$~~$_{n\mathrm{c}}$ and $I$~~$_{\mathrm{p}}$~~$_{n\mathrm{c}}$ are obtained by solution of equations of the following form where there are ~~p~~$n_{\mathrm{c}}$ conductors in parallel and a total of ~~n~~ 6 · $n_{\mathrm{c}}$ conductors in a three-phase system. To simplify matters, both the phase conductors and the sheaths are referred to as conductors. The phase conductor currents are $I_1$, $I_2$, etc. The sheath currents are $I_{3}$~~$_{\mathrm{p}}$~~$_{n\mathrm{c}+1}$, $I_{3}$~~$_{\mathrm{p}}$~~$_{n\mathrm{c}+2}$, $I_{3}$~~$_{\mathrm{p}}$~~$_{n\mathrm{c}+3}$, etc.

For convenience in the calculations, the following notation is used:

Cable references

| | | | | | |
|---|---|---|---|---|---|
| Circuit | 1 | … | i | … | ~~p~~$n_{\mathrm{c}}$ |
| Phase R | 1 | … | i | … | ~~p~~$n_{\mathrm{c}}$ |
| Phase S | ~~p~~$n_{\mathrm{c}}$ + 1 | … | ~~p~~$n_{\mathrm{c}}$ + i | … | 2~~p~~$n_{\mathrm{c}}$ |
| Phase T | 2~~p~~$n_{\mathrm{c}}$ + 1 | … | 2~~p~~$n_{\mathrm{c}}$ + i | … | 3~~p~~$n_{\mathrm{c}}$ |

The conductors can then be identified as follows: