IEC 60287-2-1

Edition 3.0 2023-05
COMMENTED VERSION

INTERNATIONAL STANDARD

colour inside

Electric cables – Calculation of the current rating –
Part 2-1: Thermal resistance – Calculation of thermal resistance



IEC 60287-2-1:2023-05 CMV(en)



THIS PUBLICATION IS COPYRIGHT PROTECTED
Copyright © 2023 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

IEC Secretariat
3, rue de Varembé
CH-1211 Geneva 20
Switzerland

Tel.: +41 22 919 02 11
info@iec.ch
www.iec.ch

About the IEC
The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications
The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigendum or an amendment might have been published.

IEC publications search - webstore.iec.ch/advsearchform
The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee, …). It also gives information on projects, replaced and withdrawn publications.

IEC Just Published - webstore.iec.ch/justpublished
Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and once a month by email.

IEC Customer Service Centre - webstore.iec.ch/csc
If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: sales@iec.ch.

IEC Products & Services Portal - products.iec.ch
Discover our powerful search engine and read freely all the publications previews. With a subscription you will always have access to up to date content tailored to your needs.

Electropedia - www.electropedia.org
The world's leading online dictionary on electrotechnology, containing more than 22 300 terminological entries in English and French, with equivalent terms in 19 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

IEC 60287-2-1

Edition 3.0 2023-05
COMMENTED VERSION

INTERNATIONAL STANDARD

colour inside

Electric cables – Calculation of the current rating – Part 2-1: Thermal resistance – Calculation of thermal resistance

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

ICS 29.060.20

ISBN 978-2-8322-7061-5

Warning! Make sure that you obtained this publication from an authorized distributor.

® Registered trademark of the International Electrotechnical Commission

CONTENTS

FOREWORD 4
INTRODUCTION 7

1 Scope 8
2 Normative references 8
3 Terms, definitions and symbols 9
3.1 Terms and definitions 9
3.2 Symbols 9
4 Calculation of thermal resistances 12
4.1 Thermal resistance of the constituent parts of a cable, T_1, T_2 and T_3 12
4.1.1 General 12
4.1.2 Thermal resistance between one conductor and sheath T_1 12
4.1.3 Thermal resistance of any generic annular layer 16
4.1.4 Thermal resistance between sheath and armour T_2 17
4.1.5 Thermal resistance of outer covering (serving) T_3 17
4.1.6 Pipe-type cables 18
4.2 External thermal resistance T_4 18
4.2.1 Cables laid in free air 18
4.2.2 Single isolated buried cable 20
4.2.3 Groups of buried cables (not touching) 21
4.2.4 Groups of buried cables (touching) equally loaded 24
~~4.2.5 Buried pipes ..... ~~
4.2.5 Cables in buried troughs 26
4.2.6 Cables in ducts or pipes 27
4.2.7 Cables or conduits laid in a medium of different thermal resistivity 28
5 Digital calculation of quantities given graphically 30
5.1 General 30
5.2 Geometric factor G for two-core belted cables with circular conductors 30
5.3 Geometric factor G for three-core belted cables with circular conductors 32
5.4 Thermal resistance of three-core screened cables with circular conductors compared to that of a corresponding unscreened cable 33
5.5 Thermal resistance of three-core screened cables with sector-shaped conductors compared to that of a corresponding unscreened cable 35
5.6 Curve for $\overline{G}$ for obtaining the thermal resistance of the filling material between the sheaths and armour of SL and SA type cables 36
5.7 Calculation of $\Delta\theta_s$ by means of a diagram 37

Annex A (informative) Correction factor for increased lengths of individual cores within multicore cables 52
Bibliography 53
List of comments 54

Figure 1 – Diagram showing a group of q cables and their reflection in the ground-air surface 42

Figure 2 – Geometric factor G for two-core belted cables with circular conductors (see 4.1.2.2.2) 43
Figure 3 – Geometric factor G for three-core belted cables with circular conductors (see 4.1.2.2.4) 44
Figure 4 – Thermal resistance of three-core screened cables with circular conductors compared to that of a corresponding unscreened cable (see 4.1.2.3.1) 45
Figure 5 – Thermal resistance of three-core screened cables with sector-shaped conductors compared to that of a corresponding unscreened cable (see 4.1.2.3.3)....46
Figure 6 – Geometric factor $\overline{G}$ for obtaining the thermal resistances of the filling material between the sheaths and armour of SL and SA type cables (see 4.1.2.5)....47
Figure 7 – Heat dissipation coefficient for black surfaces of cables in free air, laying conditions 1 to 4....48
Figure 8 – Heat dissipation coefficient for black surfaces of cables in free air, laying conditions 5 to 8....49
Figure 9 – Heat dissipation coefficient for black surfaces of cables in free air, laying conditions 9 and 10 50
Figure 10 – Graph for the calculation of external thermal resistance of cables in air 51

Table 1 – Thermal resistivities of materials 39
Table 2 – Extended values of the geometric factor for duct banks and backfills 40
Table 3 – Values for constants Z, E and ~~g~~C_g for black surfaces of cables in free air....40
Table 4 – Absorption coefficient of solar radiation for cable surfaces 41
Table 5 – Values of constants U, V and Y....42
Table A.1 – Values of C_{fL} for different cases 52

INTERNATIONAL ELECTROTECHNICAL COMMISSION

_____

ELECTRIC CABLES – CALCULATION OF THE CURRENT RATING –

Part 2-1: Thermal resistance – Calculation of thermal resistance

FOREWORD

1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
6) All users should ensure that they have the latest edition of this publication.
7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

This commented version (CMV) of the official standard IEC 60287-2-1:2023 edition 3.0 allows the user to identify the changes made to the previous IEC 60287-2-1:2015 edition 2.0. Furthermore, comments from IEC TC 20 experts are provided to explain the reasons of the most relevant changes, or to clarify any part of the content.

A vertical bar appears in the margin wherever a change has been made. Additions are in green text, deletions are in strikethrough red text. Experts' comments are identified by a blue-background number. Mouse over a number to display a pop-up note with the comment.

This publication contains the CMV and the official standard. The full list of comments is available at the end of the CMV.

IEC 60287-2-1 has been prepared by IEC technical committee 20: Electric cables. It is an International Standard.

This third edition cancels and replaces the second edition published in 2015. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

a) thorough redefinition of symbols used across the IEC 60287 and IEC 60853 series to realign and unify definitions, eliminate inconsistencies and to improve cross-use of the different parts of both IEC 60287 and IEC 60853 series; **1**

b) improvement in the identification of tabulated materials and introduction of new materials in the tables;

c) introduction of generic annular layers to improve thermal modelling of existing and future cables designs;

d) improved calculation of T_4 in the case of directly buried cables;

e) introduction of corrective factors, on relevant calculated physical characteristics to take into account the effect of multicore lay-lengths; a dedicated annex to highlight correction factors for different number of cores has been introduced (Annex A);

f) improved description and formulation for the case of cables in pipe and backfill;

g) redefinition of the calculation method of T_4 for duct banks where y/x > 3, the new table based method eliminates errors, extends the usability of the new formulation while keeping a suitable conservative margin in the calculation.

The text of this International Standard is based on the following documents:

Draft	Report on voting
20/2099/FDIS	20/2106/RVD

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

The language used for the development of this International Standard is English.

This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available at www.iec.ch/members_experts/refdocs. The main document types developed by IEC are described in greater detail at www.iec.ch/publications.

A list of all parts in the IEC 60287 series, published under the general title *Electric cables – Calculation of the current rating*, can be found on the IEC website.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under webstore.iec.ch in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

IMPORTANT – The "colour inside" logo on the cover page of this document indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

INTRODUCTION

The IEC 60287 series has been divided into three parts so that revisions of, and additions to the document can be carried out more conveniently.

Each part is subdivided into subparts which are published as separate standards.

Part 1: Formulae of ratings and power losses;

Part 2: Formulae for thermal resistance;

Part 3: Operating conditions.

This part of IEC 60287-2 contains methods for calculating the internal thermal resistance of cables and the external thermal resistance for cables laid in free air, ducts and buried.

The formulae in this document contain quantities which vary with cable design and materials used. The values given in the tables are either internationally agreed, for example, electrical resistivities and resistance temperature coefficients, or are those which are generally accepted in practice, for example, thermal resistivities and permittivities of materials. In this latter category, some of the values given are not characteristic of the quality of new cables but are considered to apply to cables after a long period of use. In order that uniform and comparable results ~~may~~ can be obtained, the current ratings should be calculated with the values given in this document. However, where it is known with certainty that other values are more appropriate to the materials and design, then these may be used, and the corresponding current rating declared in addition, provided that the different values are quoted.

Quantities related to the operating conditions of cables are liable to vary considerably from one country to another. For instance, with respect to the ambient temperature and soil thermal resistivity, the values are governed in various countries by different considerations. Superficial comparisons between the values used in the various countries ~~may~~ can lead to erroneous conclusions if they are not based on common criteria: for example, there ~~may~~ can be different expectations for the life of the cables, and in some countries design is based on maximum values of soil thermal resistivity, whereas in others average values are used. Particularly, in the case of soil thermal resistivity, it is well known that this quantity is very sensitive to soil moisture content and ~~may~~ can vary significantly with time, depending on the soil type, the topographical and meteorological conditions, and the cable loading.

The following procedure for choosing the values for the various parameters should, therefore, be adopted:

Numerical values should preferably be based on results of suitable measurements. Often such results are already included in national specifications as recommended values, so that the calculation may be based on these values generally used in the country in question; a survey of such values is given in IEC 60287-3-1.

A suggested list of the information required to select the appropriate type of cable is given in IEC 60287-3-1.

ELECTRIC CABLES – CALCULATION OF THE CURRENT RATING –

Part 2-1: Thermal resistance – Calculation of thermal resistance

1 Scope

This part of IEC 60287 is solely applicable to the conditions of steady-state operation of cables at all alternating voltages, and direct voltages up to 5 kV, buried directly in the ground, in ducts, in troughs or in steel pipes, both with and without partial drying-out of the soil, as well as cables in air. The term "steady state" is intended to mean a continuous constant current (100 % load factor) just sufficient to produce asymptotically the maximum conductor temperature, the surrounding ambient conditions being assumed constant.

This document provides formulae for thermal resistance.

The formulae given are essentially literal and designedly leave open the selection of certain important parameters. These ~~may~~ can be divided into three groups:

– parameters related to construction of a cable (for example, thermal resistivity of insulating material) for which representative values have been selected based on published work;

– parameters related to the surrounding conditions which ~~may~~ can vary widely, the selection of which depends on the country in which the cables are used or ~~are to~~ will be used;

– parameters which result from an agreement between manufacturer and user and which involve a margin for security of service (for example, maximum conductor temperature).

Equations given in this document for calculating the external thermal resistance of a cable buried directly in the ground or in a buried duct are for a limited number of installation conditions. Where analytical methods are not available for calculation of external thermal resistance finite element methods ~~may~~ can be used. Guidance on the use of finite element methods for calculating cable current ratings is given in IEC TR 62095.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60287-1-1:~~2006~~2023, *Electric cables – Calculation of the current rating – Part 1-1: Current rating equations (100 % load factor) and calculation of losses – General*
~~IEC 60287-1-1:2006/AMD1:2014~~

IEC 60853-2, *Calculation of the cyclic and emergency current rating of cables – Part 2: Cyclic rating of cables greater than 18/30 (36) kV and emergency ratings for cables of all voltages*

3 Terms, definitions and symbols

3.1 Terms and definitions

No terms and definitions are listed in this document.

ISO and IEC maintain terminology databases for use in standardization at the following addresses:

- IEC Electropedia: available at https://www.electropedia.org/
- ISO Online browsing platform: available at https://www.iso.org/obp

3.2 Symbols

The symbols used in this document and the quantities which they represent are given in the following list:

C_{fL}	factor to take into account the position of the neutral axis of the helically wound cores	
C_{K1}	screening factor for the thermal resistance of screened cables	
C_{LL}	length correction factor for considering laying up of cores	
D'_a	external diameter of armour	mm
D_d	internal diameter of duct	mm
D_e	external diameter of cable, or equivalent diameter of a group of cores in pipe-type cable	mm
D^*_e	external diameter of cable (used in 4.2.1)	m
D_o	external diameter of duct	mm
D_s	external diameter of metal sheath	mm
D_{oc}	diameter of the imaginary coaxial cylinder which just touches the crests of a corrugated sheath	mm
D_{ot}	diameter of the imaginary coaxial cylinder which would just touch the outside surface of the troughs of a corrugated sheath = $D_{it} + 2t_s$	mm
D_{ic}	diameter of the imaginary cylinder which would just touch the inside surface of the crests of a corrugated sheath = $D_{oc} - 2t_s$	mm
D_{it}	diameter of the imaginary cylinder which just touches the inside surface of the troughs of a corrugated sheath	mm
D_l	the inner diameter of any generic annular concentric cable element layer	mm
E	constant used for the heat dissipation in air coefficient in 4.2.1.1	
E_e	intensity of solar radiation	W/m^2
F_1	coefficient for belted cables defined in 4.1.2.2.3	
F_2	coefficient for belted cables defined in 4.1.2.2.6	
G	geometric factor for belted cables	
$\overline{G}$	geometric factor for SL and SA type cables	
~~H~~	~~intensity of solar radiation (see 4.2.1.2)~~	~~W/m^2~~
~~K~~	~~screening factor for the thermal resistance of screened cables~~	

K_A	coefficient used in 4.2.1	
L	depth of laying, to cable axis or centre of trefoil	mm
L_G	distance from the soil surface to the centre of a duct bank	mm
L_L^*	axial cable length over which the cores make one full helical turn (m)	
N_L	number of loaded cables in a duct bank (see 4.2.7)	
P_h	part of the perimeter of the cable trough which is effective for heat dissipation (see 4.2.5.2)	m
T_1	thermal resistance per core between conductor and sheath	K · m/W
T_2	thermal resistance between sheath and armour	K · m/W
T_3	thermal resistance of external serving	K · m/W
T_4	thermal resistance of surrounding medium (ratio of cable surface temperature rise above ambient to the losses per unit length)	K · m/W
T_4^*	external thermal resistance in free air, adjusted for solar radiation	K · m/W
T_4'	thermal resistance between cable and duct (or pipe)	K · m/W
T_4''	thermal resistance of the duct (or pipe)	K · m/W
T_4'''	thermal resistance of the medium surrounding the duct (or pipe)	K · m/W
U	constant used in 4.2.6.3	
V	constant used in 4.2.6.3	
W_d	dielectric losses per unit length per phase	W/m
W_k	losses dissipated by cable k	W/m
W_{TOT}	total power dissipated in the trough per unit length	W/m
Y	coefficient used in 4.2.6.3	
Z	coefficient used in 4.2.1.1	
C_g	coefficient used in 4.2.1.1	
d_a	external diameter of belt insulation	mm
d_c	external diameter of conductor	mm
d_{cm}	minor diameter of an oval conductor	mm
d_{cM}	major diameter of an oval conductor	mm
d_M	major diameter of screen or sheath of an oval conductor	mm
d_m	minor diameter of screen or sheath of an oval conductor	mm
d_x	diameter of an equivalent circular conductor having the same cross-sectional area and degree of compactness as the shaped one	mm
~~g~~	~~coefficient used in 4.2.1.1~~	
h	heat dissipation coefficient	$W/m^2K^{5/4}$
h_b	height of the duct bank or backfill	mm
ln	natural logarithm (logarithm to base e)	
n	number of conductors in a cable	
~~p~~	~~the part of the perimeter of the cable trough which is effective for heat dissipation (see 4.2.6.2)~~	~~m~~
r_1	circumscribing radius of two- or three-sector shaped conductors	mm

s_1	axial separation of two adjacent cables in a horizontal group of three, not touching		mm
t	insulation thickness between conductors		mm
t_1	insulation thickness between conductors and sheath		mm
t_2	thickness of the bedding		mm
t_3	thickness of the serving		mm
t_i	thickness of core insulation, including screening tapes plus half the thickness of any non-metallic tapes over the laid-up cores		mm
t_l	thickness of any generic annular concentric cable element layer		mm
t_s	thickness of the sheath		mm
~~u~~	~~$\frac{2L}{D_e}$ in 4.2.~~		
~~u~~	~~$\frac{L_G}{r_b}$ in 4.2.7.4~~		
~~x, y~~	~~sides of duct bank ($y>x$) (see 4.2.7.4)~~		~~mm~~
u_1	symbol used throughout the document e.g. in 4.2		
U_2	symbol used throughout the document e.g. in 4.2.6.5		
w_b	width of the duct bank or backfill		mm
θ_m	mean temperature of medium between a cable and duct or pipe		°C
$\Delta\theta$	permissible temperature rise of conductor above ambient temperature		K
$\Delta\theta_{d0}$	factor to account for dielectric loss for calculating T_4 for cables in free air		K
$\Delta\theta_{ds}$	factor to account for both dielectric loss and direct solar radiation for calculating T_4^* for cables in free air using Figure 10		K
$\Delta\theta_{duct}$	difference between the mean temperature of air in a duct and ambient temperature		K
$\Delta\theta_s$	difference between the surface temperature of a cable in air and ambient temperature		K
$\Delta\theta_{tr}$	temperature rise of the air in a cable trough		K
λ_1~~, λ_2~~	ratio of the total losses in metallic sheaths ~~and armour respectively~~ to the total conductor losses (or losses in one sheath ~~or armour~~ to the losses in one conductor)		
λ'_{1m}	loss factor for the middle cable	Three cables in flat formation without transposition, with sheaths bonded at both ends	
λ'_{11}	loss factor for the outer cable with the greater losses		
λ'_{12}	loss factor for the outer cable with the least losses		
λ_2	ratio of the total losses in armour to the total conductor losses (or losses in one armour to the losses in one conductor)		
ρ	thermal resistivity of the soil		K · m/W
ρ_i	thermal resistivity of the insulation		K · m/W
ρ_f	thermal resistivity of the filler material		K · m/W
ρ_e	thermal resistivity of earth surrounding a duct bank		K · m/W
ρ_c	thermal resistivity of concrete used for a duct bank		K · m/W