IEC 60730-2-11

Edition 4.0 2025-08

INTERNATIONAL STANDARD

EXTENDED VERSION

This full version of IEC 60730-2-11:2025 includes the content of the references made to IEC 60730-1:2022

Automatic electrical controls –
Part 2-11: Particular requirements for energy regulators

ICS 97.120

ISBN 978-2-8327-0642-8

IEC 60730-2-11:2025-08 EXV(en)

CONTENTS

FOREWORD 9
1 Scope 12
2 Normative references 13
3 Terms and definitions 17
3.1 Definitions relating to ratings, voltages, currents, frequencies, and wattages 17
3.2 Definitions of types of control according to purpose 19
3.3 Definitions relating to the function of controls 22
3.4 Definitions relating to disconnection and interruption 25
3.5 Definitions of types of control according to construction 26
3.6 Definitions of type of automatic action of a control 27
3.7 Definitions relating to protection against electric shock and type of insulation 28
3.8 Definitions relating to component parts of controls 32
3.9 Definitions of types of terminals and terminations of controls 33
3.10 Definitions relating to the connections to controls 35
3.11 Definitions relating to the performance of type 2 actions 36
3.12 Definitions relating to the requirements for creepage distances and clearances 36
3.13 Miscellaneous definitions 37
3.14 Definitions relating to manufacturer and user 39
3.15 Definitions pertaining to thermistors 39
3.16 Definitions relating to the structure of controls using software 39
3.17 Definitions relating to error avoidance in controls using software 39
3.18 Definitions relating to fault/error control techniques for controls using software 39
3.19 Definitions relating to memory tests for controls using software 39
3.20 Definitions of software terminology – General 39
3.21 Definitions relating to classes of control functions 39
3.22 Definitions relating to functional safety 39
3.23 Definitions related to access to data exchange 40
3.24 Definitions related to EMC performance 40
4 General 42
4.1 General structure of the document 42
4.2 General requirements 43
4.3 General notes on tests 43
5 Required technical information 47
5.1 General requirements 47
5.2 Methods of providing technical information 47
5.3 Class II symbol 55
5.4 Additional requirements for marking 55
5.5 Warning or cautionary markings 57
6 Protection against electric shock 57
6.1 General requirements 57
6.2 Actuating members and actuating means 59
6.3 Capacitors 60
6.4 Covers and uninsulated live or hazardous parts 60
6.5 Battery operated controls provided with a user accessible mains supply input connector 61

7 Provision for protective earthing 61
7.1 Class 0I and Class I controls 61
7.2 Class II and class III controls 61
7.3 Adequacy of earth connections 61
7.4 Corrosion resistance 62
7.5 Other requirements 63
7.6 Protective equipotential bonding 63
8 Terminals and terminations 63
8.1 Terminals and terminations for external copper conductors 63
8.2 Terminals and terminations for internal conductors 68
8.3 Terminals and terminations for integrated conductors 70
9 Constructional requirements 70
9.1 Materials 70
9.2 Protection against electric shock 71
9.3 Actuation and operation 73
9.4 Actions 76
9.5 Openings in enclosures 79
9.6 Mounting of controls 79
9.7 Attachment of cords 80
9.8 Size of cords – non-detachable 81
9.9 Inlet openings 82
9.10 Equipment inlets and socket-outlets 83
9.11 Requirements during mounting, use, maintenance and servicing 83
9.12 Controls using software 86
9.13 Protective controls and components of protective control systems 88
10 Threaded parts and connections 91
10.1 Threaded parts moved during mounting or servicing 91
10.2 Current-carrying connections and connections providing protective earthing continuity 93
11 Creepage distances, clearances and distances through solid insulation 94
11.1 General 94
11.2 Clearances 94
11.3 Creepage distances 98
11.4 Solid insulation 102
12 Components 103
12.1 Transformers 103
12.2 Switch mode power supplies and converters 103
12.3 Capacitors 104
12.4 Fuses 104
12.5 Varistors 104
12.6 Thermistors 104
12.7 Relays 105
12.8 Other components 105
13 Fault assessment on electronic circuits 105
13.1 Fault assessment for inherent safety 105
13.2 Fault assessment to ensure functional safety 111
14 Moisture and dust resistance 111
14.1 Protection against ingress of water and dust 111

14.2 Protection against humid conditions 112
14.3 Touch current test for in-line cord controls and free-standing controls 113
15 Electric strength and insulation resistance 114
15.1 Insulation resistance 114
15.2 Electric strength 114
15.3 Additional tests for in-line cord and free-standing controls 116
16 Heating 117
16.101 Energy regulators for use in or on cooking appliances 121
17 Manufacturing deviation and drift 121
18 Environmental stress 122
18.1 Transportation and storage 122
18.2 Environmental stress of temperature 122
19 Endurance 122
19.1 General requirements 122
19.2 Electrical conditions for the tests 124
19.3 Thermal conditions for the tests 129
19.4 Manual and mechanical conditions for the tests 129
19.5 Dielectric strength requirements 130
19.6 Ageing test 130
19.7 Overvoltage test or overload test in all countries using an overload test of automatic action at accelerated rate 130
19.8 Test of automatic action at accelerated rate 131
19.9 Test of automatic action at slow rate 131
19.10 Overvoltage test or overload test in all countries that use the overload test of manual action at accelerated speed 131
19.11 Test of manual action at slow speed 132
19.12 Test of manual action at high speed which has multiple poles, and where polarity reversal occurs during the action 132
19.13 Test of manual action at accelerated speed 132
19.14 Evaluation of compliance 133
19.15 Test for particular purpose controls 133
20 Mechanical strength 133
20.1 General requirements 133
20.2 Impact resistance 134
20.3 Free-standing controls 135
20.4 In-line cord controls 135
20.5 Pull-cord actuated controls 136
20.6 Foot actuated controls 136
20.7 Actuating member and actuating means 136
20.8 Flexing – test 137
20.9 Cord anchorages – test 137
20.101 Push-and-turn or pull-and-turn actuation 138
21 Resistance to heat, fire and tracking 139
21.1 General requirements 139
21.2 Integrated, incorporated and in-line cord controls 139
21.3 Independently mounted, free-standing controls 140
22 Resistance to corrosion 141
22.1 Resistance to rusting 141

23 Electromagnetic compatibility (EMC) requirements – Emission 141
23.1 General requirement 141
23.2 High frequency emission 142
23.3 Low frequency emission 145
24 Normal operation 145
25 Electromagnetic compatibility (EMC) requirements – Immunity 145
25.1 General 145
25.2 EMC test plan and report 146
25.3 Immunity requirements 148
25.4 Performance criteria 151
25.5 Surge immunity test 152
25.6 Electrical fast transient immunity test 152
25.7 Radio-frequency electromagnetic field immunity 153
25.8 Electrostatic discharge 153
25.9 Immunity to power-frequency magnetic fields 153
25.10 Test of the influence of voltage dips and voltage interruption in the power supply network 153
26 Abnormal operation tests 154
26.1 Abnormal temperature test 154
26.2 Overload tests 155
26.3 Battery short-circuit test 156
Annex A (normative) Indelibility of markings 173
Annex B (normative) Measurement of creepage distances and clearances in air 175
Annex C (informative) Nominal voltages of supply systems for different modes of overvoltage control 179
Annex D (normative) Overvoltage categories 181
Annex E (informative) Typical usage of controls and related overvoltage categories 182
Annex F (normative) Pollution degrees 183
F.1 Pollution 183
F.2 Degrees of pollution in the micro-environment 183
Annex G (normative) Resistance to heat, fire and tracking tests 184
G.1 Glow-wire test 184
G.2 Proof tracking test 184
G.3 Ball pressure test 184
Annex H (normative) Requirements related to functional safety 186
H.3 Terms and definitions 186
H.5 Information 197
H.9 Constructional requirements 198
H.13 Fault assessment on electronic circuits 215
H.17 Manufacturing deviation and drift 219
H.19 Endurance 220
H.25 Electromagnetic compatibility (EMC) requirements – Immunity 221
Annex I (normative) Requirements for certain types of DC supplied controls 234
I.1 Scope 234
Annex J (normative) Requirements for thermistor elements and controls using thermistors 236
J.1 Scope 236
Annex K (normative) Circuit for measuring touch current 253

Annex L (normative) Printed circuit board coating performance test 254
Annex M (normative) Printed circuit board protection 256
Annex N (informative) Explanatory notes for surge immunity test 259
N.1 Different source impedances 259
N.2 Application of the tests 259
N.3 Installation classification 260
Annex O (informative) Guidance for applying Clause 11 263
Annex P (normative) Requirements for SELV and PELV 266
P.1 Overview of the requirements for SELV and PELV 266
P.2 Protection against electric shock by SELV system or PELV system 266
P.3 Protective measures for SELV system and PELV system 267
Annex Q (informative) Regional differences relevant for the member countries of Cenelec 269
Annex R (informative) National differences relevant in the United States of America 273
R.2 Normative references 273
Annex S (informative) National differences relevant in Japan 274
S.2 Normative references 274
Annex T (informative) National differences relevant in Canada 275
T.2 Normative references 275
Bibliography 276

Figure 1 – Example of ports 40
Figure 2 – Structure of the document with respect to inherent safety and functional safety 43
Figure 3 – Example of an electronic circuit with low power points 106
Figure 4 – Test pin probe 13 of IEC 61032:1997 156
Figure 5 – Test finger probe B of IEC 61032:1997 157
Figure 6 – Test fingernail 158
Figure 7 – Impact test for free-standing controls 159
Figure 8 – Tumbling barrel 159
Figure 9 – Apparatus for testing durability of markings on rating labels 160
Figure 10 – Apparatus for flexing test 160
Figure 11 – Screw terminals and stud terminals 161
Figure 12 – Pillar terminals 162
Figure 13 – Mantle terminals 163
Figure 14 – Saddle and lug terminals 164
Figure 15 – Tabs 165
Figure 16 – Tabs for non-reversible connectors 166
Figure 17 – Receptacles 167
Figure 18 – Measurement of creepage distance and clearance 168
Figure 19 – Diagram for touch current measurement at operating temperature for single-phase connection of class II controls 169
Figure 20 – Diagram for touch current measurement at operating temperature for single-phase connection of controls other than class II 169
Figure 21 – Diagram for touch current measurement at operating temperature for three-phase connection of class II controls 170

Figure 22 – Diagram for touch current measurement at operating temperature for three-phase connection of controls other than class II 171
Figure 23 – Diagram for touch current measurement at operating temperature for single-phase connection of controls to three-wire, ground neutral supply other than class II 171
Figure 24 – Diagram for touch current measurement at operating temperature for two-phase connection of controls to three-wire, ground neutral supply other than class II 172
Figure B.1 – Narrow groove 176
Figure B.2 – Wide groove 176
Figure B.3 – V-shaped groove 176
Figure B.4 – Rib 176
Figure B.5 – Uncemented joint with narrow groove 177
Figure B.6 – Uncemented joint with wide groove 177
Figure B.7 – Uncemented joint with narrow and wide grooves 177
Figure B.8 – Diverging side walls 178
Figure B.9 – Narrow recess 178
Figure B.10 – Wide recess 178
Figure B.11 – Conductive floating part 178
Figure H.1 – V-Model for the software life cycle 206
Figure H.2 – Voltage variation test 224
Figure J.1 – Generic test circuit for inrush-current limiting thermistor endurance test 252
Figure K.1 – Circuit for measuring touch currents 253
Figure L.1 – Test sample 255
Figure M.1 – Example of type 1 protection 257
Figure M.2 – Example of type 2 protection 258
Figure N.1 – Example of surge protection by shielding in buildings with common earth reference systems 261
Figure N.2 – Example of secondary surge protection in buildings with separate common earth reference systems 262
Figure N.3 – Example of primary and secondary surge protection of indoor/outdoor equipment 262
Figure O.1 – Guidance flowchart for application of requirements of Clause 11 264

Table 1 – Required technical information and methods of providing these information 50
Table 2 – Cross-sectional area of conductors 64
Table 3 – Terminal conductors 66
Table 4 – Conductor pull test values 67
Table 5 – Nominal cross-sectional areas of conductors 68
Table 6 – Axial force values for tab insertion and withdrawal 70
Table 7 – Minimum cord conductor sizes 82
Table 8 – Data exchange 87
Table 9 – Threaded parts torque test values 92
Table 10 – Rated impulse voltage for equipment energized directly from the supply mains (from IEC 60664-1:2007, Table F.1) 95
Table 11 – Clearances for insulation co-ordination (from IEC 60664-1:2007, Table F.2) 96

Table 12 – Minimum creepage distances for basic insulation 100
Table 13 – Minimum creepage distances for functional insulation 101
Table 14 – Electrical/electronic component fault modes 107
Table 15 – Minimum insulation resistance 114
Table 16 – Insulation or disconnection test voltages 115
Table 17 – Maximum heating temperatures 119
Table 18 – Electrical conditions for the overvoltage and endurance tests 125
Table 19 – Electrical conditions for the overload tests of 19.7 and 19.10 127
Table 20 – Electrical conditions for the endurance tests of 19.8, 19.9, 19.11, 19.12 and 19.13 128
Table 21 – Pull-cord force test values 136
Table 22 – Pull and torque values 138
Table 23 – Emission limit for residential electromagnetic environment 143
Table 24 – Emission limit for industrial electromagnetic environment 144
Table 25 – The applicable EMC test in relation to the class of control function and type of Action 146
Table 26 – Immunity test requirements for residential electromagnetic environments 148
Table 27 – Immunity test requirements for industrial electromagnetic environment 150
Table 28 – Performance criteria 152
Table 29 – Maximum winding temperature (for test of mechanical blocked output conditions) 155
Table B.1 – Value of X 175
Table C.1 – Inherent control or equivalent protective control 179
Table C.2 – Cases where protective control is necessary and control is provided by surge arresters having a ratio of clamping voltage to rated voltage not smaller than that specified by IEC 60099-1 180
Table E.1 – Typical usage 182
Table H.1 – Additional items to Table 1 197
Table H.2 – Acceptable measures to address fault/errors [a] 200
Table H.3 – Examples of techniques/measures for semi-formal methods 207
Table H.4 – Examples of techniques/measures for software architecture specification 207
Table H.5 – Examples of techniques/measures for module design specification 208
Table H.6 – Examples of techniques/measures for design and coding standards 208
Table H.7 – Examples of techniques/measures for software module testing 209
Table H.8 – Examples of techniques/measures for software integration testing 210
Table H.9 – Examples of techniques/measures for software safety validation 210
Table H.10 – Combinations of analytical measures during hardware development 212
Table H.11 – Examples of defences against unauthorised access and transmission failure modes 213
Table H.12 – Applicable test levels in addition to Clause 25 222
Table H.13 – Voltage dips, short interruptions and voltage variations 223
Table H.14 – Test values for voltage variations 224
Table H.15 – Test voltages for test level 2 (depending on the installation class conditions) 226
Table H.16 – Test level for electrical fast transient burst test 227

Table H.17 – Test levels for conducted disturbances on mains and I/O lines 229
Table H.18 – Test level for immunity to radiated electromagnetic fields 230
Table H.19 – Increased test level for radiated immunity 230
Table H.20 – Test level for supply frequency variations 231
Table H.21 – Test level for continuous fields 232
Table I.1 – Electrical transient conduction immunity in accordance with ISO 7637-2 234
Table I.2 – Electrical transient conduction immunity in accordance with ISO 7637-3 235
Table J.1 – Maximum current 238
Table J.2 – Normal operating conditions 239
Table J.3 – Samples for the test (clause reference) 240
Table J.4 – Electrical and thermal ratings of a thermistor 241
Table J.5 – Additional items to Table 1 242
Table J.6 – Sequence of calibration and conditioning tests for PTC thermistors 244
Table J.7 – Classes for PTC sensing thermistors 245
Table J.8 – Sequence of calibration and conditioning tests for NTC thermistors 246
Table J.9 – Classes for NTC sensing thermistors 246
Table J.10 – Number of cycles for endurance test 250
Table J.11 – Ageing test temperature 250
Table J.12 – Number of cycles for endurance test 251
Table L.1 – Environmental cycling conditions 254
Table M.1 – IEC 60664-3 test levels or conditions 256
Table O.1 – Example A – Using Annex O guidance for applying Clause 11 265
Table O.2 – Example B – Using Annex O guidance for applying Clause 11 265
Table Q.1 – Additional aging parameters for windings 270

INTERNATIONAL ELECTROTECHNICAL COMMISSION

_____

Automatic electrical controls - Part 2-11: Particular requirements for energy regulators

FOREWORD

1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as “IEC Publication(s)”). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
6) All users should ensure that they have the latest edition of this publication.
7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
9) IEC draws attention to the possibility that the implementation of this document may involve the use of (a) patent(s). IEC takes no position concerning the evidence, validity or applicability of any claimed patent rights in respect thereof. As of the date of publication of this document, IEC had not received notice of (a) patent(s), which may be required to implement this document. However, implementers are cautioned that this may not represent the latest information, which may be obtained from the patent database available at https://patents.iec.ch. IEC shall not be held responsible for identifying any or all such patent rights.

This extended version (EXV) of the official IEC Standard provides the user with the full content of the Standard.

IEC 60730-2-11:2025 EXV includes the content of IEC 60730-2-11:2025, and the references made to IEC 60730-1:2022.

The specific content of IEC 60730-2-11:2025 is displayed on a blue background.

IEC 60730-2-11 has been prepared by IEC technical committee 72: Automatic electrical controls. It is an International Standard.

This fourth edition cancels and replaces the third edition published in 2019. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

a) adoption to IEC 60730-1:2022 with all of its significant changes to IEC 60730-1:2013 IEC 60730-1:2013/AMD1:2015 and IEC 60730-1:2013/AMD2:2020.

The text of this International Standard is based on the following documents:

Draft	Report on voting
72/1485/FDIS	72/1501/RVD

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

The language used for the development of this International Standard is English.

This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available at www.iec.ch/members_experts/refdocs. The main document types developed by IEC are described in greater detail at www.iec.ch/publications.

A list of all parts of the IEC 60730 series, under the general title: *Automatic electrical controls,* can be found on the IEC website.

This part 2-11 is intended to be used in conjunction with IEC 60730-1. It was established on the basis of the sixth edition of that standard (2022). Consideration may be given to future editions of, or amendments to, IEC 60730-1.

This part 2-11 supplements or modifies the corresponding clauses in IEC 60730-1, so as to convert that publication into the IEC standard: Particular requirements for energy regulators.

Where this part 2-11 states "addition", "modification" or "replacement", the relevant requirement, test specification or explanatory matter in part 1 should be adapted accordingly.

When a particular subclause of Part 1 is not mentioned in this Part 2, that subclause applies.

In the development of a fully international standard it has been necessary to take into consideration the differing requirements resulting from practical experience in various parts of the world and to recognize the variation in national electrical systems and wiring rules.

The reader's attention is drawn to the fact that Annex Q, Annex R, Annex S and Annex T list all of the "in-some-country" clauses on differing practices of a less permanent nature relating to the subject of this document.

In this publication:

1) The following print types are used:
   - requirements proper: in roman type;
   - *test specifications: in italic type*;

– explanatory matter: in smaller roman type;

– Defined terms: **bold type**.

2) Subclauses, notes or items which are additional to those in Part 1 are numbered starting from 101, additional annexes are lettered AA, BB, etc.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under webstore.iec.ch in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn, or
- revised.

1 Scope

This document applies to **energy regulators**

- for use in, on, or in association with equipment for household appliance and similar use;

NOTE 1 Throughout this document, the word "equipment" means "appliance and equipment" and "controls" means "energy regulators".

- for equipment that is used by the public, such as equipment intended to be used in shops, offices, hospitals, farms and commercial and industrial applications;

EXAMPLE 1 **Energy regulators** for commercial catering, heating and air-conditioning equipment.

- that are **smart enabled energy regulators**;

EXAMPLE 2 Smart grid control, remote interfaces/control of energy-consuming equipment including computer or smart phone.

- that are AC or DC powered controls with a rated voltage not exceeding 690 V AC or 600 V DC;
- used in, on, or in association with equipment that use electricity, gas, oil, solid fuel, solar thermal energy, etc., or a combination thereof;
- utilized as part of a control system or controls which are mechanically integral with multifunctional controls having non-electrical outputs;
- using NTC or **PTC thermistors** and to discrete **thermistors**, requirements for which are contained in Annex J;
- that are mechanically or electrically operated, responsive to or controlling such characteristics as temperature, pressure, passage of time, humidity, light, electrostatic effects, flow, or liquid level, current, voltage, acceleration, or combinations thereof;
- as well as manual controls when such are electrically and/or mechanically integral with automatic controls.

NOTE 2 Requirements for manually actuated mechanical switches not forming part of an automatic control are contained in IEC 61058-1-1.

This document applies to

– the inherent safety of **energy regulators**, and

– **functional safety** of **energy regulators** of low complexity safety related systems and controls,

– controls where the performance (for example the effect of EMC phenomena) of the product can impair the overall safety and performance of the controlled system,

– the operating values, operating times, and operating sequences where such are associated with equipment safety.

– manual energy regulators which are electrically and/or mechanically integral with automatic controls.

– energy regulators incorporating electronic devices, requirements for which are contained in Annex H.

– the electrical and **functional safety** of controls capable of receiving and responding to communications signals, including signals for power billing rate and demand response.

The signals can be transmitted to or received from external units being part of the **control** (wired), or to and from external units which are not part of the **control** (wireless) under test.

This document specifies the requirements for construction, operation and testing of automatic **energy regulators** used in, on, or in association with an equipment.

This document does not

- apply to automatic **energy regulators** intended exclusively for industrial process applications unless explicitly mentioned in the relevant part 2 or the equipment standard. However, this document can be applied to evaluate automatic **energy regulators** intended specifically for industrial applications in cases where no relevant safety standard exists.
- take into account the **response value** of an **automatic action** of an **energy regulator**, if such a **response value** is dependent upon the method of mounting the **energy regulator** in the equipment. Where a **response value** is of significant purpose for the protection of the user, or surroundings, the value defined in the appropriate equipment standard or as determined by the manufacturer will apply.
- address the integrity of the output signal to the network devices, such as interoperability with other devices unless it has been evaluated as part of the control system.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60038, *IEC standard voltages*

IEC 60065:2014, *Audio, video and similar electronic apparatus – Safety requirements*

IEC 60068-2-75, *Environmental testing – Part 2-75: Tests – Test Eh: Hammer tests*

IEC 60085, *Electrical insulation – Thermal evaluation and designation*

IEC 60099-1:1991, *Surge arresters – Part 1: Non-linear resistor type gapped surge arresters for a.c. systems*[1]

IEC 60112:2020, *Method for the determination of the proof and the comparative tracking indices of solid insulating materials*

IEC 60127 (all parts), *Miniature fuses*

IEC 60227-1, *Polyvinyl chloride insulated cables of rated voltages up to and including 450/750 V – Part 1: General requirements*

IEC 60245-1, *Rubber insulated cables – Rated voltages up to and including 450/750 V – Part 1: General requirements*

IEC 60269 (all parts), *Low-voltage fuses*

IEC 60335-1:2020, *Household and similar electrical appliances – Safety – Part 1: General requirements*

IEC 60384-14, *Fixed capacitors for use in electronic equipment – Part 14: Sectional specification – Fixed capacitors for electromagnetic interference suppression and connection to the supply mains*

[1] Withdrawn.

IEC 60384-16, *Fixed capacitors for use in electronic equipment – Part 16: Sectional specification – Fixed metallized polypropylene film dielectric DC capacitors*

IEC 60384-17, *Fixed capacitors for use in electronic equipment – Part 17: Sectional specification – Fixed metallized polypropylene film dielectric AC and pulse capacitors*

IEC 60417, *Graphical symbols for use on equipment*

IEC 60423, *Conduit systems for cable management – Outside diameters of conduits for electrical installations and threads for conduits and fittings*

IEC 60529:1989, *Degrees of protection provided by enclosures (IP code)*
IEC 60529:1989/AMD1:1999
IEC 60529:1989/AMD2:2013

IEC 60539 (all parts), *Directly heated negative temperature coefficient thermistors*

IEC 60664-1:2007[2], *Insulation coordination for equipment within low-voltage systems – Part 1: Principles, requirements and tests*

IEC TR 60664-2 (all parts), *Insulation coordination for equipment within low-voltage systems*

IEC 60664-3:2016, *Insulation coordination for equipment within low-voltage systems – Part 3: Use of coating, potting or moulding for protection against pollution*

IEC 60664-4, *Insulation coordination for equipment within low-voltage systems – Part 4: Consideration of high-frequency voltage stress*

IEC 60695-2-10, *Fire hazard testing – Part 2-10: Glowing/hot-wire based test methods – Glow-wire apparatus and common test procedure*

IEC 60695-2-11:2021, *Fire hazard testing – Part 2-11: Glowing/hot-wire based test methods – Glow-wire flammability test method for end-products (GWEPT)*

IEC 60695-10-2, *Fire hazard testing – Part 10-2: Abnormal heat – Ball pressure test method*

IEC 60738 (all parts), *Thermistors – Directly heated positive temperature coefficient*

IEC 60747-5-5, *Semiconductor devices – Part 5-5: Optoelectronic devices – Photocouplers*

IEC 60884-1, *Plugs and socket-outlets for household and similar purposes – Part 1: General requirements*

IEC 60884-2-5:2017, *Plugs and socket-outlets for household and similar purposes – Part 2-5: Particular requirements for adaptors*

IEC 60998-2-2, *Connecting devices for low-voltage circuits for household and similar purposes – Part 2-2: Particular requirements for connecting devices as separate entities with screwless-type clamping units*

[2] Withdrawn.

IEC 60998-2-3, *Connecting devices for low-voltage circuits for household and similar purposes – Part 2-3: Particular requirements for connecting devices as separate entities with insulation-piercing clamping units*

IEC 60999-1, *Connecting devices – Electrical copper conductors – Safety requirements for screw-type and screwless-type clamping units – Part 1: General requirements and particular requirements for clamping units for conductors from 0,2 mm^2 up to 35 mm^2 (included)*

IEC 61000-3-2, *Electromagnetic compatibility (EMC) – Part 3-2: Limits – Limits for harmonic current emissions (equipment input current ≤ 16 A per phase)*

IEC 61000-3-3, *Electromagnetic compatibility (EMC) – Part 3-3: Limits – Limitation of voltage changes, voltage fluctuations and flicker in public low-voltage supply systems, for equipment with rated current ≤16 A per phase and not subject to conditional connection*

IEC 61000-3-11, *Electromagnetic compatibility (EMC) – Part 3-11: Limits – Limitation of voltage changes, voltage fluctuations and flicker in public low-voltage supply systems – Equipment with rated current ≤ 75 A and subject to conditional connection*

IEC 61000-3-12, *Electromagnetic compatibility (EMC) – Part 3-12: Limits – Limits for harmonic currents produced by equipment connected to public low-voltage systems with input current >16 A and ≤ 75 A per phase*

IEC 61000-4-2:2008, *Electromagnetic compatibility (EMC) – Part 4-2: Testing and measurement techniques – Electrostatic discharge immunity test*

IEC 61000-4-3, *Electromagnetic compatibility (EMC) – Part 4-3: Testing and measurement techniques – Radiated, radio-frequency, electromagnetic field immunity test*

IEC 61000-4-4, *Electromagnetic compatibility (EMC) – Part 4-4: Testing and measurement techniques – Electrical fast transient/burst immunity test*

IEC 61000-4-5:2014, *Electromagnetic compatibility (EMC) – Part 4-5: Testing and measurement techniques – Surge immunity test*
IEC 61000-4-5:2014/AMD1:2017

IEC 61000-4-6, *Electromagnetic compatibility (EMC) – Part 4-6: Testing and measurement techniques – Immunity to conducted disturbances, induced by radio-frequency fields*

IEC 61000-4-8, *Electromagnetic compatibility (EMC) – Part 4-8: Testing and measurement techniques – Power frequency magnetic field immunity test*

IEC 61000-4-11, *Electromagnetic compatibility (EMC) – Part 4-11: Testing and measurement techniques – Voltage dips, short interruptions and voltage variations immunity tests for equipment with current up to 16 A per phase*

IEC 61000-4-13:2002, *Electromagnetic compatibility (EMC) – Part 4-13: Testing and measurement techniques – Harmonics and interharmonics including mains signalling at a.c. power port, low frequency immunity tests*
IEC 61000-4-13:2002 /AMD1:2009
IEC 61000-4-13:2002 /AMD2:2015

IEC 61000-4-20, *Electromagnetic compatibility (EMC) – Part 4-20: Testing and measurement techniques – Emission and immunity testing in transverse electromagnetic (TEM) waveguides*

IEC 61000-4-21, *Electromagnetic compatibility (EMC) – Part 4-21: Testing and measurement techniques – Reverberation chamber test methods*

IEC 61000-4-22, *Electromagnetic compatibility (EMC) – Part 4-22: Testing and measurement techniques – Radiated emissions and immunity measurements in fully anechoic rooms (FARs)*

IEC 61000-4-28, *Electromagnetic compatibility (EMC) – Part 4-28: Testing and measurement techniques – Variation of power frequency, immunity test for equipment with input current not exceeding 16A per phase*

IEC 61000-6-1:2016, *Electromagnetic compatibility (EMC) – Part 6-1: Generic standards – Immunity standard for residential, commercial and light-industrial environments*

IEC 61000-6-2:2016, *Electromagnetic compatibility (EMC) – Part 6-2: Generic standards – Immunity standard for industrial environments*

IEC 61000-6-3:2020, *Electromagnetic compatibility (EMC) – Part 6-3: Generic standards – Emission standard for equipment in residential environments*

IEC 61000-6-4:2018, *Electromagnetic compatibility (EMC) – Part 6-4: Generic standards – Emission standard for industrial environments*

IEC 61051-1, *Varistors for use in electronic equipment – Part 1: Generic specification*

IEC 61051-2, *Varistors for use in electronic equipment – Part 2: Sectional specification for surge suppression varistors*

IEC 61051-2-2, *Varistors for use in electronic equipment – Part 2: Blank detail specification for zinc oxide surge suppression varistors. Assessment level E*

IEC 61210, *Connecting devices – Flat quick-connect terminations for electrical copper conductors – Safety requirements*

IEC 61249 (all parts), *Materials for printed boards and other interconnecting structures*

IEC 61558-2-6, *Safety of transformers, reactors, power supply units and combinations thereof − Part 2-6: Particular requirements and tests for safety isolating transformers and power supply units incorporating safety isolating transformers for general applications*

IEC 61558-2-16, *Safety of transformers, reactors, power supply units and combinations thereof − Part 2-16: Particular requirements and tests for switch mode power supply units and transformers for switch mode power supply units for general applications*

IEC 61810-3, *Electromechanical elementary relays – Part 3: Replays with forcibly guided (mechanically linked) contacts*

IEC 62151, *Safety of equipment electrically connected to a telecommunication network*

IEC 62319 (all parts), *Polymeric thermistors – Directly heated positive step function temperature coefficient*

IEC 62326 (all parts), *Printed boards*

IEC 62368-1, *Audio/video, information and communication technology equipment – Part 1: Safety requirements*

IEC 63044 (all parts), *Home and Building Electronic Systems (HBES) and Building Automation and Control Systems (BACS)*

CISPR 11, *Industrial, scientific and medical equipment – Radio-frequency disturbance characteristics – Limits and methods of measurement*

CISPR 14-1:2020, *Electromagnetic compatibility – Requirements for household appliances, electric tools and similar apparatus – Part 1: Emission*

CISPR 32:2015, *Electromagnetic compatibility of multimedia equipment – Emission* requirements
CISPR 32:2015/AMD1:2019

ISO 4046-4:2016, *Paper, board, pulps and related terms − Vocabulary − Part 4: Paper and board grades and converted products*

ISO 7637-2:2011, *Road vehicles – Electrical disturbances from conduction and coupling – Part 2: Electrical transient conduction along supply lines only*

ISO 7637-3:2016, *Road vehicles – Electrical disturbances from conduction and coupling – Part 3: Electrical transient transmission by capacitive and inductive coupling via lines other than supply lines*

ISO 16484 (all parts), *Building automation and control systems (BACS)*

IEC 60730-2-11

Edition 4.0 2025-08

INTERNATIONAL STANDARD

Automatic electrical controls –
Part 2-11: Particular requirements for energy regulators

ICS 97.120

ISBN 978-2-8327-0568-1

IEC 60730-2-11:2025-08(en)

CONTENTS

FOREWORD 2
1 Scope 5
2 Normative references 6
3 Terms and definitions 6
4 General 6
5 Required technical information 7
6 Protection against electric shock 7
7 Provision for protective earthing 7
8 Terminals and terminations 7
9 Constructional requirements 7
10 Threaded parts and connections 8
11 Creepage distances, clearances and distances through solid insulation 8
12 Components 8
13 Fault assessment on electronic circuits 8
14 Moisture and dust resistance 9
15 Electric strength and insulation resistance 9
16 Heating 9
17 Manufacturing deviation and drift 9
18 Environmental stress 9
19 Endurance 10
20 Mechanical strength 11
21 Resistance to heat, fire and tracking 11
22 Resistance to corrosion 11
23 Electromagnetic compatibility (EMC) requirements – Emission 12
24 Normal operation 12
25 Electromagnetic compatibility (EMC) requirements – Immunity 12
26 Abnormal operation tests 12
Annex H (normative) Requirements related to functional safety 13
Annex Q (informative) Regional differences relevant for the member countries of Cenelec 16
Annex R (informative) National differences relevant in the United States of America 17
Annex S (informative) National differences relevant in Japan 18
Annex T (normative) National differences relevant in Canada 19
Bibliography 20

Table 1 – Required technical information and methods of providing these information 7
Table H.1 – Additional items to Table 1 13

INTERNATIONAL ELECTROTECHNICAL COMMISSION

_____

Automatic electrical controls - Part 2-11: Particular requirements for energy regulators

FOREWORD

1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as “IEC Publication(s)”). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
6) All users should ensure that they have the latest edition of this publication.
7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
9) IEC draws attention to the possibility that the implementation of this document may involve the use of (a) patent(s). IEC takes no position concerning the evidence, validity or applicability of any claimed patent rights in respect thereof. As of the date of publication of this document, IEC had not received notice of (a) patent(s), which may be required to implement this document. However, implementers are cautioned that this may not represent the latest information, which may be obtained from the patent database available at https://patents.iec.ch. IEC shall not be held responsible for identifying any or all such patent rights.

IEC 60730-2-11 has been prepared by IEC technical committee 72: Automatic electrical controls. It is an International Standard.

This fourth edition cancels and replaces the third edition published in 2019. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

a) adoption to IEC 60730-1:2022 with all of its significant changes to IEC 60730-1:2013 IEC 60730-1:2013/AMD1:2015 and IEC 60730-1:2013/AMD2:2020.

The text of this International Standard is based on the following documents:

Draft	Report on voting
72/1485/FDIS	72/1501/RVD

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

The language used for the development of this International Standard is English.

This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available at www.iec.ch/members_experts/refdocs. The main document types developed by IEC are described in greater detail at www.iec.ch/publications.

A list of all parts of the IEC 60730 series, under the general title: *Automatic electrical controls,* can be found on the IEC website.

This part 2-11 is intended to be used in conjunction with IEC 60730-1. It was established on the basis of the sixth edition of that standard (2022). Consideration may be given to future editions of, or amendments to, IEC 60730-1.

This part 2-11 supplements or modifies the corresponding clauses in IEC 60730-1, so as to convert that publication into the IEC standard: Particular requirements for energy regulators.

Where this part 2-11 states "addition", "modification" or "replacement", the relevant requirement, test specification or explanatory matter in part 1 should be adapted accordingly.

When a particular subclause of Part 1 is not mentioned in this Part 2, that subclause applies.

In the development of a fully international standard it has been necessary to take into consideration the differing requirements resulting from practical experience in various parts of the world and to recognize the variation in national electrical systems and wiring rules.

The reader's attention is drawn to the fact that Annex Q, Annex R, Annex S and Annex T list all of the "in-some-country" clauses on differing practices of a less permanent nature relating to the subject of this document.

In this publication:

1) The following print types are used:
   - requirements proper: in roman type;
   - *test specifications: in italic type*;
   - explanatory matter: in smaller roman type;
   - Defined terms: **bold type**.
2) Subclauses, notes or items which are additional to those in Part 1 are numbered starting from 101, additional annexes are lettered AA, BB, etc.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under webstore.iec.ch in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn, or
- revised.

1 Scope

This clause of Part 1 is replaced by the following:

This document applies to **energy regulators**

- for use in, on, or in association with equipment for household appliance and similar use;

NOTE 1 Throughout this document, the word "equipment" means "appliance and equipment" and "controls" means "energy regulators".

- for equipment that is used by the public, such as equipment intended to be used in shops, offices, hospitals, farms and commercial and industrial applications;

EXAMPLE 1 **Energy regulators** for commercial catering, heating and air-conditioning equipment.

- that are **smart enabled energy regulators**;

EXAMPLE 2 Smart grid control, remote interfaces/control of energy-consuming equipment including computer or smart phone.

- that are AC or DC powered controls with a rated voltage not exceeding 690 V AC or 600 V DC;
- used in, on, or in association with equipment that use electricity, gas, oil, solid fuel, solar thermal energy, etc., or a combination thereof;
- utilized as part of a control system or controls which are mechanically integral with multifunctional controls having non-electrical outputs;
- using NTC or **PTC thermistors** and to discrete **thermistors**, requirements for which are contained in Annex J;
- that are mechanically or electrically operated, responsive to or controlling such characteristics as temperature, pressure, passage of time, humidity, light, electrostatic effects, flow, or liquid level, current, voltage, acceleration, or combinations thereof;
- as well as manual controls when such are electrically and/or mechanically integral with automatic controls.

NOTE 2 Requirements for manually actuated mechanical switches not forming part of an automatic control are contained in IEC 61058-1-1.

This document applies to

– the inherent safety of **energy regulators**, and

– **functional safety** of **energy regulators** of low complexity safety related systems and controls,

– controls where the performance (for example the effect of EMC phenomena) of the product can impair the overall safety and performance of the controlled system,

– the operating values, operating times, and operating sequences where such are associated with equipment safety.

– manual energy regulators which are electrically and/or mechanically integral with automatic controls.

– energy regulators incorporating electronic devices, requirements for which are contained in Annex H.

– the electrical and **functional safety** of controls capable of receiving and responding to communications signals, including signals for power billing rate and demand response.

The signals can be transmitted to or received from external units being part of the **control** (wired), or to and from external units which are not part of the **control** (wireless) under test.

This document specifies the requirements for construction, operation and testing of automatic **energy regulators** used in, on, or in association with an equipment.

This document does not

- apply to automatic **energy regulators** intended exclusively for industrial process applications unless explicitly mentioned in the relevant part 2 or the equipment standard. However, this document can be applied to evaluate automatic **energy regulators** intended specifically for industrial applications in cases where no relevant safety standard exists.
- take into account the **response value** of an **automatic action** of an **energy regulator**, if such a **response value** is dependent upon the method of mounting the **energy regulator** in the equipment. Where a **response value** is of significant purpose for the protection of the user, or surroundings, the value defined in the appropriate equipment standard or as determined by the manufacturer will apply.
- address the integrity of the output signal to the network devices, such as interoperability with other devices unless it has been evaluated as part of the control system.

2 Normative references

This clause of Part 1 is applicable.