IEC 60730-2-13

Edition 4.0 2025-08

INTERNATIONAL STANDARD

EXTENDED VERSION

This full version of IEC 60730-2-13:2025 includes the content of the references made to IEC 60730-1:2022

Automatic electrical controls -
Part 2-13: Particular requirements for humidity sensing controls

ICS 97.120

ISBN 978-2-8327-0671-8

IEC 60730-2-13:2025-08 EXV(en)

CONTENTS

FOREWORD 9
1 Scope 12
2 Normative references 13
3 Terms and definitions 17
3.1 Definitions relating to ratings, voltages, currents, frequencies, and wattages 17
3.2 Definitions of types of control according to purpose 19
3.3 Definitions relating to the function of controls 22
3.4 Definitions relating to disconnection and interruption 25
3.5 Definitions of types of control according to construction 26
3.6 Definitions of type of automatic action of a control 28
3.7 Definitions relating to protection against electric shock and type of insulation 28
3.8 Definitions relating to component parts of controls 32
3.9 Definitions of types of terminals and terminations of controls 33
3.10 Definitions relating to the connections to controls 35
3.11 Definitions relating to the performance of type 2 actions 36
3.12 Definitions relating to the requirements for creepage distances and clearances 36
3.13 Miscellaneous definitions 37
3.14 Definitions relating to manufacturer and user 39
3.15 Definitions pertaining to thermistors 39
3.16 Definitions relating to the structure of controls using software 39
3.17 Definitions relating to error avoidance in controls using software 39
3.18 Definitions relating to fault/error control techniques for controls using software 39
3.19 Definitions relating to memory tests for controls using software 39
3.20 Definitions of software terminology – General 39
3.21 Definitions relating to classes of control functions 40
3.22 Definitions relating to functional safety 40
3.23 Definitions related to access to data exchange 40
3.24 Definitions related to EMC performance 40
4 General 42
4.1 General structure of the document 42
4.2 General requirements 43
4.3 General notes on tests 43
5 Required technical information 47
5.1 General requirements 47
5.2 Methods of providing technical information 47
5.3 Class II symbol 55
5.4 Additional requirements for marking 55
5.5 Warning or cautionary markings 57
6 Protection against electric shock 57
6.1 General requirements 57
6.2 Actuating members and actuating means 59
6.3 Capacitors 60
6.4 Covers and uninsulated live or hazardous parts 60
6.5 Battery operated controls provided with a user accessible mains supply input connector 60

7 Provision for protective earthing 61
7.1 Class 0I and Class I controls 61
7.2 Class II and class III controls 61
7.3 Adequacy of earth connections 61
7.4 Corrosion resistance 62
7.5 Other requirements 63
7.6 Protective equipotential bonding 63
8 Terminals and terminations 63
8.1 Terminals and terminations for external copper conductors 63
8.2 Terminals and terminations for internal conductors 68
8.3 Terminals and terminations for integrated conductors 70
9 Constructional requirements 70
9.1 Materials 70
9.2 Protection against electric shock 70
9.3 Actuation and operation 73
9.4 Actions 76
9.5 Openings in enclosures 78
9.6 Mounting of controls 78
9.7 Attachment of cords 80
9.8 Size of cords – non-detachable 81
9.9 Inlet openings 81
9.10 Equipment inlets and socket-outlets 82
9.11 Requirements during mounting, use, maintenance and servicing 83
9.12 Controls using software 85
9.13 Protective controls and components of protective control systems 88
10 Threaded parts and connections 90
10.1 Threaded parts moved during mounting or servicing 90
10.2 Current-carrying connections and connections providing protective earthing continuity 92
11 Creepage distances, clearances and distances through solid insulation 93
11.1 General 93
11.2 Clearances 94
11.3 Creepage distances 98
11.4 Solid insulation 102
12 Components 103
12.1 Transformers 103
12.2 Switch mode power supplies and converters 103
12.3 Capacitors 104
12.4 Fuses 104
12.5 Varistors 104
12.6 Thermistors 104
12.7 Relays 105
12.8 Other components 105
13 Fault assessment on electronic circuits 105
13.1 Fault assessment for inherent safety 105
13.2 Fault assessment to ensure functional safety 111
14 Moisture and dust resistance 111
14.1 Protection against ingress of water and dust 111

14.2 Protection against humid conditions 112
14.3 Touch current test for in-line cord controls and free-standing controls 113
15 Electric strength and insulation resistance 114
15.1 Insulation resistance 114
15.2 Electric strength 114
15.3 Additional tests for in-line cord and free-standing controls 116
16 Heating 117
17 Manufacturing deviation and drift 122
18 Environmental stress 122
18.1 Transportation and storage 122
18.2 Environmental stress of temperature 122
19 Endurance 123
19.1 General requirements 123
19.2 Electrical conditions for the tests 124
19.3 Thermal conditions for the tests 130
19.4 Manual and mechanical conditions for the tests 130
19.5 Dielectric strength requirements 131
19.6 Ageing test 131
19.7 Overvoltage test or overload test in all countries using an overload test of automatic action at accelerated rate 131
19.8 Test of automatic action at accelerated rate 132
19.9 Test of automatic action at slow rate 132
19.10 Overvoltage test or overload test in all countries that use the overload test of manual action at accelerated speed 133
19.11 Test of manual action at slow speed 133
19.12 Test of manual action at high speed which has multiple poles, and where polarity reversal occurs during the action 133
19.13 Test of manual action at accelerated speed 133
19.14 Evaluation of compliance 134
19.15 Test for particular purpose controls 134
20 Mechanical strength 135
20.1 General requirements 135
20.2 Impact resistance 135
20.3 Free-standing controls 136
20.4 In-line cord controls 136
20.5 Pull-cord actuated controls 137
20.6 Foot actuated controls 137
20.7 Actuating member and actuating means 137
20.8 Flexing – test 138
20.9 Cord anchorages – test 138
21 Resistance to heat, fire and tracking 139
21.1 General requirements 139
21.2 Integrated, incorporated and in-line cord controls 139
21.3 Independently mounted, free-standing controls 141
22 Resistance to corrosion 141
22.1 Resistance to rusting 141
23 Electromagnetic compatibility (EMC) requirements – Emission 141
23.1 General requirement 141

23.2 High frequency emission 142
23.3 Low frequency emission 145
24 Normal operation 145
25 Electromagnetic compatibility (EMC) requirements – Immunity 145
25.1 General 145
25.2 EMC test plan and report 146
25.3 Immunity requirements 148
25.4 Performance criteria 151
25.5 Surge immunity test 152
25.6 Electrical fast transient immunity test 152
25.7 Radio-frequency electromagnetic field immunity 153
25.8 Electrostatic discharge 153
25.9 Immunity to power-frequency magnetic fields 153
25.10 Test of the influence of voltage dips and voltage interruption in the power supply network 153
26 Abnormal operation tests 154
26.1 Abnormal temperature test 154
26.2 Overload tests 155
26.3 Battery short-circuit test 156
Annex A (normative) Indelibility of markings 173
Annex B (normative) Measurement of creepage distances and clearances in air 175
Annex C (informative) Nominal voltages of supply systems for different modes of overvoltage control 179
Annex D (normative) Overvoltage categories 181
Annex E (informative) Typical usage of controls and related overvoltage categories 182
Annex F (normative) Pollution degrees 183
F.1 Pollution 183
F.2 Degrees of pollution in the micro-environment 183
Annex G (normative) Resistance to heat, fire and tracking tests 184
G.1 Glow-wire test 184
G.2 Proof tracking test 184
G.3 Ball pressure test 184
Annex H (normative) Requirements related to functional safety 186
H.3 Terms and definitions 186
H.5 Information 197
H.9 Constructional requirements 199
H.13 Fault assessment on electronic circuits 215
H.17 Manufacturing deviation and drift 219
H.19 Endurance 221
H.25 Electromagnetic compatibility (EMC) requirements – Immunity 222
Annex I (normative) Requirements for certain types of DC supplied controls 239
I.1 Scope 239
Annex J (normative) Requirements for thermistor elements and controls using thermistors 241
J.1 Scope 241
Annex K (normative) Circuit for measuring touch current 258
Annex L (normative) Printed circuit board coating performance test 259
Annex M (normative) Printed circuit board protection 261

Annex N (informative) Explanatory notes for surge immunity test 264
N.1 Different source impedances 264
N.2 Application of the tests 264
N.3 Installation classification 265
Annex O (informative) Guidance for applying Clause 11 268
Annex P (normative) Requirements for SELV and PELV 271
P.1 Overview of the requirements for SELV and PELV 271
P.2 Protection against electric shock by SELV system or PELV system 271
P.3 Protective measures for SELV system and PELV system 272
Annex Q (informative) Regional differences relevant for the member countries of Cenelec 274
Q.2 Normative references 274
Annex R (informative) National differences relevant in the United States of America 278
R.2 Normative references 278
Annex S (informative) National differences relevant in Japan 279
S.2 Normative references 279
Annex T (informative) National differences relevant in Canada 280
T.2 Normative references 280
Annex AA (normative) Independently mounted and in-line cord controls 281
Bibliography 282

Figure 1 – Example of ports 40
Figure 2 – Structure of the document with respect to inherent safety and functional safety 43
Figure 3 – Example of an electronic circuit with low power points 106
Figure 4 – Test pin probe 13 of IEC 61032:1997 156
Figure 5 – Test finger probe B of IEC 61032:1997 157
Figure 6 – Test fingernail 158
Figure 7 – Impact test for free-standing controls 159
Figure 8 – Tumbling barrel 159
Figure 9 – Apparatus for testing durability of markings on rating labels 160
Figure 10 – Apparatus for flexing test 160
Figure 11 – Screw terminals and stud terminals 161
Figure 12 – Pillar terminals 162
Figure 13 – Mantle terminals 163
Figure 14 – Saddle and lug terminals 164
Figure 15 – Tabs 165
Figure 16 – Tabs for non-reversible connectors 166
Figure 17 – Receptacles 167
Figure 18 – Measurement of creepage distance and clearance 168
Figure 19 – Diagram for touch current measurement at operating temperature for single-phase connection of class II controls 169
Figure 20 – Diagram for touch current measurement at operating temperature for single-phase connection of controls other than class II 169
Figure 21 – Diagram for touch current measurement at operating temperature for three-phase connection of class II controls 170

Figure 22 – Diagram for touch current measurement at operating temperature for three-phase connection of controls other than class II 171
Figure 23 – Diagram for touch current measurement at operating temperature for single-phase connection of controls to three-wire, ground neutral supply other than class II 171
Figure 24 – Diagram for touch current measurement at operating temperature for two-phase connection of controls to three-wire, ground neutral supply other than class II 172
Figure B.1 – Narrow groove 176
Figure B.2 – Wide groove 176
Figure B.3 – V-shaped groove 176
Figure B.4 – Rib 176
Figure B.5 – Uncemented joint with narrow groove 177
Figure B.6 – Uncemented joint with wide groove 177
Figure B.7 – Uncemented joint with narrow and wide grooves 177
Figure B.8 – Diverging side walls 178
Figure B.9 – Narrow recess 178
Figure B.10 – Wide recess 178
Figure B.11 – Conductive floating part 178
Figure H.1 – V-Model for the software life cycle 207
Figure H.2 – Voltage variation test 226
Figure J.1 – Generic test circuit for inrush-current limiting thermistor endurance test 257
Figure K.1 – Circuit for measuring touch currents 258
Figure L.1 – Test sample 260
Figure M.1 – Example of type 1 protection 262
Figure M.2 – Example of type 2 protection 263
Figure N.1 – Example of surge protection by shielding in buildings with common earth reference systems 266
Figure N.2 – Example of secondary surge protection in buildings with separate common earth reference systems 267
Figure N.3 – Example of primary and secondary surge protection of indoor/outdoor equipment 267
Figure O.1 – Guidance flowchart for application of requirements of Clause 11 269

Table 1 – Required technical information and methods of providing these information 50
Table 2 – Cross-sectional area of conductors 64
Table 3 – Terminal conductors 66
Table 4 – Conductor pull test values 66
Table 5 – Nominal cross-sectional areas of conductors 68
Table 6 – Axial force values for tab insertion and withdrawal 69
Table 7 – Minimum cord conductor sizes 81
Table 8 – Data exchange 86
Table 9 – Threaded parts torque test values 92
Table 10 – Rated impulse voltage for equipment energized directly from the supply mains (from IEC 60664-1:2007, Table F.1) 95
Table 11 – Clearances for insulation co-ordination (from IEC 60664-1:2007, Table F.2) 96

Table 12 – Minimum creepage distances for basic insulation 100
Table 13 – Minimum creepage distances for functional insulation 101
Table 14 – Electrical/electronic component fault modes 107
Table 15 – Minimum insulation resistance 114
Table 16 – Insulation or disconnection test voltages 115
Table 17 – Maximum heating temperatures 120
Table 18 – Electrical conditions for the overvoltage and endurance tests 126
Table 19 – Electrical conditions for the overload tests of 19.7 and 19.10 128
Table 20 – Electrical conditions for the endurance tests of 19.8, 19.9, 19.11, 19.12 and 19.13 129
Table 21 – Pull-cord force test values 137
Table 22 – Pull and torque values 138
Table 23 – Emission limit for residential electromagnetic environment 143
Table 24 – Emission limit for industrial electromagnetic environment 144
Table 25 – The applicable EMC test in relation to the class of control function and type of Action 146
Table 26 – Immunity test requirements for residential electromagnetic environments 148
Table 27 – Immunity test requirements for industrial electromagnetic environment 150
Table 28 – Performance criteria 152
Table 29 – Maximum winding temperature (for test of mechanical blocked output conditions) 155
Table B.1 – Value of X 175
Table C.1 – Inherent control or equivalent protective control 179
Table C.2 – Cases where protective control is necessary and control is provided by surge arresters having a ratio of clamping voltage to rated voltage not smaller than that specified by IEC 60099-1 180
Table E.1 – Typical usage 182
Table H.1 – Additional items to Table 1 197
Table H.2 – Acceptable measures to address fault/errors [a] 200
Table H.3 – Examples of techniques/measures for semi-formal methods 207
Table H.4 – Examples of techniques/measures for software architecture specification 208
Table H.5 – Examples of techniques/measures for module design specification 209
Table H.6 – Examples of techniques/measures for design and coding standards 209
Table H.7 – Examples of techniques/measures for software module testing 210
Table H.8 – Examples of techniques/measures for software integration testing 211
Table H.9 – Examples of techniques/measures for software safety validation 211
Table H.10 – Combinations of analytical measures during hardware development 212
Table H.11 – Examples of defences against unauthorised access and transmission failure modes 214
Table H.12 – Applicable test levels in addition to Clause 25 222
Table H.13 – Voltage dips, short interruptions and voltage variations 224
Table H.14 – Test values for voltage variations 225
Table H.15 – Test voltages for test level 2 (depending on the installation class conditions) 228
Table H.16 – Test level for electrical fast transient burst test 230

Table H.17 – Test levels for conducted disturbances on mains and I/O lines 232
Table H.18 – Test level for immunity to radiated electromagnetic fields 233
Table H.19 – Increased test level for radiated immunity 234
Table H.20 – Test level for supply frequency variations 235
Table H.21 – Test level for continuous fields 236
Table I.1 – Electrical transient conduction immunity in accordance with ISO 7637-2 239
Table I.2 – Electrical transient conduction immunity in accordance with ISO 7637-3 240
Table J.1 – Maximum current 243
Table J.2 – Normal operating conditions 244
Table J.3 – Samples for the test (clause reference) 245
Table J.4 – Electrical and thermal ratings of a thermistor 246
Table J.5 – Additional items to Table 1 247
Table J.6 – Sequence of calibration and conditioning tests for PTC thermistors 249
Table J.7 – Classes for PTC sensing thermistors 250
Table J.8 – Sequence of calibration and conditioning tests for NTC thermistors 251
Table J.9 – Classes for NTC sensing thermistors 251
Table J.10 – Number of cycles for endurance test 255
Table J.11 – Ageing test temperature 255
Table J.12 – Number of cycles for endurance test 256
Table L.1 – Environmental cycling conditions 259
Table M.1 – IEC 60664-3 test levels or conditions 261
Table O.1 – Example A – Using Annex O guidance for applying Clause 11 270
Table O.2 – Example B – Using Annex O guidance for applying Clause 11 270
Table Q.1 – Additional aging parameters for windings 275
Table AA.1 – Number of cycles 281

INTERNATIONAL ELECTROTECHNICAL COMMISSION

_____

Automatic electrical controls - Part 2-13: Particular requirements for humidity sensing controls

FOREWORD

1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as “IEC Publication(s)”). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
6) All users should ensure that they have the latest edition of this publication.
7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
9) IEC draws attention to the possibility that the implementation of this document may involve the use of (a) patent(s). IEC takes no position concerning the evidence, validity or applicability of any claimed patent rights in respect thereof. As of the date of publication of this document, IEC had not received notice of (a) patent(s), which may be required to implement this document. However, implementers are cautioned that this may not represent the latest information, which may be obtained from the patent database available at https://patents.iec.ch. IEC shall not be held responsible for identifying any or all such patent rights.

This extended version (EXV) of the official IEC Standard provides the user with the full content of the Standard.

IEC 60730-2-13:2025 EXV includes the content of IEC 60730-2-13:2025, and the references made to IEC 60730-1:2022.

The specific content of IEC 60730-2-13:2025 is displayed on a blue background.

IEC 60730-2-13 has been prepared by IEC technical committee 72: Automatic electrical controls. It is an International Standard.

This fourth edition cancels and replaces the third edition published in 2017. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

a) adoption to IEC 60730-1:2022 with all of its significant changes to IEC 60730-1:2013, IEC 60730-1:2013/AMD1:2015 and IEC 60730-1:2013/AMD2:2020.

The text of this International Standard is based on the following documents:

Draft	Report on voting
72/1487/FDIS	72/1503/RVD

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

The language used for the development of this International Standard is English.

This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available at www.iec.ch/members_experts/refdocs. The main document types developed by IEC are described in greater detail at www.iec.ch/publications.

A list of all parts of the IEC 60730 series, under the general title: *Automatic electrical controls*, can be found on the IEC website.

This part 2-13 is intended to be used in conjunction with IEC 60730-1. It was established on the basis of the sixth edition of that standard (2022). Consideration may be given to future editions of, or amendments to, IEC 60730-1.

This part 2-13 supplements or modifies the corresponding clauses in IEC 60730-1, so as to convert that publication into the IEC standard: Particular requirements for humidity sensing controls.

Where this part 2-13 states "addition", "modification" or "replacement", the relevant requirement, test specification or explanatory matter in Part 1 should be adapted accordingly.

When a particular subclause of Part 1 is not mentioned in this Part 2, that subclause applies.

In the development of a fully international standard it has been necessary to take into consideration the differing requirements resulting from practical experience in various parts of the world and to recognize the variation in national electrical systems and wiring rules.

The reader's attention is drawn to the fact that Annex Q, Annex R, Annex S and Annex T list all of the "in-some-country" clauses on differing practices of a less permanent nature relating to the subject of this document.

In this publication:

1) The following print types are used:
   - requirements proper: in roman type;
   - *test specifications: in italic type;*

– explanatory matter: in smaller roman type.

– Defined terms: **bold type**.

2) Subclauses, notes or items which are additional to those in Part 1 are numbered starting from 101, additional annexes are lettered AA, BB, etc.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under webstore.iec.ch in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn, or
- revised.

1 Scope

This document applies to automatic **electrical humidity sensing controls**

- for use in, on, or in association with equipment for household appliance and similar use;

NOTE 1 Throughout this document, the word "equipment" means "appliance and equipment" and "controls" means "**humidity sensing control**".

- for building automation within the scope of ISO 16484 series and IEC 63044 series (HBES/BACS);
- for equipment that is used by the public, such as equipment intended to be used in shops, offices, hospitals, farms and commercial and industrial applications;

EXAMPLE 1 **Humidity sensing controls** for commercial catering, heating and air-conditioning equipment.

- that are **smart enabled controls**;

EXAMPLE 2 Smart grid control, remote interfaces/control of energy-consuming equipment including computer or smart phone.

- that are AC or DC powered controls with a rated voltage not exceeding 690 V AC or 600 V DC;
- used in, on, or in association with equipment that use electricity, gas, oil, solid fuel, solar thermal energy, etc., or a combination thereof;
- utilized as part of a control system or controls which are mechanically integral with multifunctional controls having non-electrical outputs;
- using NTC or **PTC thermistors** and to discrete **thermistors**, requirements for which are contained in Annex J;
- that are mechanically or electrically operated, responsive to or controlling such characteristics as temperature, pressure, passage of time, humidity, light, electrostatic effects, flow, or liquid level, current, voltage, acceleration, or combinations thereof;
- as well as manual controls when such are electrically and/or mechanically integral with automatic controls.

NOTE 2 Requirements for manually actuated mechanical switches not forming part of an automatic control are contained in IEC 61058-1-1.

This document applies to

– the inherent safety of automatic **electrical humidity sensing controls**, and
– functional safety of automatic **electrical humidity sensing controls** and safety related systems,
– **humidity sensing controls** where the performance (for example the effect of EMC phenomena) of the product can impair the overall safety and performance of the controlled system,
– the operating values, operating times, and operating sequences where such are associated with equipment safety.

This document specifies the requirements for construction, operation and testing of automatic electrical **humidity sensing controls** used in, on, or in association with an equipment.

This document does not

- apply to automatic **electrical humidity sensing controls** intended exclusively for industrial process applications unless explicitly mentioned in the relevant part 2 or the equipment standard. However, this document can be applied to evaluate **humidity sensing controls** intended specifically for industrial applications in cases where no relevant safety standard exists;
- take into account the response value of an automatic action of a **humidity sensing control**, if such a response value is dependent upon the method of mounting the **humidity sensing control** in the equipment. Where a response value is of significant purpose for the protection of the user, or surroundings, the value defined in the appropriate equipment standard or as determined by the manufacturer will apply;
- address the integrity of the output signal to the network devices, such as interoperability with other devices unless it has been evaluated as part of the control system.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60038, *IEC standard voltages*

IEC 60065:2014, *Audio, video and similar electronic apparatus – Safety requirements*

IEC 60068-2-75, *Environmental testing – Part 2-75: Tests – Test Eh: Hammer tests*

IEC 60085, *Electrical insulation – Thermal evaluation and designation*

IEC 60099-1:1991, *Surge arresters – Part 1: Non-linear resistor type gapped surge arresters for a.c. systems*[1]

IEC 60112:2020, *Method for the determination of the proof and the comparative tracking indices of solid insulating materials*

IEC 60127 (all parts), *Miniature fuses*

IEC 60227-1, *Polyvinyl chloride insulated cables of rated voltages up to and including 450/750 V – Part 1: General requirements*

IEC 60245-1, *Rubber insulated cables – Rated voltages up to and including 450/750 V – Part 1: General requirements*

IEC 60269 (all parts), *Low-voltage fuses*

IEC 60335-1:2020, *Household and similar electrical appliances – Safety – Part 1: General requirements*

IEC 60384-14, *Fixed capacitors for use in electronic equipment – Part 14: Sectional specification – Fixed capacitors for electromagnetic interference suppression and connection to the supply mains*

[1] Withdrawn.

IEC 60384-16, *Fixed capacitors for use in electronic equipment – Part 16: Sectional specification – Fixed metallized polypropylene film dielectric DC capacitors*

IEC 60384-17, *Fixed capacitors for use in electronic equipment – Part 17: Sectional specification – Fixed metallized polypropylene film dielectric AC and pulse capacitors*

IEC 60417, *Graphical symbols for use on equipment*

IEC 60423, *Conduit systems for cable management – Outside diameters of conduits for electrical installations and threads for conduits and fittings*

IEC 60529:1989, *Degrees of protection provided by enclosures (IP code)*
IEC 60529:1989/AMD1:1999
IEC 60529:1989/AMD2:2013

IEC 60539 (all parts), *Directly heated negative temperature coefficient thermistors*

IEC 60664-1:2007[2], *Insulation coordination for equipment within low-voltage systems – Part 1: Principles, requirements and tests*

IEC TR 60664-2 (all parts), *Insulation coordination for equipment within low-voltage systems*

IEC 60664-3:2016, *Insulation coordination for equipment within low-voltage systems – Part 3: Use of coating, potting or moulding for protection against pollution*

IEC 60664-4, *Insulation coordination for equipment within low-voltage systems – Part 4: Consideration of high-frequency voltage stress*

IEC 60695-2-10, *Fire hazard testing – Part 2-10: Glowing/hot-wire based test methods – Glow-wire apparatus and common test procedure*

IEC 60695-2-11:2021, *Fire hazard testing – Part 2-11: Glowing/hot-wire based test methods – Glow-wire flammability test method for end-products (GWEPT)*

IEC 60695-10-2, *Fire hazard testing – Part 10-2: Abnormal heat – Ball pressure test method*

IEC 60738 (all parts), *Thermistors – Directly heated positive temperature coefficient*

IEC 60747-5-5, *Semiconductor devices – Part 5-5: Optoelectronic devices – Photocouplers*

IEC 60884-1, *Plugs and socket-outlets for household and similar purposes – Part 1: General requirements*

IEC 60884-2-5:2017, *Plugs and socket-outlets for household and similar purposes – Part 2-5: Particular requirements for adaptors*

IEC 60998-2-2, *Connecting devices for low-voltage circuits for household and similar purposes – Part 2-2: Particular requirements for connecting devices as separate entities with screwless-type clamping units*

[2] Withdrawn.

IEC 60998-2-3, *Connecting devices for low-voltage circuits for household and similar purposes – Part 2-3: Particular requirements for connecting devices as separate entities with insulation-piercing clamping units*

IEC 60999-1, *Connecting devices – Electrical copper conductors – Safety requirements for screw-type and screwless-type clamping units – Part 1: General requirements and particular requirements for clamping units for conductors from 0,2 mm^2 up to 35 mm^2 (included)*

IEC 61000-3-2, *Electromagnetic compatibility (EMC) – Part 3-2: Limits – Limits for harmonic current emissions (equipment input current ≤ 16 A per phase)*

IEC 61000-3-3, *Electromagnetic compatibility (EMC) – Part 3-3: Limits – Limitation of voltage changes, voltage fluctuations and flicker in public low-voltage supply systems, for equipment with rated current ≤16 A per phase and not subject to conditional connection*

IEC 61000-3-11, *Electromagnetic compatibility (EMC) – Part 3-11: Limits – Limitation of voltage changes, voltage fluctuations and flicker in public low-voltage supply systems – Equipment with rated current ≤ 75 A and subject to conditional connection*

IEC 61000-3-12, *Electromagnetic compatibility (EMC) – Part 3-12: Limits – Limits for harmonic currents produced by equipment connected to public low-voltage systems with input current >16 A and ≤ 75 A per phase*

IEC 61000-4-2:2008, *Electromagnetic compatibility (EMC) – Part 4-2: Testing and measurement techniques – Electrostatic discharge immunity test*

IEC 61000-4-3, *Electromagnetic compatibility (EMC) – Part 4-3: Testing and measurement techniques – Radiated, radio-frequency, electromagnetic field immunity test*

IEC 61000-4-4, *Electromagnetic compatibility (EMC) – Part 4-4: Testing and measurement techniques – Electrical fast transient/burst immunity test*

IEC 61000-4-5:2014, *Electromagnetic compatibility (EMC) – Part 4-5: Testing and measurement techniques – Surge immunity test*
IEC 61000-4-5:2014/AMD1:2017

IEC 61000-4-6, *Electromagnetic compatibility (EMC) – Part 4-6: Testing and measurement techniques – Immunity to conducted disturbances, induced by radio-frequency fields*

IEC 61000-4-8, *Electromagnetic compatibility (EMC) – Part 4-8: Testing and measurement techniques – Power frequency magnetic field immunity test*

IEC 61000-4-11, *Electromagnetic compatibility (EMC) – Part 4-11: Testing and measurement techniques – Voltage dips, short interruptions and voltage variations immunity tests for equipment with current up to 16 A per phase*

IEC 61000-4-13:2002, *Electromagnetic compatibility (EMC) – Part 4-13: Testing and measurement techniques – Harmonics and interharmonics including mains signalling at a.c. power port, low frequency immunity tests*
IEC 61000-4-13:2002 /AMD1:2009
IEC 61000-4-13:2002 /AMD2:2015

IEC 61000-4-20, *Electromagnetic compatibility (EMC) – Part 4-20: Testing and measurement techniques – Emission and immunity testing in transverse electromagnetic (TEM) waveguides*

IEC 61000-4-21, *Electromagnetic compatibility (EMC) – Part 4-21: Testing and measurement techniques – Reverberation chamber test methods*

IEC 61000-4-22, *Electromagnetic compatibility (EMC) – Part 4-22: Testing and measurement techniques – Radiated emissions and immunity measurements in fully anechoic rooms (FARs)*

IEC 61000-4-28, *Electromagnetic compatibility (EMC) – Part 4-28: Testing and measurement techniques – Variation of power frequency, immunity test for equipment with input current not exceeding 16A per phase*

IEC 61000-6-1:2016, *Electromagnetic compatibility (EMC) – Part 6-1: Generic standards – Immunity standard for residential, commercial and light-industrial environments*

IEC 61000-6-2:2016, *Electromagnetic compatibility (EMC) – Part 6-2: Generic standards – Immunity standard for industrial environments*

IEC 61000-6-3:2020, *Electromagnetic compatibility (EMC) – Part 6-3: Generic standards – Emission standard for equipment in residential environments*

IEC 61000-6-4:2018, *Electromagnetic compatibility (EMC) – Part 6-4: Generic standards – Emission standard for industrial environments*

IEC 61051-1, *Varistors for use in electronic equipment – Part 1: Generic specification*

IEC 61051-2, *Varistors for use in electronic equipment – Part 2: Sectional specification for surge suppression varistors*

IEC 61051-2-2, *Varistors for use in electronic equipment – Part 2: Blank detail specification for zinc oxide surge suppression varistors. Assessment level E*

IEC 61210, *Connecting devices – Flat quick-connect terminations for electrical copper conductors – Safety requirements*

IEC 61249 (all parts), *Materials for printed boards and other interconnecting structures*

IEC 61558-2-6, *Safety of transformers, reactors, power supply units and combinations thereof − Part 2-6: Particular requirements and tests for safety isolating transformers and power supply units incorporating safety isolating transformers for general applications*

IEC 61558-2-16, *Safety of transformers, reactors, power supply units and combinations thereof − Part 2-16: Particular requirements and tests for switch mode power supply units and transformers for switch mode power supply units for general applications*

IEC 61810-3, *Electromechanical elementary relays – Part 3: Replays with forcibly guided (mechanically linked) contacts*

IEC 62151, *Safety of equipment electrically connected to a telecommunication network*

IEC 62319 (all parts), *Polymeric thermistors – Directly heated positive step function temperature coefficient*

IEC 62326 (all parts), *Printed boards*

IEC 62368-1, *Audio/video, information and communication technology equipment – Part 1: Safety requirements*

IEC 63044 (all parts), *Home and Building Electronic Systems (HBES) and Building Automation and Control Systems (BACS)*

CISPR 11, *Industrial, scientific and medical equipment – Radio-frequency disturbance characteristics – Limits and methods of measurement*

CISPR 14-1:2020, *Electromagnetic compatibility – Requirements for household appliances, electric tools and similar apparatus – Part 1: Emission*

CISPR 32:2015, *Electromagnetic compatibility of multimedia equipment – Emission* requirements
CISPR 32:2015/AMD1:2019

ISO 4046-4:2016, *Paper, board, pulps and related terms − Vocabulary − Part 4: Paper and board grades and converted products*

ISO 7637-2:2011, *Road vehicles – Electrical disturbances from conduction and coupling – Part 2: Electrical transient conduction along supply lines only*

ISO 7637-3:2016, *Road vehicles – Electrical disturbances from conduction and coupling – Part 3: Electrical transient transmission by capacitive and inductive coupling via lines other than supply lines*

ISO 16484 (all parts), *Building automation and control systems (BACS)*

IEC 60730-2-13

Edition 4.0 2025-08

INTERNATIONAL STANDARD

NORME INTERNATIONALE

Automatic electrical controls -
Part 2-13: Particular requirements for humidity sensing controls

Dispositifs de commande électrique automatiques -
Partie 2-13: Exigences particulières pour les dispositifs de commande sensibles à l'humidité

ICS 97.120

ISBN 978-2-8327-0596-4

IEC 60730-2-13:2025-08(en-fr)

CONTENTS

FOREWORD 2
1 Scope 5
2 Normative references 6
3 Terms and definitions 6
4 General 6
5 Required technical information 7
6 Protection against electric shock 7
7 Provision for protective earthing 7
8 Terminals and terminations 7
9 Constructional requirements 7
10 Threaded parts and connections 7
11 Creepage distances, clearances and distances through solid insulation 7
12 Components 7
13 Fault assessment on electronic circuits 7
14 Moisture and dust resistance 8
15 Electric strength and insulation resistance 8
16 Heating 8
17 Manufacturing deviation and drift 8
18 Environmental stress 8
19 Endurance 8
20 Mechanical strength 9
21 Resistance to heat, fire and tracking 9
22 Resistance to corrosion 9
23 Electromagnetic compatibility (EMC) requirements – Emission 9
24 Normal operation 9
25 Electromagnetic compatibility (EMC) requirements – Immunity 9
26 Abnormal operation tests 9
Annex H (normative) Requirements related to functional safety 10
Annex Q (informative) Regional differences relevant for the member countries of Cenelec 20
Annex R (informative) National differences relevant in the United States of America 21
Annex S (informative) National differences relevant in Japan 22
Annex T (informative) National differences relevant in Canada 23
Annex AA (normative) Independently mounted and in-line cord controls 24
Bibliography 25

Table 16 – Insulation or disconnection test voltages 8
Table H.1 – Additional items to Table 1 10
Table AA.1 – Number of cycles 24

INTERNATIONAL ELECTROTECHNICAL COMMISSION

_____

Automatic electrical controls - Part 2-13: Particular requirements for humidity sensing controls

FOREWORD

1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as “IEC Publication(s)”). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
6) All users should ensure that they have the latest edition of this publication.
7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
9) IEC draws attention to the possibility that the implementation of this document may involve the use of (a) patent(s). IEC takes no position concerning the evidence, validity or applicability of any claimed patent rights in respect thereof. As of the date of publication of this document, IEC had not received notice of (a) patent(s), which may be required to implement this document. However, implementers are cautioned that this may not represent the latest information, which may be obtained from the patent database available at https://patents.iec.ch. IEC shall not be held responsible for identifying any or all such patent rights.

IEC 60730-2-13 has been prepared by IEC technical committee 72: Automatic electrical controls. It is an International Standard.

This fourth edition cancels and replaces the third edition published in 2017. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

a) adoption to IEC 60730-1:2022 with all of its significant changes to IEC 60730-1:2013, IEC 60730-1:2013/AMD1:2015 and IEC 60730-1:2013/AMD2:2020.

The text of this International Standard is based on the following documents:

Draft	Report on voting
72/1487/FDIS	72/1503/RVD

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

The language used for the development of this International Standard is English.

This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available at www.iec.ch/members_experts/refdocs. The main document types developed by IEC are described in greater detail at www.iec.ch/publications.

A list of all parts of the IEC 60730 series, under the general title: *Automatic electrical controls*, can be found on the IEC website.

This part 2-13 is intended to be used in conjunction with IEC 60730-1. It was established on the basis of the sixth edition of that standard (2022). Consideration may be given to future editions of, or amendments to, IEC 60730-1.

This part 2-13 supplements or modifies the corresponding clauses in IEC 60730-1, so as to convert that publication into the IEC standard: Particular requirements for humidity sensing controls.

Where this part 2-13 states "addition", "modification" or "replacement", the relevant requirement, test specification or explanatory matter in Part 1 should be adapted accordingly.

When a particular subclause of Part 1 is not mentioned in this Part 2, that subclause applies.

In the development of a fully international standard it has been necessary to take into consideration the differing requirements resulting from practical experience in various parts of the world and to recognize the variation in national electrical systems and wiring rules.

The reader's attention is drawn to the fact that Annex Q, Annex R, Annex S and Annex T list all of the "in-some-country" clauses on differing practices of a less permanent nature relating to the subject of this document.

In this publication:

1) The following print types are used:
   - requirements proper: in roman type;
   - *test specifications: in italic type;*
   - explanatory matter: in smaller roman type.
   - Defined terms: **bold type**.
2) Subclauses, notes or items which are additional to those in Part 1 are numbered starting from 101, additional annexes are lettered AA, BB, etc.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under webstore.iec.ch in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn, or
- revised.

1 Scope

This clause of Part 1 is replaced by the following:

This document applies to automatic **electrical humidity sensing controls**

- for use in, on, or in association with equipment for household appliance and similar use;

NOTE 1 Throughout this document, the word "equipment" means "appliance and equipment" and "controls" means "**humidity sensing control**".

- for building automation within the scope of ISO 16484 series and IEC 63044 series (HBES/BACS);
- for equipment that is used by the public, such as equipment intended to be used in shops, offices, hospitals, farms and commercial and industrial applications;

EXAMPLE 1 **Humidity sensing controls** for commercial catering, heating and air-conditioning equipment.

- that are **smart enabled controls**;

EXAMPLE 2 Smart grid control, remote interfaces/control of energy-consuming equipment including computer or smart phone.

- that are AC or DC powered controls with a rated voltage not exceeding 690 V AC or 600 V DC;
- used in, on, or in association with equipment that use electricity, gas, oil, solid fuel, solar thermal energy, etc., or a combination thereof;
- utilized as part of a control system or controls which are mechanically integral with multifunctional controls having non-electrical outputs;
- using NTC or **PTC thermistors** and to discrete **thermistors**, requirements for which are contained in Annex J;
- that are mechanically or electrically operated, responsive to or controlling such characteristics as temperature, pressure, passage of time, humidity, light, electrostatic effects, flow, or liquid level, current, voltage, acceleration, or combinations thereof;
- as well as manual controls when such are electrically and/or mechanically integral with automatic controls.

NOTE 2 Requirements for manually actuated mechanical switches not forming part of an automatic control are contained in IEC 61058-1-1.

This document applies to

– the inherent safety of automatic **electrical humidity sensing controls**, and

– functional safety of automatic **electrical humidity sensing controls** and safety related systems,

– **humidity sensing controls** where the performance (for example the effect of EMC phenomena) of the product can impair the overall safety and performance of the controlled system,

– the operating values, operating times, and operating sequences where such are associated with equipment safety.

This document specifies the requirements for construction, operation and testing of automatic electrical **humidity sensing controls** used in, on, or in association with an equipment.

This document does not

- apply to automatic **electrical humidity sensing controls** intended exclusively for industrial process applications unless explicitly mentioned in the relevant part 2 or the equipment standard. However, this document can be applied to evaluate **humidity sensing controls** intended specifically for industrial applications in cases where no relevant safety standard exists;
- take into account the response value of an automatic action of a **humidity sensing control**, if such a response value is dependent upon the method of mounting the **humidity sensing control** in the equipment. Where a response value is of significant purpose for the protection of the user, or surroundings, the value defined in the appropriate equipment standard or as determined by the manufacturer will apply;
- address the integrity of the output signal to the network devices, such as interoperability with other devices unless it has been evaluated as part of the control system.

2 Normative references

This clause of Part 1 is applicable.

SOMMAIRE

AVANT-PROPOS 2
1 Domaine d'application 5
2 Références normatives 6
3 Termes et définitions 6
4 Généralités 7
5 Informations techniques exigées 7
6 Protection contre les chocs électriques 7
7 Dispositions en vue de la mise à la terre de protection 7
8 Bornes et connexions 7
9 Exigences de construction 7
10 Parties filetées et connexions 7
11 Lignes de fuite, distances dans l'air et distances à travers l'isolation solide 7
12 Éléments constituants 7
13 Évaluation des pannes sur les circuits électroniques 8
14 Résistance à l'humidité et à la poussière 8
15 Résistance d'isolement et rigidité diélectrique 8
16 Échauffements 8
17 Tolérances de fabrication et dérive 8
18 Contraintes climatiques 8
19 Endurance 9
20 Résistance mécanique 9
21 Résistance à la chaleur, au feu et aux courants de cheminement 9
22 Résistance à la corrosion 9
23 Exigences de compatibilité électromagnétique (CEM) – Émission 9
24 Fonctionnement normal 10
25 Exigences de compatibilité électromagnétique (CEM) – Immunité 10
26 Essais en fonctionnement anormal 10
Annexe H (normative) Exigences relatives à la sécurité fonctionnelle 11
Annexe Q (informative) Différences régionales pertinentes pour les pays membres du CENELEC 23
Annexe R (informative) Différences nationales applicables aux États-Unis 24
Annexe S (informative) Différences nationales applicables au Japon 25
Annexe T (informative) Différences nationales applicables au Canada 26
Annexe AA (normative) Dispositifs de commande à montage indépendant et intercalés dans un câble souple 27
Bibliographie 28

Tableau 16 – Tensions d'essai d'isolation ou de déconnexion 8
Tableau H.1 – Points complémentaires au Tableau 1 11
Tableau AA.1 – Nombre de cycles 27

COMMISSION ÉLECTROTECHNIQUE INTERNATIONALE

_____

Dispositifs de commande électrique automatiques - Partie 2-13: Exigences particulières pour les dispositifs de commande sensibles à l'humidité

AVANT-PROPOS

1) La Commission Électrotechnique Internationale (IEC) est une organisation mondiale de normalisation composée de l'ensemble des comités électrotechniques nationaux (Comités nationaux de l'IEC). L'IEC a pour objet de favoriser la coopération internationale pour toutes les questions de normalisation dans les domaines de l'électricité et de l'électronique. À cet effet, l'IEC – entre autres activités – publie des Normes internationales, des Spécifications techniques, des Rapports techniques, des Spécifications accessibles au public (PAS) et des Guides (ci-après dénommés "Publication(s) de l'IEC"). Leur élaboration est confiée à des comités d'études, aux travaux desquels tout Comité national intéressé par le sujet traité peut participer. Les organisations internationales, gouvernementales et non gouvernementales, en liaison avec l'IEC, participent également aux travaux. L'IEC collabore étroitement avec l'Organisation Internationale de Normalisation (ISO), selon des conditions fixées par accord entre les deux organisations.
2) Les décisions ou accords officiels de l'IEC concernant les questions techniques représentent, dans la mesure du possible, un accord international sur les sujets étudiés, étant donné que les Comités nationaux de l'IEC intéressés sont représentés dans chaque comité d'études.
3) Les Publications de l'IEC se présentent sous la forme de recommandations internationales et sont agréées comme telles par les Comités nationaux de l'IEC. Tous les efforts raisonnables sont entrepris afin que l'IEC s'assure de l'exactitude du contenu technique de ses publications; l'IEC ne peut pas être tenue responsable de l'éventuelle mauvaise utilisation ou interprétation qui en est faite par un quelconque utilisateur final.
4) Dans le but d'encourager l'uniformité internationale, les Comités nationaux de l'IEC s'engagent, dans toute la mesure possible, à appliquer de façon transparente les Publications de l'IEC dans leurs publications nationales et régionales. Toutes divergences entre toutes Publications de l'IEC et toutes publications nationales ou régionales correspondantes doivent être indiquées en termes clairs dans ces dernières.
5) L'IEC elle-même ne fournit aucune attestation de conformité. Des organismes de certification indépendants fournissent des services d'évaluation de conformité et, dans certains secteurs, accèdent aux marques de conformité de l'IEC. L'IEC n'est responsable d'aucun des services effectués par les organismes de certification indépendants.
6) Tous les utilisateurs doivent s'assurer qu'ils sont en possession de la dernière édition de cette publication.
7) Aucune responsabilité ne doit être imputée à l'IEC, à ses administrateurs, employés, auxiliaires ou mandataires, y compris ses experts particuliers et les membres de ses comités d'études et des Comités nationaux de l'IEC, pour tout préjudice causé en cas de dommages corporels et matériels, ou de tout autre dommage de quelque nature que ce soit, directe ou indirecte, ou pour supporter les coûts (y compris les frais de justice) et les dépenses découlant de la publication ou de l'utilisation de cette Publication de l'IEC ou de toute autre Publication de l'IEC, ou au crédit qui lui est accordé.
8) L'attention est attirée sur les références normatives citées dans cette publication. L'utilisation de publications référencées est obligatoire pour une application correcte de la présente publication.
9) L'IEC attire l'attention sur le fait que la mise en application du présent document peut entraîner l'utilisation d'un ou de plusieurs brevets. L'IEC ne prend pas position quant à la preuve, à la validité et à l'applicabilité de tout droit de brevet revendiqué à cet égard. À la date de publication du présent document, l'IEC n'avait pas reçu notification qu'un ou plusieurs brevets pouvaient être nécessaires à sa mise en application. Toutefois, il y a lieu d'avertir les responsables de la mise en application du présent document que des informations plus récentes sont susceptibles de figurer dans la base de données de brevets, disponible à l'adresse https://patents.iec.ch. L'IEC ne saurait être tenue pour responsable de ne pas avoir identifié de tels droits de brevets.

L'IEC 60730-2-13 a été établie par le comité d'études 72 de l'IEC: Commandes électriques automatiques. Il s'agit d'une Norme internationale.

Cette quatrième édition annule et remplace la troisième édition parue en 2017. Cette édition constitue une révision technique.

Cette édition inclut les modifications techniques majeures suivantes par rapport à l'édition précédente:

a) adoption de l'IEC 60730-1:2022 avec toutes les modifications majeures par rapport à l'IEC 60730-1:2013, l'IEC 60730-1:2013/AMD1:2015 et l'IEC 60730-1:2013/AMD2:2020.

Le texte de cette Norme internationale est issu des documents suivants:

Projet	Rapport de vote
72/1487/FDIS	72/1503/RVD

Le rapport de vote indiqué dans le tableau ci-dessus donne toute information sur le vote ayant abouti à son approbation.

La langue employée pour l'élaboration de cette Norme internationale est l'anglais.

Ce document a été rédigé selon les Directives ISO/IEC, Partie 2, il a été développé selon les Directives ISO/IEC, Partie 1 et les Directives ISO/IEC, Supplément IEC, disponibles sous www.iec.ch/members_experts/refdocs. Les principaux types de documents développés par l'IEC sont décrits plus en détail sous www.iec.ch/standardsdev/publications.

Une liste de toutes les parties de la série IEC 60730, publiées sous le titre général: *Dispositifs de commande électrique automatiques*, se trouve sur le site web de l'IEC.

La présente partie 2-13 est destinée à être utilisée conjointement avec l'IEC 60730-1. Elle a été établie sur la base de la sixième édition de cette norme (2022). Les éditions futures de l'IEC 60730-1 ou ses amendements pourront être pris en considération.

La présente partie 2-13 complète ou modifie les articles correspondants de l'IEC 60730-1, de façon à transformer cette publication en norme IEC: Exigences particulières pour les dispositifs de commande sensibles à l'humidité.

Lorsque la présente partie 2-13 spécifie "addition", "modification" ou "remplacement", il convient d'adapter l'exigence, la modalité d'essai ou la note correspondante de la Partie 1 en conséquence.

Lorsqu'un paragraphe particulier de la Partie 1 n'est pas mentionné dans cette Partie 2, ce paragraphe s'applique.

Pour les besoins d'élaboration d'une Norme internationale, il a été nécessaire d'examiner les différentes exigences en s'appuyant sur l'expérience pratique acquise dans différentes régions du monde et d'identifier les variantes nationales au niveau des réseaux d'alimentation électrique et des règles d'installation.

L'attention du lecteur est attirée sur le fait que l'Annexe Q, l'Annexe R, l'Annexe S et l'Annexe T donnent une liste de tous les articles qui traitent des différences de pratiques à caractère moins permanent qui existent dans certains pays dans le domaine couvert par le présent document.

Dans cette publication:

1) Les caractères d'imprimerie suivants sont utilisés:
   - exigences proprement dites: caractères romains;
   - *modalités d'essais: caractères italiques;*
   - notes: petits caractères romains;
   - termes définis: **caractères gras**.
2) Les paragraphes, notes ou articles qui s'ajoutent à ceux de la Partie 1 sont numérotés à partir de 101 et les annexes qui sont ajoutées sont désignées AA, BB, etc.

Le comité a décidé que le contenu de ce document ne sera pas modifié avant la date de stabilité indiquée sur le site web de l'IEC sous webstore.iec.ch dans les données relatives au document recherché. À cette date, le document sera

- reconduit,
- supprimé, ou
- révisé.

1 Domaine d'application

L'article de la Partie 1 est remplacé par le texte suivant:

Le présent document s'applique aux **dispositifs de commande électrique** automatiques **sensibles à la l'humidité**

- utilisés dans, sur ou avec des matériels pour appareil domestique et usage analogue;

NOTE 1 Dans le présent document, le terme "matériel" signifie "appareil et matériel" et "dispositifs de commande" signifie "**dispositifs de commande sensibles à l'humidité**".

- pour l'automatisation des bâtiments qui relèvent du domaine d'application de la série ISO 16484 et de la série IEC 63044 (HBES/BACS);
- pour des matériels utilisés par le public, tels que les matériels destinés à être utilisés dans des magasins, des bureaux, des hôpitaux, des fermes et des applications commerciales et industrielles;

EXEMPLE 1 Les **dispositifs de commande sensibles à l'humidité** pour les installations de restauration, de chauffage et d'air conditionné.

- qui sont des **dispositifs de commande activés intelligents**;

EXEMPLE 2 Les dispositifs de commande de réseau intelligent, les interfaces distantes/dispositifs de commande de matériels utilisateurs d'énergie électrique, y compris les ordinateurs ou les mobiles multifonctions.

- qui sont des dispositifs de commande à courant alternatif ou continu dont la tension assignée ne dépasse pas 690 V en courant alternatif ou 600 V en courant continu;
- qui sont utilisés dans, sur ou avec des matériels qui utilisent l'électricité, le gaz, le pétrole, des combustibles solides, l'énergie thermique solaire, etc. ou une combinaison de ces sources d'énergie;
- qui sont utilisés dans le cadre d'un système de commande ou de dispositifs de commande qui sont mécaniquement intégrés à des dispositifs de commande multifonctions comportant des sorties non électriques;
- qui utilisent des **thermistances CTN** ou CTP ainsi qu'aux dispositifs à **thermistances** discrètes, dont les exigences sont fournies à l'Annexe J;
- à commande mécanique ou électrique, qui réagissent à des caractéristiques telles que la température, la pression, le passage du temps, l'humidité, la lumière, les effets électrostatiques, le débit ou le niveau d'un liquide, le courant, la tension, l'accélération, ou une combinaison de ces caractéristiques, ou qui les régulent;
- ainsi qu'aux dispositifs de commande manuels qui sont électriquement et/ou mécaniquement intégrés à des dispositifs de commande automatique.

NOTE 2 Les exigences relatives aux interrupteurs mécaniques à action manuelle qui ne font pas partie d'un dispositif de commande automatique sont contenues dans l'IEC 61058-1-1.

Le présent document s'applique

– à la sécurité intrinsèque des **dispositifs de commande électrique** automatiques **sensibles à l'humidité**; et

– à la sécurité fonctionnelle des **dispositifs de commande électrique** automatiques **sensibles à l'humidité** et des systèmes de sécurité;

– aux **dispositifs de commande sensibles à l'humidité** pour lesquels les performances (par exemple, l'effet des phénomènes CEM) du produit peuvent compromettre la sécurité et les performances globales du système commandé;

– aux valeurs de fonctionnement, aux temps de fonctionnement et aux séquences de fonctionnement lorsque ces éléments interviennent dans la sécurité du matériel.

Le présent document spécifie les exigences relatives à la construction, au fonctionnement et aux essais des **dispositifs de commande électrique** automatiques **sensibles à l'humidité** utilisés dans, sur ou avec du matériel.

Le présent document

- ne s'applique pas aux **dispositifs de commande électrique** automatiques **sensibles à l'humidité** destinés exclusivement à des applications de processus industriels, sauf mention particulière dans la partie 2 applicable ou la norme du matériel. Toutefois, le présent document peut être utilisé pour évaluer les **dispositifs de commande sensibles à l'humidité** destinés spécifiquement aux applications industrielles lorsqu'il n'existe aucune norme de sécurité pertinente;
- ne prend pas en compte la valeur de réponse d'une action automatique d'un **dispositif de commande sensible à l'humidité**, lorsque cette valeur de réponse dépend de la méthode de montage du **dispositif de commande sensible à l'humidité** dans le matériel. Lorsqu'une valeur de réponse est importante du point de vue de la protection de l'utilisateur ou de l'environnement, la valeur définie dans la norme de matériel pertinente ou déterminée par le fabricant s'applique;
- ne traite pas de l'intégrité du signal de sortie transmis aux dispositifs de réseau, comme l'interopérabilité avec d'autres dispositifs, à moins qu'elle ait été évaluée comme partie intégrante du système de commande.

2 Références normatives

L'article de la Partie 1 s'applique.