IEC 61400-24

Edition 2.1 2024-11
CONSOLIDATED VERSION

INTERNATIONAL STANDARD

colour inside

Wind energy generation systems – Part 24: Lightning protection

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

ICS 27.180

ISBN 978-2-8327-0032-7

Warning! Make sure that you obtained this publication from an authorized distributor.

® Registered trademark of the International Electrotechnical Commission

CONTENTS

FOREWORD 11
INTRODUCTION to Amendment 1 13
1 Scope 14
2 Normative references 14
3 Terms and definitions 16
4 Symbols and units 22
5 Abbreviated terms 25
6 Lightning environment for wind turbine 26
6.1 General 26
6.2 Lightning current parameters and lightning protection levels (LPL) 26
7 Lightning exposure assessment 27
7.1 General 27
7.2 Assessing the frequency of lightning affecting a single wind turbine or a group of wind turbines 29
7.2.1 Categorization of lightning events 29
7.2.2 Estimation of average number of lightning flashes to a single or a group of wind turbines 29
7.2.3 Estimation of average annual number of lightning flashes near the wind turbine (N_M) 32
7.2.4 Estimation of average annual number of lightning flashes to the service lines connecting the wind turbines (N_L) 32
7.2.5 Estimation of average annual number of lightning flashes near the service lines connecting the wind turbine (N_I) 33
7.3 Assessing the risk of damage 34
7.3.1 Basic equation 34
7.3.2 Assessment of risk components due to flashes to the wind turbine (S1) 35
7.3.3 Assessment of the risk component due to flashes near the wind turbine (S2) 35
7.3.4 Assessment of risk components due to flashes to a service line connected to the wind turbine (S3) 36
7.3.5 Assessment of risk component due to flashes near a service line connected to the wind turbine (S4) 36
8 Lightning protection of subcomponents 37
8.1 General 37
8.1.1 Lightning protection level (LPL) 37
8.1.2 Lightning protection zones (LPZ) 38
8.2 Blades 38
8.2.1 General 38
8.2.2 Requirements 38
8.2.3 Verification 39
8.2.4 Protection design considerations 39
8.2.5 Test methods 42
8.3 Nacelle and other structural components 43
8.3.1 General 43
8.3.2 Hub 43
8.3.3 Spinner 43
8.3.4 Nacelle 44
8.3.5 Tower 44

8.3.6 Verification methods 45
8.4 Mechanical drive train and yaw system 45
8.4.1 General 45
8.4.2 Bearings 45
8.4.3 Hydraulic systems 46
8.4.4 Spark gaps and sliding contacts 47
8.4.5 Verification 47
8.5 Electrical low-voltage systems and electronic systems and installations 48
8.5.1 General 48
8.5.2 Equipotential bonding within the wind turbine 52
8.5.3 LEMP protection and immunity levels 53
8.5.4 Shielding and line routing 54
8.5.5 SPD protection 55
8.5.6 Testing methods for system immunity tests 59
8.6 Electrical high-voltage (HV) power systems 59
9 Earthing of wind turbines 61
9.1 General 61
9.1.1 Purpose and scope 61
9.1.2 Basic requirements 61
9.1.3 Earth electrode arrangements 61
9.1.4 Earthing system impedance 62
9.2 Equipotential bonding 62
9.2.1 General 62
9.2.2 Lightning equipotential bonding for metal installations 62
9.3 Structural components 63
9.3.1 General 63
9.3.2 Metal tubular type tower 63
9.3.3 Metal reinforced concrete towers 63
9.3.4 Lattice tower 63
9.3.5 Systems inside the tower 64
9.3.6 Concrete foundation 64
9.3.7 Rocky area foundation 64
9.3.8 Metal mono-pile foundation 65
9.3.9 Offshore foundation 65
9.4 Electrode shape dimensions 65
9.5 Execution and maintenance of the earthing system 66
10 Personal safety 66
11 Documentation of lightning protection system 68
11.1 General 68
11.2 Documentation necessary during assessment for design evaluation 68
11.2.1 General 68
11.2.2 General documentation 68
11.2.3 Documentation for rotor blades 69
11.2.4 Documentation of mechanical systems 69
11.2.5 Documentation of electrical and electronic systems 69
11.2.6 Documentation of earthing and bonding systems 69
11.2.7 Documentation of nacelle cover, hub and tower lightning protection systems 69
11.3 Site-specific information 70

11.4 Documentation to be provided in the manuals for LPS inspections 70
11.5 Manuals 70
12 Inspection of lightning protection system 70
12.1 Scope of inspection 70
12.2 Order of inspections 71
12.2.1 General 71
12.2.2 Inspection during production of the wind turbine 71
12.2.3 Inspection during installation of the wind turbine 71
12.2.4 Inspection during commissioning of the wind turbine and periodic inspection 71
12.2.5 Inspection after dismantling or repair of main parts 72
12.3 Maintenance 73
Annex A (informative) The lightning phenomenon in relation to wind turbines 74
A.1 Lightning environment for wind turbines 74
A.1.1 General 74
A.1.2 The properties of lightning 74
A.1.3 Lightning discharge formation and electrical parameters 74
A.1.4 Cloud-to-ground flashes 75
A.1.5 Upward initiated flashes 81
A.2 Lightning current parameters relevant to the point of strike 84
A.3 Leader current without return stroke 85
A.4 Lightning electromagnetic impulse, LEMP, effects 85
Annex B (informative) Lightning exposure assessment 86
B.1 General 86
B.2 Methodology to estimate the average annual flashes or strokes to the wind turbines of a wind farm and upward lightning activity in wind turbines 86
B.2.1 General 86
B.2.2 Methodology to determine average annual flashes to turbines of a wind farm estimation by increase of the location factor to consider upward lightning from wind turbines 86
B.2.3 Upward lightning percentage in wind farms 90
B.3 Explanation of terms 90
B.3.1 Damage and loss 90
B.3.2 Composition of risk 92
B.3.3 Assessment of risk components 92
B.3.4 Frequency of damage 93
B.3.5 Assessment of probability, P_X, of damage 94
B.4 Assessing the probability of damage to the wind turbine 95
B.4.1 Probability, P_{AT}, that a lightning flash to a wind turbine will cause dangerous touch and step voltage 95
B.4.2 Probability, P_{AD}, that a lightning flash to the wind turbine will cause injury to an exposed person on the structure 96
B.4.3 Probability, P_B, that a lightning flash to the wind turbine will cause physical damage 97
B.4.4 Probability, P_C, that a lightning flash to the wind turbine will cause failure of internal systems 98
B.4.5 Probability, P_M, that a lightning flash near the wind turbine will cause failure of internal systems 98
B.4.6 Probability, P_U, that a lightning flash to a service line will cause injury to human beings owing to touch voltage 98

B.4.7 Probability, P_V, that a lightning flash to a service line will cause physical damage 99
B.4.8 Probability, P_W, that a lightning flash to a service line will cause failure of internal systems 100
B.4.9 Probability, P_Z, that a lightning flash near an incoming service line will cause failure of internal systems 100
B.4.10 Probability P_P that a person will be in a dangerous place 101
B.4.11 Probability P_e that equipment will be exposed to damaging event 101
B.5 Assessing the amount of loss L_X in a wind turbine 101
B.5.1 General 101
B.5.2 Mean relative loss per dangerous event 101
Annex C (informative) Protection methods for blades 103
C.1 General 103
C.1.1 Types of blades and types of protection methods for blades 103
C.1.2 Blade damage mechanism 104
C.2 Protection methods 105
C.2.1 General 105
C.2.2 Lightning air-termination systems on the blade surface or embedded in the surface 106
C.2.3 Adhesive metallic tapes and segmented diverter strips 106
C.2.4 Internal down conductor systems 107
C.2.5 Conducting surface materials 107
C.3 CFRP structural components 108
C.4 Particular concerns with conducting components 109
C.5 Interception efficiency 110
C.6 Dimensioning of lightning protection systems 111
C.7 Blade-to-hub connection 113
C.8 WTG blade field exposure 114
C.8.1 General 114
C.8.2 Application 114
C.8.3 Field exposure 114
Annex D (normative) Test specifications 115
D.1 General 115
D.2 High-voltage strike attachment tests 115
D.2.1 Verification of air termination system effectiveness 115
D.2.2 Initial leader attachment test 115
D.2.3 Subsequent stroke attachment test 125
D.3 High-current physical damage tests 129
D.3.1 General 129
D.3.2 Arc entry test 129
D.3.3 Conducted current test 134
Annex E (informative) Application of lightning environment and lightning protection zones (LPZ) 139
E.1 Lightning environment for blades 139
E.1.1 Application 139
E.1.2 Examples of simplified lightning environment areas 139
E.1.3 Area transitions 141
E.2 Definition of lightning protection zones for turbines (not blades) 141
E.2.1 General 141
E.2.2 LPZ 0 142

E.2.3 Other zones 143
E.2.4 Zone boundaries 144
E.2.5 Zone protection requirements 145
Annex F (informative) Selection and installation of a coordinated SPD protection in wind turbines 148
F.1 Location of SPDs 148
F.2 Selection of SPDs 148
F.3 Installation of SPDs 148
F.4 Environmental stresses of SPDs 149
F.5 SPD status indication and SPD monitoring in case of an SPD failure 150
F.6 Selection of SPDs with regard to protection level (U_p) and system level immunity 150
F.7 Selection of SPDs with regard to overvoltages created within wind turbines 150
F.8 Selection of SPDs with regard to discharge current (I_n) and impulse current (I_{imp}) 150
Annex G (informative) Information on bonding and shielding and installation technique 152
G.1 Additional information on bonding 152
G.2 Additional information on shielding and installation technique 153
Annex H (informative) Testing methods for system level immunity tests 156
Annex I (informative) Earth termination system 161
I.1 General 161
I.1.1 Types of earthing systems 161
I.1.2 Construction 161
I.2 Electrode shape dimensions 163
I.2.1 Type of arrangement 163
I.2.2 Frequency dependence on earthing impedance 165
I.3 Earthing resistance expressions for different electrode configurations 166
Annex J (informative) Example of defined measuring points 169
Annex K (informative) Classification of lightning damage based on risk management 171
K.1 General 171
K.2 Lightning damage in blade 171
K.2.1 Classification of blade damage due to lightning 171
K.2.2 Possible cause of blade damage due to lightning 172
K.2.3 Countermeasures against blade damage due to lightning 173
K.3 Lightning damage to other components 175
K.3.1 Classification of damage in other components due to lightning 175
K.3.2 Countermeasures against lightning damage to other components 175
K.4 Typical lightning damage questionnaire 175
K.4.1 General 175
K.4.2 Sample of questionnaire 175
Annex L (informative) ~~Monitoring systems~~ Lightning detection and measurement systems 179
L.1 General 181
L.1.1 Purpose 181
L.1.2 Nomenclature 181
L.2 Benefits of lightning detection and measurement systems 181
L.3 Lightning detection and measurement systems 183
L.3.1 General 183
L.3.2 Lightning detection systems 183

L.3.3 Lightning measurement systems (LMS) 184
Annex M (informative) Guidelines for small wind turbines 191
Annex N (informative) Guidelines for verification of blade similarity 192
N.1 General 192
N.2 Similarity constraints 192
Annex O (informative) Guidelines for validation of numerical analysis methods 195
O.1 General 195
O.2 Blade voltage and current distribution 195
O.3 Indirect effects analysis 196
Annex P (informative) Testing of rotating components 197
P.1 General 197
P.2 Test specimen 197
P.2.1 Test specimen representing a stationary / quasi stationary bearing 197
P.2.2 Test specimen representing a rotating bearing 197
P.3 Test setup 197
P.3.1 Test set-up representing a stationary/quasi-stationary bearing 197
P.3.2 Test set-up representing a rotating bearing 198
P.4 Test procedure 199
P.5 Pass/fail criteria 200
Annex Q (informative) Earthing systems for wind farms 201
Bibliography 202

Figure 1 – Collection area of the wind turbine 31
Figure 2 – Example of collection area for a complete wind farm (A_{DWF}) with 10 wind turbines (black points) considering overlapping 31
Figure 4 – Examples of possible SPM (surge protection measures) 51
Figure 5 – Interconnecting two LPZ 1 using SPDs 52
Figure 6 – Interconnecting two LPZ 1 using shielded cables or shielded cable ducts 52
Figure 7 – Magnetic field inside an enclosure due to a long connection cable from enclosure entrance to the SPD 55
Figure 8 – Additional protective measures 56
Figure 9 – Examples of placement of HV arresters in two typical main electrical circuits of wind turbines 60
Figure A.1 – Processes involved in the formation of a downward initiated cloud-to-ground flash 76
Figure A.2 – Typical profile of a negative cloud-to-ground flash 77
Figure A.3 – Definitions of short stroke parameters (typically T_2 < 2 ms) 77
Figure A.4 – Definitions of long stroke parameters (typically 2 ms < T_{long} < 1 s) 78
Figure A.5 – Possible components of downward flashes (typical in flat territory and to lower structures) 80
Figure A.6 – Typical profile of a positive cloud-to-ground flash 81
Figure A.7 – Processes involved in the formation of an upward initiated cloud-to-ground flash during summer and winter conditions 81
Figure A.8 – Typical profile of a negative upward initiated flash 82
Figure A.9 – Possible components of upward flashes (typical to exposed and/or higher structures) 83
Figure B.1 – Winter lightning world map based on LLS data and weather conditions 88

Figure B.2 – Detailed winter lightning maps based on LLS data and weather conditions 89
Figure B.3 – Ratio *h/d* description 89
Figure C.1 – Types of wind turbine blades 103
Figure C.2 – Lightning protection concepts for large modern wind turbine blades 106
Figure C.3 – Voltages between lightning current path and sensor wiring due to the mutual coupling and the impedance of the current path 109
Figure D.1 – Example of initial leader attachment test setup A 117
Figure D.2 – Possible orientations for the initial leader attachment test setup A 118
Figure D.3 – Definition of the blade length axis during strike attachment tests 119
Figure D.4 – Example of the application of angles during the HV test 119
Figure D.5 – Example of leader connection point away from test specimen 120
Figure D.6 – Initial leader attachment test setup B 121
Figure D.7 – Typical switching impulse voltage rise to flashover (100 μs per division) 123
Figure D.8 – Subsequent stroke attachment test arrangement 126
Figure D.9 – Lightning impulse voltage waveform 127
Figure D.10 – Lightning impulse voltage chopped on the front 127
Figure D.11 – HV electrode positions for the subsequent stroke attachment test 129
Figure D.12 – High-current test arrangement for the arc entry test 131
Figure D.13 – Typical jet diverting test electrodes 132
Figure D.14 – Example of an arrangement for conducted current tests 136
Figure E.1 – Examples of generic blade lightning environment definition 140
Figure E.2 – Rolling sphere method applied on wind turbine 143
Figure E.3 – Mesh with large mesh dimension for nacelle with GFRP cover 144
Figure E.4 – Mesh with small mesh dimension for nacelle with GFRP cover 144
Figure E.5 – Two cabinets both defined as LPZ 2 connected via the shield of a shielded cable 145
Figure E.6 – Example: division of wind turbine into different lightning protection zones 146
Figure E.7 – Example of how to document a surge protection measures (SPM) system by division of the electrical system into protection zones with indication of where circuits cross LPZ boundaries and showing the long cables running between tower base and nacelle 147
Figure F.1 – Point-to-point installation scheme 149
Figure F.2 – Earthing connection installation scheme 149
Figure G.1 – Two control cabinets located on different metallic planes inside a nacelle 152
Figure G.2 – Magnetic coupling mechanism 153
Figure G.3 – Measuring of transfer impedance 155
Figure H.1 – Example circuit of a SPD discharge current test under service conditions 157
Figure H.2 – Typical test set-up for injection of test current 159
Figure H.3 – Example circuit of an induction test for lightning currents 160
Figure I.1 – Minimum length (l_1) of each earth electrode according to the class of LPS 164
Figure I.2 – Frequency dependence on the impedance to earth 165
Figure J.1 – Example of measuring points 169
Figure K.1 – Recommended countermeasures schemes according to the incident classification 173
Figure K.2 – Blade outlines for marking locations of damage 178

Figure L.1 – Example of flow chart for lightning detection and alarm output for LPS designs sensitive to charge transfer 190
Figure N.1 – Definitions of blade aerofoil nomenclature 194
Figure O.1 – Example geometry for blade voltage and current distribution simulations 195
Figure O.2 – Example geometry for nacelle indirect effects simulations 196
Figure P.1 – Possible test setup for a pitch bearing 197
Figure P.2 – Possible injection of test current into a pitch bearing 198
Figure P.3 – Possible test setup for a main bearing 199
Figure P.4 – Example measurement of the series resistance of the test sample 200

Table 1 – Maximum values of lightning parameters according to LPL (adapted from IEC 62305-1) 26
Table 2 – Minimum values of lightning parameters and related rolling sphere radius corresponding to LPL (adapted from IEC 62305-1) 27
Table 3 – Collection areas A_L and A_I of service line depending on whether aerial or buried 34
Table 4 – Parameters relevant to the assessment of risk components for wind turbine (corresponds to IEC 62305-2) 37
Table 5 – Verification of bearing and bearing protection design concepts 46
Table 6 – LPS General inspection intervals 72
Table A.1 – Cloud-to-ground lightning current parameters 79
Table A.2 – Upward initiated lightning current parameters 83
Table A.3 – Summary of the lightning threat parameters to be considered in the calculation of the test values for the different LPS components and for the different LPL 84
Table B.1 – Recommended values of individual location factors 87
Table B.2 – Range of upward lightning activity as a function of winter lightning activity for wind farm located in flat terrain 90
Table B.3 – Values of probability, P_A, that a lightning flash to a wind turbine will cause shock to human beings owing to dangerous touch and step voltages (corresponds to IEC 62305-2) 95
Table B.4 – Values of reduction factor r_t as a function of the type of surface of soil or floor (corresponds to IEC 62305-2) 95
Table B.5 – Values of factor P_o according to the position of a person in the exposed area (corresponds to IEC 62305-2) 96
Table B.6 – Values of probability, P_{LPS}, depending on the protection measures to protect the exposed areas of the wind turbine against direst lightning flash and to reduce physical damage (corresponds to IEC 62305-2) 96
Table B.7 – Values of probability P_S that a flash to a wind turbine will cause dangerous sparking (corresponds to IEC 62305-2) 97
Table B.8 – Values of reduction factor r_p as a function of provisions taken to reduce the consequences of fire (corresponds to IEC 62305-2) 97
Table B.9 – Values of reduction factor r_f as a function of risk of fire of the wind turbine (corresponds to IEC 62305-2) 97
Table B.10 – Values of probability P_{LI} depending on the line type and the impulse withstand voltage U_W of the equipment (corresponds to IEC 62305-2) 101
Table B.11 – Loss values for each zone (corresponds to IEC 62305-2) 102
Table B.12 – Typical mean values of L_T, L_D, L_F and L_O (corresponds to IEC 62305-2) 102

Table C.1 – Material, configuration and minimum nominal cross-sectional area of air-termination conductors, air-termination rods, earth lead-in rods and down conductors[a] (corresponds to IEC 62305-3) 111
Table C.2 – Physical characteristics of typical materials used in lightning protection systems (corresponds to IEC 62305-1) 112
Table C.3 – Temperature rise [K] for different conductors as a function of W/R (corresponds to IEC 62305-1) 113
Table C.4 – Range of distribution of direct strikes from field campaigns collecting data on attachment distribution vs. the distance from the tip of wind turbine blades, 39 m to 45 m blades with and without CFRP 114
Table D.1 – Test current parameters corresponding to LPL I 133
Table D.2 – Test current parameters for winter lightning exposure testing (duration maximum 1 s) 133
Table D.3 – Test current parameters corresponding to LPL I 137
Table D.4 – Test current parameters corresponding to LPL I (for flexible paths) 137
Table D.5 – Test current parameters for winter lightning exposure testing (duration maximum 1 s) 138
Table E.1 – Blade area definition for the example in concept A 141
Table E.2 – Blade area definition for the example in concept B 141
Table E.3 – Definition of lightning protection zones according to IEC 62305-1 142
Table F.1 – Discharge and impulse current levels for TN systems given in IEC 60364-5-53 151
Table F.2 – Example of increased discharge and impulse current levels for TN systems 151
Table I.1 – Impulse efficiency of several ground rod arrangements relative to a 12 m vertical ground rod (100 %) 166
Table I.2 – Symbols used in Tables I.3 to I.6 166
Table I.3 – Formulae for different earthing electrode configurations 167
Table I.4 – Formulae for buried ring electrode combined with vertical rods 167
Table I.5 – Formulae for buried ring electrode combined with radial electrodes 168
Table I.6 – Formulae for buried straight horizontal electrode combined with vertical rods 168
Table J.1 – Measuring points and resistances to be recorded 170
Table K.1 – Classification of blade damage due to lightning 172
Table K.2 – Matrix of blade damages due to lightning, taking account of risk management 174
Table K.3 – Classification of damage to other components due to lightning 175
Table L.1 – Considerations and benefits for the OEM (original equipment manufacturer) 182
Table L.2 – Considerations and benefits for owner and/or operator 182
Table L.3 – Considerations and benefits for the Insurance company 183
Table L.4 – Considerations relevant for lightning event counters and peak current sensors 184
Table L.5 – Requirement for each class of lightning measurement systems 185
Table N.1 – Items to be checked and verified when evaluating similarity 193
Table P.1 – Test sequence for high current testing of rotating components 200

INTERNATIONAL ELECTROTECHNICAL COMMISSION

_____

WIND ENERGY GENERATION SYSTEMS –

Part 24: Lightning protection

FOREWORD

1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
6) All users should ensure that they have the latest edition of this publication.
7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
9) IEC draws attention to the possibility that the implementation of this document may involve the use of (a) patent(s). IEC takes no position concerning the evidence, validity or applicability of any claimed patent rights in respect thereof. As of the date of publication of this document, IEC had not received notice of (a) patent(s), which may be required to implement this document. However, implementers are cautioned that this may not represent the latest information, which may be obtained from the patent database available at https://patents.iec.ch. IEC shall not be held responsible for identifying any or all such patent rights.

This consolidated version of the official IEC Standard and its amendment has been prepared for user convenience.

IEC 61400-24 edition 2.1 contains the second edition (2019-07) [documents 88/709/FDIS and 88/713/RVD] and its amendment 1 (2024-11) [documents 88/1040/FDIS and 88/1054/RVD].

In this Redline version, a vertical line in the margin shows where the technical content is modified by amendment 1. Additions are in green text, deletions are in strikethrough red text. A separate Final version with all changes accepted is available in this publication.

International Standard IEC 61400-24 has been prepared by IEC technical committee 88: Wind energy generation systems.

This second edition cancels and replaces the first edition, published in 2010. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

a) it is restructured with a main normative part, while informative information is placed in annexes.

This document has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all parts in the IEC 61400 series, published under the general title *Wind energy generation systems*, can be found on the IEC website.

The committee has decided that the contents of this document and its amendment will remain unchanged until the stability date indicated on the IEC website under webstore.iec.ch in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn, or
- revised.

IMPORTANT – The *'colour inside'* logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

INTRODUCTION to Amendment 1

This amendment to IEC 61400-24:2019 addresses an update of the content in Annex L regarding monitoring systems for detecting lightning strikes on wind turbines.

WIND ENERGY GENERATION SYSTEMS –

Part 24: Lightning protection

1 Scope

This part of IEC 61400 applies to lightning protection of wind turbine generators and wind power systems. Refer to Annex M guidelines for small wind turbines.

This document defines the lightning environment for wind turbines and risk assessment for wind turbines in that environment. It defines requirements for protection of blades, other structural components and electrical and control systems against both direct and indirect effects of lightning. Test methods to validate compliance are included.

Guidance on the use of applicable lightning protection, industrial electrical and EMC standards including earthing is provided.

Guidance regarding personal safety is provided.

Guidelines for damage statistics and reporting are provided.

Normative references are made to generic standards for lightning protection, low-voltage systems and high-voltage systems for machinery and installations and electromagnetic compatibility (EMC).

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60364-4-44, *Low-voltage electrical installations – Part 4-44: Protection for safety – Protection against voltage disturbances and electromagnetic disturbances*

IEC 60364-5-53, *Electrical installations of buildings – Part 5-53: Selection and erection of electrical equipment – Isolation, switching and control*

IEC 60364-5-54, *Low-voltage electrical installations – Part 5-54: Selection and erection of electrical equipment – Earthing arrangements and protective conductors*

IEC 60364-6, *Low-voltage electrical installations – Part 6: Verification*

IEC TS 60479-1, *Effects of current on human beings and livestock – Part 1: General aspects*

IEC TR 60479-4, *Effects of current on human beings and livestock – Part 4: Effects of lightning strokes*

IEC 60664-1, *Insulation coordination for equipment within low-voltage systems – Part 1: Principles, requirements and tests*

IEC 61000 (all parts), *Electromagnetic compatibility (EMC)*

IEC 61000-4-5, *Electromagnetic compatibility (EMC) – Part 4-5: Testing and measurement techniques – Surge immunity test*

IEC 61000-4-9, *Electromagnetic compatibility (EMC) – Part 4-9: Testing and measurement techniques – Impulse magnetic field immunity test*

IEC 61000-4-10, *Electromagnetic compatibility (EMC) – Part 4-10: Testing and measurement techniques – Damped oscillatory magnetic field immunity test*

IEC TR 61000-5-2, *Electromagnetic compatibility (EMC) – Part 5: Installation and mitigation guidelines – Section 2: Earthing and cabling*

IEC 61400-23, *Wind turbine generator systems – Part 23: Full-scale structural testing of rotor blades*

IEC 61587-3, *Mechanical structures for electronic equipment – Tests for IEC 60917 and IEC 60297 – Part 3: Electromagnetic shielding performance tests for cabinets and subracks*

IEC 61643-11, *Low-voltage surge protective devices – Part 11: Surge protective devices connected to low-voltage power distribution systems – Requirements and test methods*

IEC 61643-12, *Low-voltage surge protective devices – Part 12: Surge protective devices connected to low-voltage power distribution systems – Selection and application principles*

IEC 61643-21, *Low voltage surge protective devices – Part 21: Surge protective devices connected to telecommunications and signalling networks – Performance requirements and testing methods*

IEC 61643-22, *Low-voltage surge protective devices – Part 22: Surge protective devices connected to telecommunications and signalling networks – Selection and application principles*

IEC 61936-1, *Power installations exceeding 1 kV a.c. – Part 1: Common rules*

IEC TS 61936-2, *Power installations exceeding 1 kV a.c. and 1,5 kV d.c. – Part 2: d.c.*

IEC 62305-1:2010, *Protection against lightning – Part 1: General principles*

IEC 62305-2:2010, *Protection against lightning – Part 2: Risk management*

IEC 62305-3:2010, *Protection against lightning – Part 3: Physical damage to structures and life hazard*

IEC 62305-4:2010, *Protection against lightning – Part 4: Electrical and electronic systems within structures*

IECRE OD-501, *Type and Component Certification Scheme (wind turbines)*

ITU-T K.20, *Resistibility of telecommunication equipment installed in a telecommunications centre to overvoltages and overcurrents*

ITU-T K.21, *Resistibility of telecommunications equipment installed in customer premises to overvoltages and overcurrents*

CONTENTS

FOREWORD 11
INTRODUCTION to Amendment 1 13
1 Scope 14
2 Normative references 14
3 Terms and definitions 16
4 Symbols and units 22
5 Abbreviated terms 25
6 Lightning environment for wind turbine 26
6.1 General 26
6.2 Lightning current parameters and lightning protection levels (LPL) 26
7 Lightning exposure assessment 27
7.1 General 27
7.2 Assessing the frequency of lightning affecting a single wind turbine or a group of wind turbines 29
7.2.1 Categorization of lightning events 29
7.2.2 Estimation of average number of lightning flashes to a single or a group of wind turbines 29
7.2.3 Estimation of average annual number of lightning flashes near the wind turbine (N_M) 32
7.2.4 Estimation of average annual number of lightning flashes to the service lines connecting the wind turbines (N_L) 32
7.2.5 Estimation of average annual number of lightning flashes near the service lines connecting the wind turbine (N_I) 33
7.3 Assessing the risk of damage 34
7.3.1 Basic equation 34
7.3.2 Assessment of risk components due to flashes to the wind turbine (S1) 35
7.3.3 Assessment of the risk component due to flashes near the wind turbine (S2) 35
7.3.4 Assessment of risk components due to flashes to a service line connected to the wind turbine (S3) 36
7.3.5 Assessment of risk component due to flashes near a service line connected to the wind turbine (S4) 36
8 Lightning protection of subcomponents 37
8.1 General 37
8.1.1 Lightning protection level (LPL) 37
8.1.2 Lightning protection zones (LPZ) 38
8.2 Blades 38
8.2.1 General 38
8.2.2 Requirements 38
8.2.3 Verification 39
8.2.4 Protection design considerations 39
8.2.5 Test methods 42
8.3 Nacelle and other structural components 43
8.3.1 General 43
8.3.2 Hub 43
8.3.3 Spinner 43
8.3.4 Nacelle 44
8.3.5 Tower 44

8.3.6 Verification methods 45
8.4 Mechanical drive train and yaw system 45
8.4.1 General 45
8.4.2 Bearings 45
8.4.3 Hydraulic systems 46
8.4.4 Spark gaps and sliding contacts 47
8.4.5 Verification 47
8.5 Electrical low-voltage systems and electronic systems and installations 48
8.5.1 General 48
8.5.2 Equipotential bonding within the wind turbine 52
8.5.3 LEMP protection and immunity levels 53
8.5.4 Shielding and line routing 54
8.5.5 SPD protection 55
8.5.6 Testing methods for system immunity tests 59
8.6 Electrical high-voltage (HV) power systems 59
9 Earthing of wind turbines 61
9.1 General 61
9.1.1 Purpose and scope 61
9.1.2 Basic requirements 61
9.1.3 Earth electrode arrangements 61
9.1.4 Earthing system impedance 62
9.2 Equipotential bonding 62
9.2.1 General 62
9.2.2 Lightning equipotential bonding for metal installations 62
9.3 Structural components 63
9.3.1 General 63
9.3.2 Metal tubular type tower 63
9.3.3 Metal reinforced concrete towers 63
9.3.4 Lattice tower 63
9.3.5 Systems inside the tower 64
9.3.6 Concrete foundation 64
9.3.7 Rocky area foundation 64
9.3.8 Metal mono-pile foundation 65
9.3.9 Offshore foundation 65
9.4 Electrode shape dimensions 65
9.5 Execution and maintenance of the earthing system 66
10 Personal safety 66
11 Documentation of lightning protection system 68
11.1 General 68
11.2 Documentation necessary during assessment for design evaluation 68
11.2.1 General 68
11.2.2 General documentation 68
11.2.3 Documentation for rotor blades 69
11.2.4 Documentation of mechanical systems 69
11.2.5 Documentation of electrical and electronic systems 69
11.2.6 Documentation of earthing and bonding systems 69
11.2.7 Documentation of nacelle cover, hub and tower lightning protection systems 69
11.3 Site-specific information 70

11.4 Documentation to be provided in the manuals for LPS inspections 70
11.5 Manuals 70
12 Inspection of lightning protection system 70
12.1 Scope of inspection 70
12.2 Order of inspections 71
12.2.1 General 71
12.2.2 Inspection during production of the wind turbine 71
12.2.3 Inspection during installation of the wind turbine 71
12.2.4 Inspection during commissioning of the wind turbine and periodic inspection 71
12.2.5 Inspection after dismantling or repair of main parts 72
12.3 Maintenance 73
Annex A (informative) The lightning phenomenon in relation to wind turbines 74
A.1 Lightning environment for wind turbines 74
A.1.1 General 74
A.1.2 The properties of lightning 74
A.1.3 Lightning discharge formation and electrical parameters 74
A.1.4 Cloud-to-ground flashes 75
A.1.5 Upward initiated flashes 81
A.2 Lightning current parameters relevant to the point of strike 84
A.3 Leader current without return stroke 85
A.4 Lightning electromagnetic impulse, LEMP, effects 85
Annex B (informative) Lightning exposure assessment 86
B.1 General 86
B.2 Methodology to estimate the average annual flashes or strokes to the wind turbines of a wind farm and upward lightning activity in wind turbines 86
B.2.1 General 86
B.2.2 Methodology to determine average annual flashes to turbines of a wind farm estimation by increase of the location factor to consider upward lightning from wind turbines 86
B.2.3 Upward lightning percentage in wind farms 90
B.3 Explanation of terms 90
B.3.1 Damage and loss 90
B.3.2 Composition of risk 92
B.3.3 Assessment of risk components 92
B.3.4 Frequency of damage 93
B.3.5 Assessment of probability, P_X, of damage 94
B.4 Assessing the probability of damage to the wind turbine 95
B.4.1 Probability, P_{AT}, that a lightning flash to a wind turbine will cause dangerous touch and step voltage 95
B.4.2 Probability, P_{AD}, that a lightning flash to the wind turbine will cause injury to an exposed person on the structure 96
B.4.3 Probability, P_B, that a lightning flash to the wind turbine will cause physical damage 97
B.4.4 Probability, P_C, that a lightning flash to the wind turbine will cause failure of internal systems 98
B.4.5 Probability, P_M, that a lightning flash near the wind turbine will cause failure of internal systems 98
B.4.6 Probability, P_U, that a lightning flash to a service line will cause injury to human beings owing to touch voltage 98

B.4.7 Probability, P_V, that a lightning flash to a service line will cause physical damage 99
B.4.8 Probability, P_W, that a lightning flash to a service line will cause failure of internal systems 100
B.4.9 Probability, P_Z, that a lightning flash near an incoming service line will cause failure of internal systems 100
B.4.10 Probability P_P that a person will be in a dangerous place 101
B.4.11 Probability P_e that equipment will be exposed to damaging event 101
B.5 Assessing the amount of loss L_X in a wind turbine 101
B.5.1 General 101
B.5.2 Mean relative loss per dangerous event 101
Annex C (informative) Protection methods for blades 103
C.1 General 103
C.1.1 Types of blades and types of protection methods for blades 103
C.1.2 Blade damage mechanism 104
C.2 Protection methods 105
C.2.1 General 105
C.2.2 Lightning air-termination systems on the blade surface or embedded in the surface 106
C.2.3 Adhesive metallic tapes and segmented diverter strips 106
C.2.4 Internal down conductor systems 107
C.2.5 Conducting surface materials 107
C.3 CFRP structural components 108
C.4 Particular concerns with conducting components 109
C.5 Interception efficiency 110
C.6 Dimensioning of lightning protection systems 111
C.7 Blade-to-hub connection 113
C.8 WTG blade field exposure 114
C.8.1 General 114
C.8.2 Application 114
C.8.3 Field exposure 114
Annex D (normative) Test specifications 115
D.1 General 115
D.2 High-voltage strike attachment tests 115
D.2.1 Verification of air termination system effectiveness 115
D.2.2 Initial leader attachment test 115
D.2.3 Subsequent stroke attachment test 125
D.3 High-current physical damage tests 129
D.3.1 General 129
D.3.2 Arc entry test 129
D.3.3 Conducted current test 134
Annex E (informative) Application of lightning environment and lightning protection zones (LPZ) 139
E.1 Lightning environment for blades 139
E.1.1 Application 139
E.1.2 Examples of simplified lightning environment areas 139
E.1.3 Area transitions 141
E.2 Definition of lightning protection zones for turbines (not blades) 141
E.2.1 General 141
E.2.2 LPZ 0 142

E.2.3 Other zones 143
E.2.4 Zone boundaries 144
E.2.5 Zone protection requirements 145
Annex F (informative) Selection and installation of a coordinated SPD protection in wind turbines 148
F.1 Location of SPDs 148
F.2 Selection of SPDs 148
F.3 Installation of SPDs 148
F.4 Environmental stresses of SPDs 149
F.5 SPD status indication and SPD monitoring in case of an SPD failure 150
F.6 Selection of SPDs with regard to protection level (U_p) and system level immunity 150
F.7 Selection of SPDs with regard to overvoltages created within wind turbines 150
F.8 Selection of SPDs with regard to discharge current (I_n) and impulse current (I_{imp}) 150
Annex G (informative) Information on bonding and shielding and installation technique 152
G.1 Additional information on bonding 152
G.2 Additional information on shielding and installation technique 153
Annex H (informative) Testing methods for system level immunity tests 156
Annex I (informative) Earth termination system 161
I.1 General 161
I.1.1 Types of earthing systems 161
I.1.2 Construction 161
I.2 Electrode shape dimensions 163
I.2.1 Type of arrangement 163
I.2.2 Frequency dependence on earthing impedance 165
I.3 Earthing resistance expressions for different electrode configurations 166
Annex J (informative) Example of defined measuring points 169
Annex K (informative) Classification of lightning damage based on risk management 171
K.1 General 171
K.2 Lightning damage in blade 171
K.2.1 Classification of blade damage due to lightning 171
K.2.2 Possible cause of blade damage due to lightning 172
K.2.3 Countermeasures against blade damage due to lightning 173
K.3 Lightning damage to other components 175
K.3.1 Classification of damage in other components due to lightning 175
K.3.2 Countermeasures against lightning damage to other components 175
K.4 Typical lightning damage questionnaire 175
K.4.1 General 175
K.4.2 Sample of questionnaire 175
Annex L (informative) Lightning detection and measurement systems 179
L.1 General 179
L.1.1 Purpose 179
L.1.2 Nomenclature 179
L.2 Benefits of lightning detection and measurement systems 179
L.3 Lightning detection and measurement systems 181
L.3.1 General 181
L.3.2 Lightning detection systems 181
L.3.3 Lightning measurement systems (LMS) 182

Annex M (informative) Guidelines for small wind turbines 189
Annex N (informative) Guidelines for verification of blade similarity 190
N.1 General 190
N.2 Similarity constraints 190
Annex O (informative) Guidelines for validation of numerical analysis methods 193
O.1 General 193
O.2 Blade voltage and current distribution 193
O.3 Indirect effects analysis 194
Annex P (informative) Testing of rotating components 195
P.1 General 195
P.2 Test specimen 195
P.2.1 Test specimen representing a stationary / quasi stationary bearing 195
P.2.2 Test specimen representing a rotating bearing 195
P.3 Test setup 195
P.3.1 Test set-up representing a stationary/quasi-stationary bearing 195
P.3.2 Test set-up representing a rotating bearing 196
P.4 Test procedure 197
P.5 Pass/fail criteria 198
Annex Q (informative) Earthing systems for wind farms 199
Bibliography 200

Figure 1 – Collection area of the wind turbine 31
Figure 2 – Example of collection area for a complete wind farm (A_{DWF}) with 10 wind turbines (black points) considering overlapping 31
Figure 4 – Examples of possible SPM (surge protection measures) 51
Figure 5 – Interconnecting two LPZ 1 using SPDs 52
Figure 6 – Interconnecting two LPZ 1 using shielded cables or shielded cable ducts 52
Figure 7 – Magnetic field inside an enclosure due to a long connection cable from enclosure entrance to the SPD 55
Figure 8 – Additional protective measures 56
Figure 9 – Examples of placement of HV arresters in two typical main electrical circuits of wind turbines 60
Figure A.1 – Processes involved in the formation of a downward initiated cloud-to-ground flash 76
Figure A.2 – Typical profile of a negative cloud-to-ground flash 77
Figure A.3 – Definitions of short stroke parameters (typically $T_2 < 2$ ms) 77
Figure A.4 – Definitions of long stroke parameters (typically 2 ms $< T_{long} <$ 1 s) 78
Figure A.5 – Possible components of downward flashes (typical in flat territory and to lower structures) 80
Figure A.6 – Typical profile of a positive cloud-to-ground flash 81
Figure A.7 – Processes involved in the formation of an upward initiated cloud-to-ground flash during summer and winter conditions 81
Figure A.8 – Typical profile of a negative upward initiated flash 82
Figure A.9 – Possible components of upward flashes (typical to exposed and/or higher structures) 83
Figure B.1 – Winter lightning world map based on LLS data and weather conditions 88
Figure B.2 – Detailed winter lightning maps based on LLS data and weather conditions 89

Figure B.3 – Ratio *h/d* description 89
Figure C.1 – Types of wind turbine blades 103
Figure C.2 – Lightning protection concepts for large modern wind turbine blades 106
Figure C.3 – Voltages between lightning current path and sensor wiring due to the mutual coupling and the impedance of the current path 109
Figure D.1 – Example of initial leader attachment test setup A 117
Figure D.2 – Possible orientations for the initial leader attachment test setup A 118
Figure D.3 – Definition of the blade length axis during strike attachment tests 119
Figure D.4 – Example of the application of angles during the HV test 119
Figure D.5 – Example of leader connection point away from test specimen 120
Figure D.6 – Initial leader attachment test setup B 121
Figure D.7 – Typical switching impulse voltage rise to flashover (100 μs per division) 123
Figure D.8 – Subsequent stroke attachment test arrangement 126
Figure D.9 – Lightning impulse voltage waveform 127
Figure D.10 – Lightning impulse voltage chopped on the front 127
Figure D.11 – HV electrode positions for the subsequent stroke attachment test 129
Figure D.12 – High-current test arrangement for the arc entry test 131
Figure D.13 – Typical jet diverting test electrodes 132
Figure D.14 – Example of an arrangement for conducted current tests 136
Figure E.1 – Examples of generic blade lightning environment definition 140
Figure E.2 – Rolling sphere method applied on wind turbine 143
Figure E.3 – Mesh with large mesh dimension for nacelle with GFRP cover 144
Figure E.4 – Mesh with small mesh dimension for nacelle with GFRP cover 144
Figure E.5 – Two cabinets both defined as LPZ 2 connected via the shield of a shielded cable 145
Figure E.6 – Example: division of wind turbine into different lightning protection zones 146
Figure E.7 – Example of how to document a surge protection measures (SPM) system by division of the electrical system into protection zones with indication of where circuits cross LPZ boundaries and showing the long cables running between tower base and nacelle 147
Figure F.1 – Point-to-point installation scheme 149
Figure F.2 – Earthing connection installation scheme 149
Figure G.1 – Two control cabinets located on different metallic planes inside a nacelle 152
Figure G.2 – Magnetic coupling mechanism 153
Figure G.3 – Measuring of transfer impedance 155
Figure H.1 – Example circuit of a SPD discharge current test under service conditions 157
Figure H.2 – Typical test set-up for injection of test current 159
Figure H.3 – Example circuit of an induction test for lightning currents 160
Figure I.1 – Minimum length (l_1) of each earth electrode according to the class of LPS 164
Figure I.2 – Frequency dependence on the impedance to earth 165
Figure J.1 – Example of measuring points 169
Figure K.1 – Recommended countermeasures schemes according to the incident classification 173
Figure K.2 – Blade outlines for marking locations of damage 178

Figure L.1 – Example of flow chart for lightning detection and alarm output for LPS designs sensitive to charge transfer 188
Figure N.1 – Definitions of blade aerofoil nomenclature 192
Figure O.1 – Example geometry for blade voltage and current distribution simulations 193
Figure O.2 – Example geometry for nacelle indirect effects simulations 194
Figure P.1 – Possible test setup for a pitch bearing 195
Figure P.2 – Possible injection of test current into a pitch bearing 196
Figure P.3 – Possible test setup for a main bearing 197
Figure P.4 – Example measurement of the series resistance of the test sample 198

Table 1 – Maximum values of lightning parameters according to LPL (adapted from IEC 62305-1) 26
Table 2 – Minimum values of lightning parameters and related rolling sphere radius corresponding to LPL (adapted from IEC 62305-1) 27
Table 3 – Collection areas A_L and A_I of service line depending on whether aerial or buried 34
Table 4 – Parameters relevant to the assessment of risk components for wind turbine (corresponds to IEC 62305-2) 37
Table 5 – Verification of bearing and bearing protection design concepts 46
Table 6 – LPS General inspection intervals 72
Table A.1 – Cloud-to-ground lightning current parameters 79
Table A.2 – Upward initiated lightning current parameters 83
Table A.3 – Summary of the lightning threat parameters to be considered in the calculation of the test values for the different LPS components and for the different LPL 84
Table B.1 – Recommended values of individual location factors 87
Table B.2 – Range of upward lightning activity as a function of winter lightning activity for wind farm located in flat terrain 90
Table B.3 – Values of probability, P_A, that a lightning flash to a wind turbine will cause shock to human beings owing to dangerous touch and step voltages (corresponds to IEC 62305-2) 95
Table B.4 – Values of reduction factor r_t as a function of the type of surface of soil or floor (corresponds to IEC 62305-2) 95
Table B.5 – Values of factor P_o according to the position of a person in the exposed area (corresponds to IEC 62305-2) 96
Table B.6 – Values of probability, P_{LPS}, depending on the protection measures to protect the exposed areas of the wind turbine against direst lightning flash and to reduce physical damage (corresponds to IEC 62305-2) 96
Table B.7 – Values of probability P_S that a flash to a wind turbine will cause dangerous sparking (corresponds to IEC 62305-2) 97
Table B.8 – Values of reduction factor r_p as a function of provisions taken to reduce the consequences of fire (corresponds to IEC 62305-2) 97
Table B.9 – Values of reduction factor r_f as a function of risk of fire of the wind turbine (corresponds to IEC 62305-2) 97
Table B.10 – Values of probability P_{LI} depending on the line type and the impulse withstand voltage U_W of the equipment (corresponds to IEC 62305-2) 101
Table B.11 – Loss values for each zone (corresponds to IEC 62305-2) 102
Table B.12 – Typical mean values of L_T, L_D, L_F and L_O (corresponds to IEC 62305-2) 102

Table C.1 – Material, configuration and minimum nominal cross-sectional area of air-termination conductors, air-termination rods, earth lead-in rods and down conductors[a] (corresponds to IEC 62305-3) 111
Table C.2 – Physical characteristics of typical materials used in lightning protection systems (corresponds to IEC 62305-1) 112
Table C.3 – Temperature rise [K] for different conductors as a function of W/R (corresponds to IEC 62305-1) 113
Table C.4 – Range of distribution of direct strikes from field campaigns collecting data on attachment distribution vs. the distance from the tip of wind turbine blades, 39 m to 45 m blades with and without CFRP 114
Table D.1 – Test current parameters corresponding to LPL I 133
Table D.2 – Test current parameters for winter lightning exposure testing (duration maximum 1 s) 133
Table D.3 – Test current parameters corresponding to LPL I 137
Table D.4 – Test current parameters corresponding to LPL I (for flexible paths) 137
Table D.5 – Test current parameters for winter lightning exposure testing (duration maximum 1 s) 138
Table E.1 – Blade area definition for the example in concept A 141
Table E.2 – Blade area definition for the example in concept B 141
Table E.3 – Definition of lightning protection zones according to IEC 62305-1 142
Table F.1 – Discharge and impulse current levels for TN systems given in IEC 60364-5-53 151
Table F.2 – Example of increased discharge and impulse current levels for TN systems 151
Table I.1 – Impulse efficiency of several ground rod arrangements relative to a 12 m vertical ground rod (100 %) 166
Table I.2 – Symbols used in Tables I.3 to I.6 166
Table I.3 – Formulae for different earthing electrode configurations 167
Table I.4 – Formulae for buried ring electrode combined with vertical rods 167
Table I.5 – Formulae for buried ring electrode combined with radial electrodes 168
Table I.6 – Formulae for buried straight horizontal electrode combined with vertical rods 168
Table J.1 – Measuring points and resistances to be recorded 170
Table K.1 – Classification of blade damage due to lightning 172
Table K.2 – Matrix of blade damages due to lightning, taking account of risk management 174
Table K.3 – Classification of damage to other components due to lightning 175
Table L.1 – Considerations and benefits for the OEM (original equipment manufacturer) 180
Table L.2 – Considerations and benefits for owner and/or operator 180
Table L.3 – Considerations and benefits for the Insurance company 181
Table L.4 – Considerations relevant for lightning event counters and peak current sensors 182
Table L.5 – Requirement for each class of lightning measurement systems 183
Table N.1 – Items to be checked and verified when evaluating similarity 191
Table P.1 – Test sequence for high current testing of rotating components 198

© IEC 2024

INTERNATIONAL ELECTROTECHNICAL COMMISSION

_____

WIND ENERGY GENERATION SYSTEMS –

Part 24: Lightning protection

FOREWORD

1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
6) All users should ensure that they have the latest edition of this publication.
7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
9) IEC draws attention to the possibility that the implementation of this document may involve the use of (a) patent(s). IEC takes no position concerning the evidence, validity or applicability of any claimed patent rights in respect thereof. As of the date of publication of this document, IEC had not received notice of (a) patent(s), which may be required to implement this document. However, implementers are cautioned that this may not represent the latest information, which may be obtained from the patent database available at https://patents.iec.ch. IEC shall not be held responsible for identifying any or all such patent rights.

This consolidated version of the official IEC Standard and its amendment has been prepared for user convenience.

IEC 61400-24 edition 2.1 contains the second edition (2019-07) [documents 88/709/FDIS and 88/713/RVD] and its amendment 1 (2024-11) [documents 88/1040/FDIS and 88/1054/RVD].

This Final version does not show where the technical content is modified by amendment 1. A separate Redline version with all changes highlighted is available in this publication.

International Standard IEC 61400-24 has been prepared by IEC technical committee 88: Wind energy generation systems.

This second edition cancels and replaces the first edition, published in 2010. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

a) it is restructured with a main normative part, while informative information is placed in annexes.

This document has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all parts in the IEC 61400 series, published under the general title *Wind energy generation systems*, can be found on the IEC website.

The committee has decided that the contents of this document and its amendment will remain unchanged until the stability date indicated on the IEC website under webstore.iec.ch in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn, or
- revised.

IMPORTANT – The *'colour inside'* logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

INTRODUCTION to Amendment 1

This amendment to IEC 61400-24:2019 addresses an update of the content in Annex L regarding monitoring systems for detecting lightning strikes on wind turbines.

WIND ENERGY GENERATION SYSTEMS –

Part 24: Lightning protection

1 Scope

This part of IEC 61400 applies to lightning protection of wind turbine generators and wind power systems. Refer to Annex M guidelines for small wind turbines.

This document defines the lightning environment for wind turbines and risk assessment for wind turbines in that environment. It defines requirements for protection of blades, other structural components and electrical and control systems against both direct and indirect effects of lightning. Test methods to validate compliance are included.

Guidance on the use of applicable lightning protection, industrial electrical and EMC standards including earthing is provided.

Guidance regarding personal safety is provided.

Guidelines for damage statistics and reporting are provided.

Normative references are made to generic standards for lightning protection, low-voltage systems and high-voltage systems for machinery and installations and electromagnetic compatibility (EMC).

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60364-4-44, *Low-voltage electrical installations – Part 4-44: Protection for safety – Protection against voltage disturbances and electromagnetic disturbances*

IEC 60364-5-53, *Electrical installations of buildings – Part 5-53: Selection and erection of electrical equipment – Isolation, switching and control*

IEC 60364-5-54, *Low-voltage electrical installations – Part 5-54: Selection and erection of electrical equipment – Earthing arrangements and protective conductors*

IEC 60364-6, *Low-voltage electrical installations – Part 6: Verification*

IEC TS 60479-1, *Effects of current on human beings and livestock – Part 1: General aspects*

IEC TR 60479-4, *Effects of current on human beings and livestock – Part 4: Effects of lightning strokes*

IEC 60664-1, *Insulation coordination for equipment within low-voltage systems – Part 1: Principles, requirements and tests*

IEC 61000 (all parts), *Electromagnetic compatibility (EMC)*

IEC 61000-4-5, *Electromagnetic compatibility (EMC) – Part 4-5: Testing and measurement techniques – Surge immunity test*

IEC 61000-4-9, *Electromagnetic compatibility (EMC) – Part 4-9: Testing and measurement techniques – Impulse magnetic field immunity test*

IEC 61000-4-10, *Electromagnetic compatibility (EMC) – Part 4-10: Testing and measurement techniques – Damped oscillatory magnetic field immunity test*

IEC TR 61000-5-2, *Electromagnetic compatibility (EMC) – Part 5: Installation and mitigation guidelines – Section 2: Earthing and cabling*

IEC 61400-23, *Wind turbine generator systems – Part 23: Full-scale structural testing of rotor blades*

IEC 61587-3, *Mechanical structures for electronic equipment – Tests for IEC 60917 and IEC 60297 – Part 3: Electromagnetic shielding performance tests for cabinets and subracks*

IEC 61643-11, *Low-voltage surge protective devices – Part 11: Surge protective devices connected to low-voltage power distribution systems – Requirements and test methods*

IEC 61643-12, *Low-voltage surge protective devices – Part 12: Surge protective devices connected to low-voltage power distribution systems – Selection and application principles*

IEC 61643-21, *Low voltage surge protective devices – Part 21: Surge protective devices connected to telecommunications and signalling networks – Performance requirements and testing methods*

IEC 61643-22, *Low-voltage surge protective devices – Part 22: Surge protective devices connected to telecommunications and signalling networks – Selection and application principles*

IEC 61936-1, *Power installations exceeding 1 kV a.c. – Part 1: Common rules*

IEC TS 61936-2, *Power installations exceeding 1 kV a.c. and 1,5 kV d.c. – Part 2: d.c.*

IEC 62305-1:2010, *Protection against lightning – Part 1: General principles*

IEC 62305-2:2010, *Protection against lightning – Part 2: Risk management*

IEC 62305-3:2010, *Protection against lightning – Part 3: Physical damage to structures and life hazard*

IEC 62305-4:2010, *Protection against lightning – Part 4: Electrical and electronic systems within structures*

IECRE OD-501, *Type and Component Certification Scheme (wind turbines)*

ITU-T K.20, *Resistibility of telecommunication equipment installed in a telecommunications centre to overvoltages and overcurrents*

ITU-T K.21, *Resistibility of telecommunications equipment installed in customer premises to overvoltages and overcurrents*