IEC 61558-2-20

Edition 3.0 2022-12
REDLINE VERSION

INTERNATIONAL STANDARD

colour inside

GROUP SAFETY PUBLICATION

Safety of transformers, reactors, power supply units and combinations thereof – Part 2-20: Particular requirements and tests for small reactors



IEC 61558-2-20:2022-12 RLV(en)



THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2022 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

IEC Secretariat
3, rue de Varembé
CH-1211 Geneva 20
Switzerland

Tel.: +41 22 919 02 11
info@iec.ch
www.iec.ch

About the IEC
The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications
The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigendum or an amendment might have been published.

IEC publications search - webstore.iec.ch/advsearchform
The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee, …). It also gives information on projects, replaced and withdrawn publications.

IEC Just Published - webstore.iec.ch/justpublished
Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and once a month by email.

IEC Customer Service Centre - webstore.iec.ch/csc
If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: sales@iec.ch.

IEC Products & Services Portal - products.iec.ch
Discover our powerful search engine and read freely all the publications previews. With a subscription you will always have access to up to date content tailored to your needs.

Electropedia - www.electropedia.org
The world's leading online dictionary on electrotechnology, containing more than 22 300 terminological entries in English and French, with equivalent terms in 19 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

IEC 61558-2-20

Edition 3.0 2022-12
REDLINE VERSION

INTERNATIONAL STANDARD

colour inside

GROUP SAFETY PUBLICATION

Safety of transformers, reactors, power supply units and combinations thereof – Part 2-20: Particular requirements and tests for small reactors

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

ICS 29.180

ISBN 978-2-8322-6233-7

Warning! Make sure that you obtained this publication from an authorized distributor.

® Registered trademark of the International Electrotechnical Commission

CONTENTS

FOREWORD 3
INTRODUCTION 2
1 Scope 7
2 Normative references 8
3 Terms and definitions 8
4 General requirements 11
5 General notes on tests 11
6 Ratings 11
7 Classification 11
8 Marking and other information 12
9 Protection against electric shock 15
10 Change of voltage setting 15
11 Voltage drop 15
12 No-load output voltage 15
13 Short-circuit voltage 16
14 Heating 16
15 Short-circuit and overload protection 16
16 Mechanical strength 18
17 Protection against harmful ingress of dust, solid objects and moisture 18
18 Insulation resistance, dielectric strength and leakage current 18
19 Construction 18
20 Components 19
21 Internal wiring 19
22 Supply connection and other external flexible cable or cords 19
23 Terminals for external conductors 19
24 Provisions for protective earthing 19
25 Screws and connections 19
26 Creepage distances, clearances and distances through insulation 20
27 Resistance to heat, fire and tracking 20
28 Resistance to rusting 20
Annexes 21
Annex AA (informative) Characteristic parameter measurements 21
Annex BB (normative) Particular requirements for associated reactors with frequencies > 500 Hz 21
Annex CC (normative) Partial discharge (PD) test 23
Bibliography 24

Table 101 – Symbols indicating the kind of transformer 14

INTERNATIONAL ELECTROTECHNICAL COMMISSION

_____

SAFETY OF TRANSFORMERS, REACTORS, POWER SUPPLY UNITS AND COMBINATIONS THEREOF –

Part 2-20: Particular requirements and tests for small reactors

FOREWORD

1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
6) All users should ensure that they have the latest edition of this publication.
7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

This redline version of the official IEC Standard allows the user to identify the changes made to the previous edition IEC 61558-2-20:2010. A vertical bar appears in the margin wherever a change has been made. Additions are in green text, deletions are in strikethrough red text.

IEC 61558-2-20 has been prepared by IEC technical committee 96: Transformers, reactors, power supply units and combinations thereof. It is an International Standard.

This third edition cancels and replaces the second edition published in 2010. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

a) Adjustment of structure and references in accordance with IEC 61558-1:2017.
b) Additional Annex AA with references for characteristic parameter measurements.
c) Additional Annex BB for associated reactors with frequencies above 500 Hz.
d) Additional Annex CC for partial discharge.

The text of this International Standard is based on the following documents:

Draft	Report on voting
96/556/FDIS	96/564/RVD

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

The language used for the development of this International Standard is English.

This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available at www.iec.ch/members_experts/refdocs. The main document types developed by IEC are described in greater detail at www.iec.ch/publications.

It has the status of a group safety publication in accordance with IEC Guide 104.

This International Standard is to be used in conjunction with IEC 61558-1:2017.

This document supplements or modifies the corresponding clauses in IEC 61558-1:2017, so as to convert that publication into the IEC standard: *Particular requirements and tests for small reactors.*

A list of all parts in the IEC 61558 series published under the general title *Safety of transformers, reactors, power supply units and combinations thereof,* can be found on the IEC website.

Future standards in this series will carry the new general title as cited above. Titles of existing standards in this series will be updated at the time of the next edition.

Where this document states *"addition", "modification"* or *"replacement"*, the relevant text of IEC 61558-1:2017 is to be adopted accordingly.

In this document, the following print types are used:

– requirements proper: in roman type;
– *test specifications: in italic type;*
– explanatory matter: in smaller roman type.

In the text of this document, the words in **bold** are defined in Clause 3.

Subclauses, notes, figures and tables additional to those in IEC 61558-1:2017 are numbered starting from 101; supplementary annexes are entitled AA, BB, etc.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under webstore.iec.ch in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

IMPORTANT – The "colour inside" logo on the cover page of this document indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

INTRODUCTION

IEC TC 96 has a group safety function in accordance with IEC Guide 104 for transformers other than those intended to supply distribution networks, in particular transformers and power supply units intended to allow the application of protective measures against electric shock as defined by TC 64, but in certain cases including the limitation of voltage and horizontal safety function for SELV, in accordance with IEC 60364-4-41.

The group safety function (GSF) is used because of responsibility for safety extra-low voltage (SELV) in accordance with IEC 61140:2016, 5.2.6 and IEC 60364-4-41:2005, 414.3.1 or control circuits in accordance with IEC 60204-1:2016, 7.2.4.

The group safety function is used for each part of IEC 61558-2 because different standards of the IEC 61558 series can be combined in one construction but in certain cases with no limitation of rated output power.

For example an auto-transformer in accordance with IEC 61558-2-13 can be designed with a separate SELV-circuit in accordance with the particular requirements for IEC 61558-2-6 relating to the general requirements of IEC 61558-1.

SAFETY OF TRANSFORMERS, REACTORS, POWER SUPPLY UNITS AND COMBINATIONS THEREOF –

Part 2-20: Particular requirements and tests for small reactors

1 Scope

Replacement

This part of IEC 61558 deals with the safety of **small reactors** for general applications. **Small reactors** incorporating **electronic circuits** are also covered by this document.

NOTE 1 Safety includes electrical, thermal and mechanical aspects.

Unless otherwise specified, from here onward, the term **transformer** or **reactor** covers **small reactors**.

This document is applicable to **stationary** or **portable**, single-phase or polyphase, air-cooled (natural or forced) general purpose **reactors** including alternating current, premagnetised and current compensated **independent** or **associated** **dry-type** **reactors.** The windings can be encapsulated or non-encapsulated.

The **rated supply voltage** does not exceed 1 000 V AC or 1 500 V ripple-free DC, the **rated supply frequency** and the **internal** ~~**operational**~~ **operating** **frequencies** do not exceed ~~1~~ 100 MHz.

This document can be used for **reactors** with a fundamental frequency above 500 Hz (see Annex BB).

The **rated power** does not exceed:

– 25 kVAR AC (25 kW DC) for single-phase **reactors**,
– 50 kVAR AC (50 kW DC) for poly-phase **reactors**.

This document is applicable to **reactors** without limitation of the **rated power** subject to an agreement between the purchaser and the manufacturer.

~~This part is applicable to **dry-type reactors**. The windings may be encapsulated or non-encapsulated.~~

This document does not apply to:

– **reactors** covered by ~~IEC 60289~~ IEC 60076-6 for rated voltages above 1 000 V;
– ballast for tubular fluorescent covered by IEC 61347-2-8;
– ballast for discharge lamps (excluding tubular fluorescent lamps) covered by IEC 61347-2-9.
– fixed inductors for electromagnetic interference suppression covered by IEC 60938 series

NOTE 2 For **reactors** filled with liquid dielectric or pulverised material such as sand, additional requirements are under consideration.

NOTE 3 Normally, **reactors** are intended to be associated with equipment for functional requirements of the equipment or requirements by the installation rules or by other appliance specifications. The protection against electric shock may be provided or completed by other parts or features of the equipment, such as the **body**.

NOTE 4 **Reactors** for particular applications will in the future be covered by complementary normative annexes.

~~NOTE 3~~ Attention is drawn to the following if necessary:

- for **reactors** intended to be used in vehicles, on board ships, and aircraft, additional requirements (from other applicable standards, national rules, etc.) ~~may be necessary~~;
- measures to protect the **enclosure** and the components inside the enclosure against external influences such as fungus, vermin, termites, solar-radiation, and icing ~~should also be considered~~;
- the different conditions for transportation, storage, and operation of the **reactors** ~~should also be considered~~;
- additional requirements in accordance with other appropriate standards and national rules may be applicable to **reactors** intended for use in special environments~~, such as tropical environment~~.

~~NOTE 4 Normally, **reactors** are intended to be associated with equipment for functional requirements of the equipment or requirements by the installation rules or by other appliance specifications.~~

~~NOTE 5 **Reactors** incorporating **electronic circuits** and components are also covered by this standard.~~

~~NOTE 6 The protection against electric shock may be provided (or completed) by other parts or features of the equipment, such as the **body**.~~

~~NOTE 7 **Reactors** for particular applications will in the future be covered by complementary normative annexes.~~

~~NOTE 8~~ Future technological development of **reactors** may necessitate a need to increase the upper limit of the frequencies. Until then, this document may be used as a guidance document.

This group safety publication focusing on safety guidance is primarily intended to be used as a product safety standard for the products mentioned in the scope, but is also intended to be used by technical committees in the preparation of publications for products similar to those mentioned in the scope of this group safety publication, in accordance with the principles laid down in IEC Guide 104 and ISO/IEC Guide 51.

One of the responsibilities of a technical committee is, wherever applicable, to make use of basic safety publications and/or group safety publications in the preparation of its publications.

2 Normative references

This clause of IEC 61558-1:2017 is applicable, except as follows:

Addition

IEC 60076-6:2007, *Power transformers – Part 6: Reactors*

IEC 61558-1:~~2005~~2017, *Safety of ~~power transformers, power supplies, reactors and similar products~~ transformers, reactors, power supply units and combinations thereof – Part 1: General requirements and tests*

IEC 61558-2-16:2021, *Safety of transformers, reactors, power supply units and combinations thereof – Part 16: Particular requirements and tests for switch mode power supply units and transformers for switch mode power supply units for general applications*

3 Terms and definitions

~~This clause of Part 1 is applicable, except as follows:~~

For the purposes of this document, the terms and definitions given in IEC 61558-1:2017 apply.

ISO and IEC maintain terminology databases for use in standardization at the following addresses:

- IEC Electropedia: available at https://www.electropedia.org/
- ISO Online browsing platform: available at https://www.iso.org/obp

Modification

Where IEC 61558-1:2017 is applicable, the word "**transformer**", if used, shall be replaced by "**reactor**".

3.1 Transformers

This subclause of IEC 61558-1:2017 is applicable, except as follows:

Addition

~~**3.1.101**~~
~~**reactor**~~
~~arrangement comprising one or more windings with an impedance depending on the frequency, working in accordance with the principle of self-induction whereby a magnetising current generates a magnetic field through a magnetically effective core or through air~~

~~NOTE **Reactors** with toroidal core are also included in this definition.~~

3.1.~~102~~101
alternating current reactor
reactor in which the magnetising current generates an alternating magnetic field, changing its polarity depending on the frequency

3.1.~~103~~102
premagnetised reactor
reactor in which the magnetising direct current generates a magnetic field of only one polarity, while a superimposed alternating current alters the direct magnetic field depending on its strength and the frequency

3.1.~~104~~103
current compensated reactor
reactor with at least two windings on a common core, where the magnetising currents are in opposite directions in order to reduce the magnetic flux

Replacement

3.1.~~105~~9
overload proof reactor
reactor in which the temperature does not exceed the specified limits when the **reactor** is overloaded and continues to meet all requirements of this document after the removal of the overload

3.1.~~105~~9.1
non-inherently overload proof reactor
overload proof reactor equipped with a protective device which opens the circuit, or reduces the current in the circuit when the **reactor** is overloaded, and which continues to meet all requirements of this document after the removal of the overload and resetting or replacing of the protective device

Note 1 to entry: Examples of protective devices are fuses, **overload releases**, thermal fuses, **thermal links**, **thermal cut-outs,** PTC resistors, and automatic circuit-breakers.