IEC 61850-5

Edition 2.1 2022-03
CONSOLIDATED VERSION

INTERNATIONAL STANDARD

colour inside

Communication networks and systems for power utility automation – Part 5: Communication requirements for functions and device models

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

ICS 33.200

ISBN 978-2-8322-1095-7

Warning! Make sure that you obtained this publication from an authorized distributor.

® Registered trademark of the International Electrotechnical Commission

CONTENTS

FOREWORD 9
INTRODUCTION 11
1 Scope 12
2 Normative references 12
3 Terms and definitions 15
3.1 General 15
3.2 Connections 17
3.3 Relations between IEDs 18
3.4 Substation structures 18
3.5 Power utility automation functions at different levels 19
3.6 Miscellaneous 20
4 Abbreviations 20
5 Power utility automation functions 21
5.1 General 21
5.2 Example substation automation system 21
5.2.1 General 21
5.2.2 Logical allocation of application functions and interfaces 21
5.2.3 The physical allocation of functions and interfaces 23
5.2.4 The role of interfaces 23
5.3 Other application examples 24
5.3.1 Substation – Substation 24
5.3.2 Substation – Network Control Center 24
5.3.3 Wind 24
5.3.4 Hydro 24
5.3.5 DER and distribution automation 24
5.3.6 FACTS and Power Conversion 25
5.3.7 Distribution Automation and Feeder Automation 25
6 Goal and requirements 26
6.1 Interoperability 26
6.2 Static design requirements 26
6.3 Dynamic interaction requirements 27
6.4 Response behaviour requirements 27
6.5 Approach to interoperability 28
6.6 Conformance test requirements 28
7 Categories of application functions 28
7.1 General 28
7.2 System support functions 29
7.3 System configuration or maintenance functions 29
7.4 Operational or control functions 29
7.5 Bay local process automation functions 29
7.6 Distributed process automation functions 30
8 Description and requirements of application functions 30
8.1 Approach 30
8.2 Application function description 31
8.3 The PICOM description 31

8.3.1 The PICOM approach 31
8.3.2 The content of PICOM description 31
8.3.3 Attributes of PICOMs 32
8.3.4 PICOM attributes to be covered by any message 32
8.3.5 PICOM attributes to be covered at configuration time only 32
8.3.6 PICOM attributes to be used for data flow calculations only 32
8.4 Logical node description 32
8.4.1 The logical node concept 32
8.4.2 Logical nodes and logical connections 33
8.4.3 Examples for decomposition of common functions into logical nodes 34
8.5 List of logical nodes 35
8.5.1 Logical Node allocation and distributed application functions 35
8.5.2 Explanation of tables 36
8.5.3 Defining and modelling of protection functions 37
8.5.4 Defining and modelling of protection related functions 43
8.5.5 Defining and modelling control functions 45
8.5.6 Definition and modelling Interfaces, logging and archiving functions 46
8.5.7 Defining and modelling automatic process control functions 47
8.5.8 Defining and modelling functional block functions 48
8.5.9 Defining and modelling metering and measurement functions 49
8.5.10 Defining and modelling power quality functions 51
8.5.11 Defining and modelling physical device functions and common data 52
8.5.12 Defining and modelling of system services 52
8.5.13 Definition and modelling of switching devices 53
8.5.14 Definition and modelling of supervision and monitoring functions 54
8.5.15 Definition and modelling of Instrument transformer functions 56
8.5.16 Definition and modelling of position sensors functions 56
8.5.17 Definition and modelling of material status sensors functions 56
8.5.18 Definition and modelling of flow status sensor functions 57
8.5.19 Definition and modelling of generic sensor functions 57
8.5.20 Definition and modelling of power transformer functions 58
8.5.21 Definition and modelling of further power system equipment 58
8.5.22 Definition and modelling of generic process I/O 59
8.6 Definition and modelling of mechanical non-electrical process equipment 60
9 The application concept for Logical Nodes 60
9.1 Example out of the substation automation domain 60
9.2 Typical allocation and use of Logical Nodes 60
9.2.1 Free allocation of Logical Nodes 60
9.2.2 Station level 60
9.2.3 Bay level 60
9.2.4 Process/switchgear level 61
9.2.5 The use of generic Logical Nodes 61
9.3 Basic examples 61
9.4 Additional examples 62
9.5 Modelling 64
9.5.1 Important remarks 64
9.5.2 Object classes and instances 64
9.5.3 Requirements and modelling 64
9.5.4 Logical Nodes and modelling 64

9.5.5 Use of Logical Nodes for applications 65
10 System description and system requirements 65
10.1 Need for a formal system description 65
10.2 Requirements for Logical Node behaviour in the system 65
11 Performance requirements 66
11.1 Time synchronisation 66
11.1.1 Basics 66
11.2 Message performance requirements 70
11.2.1 Basic definitions and requirements 70
11.2.2 Concepts of message types and performance classes 73
11.2.3 Definition of transfer time and synchronization classes 75
11.3 Definition of messages types and performances classes 76
11.3.1 Type 1 – Fast messages ("Protection") 76
11.3.2 Type 2 – Medium speed messages ("Automatics") 77
11.3.3 Type 3 – Low speed messages ("Operator") 77
11.3.4 Type 4 – Raw data messages ("Samples") 77
11.3.5 Type 5 – File transfer functions 78
11.3.6 Type 6 – Command messages and file transfer with access control 78
11.4 Requirements for data and communication quality 79
11.4.1 General remarks 79
11.4.2 Data integrity 79
11.4.3 Reliability 80
11.5 Requirements concerning the communication system 82
11.5.1 Communication failures 82
11.5.2 Requirements for station and bay level communication 82
11.5.3 Requirements for process level communication 83
11.5.4 Requirements for recovery delay 83
11.5.5 Requirements for communication redundancy 83
11.6 System performance requirements 84
12 Additional requirements for the data model 84
12.1 Semantics 84
12.2 Logical and physical identification and addressing 84
12.3 Self-description 84
12.4 Administrative issues 84
Annex A (informative) Logical nodes and related PICOMs 86
Annex B (informative) PICOM identification and message classification 101
B.1 General 101
B.2 Identification and type allocation of PICOMs 102
Annex C (informative) Communication optimization 109
Annex D (informative) Rules for function definition 110
D.1 Function definition 110
D.2 Function description 110
D.2.1 Task of the function 110
D.2.2 Starting criteria for the function 110
D.2.3 Result or impact of the function 110
D.2.4 Performance of the function 110
D.2.5 Function decomposition 110
D.2.6 Interaction with other functions 110

D.3 Logical node description 111
D.3.1 General 111
D.3.2 Starting criteria 111
D.4 PICOM description 111
D.4.1 Input and outputs by PICOMs 111
D.4.2 Operation modes 111
D.4.3 Performance 111
Annex E (informative) Interaction of functions and logical nodes 112
Annex F (informative) Functions 113
F.1 System support functions 113
F.1.1 Network management 113
F.1.2 Time synchronization 114
F.1.3 Physical device self-checking 114
F.1.4 Software management 115
F.1.5 Configuration management 116
F.1.6 Operative mode control of logical nodes 117
F.1.7 Setting 118
F.1.8 Test mode 119
F.1.9 System security management 120
F.2 Operational or control functions 120
F.2.1 Access security management 120
F.2.2 Control 122
F.2.3 Operational use of spontaneous change of indications 123
F.2.4 Synchronized switching (point-on-wave switching) 124
F.2.5 Parameter set switching 125
F.2.6 Alarm management 125
F.2.7 Event management (SER) 126
F.2.8 Data retrieval of configuration data and settings 127
F.2.9 Disturbance/fault record retrieval 128
F.2.10 Log management 128
F.3 Local process automation functions 128
F.3.1 Protection function (generic) 128
F.3.2 Distance protection (example of protection function) 129
F.3.3 Bay interlocking 130
F.4 Distributed automatic functions 130
F.4.1 Station-wide interlocking 130
F.4.2 Distributed synchrocheck 131
F.4.3 Breaker failure 132
F.4.4 Automatic protection adaptation (generic) 133
F.4.5 Reverse blocking function (example for automatic protection adaptation) 133
F.4.6 Load shedding 134
F.4.7 Load restoration 134
F.4.8 Voltage and reactive power control 135
F.4.9 Infeed switchover and transformer change 135
F.4.10 Automatic switching sequences 136
Annex G (informative) Results from function description 138

Annex H (informative) Substation configurations 144
H.1 Selected substations and associated layouts 144
H.2 Assigned protection and control functions 145
H.2.1 General 145
H.2.2 Substation T1-1 145
H.2.3 Substation D2-1 147
H.2.4 Substation T1-2 147
H.2.5 Substation T2-2 147
Annex I (informative) Examples for protection functions in compensated networks 149
I.1 The Transient Earth Fault (PTEF) 149
I.2 Short term bypass (YPSH) 150
I.3 The double earth fault (PTOC) 150
Bibliography 151

Figure 2 – Levels and logical interfaces in substation automation systems 22
Figure 3 – The logical node and link concept (explanation see text) 34
Figure 4 – Examples of the application of the logical node concept (explanation see text) 35
Figure 5 – Protection function consisting of three Logical Nodes 36
Figure 6 – The basic communication links of a logical node of main protection type 43
Figure 7 – Decomposition of functions into interacting LNs on different levels: Examples for generic automatic function, breaker control function and voltage control function 61
Figure 8 – Decomposition of functions into interacting LN on different levels: Examples for generic function with telecontrol interface, protection function and measuring/metering function 62
Figure 9 – Example for control and protection LNs of a transformer bay combined in one physical device (some kind of maximum allocation) 62
Figure 10 – Example for interaction of LNs for switchgear control, interlocking, synchrocheck, autoreclosure and protection (Abbreviation for LN see above) 63
Figure 11 – Example for sequential interacting of LNs (local and remote) in a complex function like point-on-wave switching (Abbreviations for LN see above) – Sequence view 63
Figure 12 – Circuit breaker controllable per phase (XCBR instances per phase) and instrument transformers with measuring units per phase (TCTR or TVTR per phase) 64
Figure 14 – Transfer time for binary signal with conventional output and input delays 71
Figure 15 – Definition of transfer time *t* for binary signals in case of line protection 72
Figure 16 – Definition of transfer time t over serial link in case of line protection 73
Figure H.1 – T1-1 Small size transmission substation (single busbar 132 kV with infeed from 220 kV) 144
Figure H.2 – D2-1 Medium size distribution substation (double busbar 22 kV with infeed from 69 kV) 144
Figure H.3 – T1-2 Small size transmission substation (1 1/2 breaker busbar at 110 kV) 144
Figure H.4 – T2-2 Large size transmission substation (ring bus at 526 kV, double busbar at 138 kV) 145
Figure H.5 – Substation of type T1-1 with allocation functions 146
Figure H.6 – Substation of type D2-1 with allocated functions 147
Figure H.7 – Substation of type T1-2 (functions allocated same as for T2-2 in Figure H.8) 147
Figure H.8 – Substation of type T2-2 with allocated functions 148
Figure I.1 – The transient earth fault in a compensated network 149

Figure I.2 – Short term bypass for single earth fault in compensated networks 150
Figure I.3 – Double earth fault in compensated networks 150

Table 8 – Logical Nodes for protection functions 37
Table 9 – Logical Nodes for protection related functions 43
Table 10 – Logical Nodes for control functions 45
Table 11 – Logical Nodes for interface functions 46
Table 12 – Logical Nodes for automatic process control functions 47
Table 13 – Logical Nodes for functional block functions 49
Table 14 – Logical Nodes for metering and measurement functions 50
Table 15 – Logical Nodes for power quality functions 51
Table 16 – Logical Nodes for physical device functions and common data 52
Table 17 – Logical Nodes for time, supervision and testing 53
Table 18 – Logical Nodes for system and device security 53
Table 19 – Logical Nodes for switching devices 54
Table 20 – Logical Nodes for supervision and monitoring functions 54
Table 21 – Logical Nodes for instrument transformers functions 56
Table 22 – Logical Nodes for position sensor functions 56
Table 23 – Logical Nodes for material status sensor functions 57
Table 24 – Logical Nodes for flow status sensor functions 57
Table 25 – Logical Nodes for Generic Sensor Functions 58
Table 26 – Logical Nodes for power transformer functions 58
Table 27 – Logical Nodes for further power system equipment 58
Table 28 – Logical Nodes for generic process I/O 59
Table 29 – Logical Nodes for mechanical non-electrical process equipment 60
Table 2 – Time synchronization classes for AC applications synchronization 68
Table 3 – Time synchronization classes for time tagging or sampling 68
Table 30 – Classes for transfer times 75
Table 31 -– Data integrity classes 79
Table 32 – Security classes 80
Table 33 – Dependability classes 81
Table 34 – Requirements for recovery time (examples) 83
Table A.1 – PICOM groups 86
Table A.2 – Logical node list 87
Table B.1 – PICOM identification (Part 1) 102
Table B.2 – PICOM identification (Part 2) 103
Table B.3 – PICOM allocation (Part 1) 104
Table B.4 – PICOM allocation (Part 2) 105
Table B.5 – PICOM types 107
Table G.1 – Function-function interaction (Part 1) 138
Table G.2 – Function-function interaction (Part 2) 139
Table G.3 – Function decomposition into logical nodes (Part 1) 140
Table G.4 – Function decomposition into logical nodes (Part 2) 141

Table G.5 – Function decomposition into logical nodes (Part 3) 142
Table G.6 – Function decomposition into logical nodes (Part 4) 143
Table H.1 – Definition of the configuration of all substations evaluated 145

INTERNATIONAL ELECTROTECHNICAL COMMISSION

_____

COMMUNICATION NETWORKS AND SYSTEMS FOR POWER UTILITY AUTOMATION –

Part 5: Communication requirements for functions and device models

FOREWORD

1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national Electrotechnical Committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as “IEC Publication(s)”). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
6) All users should ensure that they have the latest edition of this publication.
7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
8) Attention is drawn to the normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

This consolidated version of the official IEC Standard and its amendment has been prepared for user convenience.

IEC 61850-5 edition 2.1 contains the second edition (2013-01) [documents 57/1286/FDIS and 57/1309/RVD] and its amendment 1 (2022-03) [documents 57/2448/FDIS and 57/2467/RVD].

International Standard IEC 61850-5 has been prepared by IEC technical committee 57: Power systems management and associated information exchange.

The changes, corrections and updates have been made mainly according to the comments received.

The major changes of this consolidated version with regard to the edition 2 are as follows:

a) extensions of the requirements with some Logical Nodes
b) errors and typos have been corrected
c) harmonization of all Logical Node descriptions (impact on all Logical Node tables)
d) re-organization of selected clause structures
e) updating of headlines
f) re-ordering subclauses in the chapter about performances

to provide

– ease of reading and understanding of the requirements for the IEC 61850 series
– consistent and updated requirement references for the data model and communication service parts

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all the parts in the IEC 61850 series, published under the general title *Communication networks and systems for power utility automation,* can be found on the IEC website.

Future standards in this series will carry the new general title as cited above. Titles of existing standards in this series will be updated at the time of the next edition.

The committee has decided that the contents of the base publication and its amendment will remain unchanged until the stability date indicated on the IEC web site under webstore.iec.ch in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

INTRODUCTION

This part of IEC 61850 is part of a set of standards, the IEC 61850 series. The IEC 61850 series is intended to provide interoperability between all devices in power utility automation systems. Therefore, it defines communication networks and systems for power utility automation, and more specially the communication architecture for subsystems like substation automation systems. The sum of all subsystems may result also in the description of the communication architecture for the overall power system management.

Communication between these devices in subsystems and between the subsystems within the overall power utility automation system fulfils a lot of requirements imposed by all the functions to be performed in power utility automation systems starting from the core requirements in substations. These requirements are stated both for the data to be organized in a data model and for the data exchange resulting in services. Performance of the data exchange means not only transfer times but also the quality of the data exchange avoiding losses of information in the communication.

Depending on the philosophy both of the manufacturer and the user and on the state-of-the-art in technology, the allocation of functions to devices and control levels is not commonly fixed. Therefore, the standard shall support any allocation of functions. This results in different requirements for the different communication interfaces within the substation or plant, at its border and beyond.

The IEC 61850 series shall be long living but allow following the fast changes in communication technology by both its technical approach and its document structure. The IEC 61850 series has been organized so that at least minor changes to one part do not require a significant rewriting of another part. For example, the derived data models in subsequent parts (IEC 61850-7-x) and mappings to dedicated stacks (IEC 61850-8-x and IEC 61850-9-x) based on the communication requirements in IEC 61850-5 will not change the requirements defined in IEC 61850-5. In addition, the general parts, the requirement specification and the modelling parts are independent from any implementation. The implementation needed for the use of the standard is defined in some few dedicated parts referring to main stream communication means thus supporting the long living of the standard and its potential for later technical changes.

This consolidated version of IEC 61850-5:2013 and its Amendment 1 defines the communication requirements for functions and device models for power utility automation systems.

The modelling of communication requires the definition of objects (e.g., data objects, data sets, report control, log control) and services accessing the objects (e.g., get, set, report, create, delete). This is defined in IEC 61850-7 with a clear interface to implementation. To use the benefits of communication technology, in this standard no new protocol stacks are defined but a standardized mapping on existing stacks is given in IEC 61850-8 and IEC 61850-9. A System configuration language (IEC 61850-6) for strong formal description of the system usable for software tools and a standardized conformance testing (IEC 61850-10) complement the standard.

NOTE 1 To keep the layered approach of the standard not mixing application and implementation requirements, terms like client, server, data objects, etc. are normally not used in IEC 61850-5 (requirements). In IEC 61850-7 (modelling), -8 and -9 (specific communication service mapping) terms belonging to application requirements like PICOM are normally not used.

NOTE 2 Specific requirements concerning extensions of part 8 are covered in separate technical reports, e.g. IEC TR 61850-80-3.

COMMUNICATION NETWORKS AND SYSTEMS FOR POWER UTILITY AUTOMATION –

Part 5: Communication requirements for functions and device models

1 Scope

The specifications of this document refer to general, respectively core, communication requirements of the application functions in all domains of power utility automation systems. Dedicated communication requirements and most examples of application functions in this document are from the domain substation automation but may be reused in or extended to other domains within power utility automation systems. Note that sometimes instead of the term substation automation domain the term substation domain is used, especially if both the switchyard devices (primary system) and the automation system (secondary system) are regarded.

The description of the application functions is not used to standardize these functions, but to identify communication requirements between Intelligent Electronic Devices (IEDs) hosting these functions within plants and substations in the power system, between such stations (e.g. between substation for line protection) and between the plant or substation and higher-level remote operating places (e.g. network control centres) and maintenance places. In addition interfaces to remote technical services (e.g. maintenance centres) are considered. The general scope is the communication requirements for power utility automation systems. The basic goal is interoperability for all interactions providing a seamless communication system for the overall power system management. Another prerequisite for interoperability is a commonly defined method for time synchronization.

Standardizing application functions and their implementation is completely outside the scope of this document. Therefore, it cannot be assumed a single philosophy of allocating application functions to devices. To support the resulting request for free allocation of these functions, a proper breakdown of these functions into parts relevant for communication is defined. The exchanged data and their required performance are defined.

The same or similar IEDs from substations like protective and control devices are found in other domains like power plants also. Using this document for such devices in these plants facilitates the system integration e.g. between the power plant control and the related substation automation system. For some of such other application domains like wind power plants, hydro power plants and distributed energy resources specific standard parts according to the IEC 61850 series have been already defined and published.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60617, *Graphical symbols for diagrams – 12-month subscription to regularly updated online database comprising parts 2 to 13 of IEC 60617*

IEC 60834-1:1999, *Teleprotection equipment of power systems – Performance and testing – Part 1: Command systems*

IEC 60834-2:1993, *Performance and testing of teleprotection equipment of power systems – Part 2: Analogue comparison systems*

IEC 60870-4:1990, *Telecontrol equipment and systems. Part 4: Performance requirements*

IEC 60870-5 (all parts), *Telecontrol equipment and systems – Part 5: Transmission protocols*

IEC 61000-4-15:2010, *Electromagnetic compatibility (EMC) – Part 4-15: Testing and measurement techniques – Flickermeter – Functional and design specifications*

IEC 61000-4-30:2015, *Electromagnetic compatibility (EMC) – Part 4-30: Testing and measurement techniques – Power quality measurement methods*

IEC 61508 (all parts), *Functional safety of electrical/electronic/programmable electronic safety-related systems*

IEC TR 61850-1:2013, *Communication networks and systems for power utility automation – Part 1: Introduction and overview*

IEC TS 61850-2:2019, *Communication networks and systems for power utility automation – Part 2: Glossary*

IEC 61850-3:2013, *Communication networks and systems for power utility automation – Part 3: General requirements*

IEC 61850-4:2011, *Communication networks and systems for power utility automation – Part 4: System and project management*

IEC 61850-6:2009, *Communication networks and systems for power utility automation – Part 6: Configuration description language for communication in electrical substations related to IEDs*
IEC 61850-6:2009/AMD1:2018

IEC 61850-7-1:2011, *Communication networks and systems for power utility automation – Part 7-1: Basic communication structure – Principles and models*
IEC 61850-7-1:2011/AMD1:2020

IEC 61850-7-2:2010, *Communication networks and systems for power utility automation – Part 7-2: Basic information and communication structure – Abstract communication service interface (ACSI)*
IEC 61850-7-2:2010/AMD1:2020

IEC 61850-7-3:2010, *Communication networks and systems for power utility automation – Part 7-3: Basic communication structure – Common data classes*
IEC 61850-7-3:2010/AMD1:2020

IEC 61850-7-4:2010, *Communication networks and systems for power utility automation – Part 7-4: Basic communication structure – Compatible logical node classes and data object classes*
IEC 61850-7-4:2010/AMD1:2020

IEC TR 61850-7-5, *Communication networks and systems for power utility automation – Part 7-5: IEC 61850 modelling concepts*

IEC TR 61850-7-500:2017, *Communication networks and systems for power utility automation – Part 7-500: Basic information and communication structure – Use of logical nodes for modeling application functions and related concepts and guidelines for substations*

IEC TR 61850-7-510:2012, *Communication networks and systems for power utility automation – Part 7-510: Basic communication structure – Hydroelectric power plants – Modelling concepts and guidelines*

IEC TR 61850-7-6:2019, *Communication networks and systems for power utility automation – Part 7-6: Guideline for definition of Basic Application Profiles (BAPs) using IEC 61850*

IEC TS 61850-7-7:2018, *Communication networks and systems for power utility automation – Part 7-7: Machine-processable format of IEC 61850-related data models for tools*

IEC 61850-8-1:2011, *Communication networks and systems for power utility automation – Part 8-1: Specific communication service mapping (SCSM) – Mappings to MMS (ISO 9506-1 and ISO 9506-2) and to ISO/IEC 8802-3*
IEC 61850-8-1:2011/AMD1:2020

IEC 61850-8-2:2018, *Communication networks and systems for power utility automation – Part 8-2: Specific communication service mapping (SCSM) – Mapping to Extensible Messaging Presence Protocol (XMPP)*

IEC 61850-9-2:2011, *Communication networks and systems for power utility automation – Part 9-2: Specific communication service mapping (SCSM) – Sampled values over ISO/IEC 8802-3*
IEC 61850-9-2:2011/AMD1:2020

IEC/IEEE 61850-9-3:2016, *Communication networks and systems for power utility automation – Part 9-3: Precision time protocol profile for power utility automation*

IEC 61850-10:2012, *Communication networks and systems for power utility automation – Part 10: Conformance testing*

IEC TR 61850-80-3:2015, *Communication networks and systems for power utility automation – Part 80-3: Mapping to web protocols – Requirements and technical choices*

IEC TR 61850-90-1:2010, *Communication networks and systems for power utility automation – Part 90-1: Use of IEC 61850 for the communication between substations*

IEC TR 61850-90-2:2016, *Communication networks and systems for power utility automation – Part 90-2: Using IEC 61850 for communication between substations and control centres*

IEC TR 61850-90-4:2020, *Communication networks and systems for power utility automation – Part 90-4: Network engineering guidelines*

IEC TR 61850-90-5:2012, *Communication networks and systems for power utility automation – Part 90-5: Use of IEC 61850 to transmit synchrophasor information according to IEEE C37.118*

IEC TR 61850-90-12:2020, *Communication networks and systems for power utility automation – Part 90-12: Wide area network engineering guidelines*

IEC 61869 (all parts), *Instrument transformers*

IEC TR 62357-1:2016, *Power systems management and associated information exchange – Part 1: Reference architecture*

IEC 81346 (all parts), *Industrial systems, installations and equipment and industrial products – Structuring principles and reference designations*

IEEE Std C37.2-2008, *Electrical Power System Device Function Numbers, Acronyms and Contact Designations*