IEC 61970-600-1

Edition 1.0 2021-06

INTERNATIONAL STANDARD

colour inside

Energy management system application program interface (EMS-API) – Part 600-1: Common Grid Model Exchange Standard (CGMES) – Structure and rules



IEC 61970-600-1:2021-06(en)



THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2021 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

IEC Central Office
3, rue de Varembé
CH-1211 Geneva 20
Switzerland

Tel.: +41 22 919 02 11
info@iec.ch
www.iec.ch

About the IEC
The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications
The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigendum or an amendment might have been published.

IEC publications search - webstore.iec.ch/advsearchform
The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee, …). It also gives information on projects, replaced and withdrawn publications.

IEC Just Published - webstore.iec.ch/justpublished
Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and once a month by email.

IEC Customer Service Centre - webstore.iec.ch/csc
If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: sales@iec.ch.

IEC online collection - oc.iec.ch
Discover our powerful search engine and read freely all the publications previews. With a subscription you will always have access to up to date content tailored to your needs.

Electropedia - www.electropedia.org
The world's leading online dictionary on electrotechnology, containing more than 22 000 terminological entries in English and French, with equivalent terms in 18 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

IEC 61970-600-1

Edition 1.0 2021-06

INTERNATIONAL STANDARD

colour inside

Energy management system application program interface (EMS-API) – Part 600-1: Common Grid Model Exchange Standard (CGMES) – Structure and rules

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

ICS 33.200

ISBN 978-2-8322-9814-5

Warning! Make sure that you obtained this publication from an authorized distributor.

® Registered trademark of the International Electrotechnical Commission

CONTENTS

FOREWORD 4
INTRODUCTION 7
1 Scope 8
2 Normative references 9
3 Terms, definitions and abbreviated terms 10
3.1 Terms and definitions 10
3.2 Abbreviated terms 11
4 Data exchange context 12
5 Specifications and functionalities 15
5.1 General constraints 15
5.2 Model authority sets (MAS) 17
5.3 File header 18
5.4 File body 19
5.5 Profiles and instance file types 19
5.5.1 General 19
5.5.2 CGMES profiles' properties 19
5.5.3 CGMES extensions 21
5.5.4 Equipment profile and instance file 22
5.5.5 Topology profile and instance file 23
5.5.6 Steady state hypothesis profile and instance file 23
5.5.7 State variables profile and instance file 24
5.5.8 Equipment boundary profile and instance file 24
5.5.9 Topology boundary profile and instance file 24
5.5.10 Diagram layout profile and instance file 24
5.5.11 Geographical location profile and instance file 25
5.5.12 Dynamics profile and instance file 25
5.6 File exchange 26
5.7 Boundary point – properties and location 27
5.8 Model merging process 29
5.9 CIM XML document/distribution validity 32
5.10 Naming Convention 33
6 CGMES governance 36
6.1 General 36
6.2 Versions of the CGMES and the profiles 37
6.3 Conformity assessment 38
6.4 Implementation process 38
Annex A (xxxx) 39
Annex B (normative) File header guidelines 40
B.1 General 40
B.2 Exchange scenarios 40
B.3 Examples 41
B.3.1 Example 1: File header of full model 41
B.3.2 Example 2: File header of full model that is depending on another model 42
B.3.3 Example 3: File header of full model that is depending on a model and supersedes another model 43

B.3.4 Example 4: File header of difference model that is depending on a full model and supersedes another full model 44
B.3.5 Example 5: File header of difference model that is depending on a difference model and supersedes another difference model 45
Bibliography 47

Figure 1 – CGMES instance file dependency 20
Figure 2 – Boundary point placed on a tie-line 27
Figure 3 – Boundary point placed in a substation 27
Figure 4 – HVDC as interconnection or internal line 28
Figure 5 – HVDC grid 28
Figure 6 – Merge process 31
Figure B.1 – Example workflow events 40

Table 1 – IdentifiedObject attributes 36
Table 2 – IdentifiedObject attributes in EQBD profile 36

INTERNATIONAL ELECTROTECHNICAL COMMISSION

_____

ENERGY MANAGEMENT SYSTEM APPLICATION PROGRAM INTERFACE (EMS-API) –

Part 600-1: Common Grid Model Exchange Standard (CGMES) – Structure and rules

FOREWORD

1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
6) All users should ensure that they have the latest edition of this publication.
7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 61970-600-1 has been prepared by IEC technical committee 57: Power systems management and associated information exchange.

This first edition cancels and replaces IEC TS 61970-600-1 published in 2017. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to IEC TS 61970-600-1:2017:

- Terms and definitions were updated.
- The "Type" column in all tables was deleted to increase readability of the document as all the rules are considered required, hence categorisation is not necessary.
- Requirement HGEN4 was added to define additional rules to the file header compared to IEC 61970-552:2016.

- Annex B on “Summary of specific rules for naming conventions” is deleted as the information was either integrated in the UML or considered outdated.
- Annex D referring to the PST modelling is deleted as it will be fully integrated in IEC 61970-301:2020+AMD1[1].
- Annex E “Implementation guide” is deleted as all rules and implementation guidance is or will be integrated in either Clause 5 of this document or IEC 61970-301:2020 (and its future Amendment 1) or IEC 61970-452 or IEC 61970-456 as referenced by this document. Note that former Subclause E.11.2 on ConformLoadGroup and NonConformLoadGroup was implemented differently due to another issue, please refer to IEC 61970-600-2:2020.
- Rules GENC17, GENC18, GENC19, EQ__4, EQ__5, SV__4, BPPL12, BPPL13, MVAL5, EXCH9, TP__4 and MARP12 were added.
- Rules GENC3, GENC6, PROF2, PROF4, PROF5, PROF8, PROF9, EXCH5, EXCH6, EXCH7, MAS_4, MAS_6, MAS_9, MAS_10, MAS_11, MAS_13, EQ__1, HREF2, HREF3, HREF5, MVAL3, TPBD1, TPBD2, BPPL10, NAMC12 and NAMC13 are deleted as they are considered not relevant due to other changes.
- The following rules were modified: GENC1, GENC2, GENC4, GENC5, GENC7, GENC8, GENC9, GENC10, GENC16, EQBD2, BPPL11, EXCH2, EXCH3, EXCH8, FBOD3, FBOD5, PROF10, PROF11, MAS_1, MAS_8, HGEN3, HREF1,EEXT1, EQ__2, TP__1, TP__2, TP__3, MARP10, MARP11, NAMC1, NAMC4, NAMC11, NAMC14, BPPL1, BPPL2 and BPPL3.
- Explicit equipment boundary profile definition (EQBD) has been deprecated (refer to Subclause 4.6.5 of IEC 61970-301:2020 and future Amendment 1 for details on deprecations) in this edition in favour of using its full profile counterpart (EQ) for exchange of boundary datasets. The topology boundary profile (TPBD) is not included in the CGMES as TP is considered output and therefore it is no need to exchange Topology information part of the boundary model authority set.
- Annex F has been deleted.

The text of this International Standard is based on the following documents:

FDIS	Report on voting
57/2366/FDIS	57/2382/RVD

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

The language used for the development of this International Standard is English.

This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available at www.iec.ch/members_experts/refdocs. The main document types developed by IEC are described in greater detail at www.iec.ch/standardsdev/publications.

A list of all parts in the IEC 61970 series, published under the general title *Energy management system application program interface (EMS-API)*, can be found on the IEC website.

[1] An amendment to IEC 61970-301:2020 is currently under consideration.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under "http://webstore.iec.ch" in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

INTRODUCTION

The purpose of this document is to define the Common Grid Model Exchange Standard (CGMES) based on Common Information Model (CIM) standards defined in IEC 61970-series, IEC 61968-series and IEC 62325-series and to address requirements defined by the European legislation. However, the document is not limited to the European legislation requirements and business processes, it is created to support data exchange between applications that support power system model management and analysis. The data exchange can be between internal applications or between applications at System Operators (SO) and Reginal Coordination Centre (RCC). This covers DSO-DSO, DSO-TSO, TSO-TSO, TSO-RCC/ISO/RTO and RCC-RCC interfaces, but not limited to these.

The CGMES is created to address the information exchange requirements provided in Common Grid Model methodologies (CGMm) in accordance with the legal requirements stated in various European network codes guidelines. The CGMES applies to applications dealing with power system data management, as well as applications supporting the following analyses:

- power flow and contingency analyses,
- short circuit calculations,
- market information and transparency,
- capacity calculation for capacity allocation and congestion management, and
- dynamic security assessment.

The conformity of applications used for system operation and system development data exchanges with the CGMES is crucial for the needed interoperability of these applications. This document provides the grouping of all principle requirements for the CGMES Conformity Assessment Framework and the guiding principles for assessing applications' CGMES conformity. The description of the CGMES Conformity Assessment Process is currently not part of the IEC 61970-600-series, but it is planned to be included as an international standard in order to validate that the CGMES is correctly implemented by suppliers of the applications used by system operators (ISO/TSO/DSO etc) and for Regional Coordination Centres (RCCs).

ENERGY MANAGEMENT SYSTEM APPLICATION PROGRAM INTERFACE (EMS-API) –

Part 600-1: Common Grid Model Exchange Standard (CGMES) – Structure and rules

1 Scope

This part of IEC 61970, which covers the definition of Common Grid Model Exchange Standard (CGMES), defines the main rules and application's requirements to meet business requirements for assembled and merged model to fit relevant business services. This document does not define the business requirements, business processes nor how applications are implemented. This document defines how relevant Common Information Model (CIM) standards work together so that specific business requirements can be resolved.

It also includes extensions to the Common Information Model (CIM). The current extensions are defined in IEC 61970-301:2020 and will be covered in its future Amendment 1, but additional extensions can be defined in other standards in the IEC 61970-600-series. The extensions can be used to define additional profiles or to expand IEC 61970-450-series or IEC 61968-13 profiles. However, primary CGMES includes additional constraints on existing profiles and validation of assembled and merged models that is based on existing profiles. This can be done by making optional attributes and associations mandatory (required).

In addition, this document includes the specification of the serialisation that must be supported by referring to an existing standard defined in IEC 61970-550-series, e.g., IEC 61970-552, and making relevant constraints related to it.

The goal is to achieve interoperability between applications using CGMES in a high-performance environment with combined minimum effort so that relevant business processes are satisfied.

An overview of IEC 61970-600 series is provided in the following table, which also presents identified needs that are not yet addressed.

Part	Description	Scope
61970-600-1	Structure and rules. This part defines the structure of the series of standard and the rules that needs to be applied on the assembled and merged models that are defined by the different profile standards.	In the scope
61970-600-2	Exchange profiles specification. This part defines the IEC 61970-450-series and IEC 61968-13 related profiles that are included in CGMES. It includes the references to published standards and additional constraints defined to the relevant standard. If the relevant edition of a standard is not published, it also includes the profile definition and the standard's constraints.	In the scope
to be defined (TBD)	Information extension. This part defines additional information model that is not included in the relevant edition of IEC 61970-301, IEC 61970-302 or IEC 61968-11 that is needed to meet business requirement.	Identified as a need and not yet addressed neither in this document nor in IEC 61970-600 series
to be defined (TBD)	Extended exchange profiles specification. This part defines additional profiles that is not included in IEC 61970-450-series and IEC 61968-13 that is needed to meet business requirement.	
to be defined (TBD)	Conformity Assessment Scheme (CAS). This part defines the Conformity Assessment Scheme (CAS) including test use cases and references to test configurations to evaluate if an application tool conforms to the CGMES.	

Clause 4, Data exchange context, describes the context the CGMES is developed to support.

Clause 5, Specifications and functionalities, defines the rules that shall be applied for validating a model part, an assembled and a merged model. When the rule is defined in the relevant profile it will include a refence to the rule.

Clause 6, CGMES governance, defines the governance of CGMES and the version strategy.

Annex A is left blank.

Annex B (normative), File header guidelines, explains the usage of the file header that is defined in IEC 61970-552.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 61970-552:2016, *Energy management system application program interface (EMS-API) – Part 552: CIMXML Model exchange format*

IEC 61970-301:2020, *Energy management system application program interface (EMS-API) – Part 301: Common information model (CIM) base*

IEC 61970-302:2018, *Energy management system application program interface (EMS-API) – Part 302: Common information model (CIM) dynamics*

3 Terms, definitions and abbreviated terms

For the purposes of this document, the following terms, definitions and abbreviated terms apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- IEC Electropedia: available at http://www.electropedia.org/
- ISO Online browsing platform: available at http://www.iso.org/obp

NOTE For definitions which are not specified in the CGMES the definitions in the IEC 61970 standard series shall be applied.

3.1 Terms and definitions

3.1.1
assembled model
model of a Model Authority Set with internal references resolved

3.1.2
boundary point
BP
connection point between two Model Authority Sets, that has been agreed on by both relevant Model Authority

3.1.3
boundary set
set containing all boundary points necessary for a merge model

3.1.4
CIM XML document/distribution
instance file which is serialised according to IEC 61970-552

3.1.5
distribution
specific representation of a dataset. A dataset might be available in multiple serializations that may differ in various ways, including natural language, media-type or format, schematic organization, temporal and spatial resolution. The level of detail in the distribution is defined by one or more profiles that the dataset conforms to

3.1.6
Common Grid Model Exchange Standard
CGMES
collection of standards defined in IEC 61970-600 series that support the exchange of power system models (e.g. individual grid model or common grid model) between model authorities (TSOs, DSOs, etc.) for the purpose of coordinated set of services to be performed on the same model according to legislation or general data exchanges in the frame of system operation, system development or utilities' projects

3.1.7
European extensions
collection of classes, attributes and associations, which either extend or are defined in the standard IEC CIM model (IEC 61970-300 series, IEC 91968-11 and IEC 62325-300 series). The European extensions aim at satisfying requirements by the European legislation hence not necessarily applicable to other continents. The worldwide adoption of these extensions may not be exactly the same as the defined extension

3.1.8
external references resolved
no dangling references are present across the models of Model Authority Sets

3.1.9
header references resolved
references defined in model header are resolved

3.1.10
internal references resolved
no dangling references are present within the model of a Model Authority Set

3.1.11
merged model
model that is a union of different assembled models with external and header references resolved

3.1.12
profile
data model to describe instance file for exchange of CIM data. A profile is a subset of classes, associations and attributes needed to accomplish a specific type of interface and based upon a CIM data model. Profiles may impose stricter rules on original classes and associations. A profile is usually converted to schema (XSD, RDF, OWL, etc.) that can be used to create, read and validate instance files for data exchange

Note 1 to entry: This term may be used to define either the semantic model for an instance data payload or the syntactic schema for an instance data payload. A profile may be expressed in XSD, RDF, and/or OWL files. An instance data conforming to a profile can be tested in exchanges between applications. A profile is necessary in order to “use” the canonical model.

3.1.13
solved model
model containing instance of State Variables (SV)

3.2 Abbreviated terms

BP	Boundary point
CIM	Common Information Model (electricity)
CGMES	Common Grid Model Exchange Standard
DL	Diagram Layout profile
DSO	Distribution System Operator
DY	Dynamics profile
ENTSO-E	European Network of Transmission System Operators for Electricity
EQ	Core Equipment profile
EQBD	Equipment Boundary profile
GL	Geographical Location profile
HVDC	High Voltage Direct Current
IEC	The International Electrotechnical Commission, headquartered in Geneva
IOP	Interoperability Test
ISO	Independent System Operator
MAS	Model Authority Set
mRID	CIM Master Resource Identifier
OCL	Object Constraint Language

OP	Operation profile
OWL	Web Ontology Language
RCC	Regional Coordination Centres
RDF	Resource Description Framework
RDFS	RDF Schema
SC	Short-Circuit profile
SHACL	Shapes Constraint Language
SSH	Steady State Hypothesis profile
SV	State Variables profile
TP	Topology profile
TSO	Transmission System Operator
URI	Uniform Resource Identifier
UUID	Universally Unique Identifier
XML	Extensible Markup Language
XSD	XML Schema Definition

4 Data exchange context

There are various levels at which an exchange of power system data/models is necessary. A pan-European model exchange level covers the territory of all system operators (TSOs and DSOs). Regional model exchanges can be realised between different TSOs in one or more synchronous areas. A model exchange on the national level includes interfaces between TSOs (in case there are multiple TSOs on a national level) as well as between different DSOs.

The purpose of model exchanges is not only to exchange the data from one authority to another but also to satisfy the ultimate goal, namely, to perform common studies using shared data. All parties involved in the process should be able to perform the same types of studies and share project tasks between different parties which are using different power system analysis applications. Indeed, the interoperability between different applications used in the exchange process is therefore crucial in both reaching seamless data exchange and obtaining comparable study results when using this data.

The CGMES covers these European and system operators (TSOs and DSOs) business processes by defining the following main types of exchanges valid for a particular study or process:

- Exchange of boundary set: An exchange of a boundary Set is necessary to prepare an exchange of an internal system operator model and to merge a common grid model. E.g. the ENTSO-E Network Modelling Database (NMD) is used to maintain the Boundary Set covering the pan-European area where all TSOs negotiate and agree on the boundary information.