IEC 62127-3

Edition 2.0 2022-12
REDLINE VERSION

INTERNATIONAL STANDARD

colour inside

Ultrasonics – Hydrophones –
Part 3: Properties of hydrophones for ultrasonic fields ~~up to 40 MHz~~



IEC 62127-3:2022-12 RLV(en)



THIS PUBLICATION IS COPYRIGHT PROTECTED
Copyright © 2022 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

IEC Secretariat
3, rue de Varembé
CH-1211 Geneva 20
Switzerland

Tel.: +41 22 919 02 11
info@iec.ch
www.iec.ch

About the IEC
The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications
The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigendum or an amendment might have been published.

IEC publications search - webstore.iec.ch/advsearchform
The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee, …). It also gives information on projects, replaced and withdrawn publications.

IEC Just Published - webstore.iec.ch/justpublished
Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and once a month by email.

IEC Customer Service Centre - webstore.iec.ch/csc
If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: sales@iec.ch.

IEC Products & Services Portal - products.iec.ch
Discover our powerful search engine and read freely all the publications previews. With a subscription you will always have access to up to date content tailored to your needs.

Electropedia - www.electropedia.org
The world's leading online dictionary on electrotechnology, containing more than 22 300 terminological entries in English and French, with equivalent terms in 19 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

IEC 62127-3

Edition 2.0 2022-12
REDLINE VERSION

INTERNATIONAL STANDARD

colour inside

Ultrasonics – Hydrophones –
Part 3: Properties of hydrophones for ultrasonic fields ~~up to 40 MHz~~

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

ICS 17.140.50

ISBN 978-2-8322-6313-6

Warning! Make sure that you obtained this publication from an authorized distributor.

® Registered trademark of the International Electrotechnical Commission

CONTENTS

FOREWORD 4
INTRODUCTION 6
1 Scope 7
2 Normative references 7
3 Terms, definitions and symbols 7
4 List of symbols 11
5 Hydrophone characteristics 12
5.1 General 12
5.2 Basic information 12
5.3 Sensitivity 12
5.4 Frequency response 13
5.4.1 Stated frequency band 13
5.4.2 Frequency dependence 13
5.5 Directional response 14
5.5.1 General 14
5.5.2 Determination of the directional response 14
5.5.3 Symmetry of directional response 15
~~5.6 Effective radius ..... 16~~
5.6 Effective hydrophone size 16
5.6.1 General 16
5.6.2 Model of directional response 16
5.6.3 Fitting of experimental response to theoretical predictions 17
5.7 Dynamic range, linearity and electromagnetic interference 18
5.8 Electric output characteristics 18
5.8.1 Hydrophone without pre-amplifier 18
5.8.2 Hydrophone assembly 19
5.8.3 Output lead configuration 19
5.9 Environmental aspects 20
5.9.1 Temperature range 20
5.9.2 Water tightness 20
5.9.3 Water properties and incompatible materials 20
5.9.4 Exposed material 20
5.10 Guidance manual 20
5.11 List of hydrophone characteristics 20
Annex A (informative) Examples of information on hydrophone properties 21
A.1 General 21
A.2 Basic information 21
A.3 Sensitivity and frequency response 21
A.4 Directional response 24
A.5 Effective ~~radius~~ dimension 26
A.6 Dynamic range, linearity and electromagnetic interference 28
A.6.1 Lower dynamic limit 28
A.6.2 Upper dynamic limit 28
A.7 Electric output characteristics 28
A.8 Environmental aspects 28
Annex B (informative) Rationale 30

B.1 General 30
B.2 Changes to the determination of directional response 30
B.3 Changes to the determination of effective radius 30
Annex C (informative) Membrane hydrophone directivity model 32
C.1 General 32
C.2 Details of model 32
Bibliography 33

~~Figure A.1 – Frequency response of 0,2 mm needle hydrophone .....~~
Figure A.1 – Frequency response of 0,2 mm needle hydrophone in the range 1 MHz to 40 MHz 23
Figure A.2 – Frequency response of 0,2 mm needle hydrophone in the range 100 kHz to 1 MHz 23
Figure A.3 – Directional response of 0,2 mm needle hydrophone 26
Figure A.4 – Effective radius of 0,2 mm needle hydrophone 27
Figure A.5 – Comparison of modelled and experimentally derived directional response 27

Table A.1 – Example of basic information for 0,2 mm needle hydrophone assembly 21

INTERNATIONAL ELECTROTECHNICAL COMMISSION

_____

ULTRASONICS – HYDROPHONES –

Part 3: Properties of hydrophones for ultrasonic fields ~~up to 40 MHz~~

FOREWORD

1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
6) All users should ensure that they have the latest edition of this publication.
7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

This redline version of the official IEC Standard allows the user to identify the changes made to the previous edition IEC 62127-3:2007+AMD1:2013 CSV. A vertical bar appears in the margin wherever a change has been made. Additions are in green text, deletions are in strikethrough red text.

IEC 62127-3 has been prepared by IEC technical committee 87: Ultrasonics. It is an International Standard.

This second edition cancels and replaces the first edition published in 2007 and Amendment 1:2013. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition.

a) The upper frequency limit of 40 MHz has been removed.
b) Hydrophone sensitivity definitions have been changed to recognize sensitivities as complex-valued quantities.
c) Procedures to determine the effective hydrophone size have been changed according to the rationale outlined in Annex B.
d) Requirements on the frequencies for which the effective hydrophone size shall be provided have been changed to achieve practicality for increased frequency bands.
e) The new Annex B and Annex C have been added.
f) Annex A has been updated to reflect the changes of the normative parts.

The text of this International Standard is based on the following documents:

Draft	Report on voting
87/818/FDIS	87/824/RVD

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

The language used for the development of this International Standard is English.

This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available at www.iec.ch/members_experts/refdocs. The main document types developed by IEC are described in greater detail at www.iec.ch/publications.

A list of all parts of IEC 62127 series, published under the general title *Ultrasonics – Hydrophones,* can be found on the IEC website.

NOTE Words in **bold** in the text are defined in Clause 3.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under webstore.iec.ch in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

IMPORTANT – The "colour inside" logo on the cover page of this document indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

INTRODUCTION

The spatial and temporal distribution of acoustic pressure in an ultrasonic field in a liquid medium is commonly determined using miniature ultrasonic **hydrophones**. The properties of these **hydrophones** have been dealt with in a number of IEC standards in various aspects. The purpose of this document is to bring together all these specifications and to establish a common standard on the properties of ultrasonic **hydrophones**. The main **hydrophone** application in this context is the measurement of ultrasonic fields emitted by medical diagnostic equipment in water. Other medical applications are field measurements for therapy equipment such as that used in lithotripsy, high-intensity focused ultrasound (HIFU) and physiotherapy. **Hydrophones** are also used extensively in non-medical applications for both product development and quality control including:

– mapping of the ultrasound field within ultrasonic cleaning baths;

– characterization of acoustic fields used in transmission measurement systems (e.g. ultrasonic spectrometers, ultrasonic attenuation meters and velocimeters);

– characterization of acoustic fields used in reflection measurement systems (e.g. Doppler flowmeters).

While the term **hydrophone** can be used in a wider sense, it is understood here as referring to miniature piezoelectric **hydrophones**. It is this instrument type that is used today in various areas of ultrasonics and, in particular, to quantitatively characterize the field structure of medical diagnostic instruments. With regard to other pressure sensor types, such as those based on fibre optics, some of the requirements of this document are applicable to these as well but others are not. If in the future these other **hydrophone** types gain more importance in field measurement practice, their properties will have to be dealt with in a revised version of this document or in a separate one.

Underwater **hydrophones** as covered by IEC 60500, IEC 60565-1, and IEC 60565-2 are not included in this document, although there is an overlap in the frequency ranges. Underwater **hydrophones** are used in natural waters, even in the ocean, and this leads to different technical concepts and requirements. In addition, the main direction of acoustic incidence in underwater applications is ~~typically~~ at various angles and often at right angles to the **hydrophone axis**, whereas in this document it is assumed that the main direction of acoustic incidence is in the direction of the **hydrophone axis**.

~~In the past, ultrasonic **hydrophones** have been applied almost exclusively as amplitude sensors. At present a change can be seen and it is increasingly considered useful to have additional phase information, which, however, is only possible if the phase characteristics of the **hydrophone** have been determined during calibration. In this standard, therefore, requirements are specified for the amplitude aspect of the **hydrophone** sensitivity, and recommendations are provided for the phase aspect, as an option to be considered.~~

Historically, ultrasonic **hydrophones** were used almost exclusively as amplitude sensors. However, the complex-valued nature of a **hydrophone's** system response function is well understood and IEC 62127-1:2022 makes use of this within the deconvolution procedures it contains. In this document, requirements are specified for the amplitude aspect of the **hydrophone** sensitivity and recommendations are provided for the phase aspect which can be derived either via calibration, or via calculation methods that are discussed in IEC 62127-1:2022.

ULTRASONICS – HYDROPHONES –

Part 3: Properties of hydrophones for ultrasonic fields ~~up to 40 MHz~~

1 Scope

This part of IEC 62127 specifies relevant **hydrophone** characteristics.

This document is applicable to:

– **hydrophones** employing piezoelectric sensor elements, designed to measure the pulsed and continuous wave ultrasonic fields generated by ultrasonic equipment;

– **hydrophones** used for measurements made in water;

– **hydrophones** with or without an associated pre-amplifier.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 62127-1, *Ultrasonics – Hydrophones – Part 1: Measurement and characterization of medical ultrasonic fields* ~~*up to 40 MHz*~~

IEC 62127-2, *Ultrasonics – Hydrophones – Part 2: Calibration for ultrasonic fields up to 40 MHz*

3 Terms, definitions and symbols

For the purposes of this document, the terms and definitions given in IEC 62127-1, IEC 62127-2 and the following apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- IEC Electropedia: available at http://www.electropedia.org/
- ISO Online browsing platform: available at http://www.iso.org/obp

3.1
acoustic pulse waveform
temporal waveform of the **instantaneous acoustic pressure** at a specified position in an acoustic field and displayed over a period sufficiently long to include all significant acoustic information in a single pulse or tone-burst, or one or more cycles in a continuous wave

Note 1 to entry: Temporal waveform is a representation (e.g. oscilloscope presentation or formula) of the **instantaneous acoustic pressure**.

[SOURCE: IEC 62127-1:2022, 3.1]

3.2
directional response
description~~, generally presented graphically,~~ of the response of a **hydrophone**, as a function of direction of propagation of the incident plane sound wave, in a specified plane through the **reference centre** and at a specified frequency

Note 1 to entry: Although **directional response** is a complex-valued function, it is generally the modulus of **directional response** that is of most interest and this is commonly presented graphically.

[SOURCE: IEC 60565:2006, 3.5, modified – In the definition, ", generally presented graphically," has been deleted; "electro-acoustic transducer" has been replaced by "hydrophone"; and "radiated or incident sound" has been replaced by "incident plane sound wave,".]

3.3
effective hydrophone ~~radius~~ size
~~a_h, a_{h3}, a_{h6}~~
a_h
~~radius of a stiff disc~~ size of a theoretical receiver **hydrophone** that has a predicted **directional response** function with an angular width equal to the observed angular width

~~NOTE 1 The angular width is determined at a specified level below the peak of the **directional response** function. For the specified levels of 3 dB and 6 dB, the radii are denoted by a_{h3} and a_{h6} respectively.~~

Note 1 to entry: The ~~radius~~ size is usually a function of frequency. For representative experimental data, see [1].

Note 2 to entry: The **effective hydrophone size** is expressed in metres (m).

Note 3 to entry: For hydrophones with a circular geometry, the **effective hydrophone size** is a radius.

Note 4 to entry: For hydrophones with a rectangular geometry, the **effective hydrophone size** is the half of the largest value of the length or width.

[SOURCE: IEC 62127-1:2022, 3.20]

3.4
electric load impedance
$\underline{Z}_L$
complex electric input impedance (consisting of a real and an imaginary part) to which the **hydrophone** ~~or **hydrophone assembly**~~ unit output cable is connected or is intended to be connected

Note 1 to entry: The **electric load impedance** is expressed in ohms (Ω).

[SOURCE: IEC 62127-1:2022, 3.22]

~~**3.4**~~
~~**end-of-cable**~~
~~specification that relates to the end of the integral output cable if the **hydrophone** or **hydrophone assembly** is provided with such a cable; if the **hydrophone** or **hydrophone assembly** is not provided with an integral output cable, the specification relates to the output connector firmly connected with the **hydrophone** or **hydrophone assembly**, not to an extra cable~~

3.5
end-of-cable
<**hydrophone** or **hydrophone assembly** with integral output cable> relating to the end of the integral output cable

3.6
end-of-cable
<**hydrophone** or **hydrophone assembly** without integral output cable> relating to the output connector firmly connected with the **hydrophone** or **hydrophone assembly** and not to an extra cable

3.7
end-of-cable loaded sensitivity
~~**end-of-cable loaded sensitivity** of a **hydrophone** or **hydrophone assembly**~~
~~M_L~~
~~ratio of the instantaneous voltage at the end of any integral cable or output connector of a **hydrophone** or **hydrophone assembly**, when connected to a specified **electric load impedance**, to the instantaneous acoustic pressure in the undisturbed **free field** of a plane wave in the position of the **reference centre** of the **hydrophone** if the **hydrophone** were removed~~

~~NOTE **End-of-cable loaded sensitivity** is expressed in volts per pascal (V/Pa).~~

$\underline{M}_L(f)$
<of a **hydrophone** or **hydrophone assembly**> quotient of the Fourier transformed **hydrophone** voltage-time signal $\mathcal{F}(u_L(t))$ at the end of any integral cable or output connector of a **hydrophone** or **hydrophone assembly**, when connected to a specified **electric load impedance**, to the Fourier transformed **acoustic pulse waveform** $\mathcal{F}(p(t))$ in the undisturbed free field of a plane wave in the position of the **reference centre** of the **hydrophone** if the **hydrophone** were removed

$$\underline{M}_L(f) = \frac{\mathcal{F}(u_L(t))}{\mathcal{F}(p(t))} \quad (1)$$

Note 1 to entry: The **end-of-cable loaded sensitivity** is a complex-valued parameter. Its modulus is expressed in units of volt per pascal (V/Pa), its phase angle is expressed in degrees, and represents the phase difference between the electrical voltage and the sound pressure.

3.8
end-of-cable open-circuit sensitivity
~~**end-of-cable open-circuit sensitivity of a hydrophone**~~
~~M_c~~
~~ratio of the instantaneous, open-circuit voltage at the end of any integral cable or output connector of a **hydrophone** to the instantaneous acoustic pressure in the undisturbed **free field** of a plane wave in the position of the **reference centre** of the **hydrophone** if the **hydrophone** were removed~~

~~NOTE 1 **End-of-cable open-circuit sensitivity** is expressed in volts per pascal (V/Pa).~~

~~NOTE 2 This corresponds to the **free field** sensitivity as defined in IEC 60565:2006, 3.15.~~

$\underline{M}_c(f)$
<of a **hydrophone**> quotient of the Fourier transformed **hydrophone** open-circuit voltage-time signal $\mathcal{F}(u_c(t))$ at the end of any integral cable or output connector of a **hydrophone** to the Fourier transformed **acoustic pulse waveform** $\mathcal{F}(p(t))$ in the undisturbed free field of a plane wave in the position of the **reference centre** of the **hydrophone** if the **hydrophone** were removed

$$\underline{M}_c(f) = \frac{\mathcal{F}(u_c(t))}{\mathcal{F}(p(t))} \quad (2)$$

Note 1 to entry: The **end-of-cable open-circuit sensitivity** is a complex-valued parameter. Its modulus is expressed in units of volt per pascal (V/Pa), its phase angle is expressed in degrees, and represents the phase difference between the electrical voltage and the sound pressure.

3.9
end-of-cable loaded sensitivity level
$L_{M_L}(f)$
<of a **hydrophone** or **hydrophone assembly**> twenty times the logarithm to the base 10 of the quotient of the modulus of the **end-of-cable loaded sensitivity** $|\underline{M}_L(f)|$ to a reference sensitivity M_{ref}

$$L_{M_L}(f) = 20 \log_{10} \frac{|\underline{M}_L(f)|}{M_{ref}} \text{ dB} \quad (3)$$

Note 1 to entry: Commonly used values of the reference sensitivity M_{ref} are 1 V/µPa or 1 V/Pa.

Note 2 to entry: The **end-of-cable loaded sensitivity level** is expressed in decibels (dB).

3.10
free field
sound field in a homogeneous and isotropic medium in which the effects of boundaries are negligible

[SOURCE: IEC 60565:2006, 3.13]

3.11
hydrophone geometrical ~~radius~~ size
geometrical ~~radius~~ size of a hydrophone active element
a_g
~~radius~~ size defined by the ~~dimensions~~ lateral extents of the active element of a **hydrophone**

Note 1 to entry: The **hydrophone geometrical size** is expressed in metres (m).

Note 2 to entry: For **hydrophones** with a circular geometry, the **hydrophone geometrical size** is a radius.

Note 3 to entry: For **hydrophones** with a rectangular geometry, the **hydrophone geometrical size** is a half of the largest value of the length or width.

3.12
hydrophone
transducer that produces electric signals in response to ~~waterborne acoustic signals~~ pressure fluctuations in water

[SOURCE: IEC 60050-801:2021, 801-32-26]

3.13
hydrophone assembly
combination of **hydrophone** and **hydrophone pre-amplifier**

3.14
hydrophone axis
nominal symmetry axis of the **hydrophone** active element

Note 1 to entry: Unless stated otherwise (explicitly and quantitatively) by the manufacturer, it is understood for the purposes of this document that this is given by the apparent geometrical symmetry axis of the **hydrophone**.

3.15
hydrophone pre-amplifier
active electronic device connected to, or to be connected to, a particular **hydrophone** and reducing its output impedance

Note 1 to entry: A **hydrophone pre-amplifier** requires a supply voltage (or supply voltages).

Note 2 to entry: The **hydrophone pre-amplifier** may have a forward voltage transmission factor of less than one, i.e. it need not necessarily be a voltage amplifier in the strict sense.

3.16
reference centre
point on or near a **hydrophone** about which its acoustic receiving sensitivity is defined

Note 1 to entry: Unless stated otherwise (explicitly and quantitatively) by the manufacturer, it is understood for the purposes of this document that this is given by the geometrical centre of the front surface of the **hydrophone** active element.

[SOURCE: IEC 60565:2006, 3.25, modified – In the definition, "transducer" has been replaced by "hydrophone" and "transmitting responses" has been omitted. The note has been replaced.]

3.17
uncertainty
parameter, associated with the result of a measurement, that characterizes the dispersion of the values that could reasonably be attributed to the measurand

Note 1 to entry: See ISO/IEC Guide 98-3:2008 [2], 2.2.3.

[SOURCE: IEC 62127-1:2022, 3.92]

4 List of symbols

a_g	**hydrophone geometrical** ~~radius~~ **size**
a_h	**effective hydrophone** ~~**radius**~~ **size** ~~(a_{h3}, a_{h6}: with special reference to a 3 dB or 6 dB definition, respectively)~~
c	speed of sound in a medium
D_H	model function used during the determination of **effective hydrophone size** from a measured **directional response** of a **hydrophone**
f	frequency
k	wavenumber, equal to $2\pi/\lambda$
$L_{M_L}(f)$	**end-of-cable loaded sensitivity level**
$\underline{M}$	general symbol for the complex **hydrophone** sensitivity, $M = \lvert\underline{M}\rvert$ being its modulus and arg($\underline{M}$) being its argument (equal to phase angle)
~~M_c~~ $\underline{M}_c$	end-of-cable open-circuit sensitivity
~~M_L~~ $\underline{M}_L$	end-of-cable loaded sensitivity
$\underline{Z}_h$	complex electric output impedance of a **hydrophone** or **hydrophone assembly**
$\underline{Z}_L$	**electric load impedance**
θ	angle of incidence of an ultrasonic wave with respect to the **hydrophone axis** ~~(θ_3, θ_6: with special reference to 3 dB and 6 dB defined levels)~~