IEC 62386-101

Edition 3.0 2022-11

INTERNATIONAL STANDARD

NORME INTERNATIONALE

colour inside

Digital addressable lighting interface – Part 101: General requirements – System components

Interface d'éclairage adressable numérique – Partie 101: Exigences générales – Composants de système



IEC 62386-101:2022-11(en-fr)



THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2022 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

Droits de reproduction réservés. Sauf indication contraire, aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de l'IEC ou du Comité national de l'IEC du pays du demandeur. Si vous avez des questions sur le copyright de l'IEC ou si vous désirez obtenir des droits supplémentaires sur cette publication, utilisez les coordonnées ci-après ou contactez le Comité national de l'IEC de votre pays de résidence.

IEC Secretariat
3, rue de Varembé
CH-1211 Geneva 20
Switzerland

Tel.: +41 22 919 02 11
info@iec.ch
www.iec.ch

About the IEC
The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications
The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigendum or an amendment might have been published.

IEC publications search - webstore.iec.ch/advsearchform
The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee, …). It also gives information on projects, replaced and withdrawn publications.

IEC Just Published - webstore.iec.ch/justpublished
Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and once a month by email.

IEC Customer Service Centre - webstore.iec.ch/csc
If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: sales@iec.ch.

IEC Products & Services Portal - products.iec.ch
Discover our powerful search engine and read freely all the publications previews. With a subscription you will always have access to up to date content tailored to your needs.

Electropedia - www.electropedia.org
The world's leading online dictionary on electrotechnology, containing more than 22 300 terminological entries in English and French, with equivalent terms in 19 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

A propos de l'IEC
La Commission Electrotechnique Internationale (IEC) est la première organisation mondiale qui élabore et publie des Normes internationales pour tout ce qui a trait à l'électricité, à l'électronique et aux technologies apparentées.

A propos des publications IEC
Le contenu technique des publications IEC est constamment revu. Veuillez vous assurer que vous possédez l'édition la plus récente, un corrigendum ou amendement peut avoir été publié.

Recherche de publications IEC - webstore.iec.ch/advsearchform
La recherche avancée permet de trouver des publications IEC en utilisant différents critères (numéro de référence, texte, comité d'études, …). Elle donne aussi des informations sur les projets et les publications remplacées ou retirées.

IEC Just Published - webstore.iec.ch/justpublished
Restez informé sur les nouvelles publications IEC. Just Published détaille les nouvelles publications parues. Disponible en ligne et une fois par mois par email.

Service Clients - webstore.iec.ch/csc
Si vous désirez nous donner des commentaires sur cette publication ou si vous avez des questions contactez-nous: sales@iec.ch.

IEC Products & Services Portal - products.iec.ch
Découvrez notre puissant moteur de recherche et consultez gratuitement tous les aperçus des publications. Avec un abonnement, vous aurez toujours accès à un contenu à jour adapté à vos besoins.

Electropedia - www.electropedia.org
Le premier dictionnaire d'électrotechnologie en ligne au monde, avec plus de 22 300 articles terminologiques en anglais et en français, ainsi que les termes équivalents dans 19 langues additionnelles. Egalement appelé Vocabulaire Electrotechnique International (IEV) en ligne.

IEC 62386-101

Edition 3.0 2022-11

INTERNATIONAL STANDARD

NORME INTERNATIONALE

colour inside

Digital addressable lighting interface – Part 101: General requirements – System components

Interface d'éclairage adressable numérique – Partie 101: Exigences générales – Composants de système

INTERNATIONAL ELECTROTECHNICAL COMMISSION

COMMISSION ELECTROTECHNIQUE INTERNATIONALE

ICS 29.140.50; 29.140.99

ISBN 978-2-8322-5964-1

Warning! Make sure that you obtained this publication from an authorized distributor.
Attention! Veuillez vous assurer que vous avez obtenu cette publication via un distributeur agréé.

® Registered trademark of the International Electrotechnical Commission
Marque déposée de la Commission Electrotechnique Internationale

CONTENTS

FOREWORD 7
INTRODUCTION 9
1 Scope 10
2 Normative references 10
3 Terms and definitions 11
4 General 16
4.1 Purpose 16
4.2 Version number 16
4.3 System structure and architecture 16
4.4 System information flow 17
4.5 Command types 17
4.6 Bus units 18
4.6.1 Transmitters and receivers in bus units 18
4.6.2 Control gear 18
4.6.3 Input device 18
4.6.4 Single-master application controller 19
4.6.5 Multi-master application controller 19
4.6.6 Sharing an interface 19
4.6.7 Power for operation 20
4.7 Bus power supply and load calculations 21
4.7.1 Current demand coverage 21
4.7.2 Maximum signal current compliance 21
4.7.3 Simplified system calculation 21
4.8 Wiring 21
4.8.1 Wiring structure 21
4.8.2 Wiring specification 21
4.9 Electrical safety requirements 22
4.9.1 General 22
4.9.2 Insulation 22
4.9.3 Electric strength 22
4.9.4 Limitation of the touch current from the device to the bus 22
4.10 Earthing of the bus 23
4.11 Power interruptions at bus units 23
4.11.1 Different levels of power interruptions 23
4.11.2 Short power interruptions of external power supply 23
4.11.3 External power cycle 24
4.11.4 Short interruptions of bus power supply 24
4.11.5 Bus power down 24
4.11.6 System start-up timing 24
5 Electrical specification 26
5.1 General 26
5.2 Marking of the interface 26
5.3 Capacitors between the interface and earth 26
5.4 Signal voltage rating 26
5.5 Signal current rating 27
5.6 Marking of bus powered bus unit 27

5.7 Signal rise time and fall time 28
6 Bus power supply 29
6.1 General 29
6.2 Marking of the bus power supply terminals 29
6.3 Capacitors between the interface and earth 29
6.4 Voltage rating 29
6.5 Current rating 30
6.5.1 General current rating 30
6.5.2 Single bus power supply current rating 30
6.5.3 Integrated bus power supply current rating 30
6.5.4 Dynamic behaviour of the bus power supply 30
6.6 Bus power supply timing requirements 32
6.6.1 Short power supply interruptions 32
6.6.2 Short circuit behaviour 32
7 Transmission protocol structure 33
7.1 General 33
7.2 Bit encoding 33
7.2.1 Start bit and data bit encoding 33
7.2.2 Stop condition encoding 33
7.3 Frame description 33
7.4 Frame types 34
7.4.1 16-bit forward frame 34
7.4.2 24-bit forward frame 34
7.4.3 32-bit forward frame 34
7.4.4 Reserved forward frame 34
7.4.5 Backward frame 34
7.4.6 Proprietary forward frames 34
8 Timing 35
8.1 Single-master transmitter timing 35
8.1.1 Single-master transmitter bit timing 35
8.1.2 Single-master transmitter frame sequence timing 35
8.2 Receiver timing 36
8.2.1 Receiver bit timing 36
8.2.2 Receiver bit timing violation 37
8.2.3 Receiver frame size violation 38
8.2.4 Receiver frame sequence timing 38
8.2.5 Reception of backward frames 38
8.3 Multi-master transmitter timing 39
8.3.1 Multi-master transmitter bit timing 39
8.3.2 Multi-master transmitter frame sequence timing 39
9 Method of operation 40
9.1 Dealing with frames and commands 40
9.1.1 General 40
9.1.2 Frame received or rejected 41
9.1.3 Frame accepted or ignored 41
9.1.4 Command accepted or ignored 41
9.1.5 Command executed or discarded 41
9.2 Collision avoidance, collision detection and collision recovery 42

9.2.1 General 42
9.2.2 Collision avoidance 42
9.2.3 Collision detection 42
9.2.4 Collision recovery 44
9.3 Transactions 45
9.4 Send-twice forward frames and send-twice commands 45
9.5 Command iteration 46
9.6 Usage of a shared interface 46
9.6.1 General 46
9.6.2 Backward frames 47
9.6.3 Forward frames 47
9.7 Use of multiple bus power supplies 47
10 Declaration of variables 47
11 Definition of commands 47
Annex A (informative) Background information for systems 48
A.1 Wiring information 48
A.2 System architectures 49
A.2.1 General 49
A.2.2 Single-master architecture 49
A.2.3 Multi-master architecture with one application controller 50
A.2.4 Multi-master architecture with more than one application controller 51
A.2.5 Multi-master architecture with integrated input device 52
A.2.6 Multi-master architecture with integrated input device and power supply 53
A.3 Collision detection 54
A.4 Timing definition explanations 55
A.4.1 General 55
A.4.2 Receiver timing 55
A.4.3 Transmitter timing 55
A.4.4 Grey areas 56
A.5 Maximum current consumption calculation explanation 56
A.5.1 Single bus power supply 56
A.5.2 Multiple bus power supplies 57
A.5.3 Redundant bus power supplies 58
A.6 Communication layer overview 59
A.6.1 General 59
A.6.2 Physical layer 60
A.6.3 Data link layer 60
A.6.4 Network layer 60
A.6.5 Transport layer 60
A.6.6 Session layer 60
A.6.7 Presentation layer 60
A.6.8 Application layer 60
A.7 Effects of combining version number 1 and version number 2.y devices 60
Annex B (informative) Touch current 62
Bibliography 63

Figure 1 – IEC 62386 graphical overview 9
Figure 2 – System structure example 17

Figure 3 – Communication between bus units (example) 17
Figure 4 – Example of a shared interface 20
Figure 5 – Start-up timing example 25
Figure 6 – Maximum signal rise and fall time measurements 28
Figure 7 – Minimum signal rise and fall time measurements 29
Figure 8 – Bus power supply current behaviour 31
Figure 9 – Bus power supply voltage behaviour 32
Figure 10 – Frame example 33
Figure 11 – Bi-phase encoded bits 33
Figure 12 – Bit timing example 35
Figure 13 – Settling time illustration 35
Figure 14 – Receiver timing decision example 37
Figure 15 – Dealing with frames and commands 41
Figure 16 – Collision detection timing decision example 44
Figure 17 – Collision recovery example 45
Figure A.1 – Single-master architecture example 50
Figure A.2 – Multi-master architecture example with one application controller 51
Figure A.3 – Multi-master architecture example with two application controllers 52
Figure A.4 – Multi-master architecture example with integrated input device 53
Figure A.5 – Multi-master architecture example with integrated input device and bus power supply 54
Figure A.6 – Collision detection timing diagram 55
Figure A.7 – Transmitter and receiver timing illustration 56
Figure A.8 – Bus power supply current values 57
Figure A.9 – Current demand coverage 57
Figure A.10 – Combination of four bus power supplies 58
Figure A.11 – Redundant bus power supplies 58
Figure B.1 – Touch current from a bus unit 62
Figure B.2 – Summation of touch currents from several bus units 62

Table 1 – System components 16
Table 2 – Transmitters and receivers in bus units 18
Table 3 – Power-interruption timing of external power 23
Table 4 – Power-interruption timing of bus power 23
Table 5 – Short power interruptions 24
Table 6 – Start-up timing 25
Table 7 – System voltage levels 26
Table 8 – Receiver voltage levels 27
Table 9 – Transmitter voltage levels 27
Table 10 – Current rating 27
Table 11 – Signal rise and fall times 28
Table 12 – Bus power supply output voltage 30
Table 13 – Bus power supply current rating 30

Table 14 – Bus power supply dynamic behaviour 31
Table 15 – Short circuit timing behaviour 32
Table 16 – Transmitter bit timing 35
Table 17 – Transmitter settling time values 36
Table 18 – Receiver timing starting at the beginning of a logical bit 37
Table 19 – Receiver timing starting at an edge inside of a logical bit 37
Table 20 – Receiver settling time values 38
Table 21 – Multi-master transmitter bit timing 39
Table 22 – Multi-master transmitter settling time values 40
Table 23 – Checking a logical bit, starting at an edge at the beginning of the bit 43
Table 24 – Checking a logical bit, starting at an edge inside the bit 43
Table 25 – Collision recovery timing 44
Table 26 – Transmitter command iteration timing 46
Table 27 – Receiver command iteration timing 46
Table A.1 – Maximum cable length 49
Table A.2 – OSI layer model of the IEC 62386 series 59
Table A.3 – Effects of combining version number 1 and version number 2.y devices 61

INTERNATIONAL ELECTROTECHNICAL COMMISSION

_____

DIGITAL ADDRESSABLE LIGHTING INTERFACE –

Part 101: General requirements – System components

FOREWORD

1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
6) All users should ensure that they have the latest edition of this publication.
7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

IEC 62386-101 has been prepared by IEC technical committee 34: Lighting. It is an International Standard.

This third edition cancels and replaces the second edition published in 2014 and Amendment 1:2018. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

a) the scope has been updated;
b) safety and earthing have been updated and extended;
c) references have been updated;
d) the use of bus-power and external-power has been clarified;
e) polarity sensitivity for bus units including a bus power supply has been updated;

f) frame sizes of 32 bits are no longer reserved.

The text of this International Standard is based on the following documents:

Draft	Report on voting
34/947/FDIS	34/988/RVD

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

The language used for the development of this International Standard is English.

This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available at www.iec.ch/members_experts/refdocs. The main document types developed by IEC are described in greater detail at www.iec.ch/standardsdev/publications.

This Part 101 of IEC 62386 is intended to be used in conjunction with:

- Part 102, which contains general requirements for the relevant product type (control gear), and with the appropriate Part 2xx (particular requirements for control gear);
- Part 103, which contains general requirements for the relevant product type (control devices), and the appropriate Part 3xx (particular requirements for control devices);
- Part 104, which contains general requirements for wireless and alternative wired system components;
- Part 105, which contains particular requirements for firmware transfer for control gear and control devices.

A list of all parts in the IEC 62386 series, published under the general title *Digital addressable lighting interface*, can be found on the IEC website

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under webstore.iec.ch in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

IMPORTANT – The "colour inside" logo on the cover page of this document indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

INTRODUCTION

IEC 62386 contains several parts, referred to as series. The IEC 62386 series specifies a bus system for control by digital signals of electronic lighting equipment. The IEC 62386-1xx series includes the basic specifications. Part 101 contains general requirements for system components, Part 102 extends this information with general requirements for control gear and Part 103 extends it further with general requirements for control devices. Parts 104 and 105 can be applied to control gear or control devices. Part 104 gives requirements for wireless and alternative wired system components. Part 105 describes firmware transfer. Part 150 gives requirements for an auxiliary power supply which can be stand-alone, or built into control gear or control devices.

The IEC 62386-2xx series extends the general requirements for control gear with lamp specific extensions (mainly for backward compatibility with Edition 1 of IEC 62386) and with control gear specific features.

The IEC 62386-3xx series extends the general requirements for control devices with input device specific extensions describing the instance types as well as some common features that can be combined with multiple instance types.

This third edition of IEC 62386-101 is intended to be used in conjunction with IEC 62386-102 and with the various parts that make up the IEC 62386-2xx series for control gear, together with IEC 62386-103 and the various parts that make up the IEC 62386-3xx series of particular requirements for control devices. The division into separately published parts provides for ease of future amendments and revisions. Additional requirements will be added as and when a need for them is recognized.

The setup of the standards is graphically represented in Figure 1 below.




Figure 1 – IEC 62386 graphical overview

When this part of IEC 62386 refers to any of the clauses of the other parts of the IEC 62386-1xx series, the extent to which such a clause is applicable is specified. The other parts also include additional requirements, as necessary.

All numbers used in this document are decimal numbers unless otherwise noted. Hexadecimal numbers are given in the format 0xVV, where VV is the value. Binary numbers are given in the format XXXXXXXXb or in the format XXXX XXXX, where X is 0 or 1, "x" in binary numbers means "don't care".

DIGITAL ADDRESSABLE LIGHTING INTERFACE –

Part 101: General requirements – System components

1 Scope

This part of IEC 62386 is applicable to system components in a bus system for control by digital signals of electronic lighting equipment.

The control methods, algorithms and data exchange methods of application controllers used for lighting control are not within the scope of the IEC 62386 series. EMC requirements are not within the scope of the IEC 62386 series.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 61347-1:2015, *Lamp controlgear – Part 1: General and safety requirements*
IEC 61347-1:2015/AMD1:2017

IEC 62386-102:2022, *Digital addressable lighting interface – Part 102: General requirements – Control gear*

IEC 62386-103:2022, *Digital addressable lighting interface – Part 103: General requirements – Control devices*

IEC 62386-104, *Digital addressable lighting interface – Part 104: General requirements – Wireless and alternative wired system components*

IEC 62386-105, *Digital addressable lighting interface – Part 105: Particular requirements for control gear and control devices – Firmware Transfer*

IEC 62386-2xx (all parts), *Digital addressable lighting interface – Part 2xx: Particular requirements for control gear*

IEC 62386-3xx (all parts), *Digital addressable lighting interface – Part 3xx: Particular requirements for control devices*

IEC 61000-4-11, *Electromagnetic compatibility (EMC) – Part 4-11:Testing and measurement techniques – Voltage dips, short interruptions and voltage variations immunity tests for equipment with input current up to 16 A per phase*

IEC 60664-1, *Insulation coordination for equipment within low-voltage supply systems – Part 1: Principles, requirements and tests*

IEC 60990:2016, *Methods of measurement of touch current and protective conductor current*

IEC 61643-11, *Low-voltage surge protective devices – Part 11: Surge protective devices connected to low-voltage power systems – Requirements and test methods*

3 Terms and definitions

For the purposes of this document, the following terms and definitions apply.

ISO and IEC maintain terminology databases for use in standardization at the following addresses:

- IEC Electropedia: available at http://www.electropedia.org/
- ISO Online browsing platform: available at http://www.iso.org/obp

3.1
active state
phase of low level voltage during a transmission

Note 1 to entry: Noise and short pulses may be ignored and therefore do not change the state.

3.2
advanced bus power supply
bus power supply capable of checking the bus for fault conditions before switching on its output continuously

Note 1 to entry: Examples of fault conditions are mains voltage connected to the bus or short circuit of the bus.

3.3
application controller
control device that is connected to the bus and sends commands in order to control input devices and/or control gear connected to the same bus

3.4
backward frame
frame used for backward transmission

3.5
backward transmission
transmission of data as a reply to and triggered by a forward transmission

3.6
bus
two-wire connection line carrying power and frames

3.7
bus powered
drawing the power for operation from the bus

3.8
bus power down
bus power interruption longer than 45 ms

3.9
bus power interruption
abnormal condition where the bus voltage is in the receiver low level voltage range, but not because of a transmitter being active

3.10
bus power supply
unit feeding defined energy to the bus

3.11
bus unit
logical unit or combination of logical units, containing one transmitter and optionally one receiver

Note 1 to entry: See 4.6.6.

3.12
charge overshoot
product of current overshoot time and current overshoot amplitude

3.13
collision
situation in which two or more transmitters are transmitting simultaneously

Note 1 to entry: Collisions can go unnoticed if the transmission timing is sufficiently similar and the transmitted frame content is identical.

3.14
command
forward transmission with appropriate information content, intended to cause a reaction in the receiver

Note 1 to entry: A receiver, having decoded a command can, when appropriate, decide to ignore the command.

Note 2 to entry: Refer to IEC 62386-102, IEC 62386-103, IEC 62386-104, IEC 62386-105, the IEC 62386-2xx series and IEC 62386-3xx series for command definitions.

3.15
control device
device that is connected to the bus and sends commands to other devices connected to the same bus

Note 1 to entry: Control devices can also receive commands and backward transmissions. Control devices can contain application controllers and/or input devices.

3.16
control gear
device that is connected to the bus and receives commands in order to control at least one output in a direct or indirect way

Note 1 to entry: The lamp controlgear described in IEC 61347-1 can cover control gear.

3.17
current overshoot time
time per bit during which the current supplied by the bus power supply is above the allowed maximum of 250 mA after a transition from idle state to active state

Note 1 to entry: See 6.5.4.

3.18
destroy area
time slot where a valid frame cannot be ensured

3.19
edge
change from active state to idle state or vice versa

3.20
event message
command sent by a control device in order to distribute information on the bus

3.21
externally powered
drawing the power for operation from a separate power supply

Note 1 to entry: The separate power supply can be mains power, DC power, etc.

3.22
forward frame
frame used for forward transmission

3.23
forward frame priority
property of a forward frame used to prioritize access to the bus

3.24
forward transmission
transmission of data initiated by a control device

Note 1 to entry: See also 3.5.

3.25
frame
set of consecutive bits followed by a stop condition

Note 1 to entry: See Clause 8 for the timing definition of a stop condition.

3.26
grey area
time slot containing the decision point separating adjacent time slots

Note 1 to entry: A grey area indicates that the decision is arbitrary. Typically the previous or next entry in a table should be used as an action. See Clause 8 for further information.

3.27
idle state
phase of high level voltage between and during transmissions

Note 1 to entry: Noise and short pulses may be ignored and therefore do not change the state.

3.28
input device
control device that is connected to the bus and sends commands using a multi-master transmitter in order to distribute information about user actions and/or sensor values

Note 1 to entry: Input devices do not transmit commands to the control gear.

3.29
instance
signal processing unit of an input device

3.30
instruction
command transmitted to change one or more variables in a bus unit

3.31
integrated bus power supply
bus power supply integrated into a physical device also containing a bus unit

3.32
interface
terminals or wires for connection to the bus

3.33
logical unit
control gear or control device that conforms to IEC 62386-102 or IEC 62386-103

Note 1 to entry: See 4.6.6.

3.34
multi-master application controller
application controller that is capable of sharing the bus with other control devices and uses a multi-master transmitter

3.35
multi-master transmitter
transmitter that follows the multi-master timing and supports collision detection, collision avoidance, and collision recovery methods

Note 1 to entry: Multi-master transmitters are used in control devices intended for multi-master control systems.

3.36
proprietary forward frame
forward frame for manufacturer-specific purposes

3.37
query
command transmitted to observe a variable in a bus unit

Note 1 to entry: A query can be followed by a backward frame.

3.38
receiver
part of a bus unit detecting and decoding frames on the bus

3.39
reserved
intended for future use

3.40
send-twice command
command transmitted by send-twice forward frames

Note 1 to entry: Refer to 9.4, IEC 62386-102, IEC 62386-103, the IEC 62386-2xx series and IEC 62386-3xx series for further details on send-twice commands.

3.41
send-twice forward frame
forward frame that needs to be transmitted twice with a limited settling time in order to be processed by the receiver

3.42
settling time
time during which the bus is in idle state after the last rising edge of one frame and before the first falling edge of the next frame

3.43
single-master application controller
application controller that is not required to use a multi-master transmitter

Note 1 to entry: The implication is that no other application controllers, and no other input devices with event messages enabled, may be connected to the bus.

3.44
standard forward frame
forward frame as defined and described in the IEC 62386 series

3.45
system failure
bus power interruption longer than 550 ms

3.46
transaction
uninterruptible set of one or more consecutive forward frames transmitted from a single control device, with zero or more backward frames

3.47
transmitter
part of a bus unit placing frames on the bus

3.48
voltage overshoot time
time per bit during which the voltage supplied by the bus power supply is above 20,5 V after a transition from active state to idle state

Note 1 to entry: See 6.5.4.

3.49
voltage undershoot time
time per bit during which the voltage supplied by the bus power supply is below 12,0 V after a transition from active state to idle state

Note 1 to entry: See 6.5.4.

3.50
frame accepted
frame that has been received and uses the correct frame type and data bit content

3.51
frame ignored
frame received but not accepted

3.52
frame received
frame with a valid start bit, valid data bits, and a stop condition

3.53
frame rejected
frame not received

3.54
FELV
functional extra-low voltage
ELV in a circuit provided for functional purposes and not fulfilling the requirements for SELV (or PELV)

Note 1 to entry: FELV has basic insulation from LV.

Note 2 to entry: An FELV circuit is not safe to touch.

[SOURCE: IEC 60598-1:2020, 1.2.42.1, modified – The notes have been added.]

4 General

4.1 Purpose

The standardization of the digital addressable lighting interface is intended to achieve interoperable multi-vendor operation below the level of building management systems.

Annex A gives further information for systems.

NOTE The IEC 63044 series and ISO/IEC 14762 are not applicable for the purposes of this IEC 62386 series. The IEC 63044 series can be applicable to application controllers if intended to be used as HBES/BACS.

4.2 Version number

The version shall be in the format "x.y", where the major version number x is in the range of 0 to 62 and the minor version number y is in the range of 0 to 2. When the version number is encoded into a byte, the major version number x shall be placed in bits 7 to 2 and the minor version number y shall be placed in bits 1 to 0.

At each amendment to an edition of IEC 62386-101 the minor version number shall be incremented by one.

At a new edition of IEC 62386-101 the major version number shall be incremented by one and the minor version number shall be set to 0.

The current version number is "3.0".

NOTE IEC documents are generally subject to two amendments before a new edition is prepared.

4.3 System structure and architecture

A system shall consist of the components listed in Table 1.

Table 1 – System components

Component	Quantity	For detailed information see
Bus power supply	≥ 1	Clause 6
Control gear	≥ 0	IEC 62386-102
Application controller	≥ 1	IEC 62386-103
Input devices	≥ 0	IEC 62386-103
Bus	1	Subclause 4.8 and Clause A.2

In a system all bus units as well as the bus power supplies are connected in parallel to the bus.

NOTE As a consequence of this, every frame is visible to all power supplies, control gear, and control devices on the bus.

Figure 2 shows a system structure example.