IEC 62561-8

Edition 1.0 2026-06

INTERNATIONAL STANDARD

COMMENTED VERSION

Lightning protection system components (LPSC) -
Part 8: Requirements for components for ~~isolated~~ electrically insulated LPS

ICS 29.020; 91.120.40

ISBN 978-2-8327-1340-2

THIS PUBLICATION IS COPYRIGHT PROTECTED
Copyright © 2026 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

IEC Secretariat
3, rue de Varembé
CH-1211 Geneva 20
Switzerland

Tel.: +41 22 919 02 11
info@iec.ch
www.iec.ch

About the IEC
The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications
The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigendum or an amendment might have been published.

IEC publications search - webstore.iec.ch/advsearchform
The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee, …). It also gives information on projects, replaced and withdrawn publications.

IEC Just Published - webstore.iec.ch/justpublished
Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and once a month by email.

IEC Customer Service Centre - webstore.iec.ch/csc
If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: sales@iec.ch.

IEC Products & Services Portal - products.iec.ch
Discover our powerful search engine and read freely all the publications previews, graphical symbols and the glossary. With a subscription you will always have access to up to date content tailored to your needs.

Electropedia - www.electropedia.org
The world's leading online dictionary on electrotechnology, containing more than 22 500 terminological entries in English and French, with equivalent terms in 25 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

Warning! Make sure that you obtained this publication from an authorized distributor.

CONTENTS

FOREWORD 4
INTRODUCTION 6
1 Scope 7
2 Normative references 7
3 Terms and definitions 8
4 Insulating stand-off 10
4.1 Classification 10
4.1.1 General 10
4.1.2 According to conductor clamping arrangement 10
4.1.3 According to mounting 10
4.2 Requirements 10
4.2.1 General 10
4.2.2 Construction 10
4.2.3 Mechanical requirements 11
4.2.4 Electrical requirements 12
4.2.5 Documentation and installation instructions 13
4.2.6 Marking 13
4.3 Tests 14
4.3.1 General test conditions 14
4.3.2 General test setup 16
4.3.3 Documentation 17
4.3.4 Marking test 17
4.3.5 Environmental influence tests 17
4.3.6 Mechanical tests 18
4.3.7 Electrical test 25
4.4 Electromagnetic compatibility (EMC) 27
4.5 Structure and content of the test report 27
4.5.1 General 27
4.5.2 Report identification 27
4.5.3 Specimen description 28
4.5.4 Characterization and condition of the test specimen or test assembly 28
5 Insulating down-conductor 29
5.1 Classification 29
5.2 Lightning current carrying capability 29
5.3 Preferred values of equivalent separation distance (s_e) 30
5.4 Requirements 30
5.4.1 General 30
5.4.2 Environmental requirements 30
5.4.3 Mechanical requirements 30
5.4.4 Electrical requirements 30
5.4.5 Documentation 31
5.4.6 Marking 31
5.5 Tests 32
5.5.1 General test conditions 32
5.5.2 General test setup 33
5.5.3 Documentation 34

5.5.4 Marking test 34
5.5.5 Environmental influence tests 34
5.5.6 Mechanical tests 36
5.5.7 Electrical tests 40
5.6 Electromagnetic compatibility (EMC) 48
5.7 Structure and content of the test report 48
5.7.1 General 48
5.7.2 Report identification 49
5.7.3 Specimen description 49
5.7.4 Characterization and condition of the test specimen or test assembly 49
5.7.5 Insulating down-conductor 49
5.7.6 Standards and references 50
5.7.7 Test procedure 50
5.7.8 Testing equipment description 50
5.7.9 Measuring instruments description 50
5.7.10 Results and parameters recorded 50
Annex A (normative) Environmental test – Corrosion resistance 51
A.1 General 51
A.2 Salt mist test 51
A.3 Humid sulphurous atmosphere test 51
A.4 Ammonia atmosphere test 51
Annex B (normative) Environmental test – Resistance to ultraviolet light 52
B.1 General 52
B.2 Test 52
B.3 First alternative test to Clause B.2 52
B.4 Second alternative test to Clause B.2 52
Annex C (normative) Flow chart of tests for insulating stand-offs 53
Annex D (normative) Flow chart of tests for insulating down-conductors 55
Annex E (informative) High voltage impulse test to determine the actual correction factor kx for insulating stand-offs 57
E.1 Specimen preparation 57
E.2 Test setup 57
E.3 Test procedure 57
Annex F (informative) Installation arrangement test to determine the influence of supporting structures on the separation distance 59
F.1 General 59
F.2 Specimen preparation for the high voltage installation arrangement test 59
F.3 Test procedure 60
Annex G (normative) Alternate test arrangement for high voltage impulse test 61
Annex H (normative) Applicability of previous tests 64
Bibliography 65
List of comments 66

Figure 1 – Typical insulating stand-off with a metallic fastener 11
Figure 2 – Typical insulating stand-off with a non-metallic fastener 12
Figure 3 – Typical insulating stand-off with a metallic fastener prepared for testing 14
Figure 4 – Typical insulating stand-off with a non-metallic fastener prepared for testing 15

Figure 5 – Basic arrangement for bending test 19
Figure 6 – Pendulum hammer test apparatus 20
~~Figure 7 – Basic arrangement for pull out test on rigidly fixed insulating stand-off ....~~
Figure 7 – Two alternative basic arrangements for pull out test on rigidly fixed insulating stand-off 22
~~Figure 8 – Basic arrangement for pull out test on free standing insulating stand-off ....~~
Figure 8 – Two alternative basic arrangements for pull out test on free standing insulating stand-off 24
Figure 9 – ~~General description of the~~ Typical test arrangement for the high voltage impulse test of an insulating stand-off 25
Figure 10 – Specimen preparation for UV light test 35
~~Figure 11 – Basic arrangement for lateral load test ....~~
~~Figure 12 – Typical arrangement for axial movement test ....~~
~~Figure 14 – General description of the test setup for the high voltage impulse test of the insulating down-conductor ....~~
Figure 11 – Basic arrangement for the lightning current carrying capability test 41
Figure 12 – Test arrangements for the high voltage impulse test of the insulating down-conductor 44
~~Figure 15 – Test arrangement for insulating down-conductors ....~~
~~Figure 16 – Test arrangement for partial insulating down -conductors ....~~
Figure 13 – Test arrangements for insulting down conductors 47
Figure C.1 – Tests for insulating stand-offs 54
Figure D.1 – Tests for insulating down-conductors 56
~~Figure E.1 – General description of the test arrangement to determine the actual correction factor k_x for insulating stand-offs ....~~
Figure F.1 – Example for installation arrangement test – Specimen under test 59
Figure F.2 – Alternate example for installation arrangement test – Specimen under test 60
Figure G.1 – Typical test arrangement for the high voltage impulse test of an insulating stand-off – Alternate test arrangement to Figure 9 61
Figure G.2 – General description of the test setup for the high voltage impulse test of the insulating down-conductor – Alternate test set-up to Figure 12 a) 62
Figure G.3 – Alternate test arrangement for the high voltage impulse test of the insulating down conductor – alternate test set-up to Figure 12 b) 62
Figure G.4 – General description rod tip and rod – Plane arrangement geometry 63

Table 1 – Type test requirements for an insulating stand-off 16
Table 2 – Lightning impulse current (I_{imp}) parameters 29
Table 3 – Type test requirements for an insulating down-conductor ~~and fasteners~~ 33
Table H.1 – Differences in the requirements for electrically insulated LPS complying with IEC TS 62561-8:2018 64

INTERNATIONAL ELECTROTECHNICAL COMMISSION

_____

Lightning protection system components (LPSC) - Part 8: Requirements for components for ~~isolated~~ electrically insulated LPS 1

FOREWORD

1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
6) All users should ensure that they have the latest edition of this publication.
7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
9) IEC draws attention to the possibility that the implementation of this document may involve the use of (a) patent(s). IEC takes no position concerning the evidence, validity or applicability of any claimed patent rights in respect thereof. As of the date of publication of this document, IEC had not received notice of (a) patent(s), which may be required to implement this document. However, implementers are cautioned that this may not represent the latest information, which may be obtained from the patent database available at https://patents.iec.ch. IEC shall not be held responsible for identifying any or all such patent rights.

This redline version of the official IEC Standard allows the user to identify the changes made to the previous edition IEC TS 62561-8:2018. A vertical bar appears in the margin wherever a change has been made. Additions are in green text, deletions are in strikethrough red text.

IEC 62561-8 has been prepared by IEC technical committee 81: Lightning protection. It is an International Standard.

This first edition cancels and replaces IEC TS 62561-8 published in 2018. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to IEC TC 62561-8:2018:

a) title and scope of the standard has been adjusted;
b) the document has been updated in line with IEC 60068-2-52:2017 on salt mist treatment;
c) the document has been updated in line with ISO 22479:2019 on humid sulphureous atmosphere treatment;
d) two different possible example configurations for pull out tests have been introduced;
e) additional information on pollution has been included;
f) an alternate test arrangement for high voltage impulse test has been included;
g) a new normative Annex H for applicability of previous tests has been introduced;
h) pass criteria for high voltage impulse testing updated;
i) explanation on high voltage impulse testing with negative polarity has been added.

The text of this International Standard is based on the following documents:

Draft	Report on voting
81/806/FDIS	81/808/RVD

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

The language used for the development of this International Standard is English.

This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available at www.iec.ch/members_experts/refdocs. The main document types developed by IEC are described in greater detail at www.iec.ch/publications.

A list of all parts in the 62561 series, published under the general title *Lightning protection system components (LPSC)*, can be found on the IEC website.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under webstore.iec.ch in the data related to the specific document. At this date, the document will be

– reconfirmed,
– withdrawn, or
– revised.

INTRODUCTION

This part of IEC 62561 deals with the requirements and tests for lightning protection system components (LPSC), specifically components for electrically insulated LPS, used for the installation of a lightning protection system (LPS) designed and implemented according to the IEC 62305 series [1][1].

[1] Numbers in square brackets refer to the Bibliography.

1 Scope

This document specifies the requirements and tests for components used for electrically insulated LPS. These components, which can reduce the separation distance, are as follows:

– insulating stand-offs, used in conjunction with an air-termination system and down-conductors with the aim of maintaining the proper separation distance~~, and the requirements and tests for insulating down-conductors, including their specific fasteners, able to reduce the separation distance.~~;

– insulating down-conductors, including their specific fasteners. **2**

Testing of insulating stand-offs and insulating down-conductor components for an explosive atmosphere is not covered by this document.

~~Requirements and tests for other types of components for isolated LPS are under consideration.~~

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60060-2:~~2010~~2025, *High-voltage test techniques - Part 2: Measuring systems*

IEC 60068-2-52:2017, *Environmental testing - Part 2-52: Tests - Test Kb: Salt mist, cyclic (sodium chloride solution)* **3**

IEC 60068-2-75:2014, *Environmental testing - Part 2-75: Tests - Test Eh: Hammer tests*

IEC 61083-1, *Instruments and software used for measurements in high-voltage ~~impulse~~ and high-current tests - Part 1: Requirements for instruments for impulse tests*

IEC 61083-2, *Instruments and software used for measurement in high-voltage and high-current tests - Part 2: Requirements for software for tests with impulse voltages and currents*

IEC 62305-3, *Protection against lightning - Part 3: Physical damage to structures and life hazard*

IEC 62561-1:~~2017~~2023, *Lightning protection system components (LPSC) - Part 1: Requirements for connection components*

IEC 62561-2:~~2012~~2025, *Lightning protection system components (LPSC) - Part 2: Requirements for conductors and earth electrodes*

IEC 62561-4, *Lightning protection system components (LPSC) - Part 4: Requirements for conductor fasteners*

ISO 4892-2, *Plastics - Methods of exposure to laboratory light sources - Part 2: Xenon-arc lamps*

ISO 4892-3:~~2016~~2024, *Plastics - Methods of exposure to laboratory light sources - Part 3: Fluorescent UV lamps*

ISO 4892-4, *Plastics - Methods of exposure to laboratory light sources - Part 4: Open-flame carbon-arc lamps*

~~ISO 6988:1985, *Metallic and other non-organic coatings – Sulfur dioxide test with general condensation of moisture*~~

ISO 6957:1988, *Copper alloys - Ammonia test for stress corrosion resistance*

ISO 22479:2019, *Corrosion of metals and alloys - Sulfur dioxide test in a humid atmosphere (fixed gas method)* **4**

3 Terms and definitions

For the purposes of this document, the following terms and definitions apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

– IEC Electropedia: available at http://www.electropedia.org/

– ISO Online browsing platform: available at http://www.iso.org/obp

3.1
insulating stand-off
non-metallic or composite component, consisting of the insulator and fixation parts, designed to retain, support and insulate the air-termination system ~~and/~~or down-conductors at a required separation distance

3.2
effective length correction factor
k_x
factor evaluating the different withstand voltages of air gaps and insulators under test voltages ~~and environmental influences like pollution and/or UV light degradation~~

3.3
steepness correction factor
c_{is_st}
<insulating stand-off> factor considering the effect of higher steepness and the probability of occurrence of subsequent negative short strokes on the ~~flashover~~ disruptive voltage of an insulating stand-off

Note 1 to entry: The value is defined in the test procedure.

3.4
effective length
l_{eff}
<insulating stand-off> length (distance) of an air gap with equivalent breakdown behaviour to an insulating stand-off

3.5
~~**corrected distance value of an**~~ **insulating length**
l_{st}
<insulating stand-off> shortest measured clearance distance between two conductive elements of different electrical potential, for example between a metallic conductor fastener and a mounting assembly