IEC 62873-3-3

Edition 2.0 2022-11
REDLINE VERSION

INTERNATIONAL STANDARD

colour inside

Residual current operated circuit-breakers for household and similar use – Part 3-3: Specific requirements for ~~RCDs~~ devices with screw-type terminals for external untreated aluminium conductors and with aluminium screw-type terminals for use with copper or with aluminium conductors



IEC 62873-3-3:2022-11 RLV(en)



THIS PUBLICATION IS COPYRIGHT PROTECTED
Copyright © 2022 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

IEC Secretariat
3, rue de Varembé
CH-1211 Geneva 20
Switzerland

Tel.: +41 22 919 02 11
info@iec.ch
www.iec.ch

About the IEC
The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications
The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigendum or an amendment might have been published.

IEC publications search - webstore.iec.ch/advsearchform
The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee, …). It also gives information on projects, replaced and withdrawn publications.

IEC Just Published - webstore.iec.ch/justpublished
Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and once a month by email.

IEC Customer Service Centre - webstore.iec.ch/csc
If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: sales@iec.ch.

IEC Products & Services Portal - products.iec.ch
Discover our powerful search engine and read freely all the publications previews. With a subscription you will always have access to up to date content tailored to your needs.

Electropedia - www.electropedia.org
The world's leading online dictionary on electrotechnology, containing more than 22 300 terminological entries in English and French, with equivalent terms in 19 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

IEC 62873-3-3

Edition 2.0 2022-11
REDLINE VERSION

INTERNATIONAL STANDARD

colour inside

Residual current operated circuit-breakers for household and similar use – Part 3-3: Specific requirements for ~~RCDs~~ devices with screw-type terminals for external untreated aluminium conductors and with aluminium screw-type terminals for use with copper or with aluminium conductors

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

ICS 29.120.50

ISBN 978-2-8322-6044-9

Warning! Make sure that you obtained this publication from an authorized distributor.

® Registered trademark of the International Electrotechnical Commission

CONTENTS

FOREWORD 3
INTRODUCTION 2
1 Scope 7
2 Normative references 7
3 Terms and definitions 8
4 Classification 8
5 Characteristics of devices 8
6 Marking and other product information 9
7 Standard conditions for operation in service and for installation 9
8 Requirements for construction and operation 9
9 Tests 10
9.1 General 10
9.2 Test conditions 13
9.3 Current cycling test 14
9.3.1 General 14
9.3.2 Preparation 14
9.3.3 Test arrangement 14
9.3.4 Temperature measurement 15
9.3.5 Test method and acceptance criteria 15
Bibliography 23

Figure 1 – General arrangement for the test 21
Figure 2 – Test specimen example 1 21
Figure 3 – Test specimen example 2 22
Figure 4 – Test specimen example 3 22
Figure 5 – Test specimen example 4 22
Figure 6 – Test specimen example 5 22

Table 1 – Marking for terminals 9
Table 2 – Connectable cross-sections of aluminium conductors for screw-type terminals 10
Table 3 – List of tests according to the material of conductors and terminals 11
Table 4 – Connectable conductors and their theoretical diameters 13
Table 5 – Cross-sections (S) of aluminium test conductors corresponding to the rated currents 13
Table 6 – Test conductor length 14
Table 7 – Equalizer and busbar dimensions 15
Table 8 – Test current as a function of rated current 17
Table 9 – Example of calculation for determining the average temperature deviation D 18
Table 10 – Connectable cross-sections of copper conductors for screw-type terminals 18
Table 11 – Test copper conductors corresponding to the rated currents 19
Table 12 – Screw thread diameters and applied torques 19

INTERNATIONAL ELECTROTECHNICAL COMMISSION

_____

RESIDUAL CURRENT OPERATED CIRCUIT-BREAKERS FOR HOUSEHOLD AND SIMILAR USE –

Part 3-3: Specific requirements for ~~RCDs~~ devices with screw-type terminals for external untreated aluminium conductors and with aluminium screw-type terminals for use with copper or with aluminium conductors

FOREWORD

1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
6) All users should ensure that they have the latest edition of this publication.
7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

This redline version of the official IEC Standard allows the user to identify the changes made to the previous edition IEC 62873-3-3:2016. A vertical bar appears in the margin wherever a change has been made. Additions are in green text, deletions are in strikethrough red text.

IEC 62873-3-3 has been prepared by subcommittee 23E: Circuit breakers and similar equipment for household use, of IEC technical committee 23: Electrical accessories. It is an International Standard.

This second edition cancels and replaces the first edition published in 2016. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

a) Modification of scope to address other devices in addition to RCDs;
b) Modification of Clause 8 so that IEC 62873-3-3 can be referred to by other product standards in addition to those for RCDs;
c) Modification of 9.1 so that IEC 62873-3-3 can be referred to by other product standards in addition to those for RCDs.

The text of this International Standard is based on the following documents:

Draft	Report on voting
23E/1274/FDIS	23E/1306/RVD

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

The language used for the development of this International Standard is English.

A list of all parts of the IEC 62873 series published under the general title *Residual current operated circuit-breakers for household and similar use* can be found on the IEC website.

The following differing practices of a less permanent nature exist in the countries indicated below:

– NOTE 2 of Clause 1: the use of aluminium screw-type terminals for use with copper conductors is not allowed (Austria, Australia and Germany);
– NOTE 2 of Clause 1: terminals for aluminium conductors only are not allowed (Austria and Germany);
– NOTE 2 of Clause 1: the use of aluminium conductors is not allowed for final circuits in household and similar installations e.g. offices, shops (Spain);
– NOTE 2 of Clause 1: the minimum cross-sectional area for aluminium conductors is 16 mm^2 (Denmark).

This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available at www.iec.ch/members_experts/refdocs. The main document types developed by IEC are described in greater detail at www.iec.ch/standardsdev/publications.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under webstore.iec.ch in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

IMPORTANT – The "colour inside" logo on the cover page of this document indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

INTRODUCTION

This document is part of the IEC 62873 series described in the outline document IEC 62873-1.

RESIDUAL CURRENT OPERATED CIRCUIT-BREAKERS FOR HOUSEHOLD AND SIMILAR USE –

Part 3-3: Specific requirements for ~~RCDs~~ devices with screw-type terminals for external untreated aluminium conductors and with aluminium screw-type terminals for use with copper or with aluminium conductors

1 Scope

This part of IEC 62873 applies to ~~RCDs~~ devices equipped with screw-type terminals of copper – or of alloys containing at least 58 % of copper (if worked cold) or at least 50 % of copper (if worked otherwise), or of other metal or suitably coated metal, no less resistant to corrosion than copper and having mechanical properties no less suitable – for use with untreated aluminium conductors, or with screw-type terminals of aluminium material for use with copper or aluminium conductors.

~~This part of IEC 62873 cannot be used alone but it is intended to be applied together with an RCD product standard (IEC 61008-1 or IEC 61009-1) if an RCD is equipped with screw-type terminals for external untreated aluminium conductors and with aluminium screw-type terminals for use with copper or with aluminium conductors.~~

This document does not cover the use of aluminium conductors or aluminium terminals for DC applications.

Flexible aluminium conductors are not covered by this document.

NOTE 1 Flexible aluminium conductors are under consideration.

This document cannot be used alone but it is intended to be applied together with the applicable product standard.

In this document, copper-clad and nickel-clad aluminium conductors are considered as aluminium conductors.

NOTE 2 In AT, AU and DE, the use of aluminium screw-type terminals for use with copper conductors is not allowed.

– In AT and DE, terminals for aluminium conductors only are not allowed;
– In ES, the use of aluminium conductors is not allowed for final circuits in household and similar installations e.g. offices, shops;
– In DK, the minimum cross-sectional area for aluminium conductors is 16 mm^2.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

~~IEC 61008-1, *Residual current operated circuit-breakers without integral overcurrent protection for household and similar uses (RCCBs) – Part 1: General rules*~~

~~IEC 61009-1, *Residual current operated circuit-breakers with integral overcurrent protection for household and similar uses (RCBOs) – Part 1: General rules*~~

IEC 62873-2, *Residual current operated circuit-breakers for household and similar use – Part 2: Residual current devices (RCDs) – Vocabulary*

3 Terms and definitions

For the purposes of this document, the terms and definitions given in IEC 62873-2 and the following apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- ISO Online browsing platform: available at https://www.iso.org/obp
- IEC Electropedia: available at http://www.electropedia.org/

3.1
treated conductor
contact area of a conductor that has had its oxide layer on the outside strands scraped away and/or has had a compound added to improve connectability and/or prevent corrosion

3.2
untreated conductor
unprepared conductor
conductor which has been cut and the insulation of which has been removed for insertion into a terminal

Note 1 to entry: A conductor, the shape of which is arranged for introduction into a terminal or the strands of which are twisted to consolidate the end, is considered to be an unprepared conductor.

[SOURCE: IEC 60050-442:1998, 442-01-26]

3.3
equalizer
arrangement used in the test loop to ensure an equipotentiality point and uniform current density in a stranded conductor, without adversely affecting the temperature of the conductor(s)

3.4
reference conductor
continuous length of the same type and size conductor as that used in the terminal unit under test and connected in the same series circuit, which enables the reference temperature and, if required, reference resistance to be determined

3.5
stability factor
Sf
measure of temperature stability of a terminal unit during the current cycling test

4 Classification

Clause 4 of the ~~RCD~~ product standard applies.

5 Characteristics of ~~RCDs~~ devices

Clause 5 of the ~~RCD~~ product standard applies.