IEC 62927

Edition 1.1 2023-05
CONSOLIDATED VERSION

INTERNATIONAL STANDARD

NORME INTERNATIONALE

colour inside

Voltage sourced converter (VSC) valves for static synchronous compensator (STATCOM) – Electrical testing

Valves de convertisseur source de tension (VSC) pour compensateur synchrone statique (STATCOM) – Essais électriques



IEC 62927:2017-07+AMD1:2023-05 CSV(en-fr)



THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2023 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

Droits de reproduction réservés. Sauf indication contraire, aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de l'IEC ou du Comité national de l'IEC du pays du demandeur. Si vous avez des questions sur le copyright de l'IEC ou si vous désirez obtenir des droits supplémentaires sur cette publication, utilisez les coordonnées ci-après ou contactez le Comité national de l'IEC de votre pays de résidence.

IEC Secretariat
3, rue de Varembé
CH-1211 Geneva 20
Switzerland

Tel.: +41 22 919 02 11
info@iec.ch
www.iec.ch

About the IEC
The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications
The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigendum or an amendment might have been published.

IEC publications search - webstore.iec.ch/advsearchform
The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee, …). It also gives information on projects, replaced and withdrawn publications.

IEC Just Published - webstore.iec.ch/justpublished
Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and once a month by email.

IEC Customer Service Centre - webstore.iec.ch/csc
If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: sales@iec.ch.

IEC Products & Services Portal - products.iec.ch
Discover our powerful search engine and read freely all the publications previews. With a subscription you will always have access to up to date content tailored to your needs.

Electropedia - www.electropedia.org
The world's leading online dictionary on electrotechnology, containing more than 22 300 terminological entries in English and French, with equivalent terms in 19 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

A propos de l'IEC
La Commission Electrotechnique Internationale (IEC) est la première organisation mondiale qui élabore et publie des Normes internationales pour tout ce qui a trait à l'électricité, à l'électronique et aux technologies apparentées.

A propos des publications IEC
Le contenu technique des publications IEC est constamment revu. Veuillez vous assurer que vous possédez l'édition la plus récente, un corrigendum ou amendement peut avoir été publié.

Recherche de publications IEC - webstore.iec.ch/advsearchform
La recherche avancée permet de trouver des publications IEC en utilisant différents critères (numéro de référence, texte, comité d'études, …). Elle donne aussi des informations sur les projets et les publications remplacées ou retirées.

IEC Just Published - webstore.iec.ch/justpublished
Restez informé sur les nouvelles publications IEC. Just Published détaille les nouvelles publications parues. Disponible en ligne et une fois par mois par email.

Service Clients - webstore.iec.ch/csc
Si vous désirez nous donner des commentaires sur cette publication ou si vous avez des questions contactez-nous: sales@iec.ch.

IEC Products & Services Portal - products.iec.ch
Découvrez notre puissant moteur de recherche et consultez gratuitement tous les aperçus des publications. Avec un abonnement, vous aurez toujours accès à un contenu à jour adapté à vos besoins.

Electropedia - www.electropedia.org
Le premier dictionnaire d'électrotechnologie en ligne au monde, avec plus de 22 300 articles terminologiques en anglais et en français, ainsi que les termes équivalents dans 19 langues additionnelles. Egalement appelé Vocabulaire Electrotechnique International (IEV) en ligne.

IEC 62927

Edition 1.1 2023-05
CONSOLIDATED VERSION

INTERNATIONAL STANDARD

NORME INTERNATIONALE

colour inside

Voltage sourced converter (VSC) valves for static synchronous compensator (STATCOM) – Electrical testing

Valves de convertisseur source de tension (VSC) pour compensateur synchrone statique (STATCOM) – Essais électriques

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

COMMISSION
ELECTROTECHNIQUE
INTERNATIONALE

ICS 29.200; 29.240.99

ISBN 978-2-8322-7025-7

Warning! Make sure that you obtained this publication from an authorized distributor.
Attention! Veuillez vous assurer que vous avez obtenu cette publication via un distributeur agréé.

® Registered trademark of the International Electrotechnical Commission
Marque déposée de la Commission Electrotechnique Internationale

IEC 62927

Edition 1.1 2023-05
CONSOLIDATED VERSION

REDLINE VERSION

VERSION REDLINE

colour inside

Voltage sourced converter (VSC) valves for static synchronous compensator (STATCOM) – Electrical testing

Valves de convertisseur source de tension (VSC) pour compensateur synchrone statique (STATCOM) – Essais électriques



IEC 62927:2017-07+AMD1:2023-05 CSV(en-fr)

CONTENTS

FOREWORD 5
1 Scope 7
2 Normative references 7
3 Terms and definitions 7
3.1 Insulation co-ordination terms 7
3.2 Power semiconductor terms 8
3.3 Operating states of converter 8
3.4 STATCOM construction terms 9
3.5 Valve structure terms 10
4 General requirements 11
4.1 Guidelines for the performance of type tests 11
4.1.1 General 11
4.1.2 Dielectric tests 11
4.1.3 Operational tests 11
4.1.4 Electromagnetic interference tests 11
4.1.5 Evidence in lieu 11
4.1.6 Test object 12
4.1.7 Test procedure 12
4.1.8 Ambient temperature for testing 12
4.1.9 Frequency for testing 12
4.1.10 Conditions to be considered in determination of type test parameters 12
4.1.11 Test reports 12
4.2 Atmospheric correction factor 13
4.3 Treatment of redundancy 13
4.3.1 Operational tests 13
4.3.2 Dielectric tests 13
4.4 Permissible component failures during type testing 14
5 List of tests 14
6 Operational tests 15
6.1 Purpose of tests 15
6.2 Test object 15
6.3 Test circuit 16
6.4 Maximum continuous operating duty test 16
6.5 Maximum temporary overload operating duty test 17
6.6 Minimum start voltage test 17
7 Dielectric tests on valve support 18
7.1 Purpose of tests 18
7.2 Test object 18
7.3 Test requirements 18
7.3.1 Valve support DC voltage test 18
7.3.2 Valve support AC voltage test 19
7.3.3 Valve support lightning impulse test 20
8 Dielectric tests on multiple valve unit (MVU) 20
8.1 General 20
8.2 Purpose of tests 20
8.3 Test object 20

8.4 Test requirements 21
8.4.1 MVU AC voltage test 21
8.4.2 MVU DC voltage test 21
8.4.3 MVU lightning impulse test 22
9 Dielectric tests between valve terminals 22
9.1 Purpose of the test 22
9.2 Test object 22
9.3 Test methods 23
9.3.1 General 23
9.3.2 Method 1 23
9.3.3 Method 2 23
9.4 Test requirements 23
9.4.1 Valve AC voltage or AC-DC voltage test 23
9.4.2 Valve switching impulse test 26
10 IGBT overcurrent turn-off test 27
10.1 Purpose of test 27
10.2 Test object 27
10.3 Test requirements 27
11 Tests for valve insensitivity to electromagnetic disturbance 27
11.1 Purpose of tests 27
11.2 Test object 28
11.3 Test requirements 28
11.3.1 General 28
11.3.2 Approach 1 28
11.3.3 Approach 2 28
11.3.4 Acceptance criteria 29
12 Short-circuit current test ~~(optional)~~ 29
12.1 Purpose of tests 29
12.2 Test object 29
12.3 Test requirements 29
13 Production tests 30
13.1 General 30
13.2 Purpose of tests 30
13.3 Test object 30
13.4 Test requirements 30
13.5 Production test objectives 30
13.5.1 Visual inspection 30
13.5.2 Connection check 31
13.5.3 Voltage-grading circuit check 31
13.5.4 Control, protection and monitoring circuit checks 31
13.5.5 Voltage withstand check 31
13.5.6 Turn-on/turn-off check 31
13.5.7 Pressure test 31
14 Presentation of type test results 31
Annex A (informative) Overview of STATCOM valves 32
A.1 General 32
A.2 STATCOM applications and operating limits 32
A.3 Overview of STATCOM valve types 33

A.4 STATCOMs based on switch type valve 33
A.4.1 General 33
A.4.2 Two-level converter 34
A.4.3 Three-level converters 34
A.4.4 Multi-level converters 35
A.5 STATCOMs based on controllable voltage source type valve 36
A.6 Valve switching principles 37
Annex B (informative) Valve component fault tolerance 39
Bibliography 40

Figure A.1 – STATCOM U-I characteristics 33
Figure A.2 – Two-level converter 34
Figure A.3 – Three-level NPC converter 35
Figure A.4 – Three-level flying capacitor converter 35
Figure A.5 – Modular multilevel converter 36
Figure A.6 – Single-phase full-bridge converter 37
Figure A.7 – Two-level converter output voltage 37
Figure A.8 – Output voltage shape of three-level converter and modular multi-level converter 38

Table 1 – Minimum number of valve levels to be tested as a function of the number of valve levels per valve 12
Table 2 – Valve level faults permitted during type tests 14
Table 3 – List of type tests 15

INTERNATIONAL ELECTROTECHNICAL COMMISSION

_____

VOLTAGE SOURCED CONVERTER (VSC) VALVES FOR STATIC SYNCHRONOUS COMPENSATOR (STATCOM) – ELECTRICAL TESTING

FOREWORD

1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
6) All users should ensure that they have the latest edition of this publication.
7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

This consolidated version of the official IEC Standard and its amendment has been prepared for user convenience.

IEC 62927 edition 1.1 contains the first edition (2017-07) [documents 22F/412/CDV and 22F/431A/RVC] and its amendment 1 (2023-05) [documents 22F/699/CDV and 22F/721/RVC].

In this Redline version, a vertical line in the margin shows where the technical content is modified by amendment 1. Additions are in green text, deletions are in strikethrough red text. A separate Final version with all changes accepted is available in this publication.

International Standard IEC 62927 has been prepared by subcommittee 22F: Power electronics for electrical transmission and distribution systems, of IEC technical committee 22: Power electronic systems and equipment.

This document has been drafted in accordance with the ISO/IEC Directives, Part 2.

The committee has decided that the contents of the base publication and its amendment will remain unchanged until the stability date indicated on the IEC web site under webstore.iec.ch in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

IMPORTANT – The *'colour inside'* logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

VOLTAGE SOURCED CONVERTER (VSC) VALVES FOR STATIC SYNCHRONOUS COMPENSATOR (STATCOM) – ELECTRICAL TESTING

1 Scope

This document applies to self-commutated valves, for use in voltage sourced converter (VSC) for static synchronous compensator (STATCOM). It is restricted to electrical type and production tests.

The tests specified in this document are based on air insulated valves. For other types of valves, the test requirements and acceptance criteria are agreed between the purchaser and the supplier.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60060 (all parts), *High-voltage test techniques*

IEC 60060-1, *High-voltage test techniques – Part 1: General definitions and test requirements*

IEC 60071-1:~~2006~~2019, *Insulation co-ordination – Part 1: Definitions, principles and rules*

IEC 60700-1:2015, *Thyristor valves for high voltage direct current (HVDC) power transmission – Part 1: Electrical testing*

IEC 62501, *Voltage sourced converter (VSC) valves for high-voltage direct current (HVDC) power transmission – Electrical testing*

3 Terms and definitions

For the purposes of this document, the following terms and definitions apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- IEC Electropedia: available at http://www.electropedia.org/
- ISO Online browsing platform: available at http://www.iso.org/obp

3.1 Insulation co-ordination terms

3.1.1
test withstand voltage
value of a test voltage of standard waveshape at which a new valve, with unimpaired integrity, does not show any disruptive discharge and meets all other acceptance criteria specified for the particular test, when subjected to a specified number of applications or a specified duration of the test voltage, under specified conditions

3.1.2
internal insulation
air external to the components and insulating materials of the valve, but contained within the profile of the valve or multiple valve unit

3.1.3
external insulation
air between the external surface of the valve or multiple valve unit and its surroundings

3.2 Power semiconductor terms

3.2.1
turn-off semiconductor device
controllable semiconductor device which may be turned on and off by a control signal, for example an IGBT

Note 1 to entry: There are several types of turn-off semiconductor devices, for example IGBT, IGCT and GTO, which can be used in voltage sourced converters for STATCOM. For convenience, the term IGBT is used throughout this document to refer to the main, controllable turn-off, semiconductor device. However, this document is equally applicable to other types of controllable semiconductor switch device.

3.2.2
gate turn-off thyristor
GTO thyristor
turn-off semiconductor device which can be turned on and off by its gate lead

Note 1 to entry: A GTO thyristor is a special type of thyristor, which is a high-power semiconductor device.

Note 2 to entry: Gate commutated thyristor (GCT) and integrated gate commutated thyristor (IGCT) are special types of GTO thyristor.

3.2.3
insulated gate bipolar transistor
IGBT
transistor provided for power switching having a conduction channel and a PN junction and in which the current flowing through the channel and the junction is controlled by an electric field resulting from a voltage applied between the gate and emitter terminals

3.2.4
free-wheeling diode
FWD
power semiconductor device with diode characteristic connected to an insulated gate bipolar transistor (IGBT) in inverse parallel

Note 1 to entry: An FWD has two terminals: an anode (A) and a cathode (K).

Note 2 to entry: The current through FWDs is in the opposite direction to the IGBT current.

Note 3 to entry: Concepts of "inverse parallel" and "anti-parallel" are identical.

3.2.5
IGBT-diode pair
arrangement of IGBT and FWD connected in inverse parallel

3.3 Operating states of converter

3.3.1
blocking state
condition of the converter, in which a turn-off signal is applied continuously to all IGBTs of the converter

3.3.2
de-blocked state
condition of the converter, in which turn-on and turn-off signals are applied repetitively to IGBTs of the converter

3.3.3
valve protective blocking
means of protecting the valve or converter from excessive electrical stress by the emergency turn-off of all IGBTs in one or more valves

3.3.4
voltage step level
voltage step caused by switching of a valve or part of a valve during the de-blocked state of the converter

Note 1 to entry: For a voltage source type valve, one half bridge cell corresponds to one voltage step level and a full bridge cell has two voltage step levels.

3.4 STATCOM construction terms

3.4.1
STATCOM
shunt connected reactive compensation equipment which is capable of generating and/or absorbing reactive power, whose capacitive or inductive output current can be controlled independently of the AC system voltage

Note 1 to entry: Previous alternative terms for the STATCOM have included static var generator (SVG), advanced static var compensator (ASVC) and static synchronous condenser (STATCON).

3.4.2
STATCOM valve
electrically and mechanically combined assembly of IGBT levels, complete with all connections, auxiliary components and mechanical structures, which can be connected in series with each phase of reactor of a STATCOM

Note 1 to entry: Depending on the converter topology, a valve can either have the function to act like a controllable switch or to act like a controllable voltage source. For controllable voltage source type converter, the STATCOM controllable voltage source type valve is a complete controllable voltage source assembly, which is generally connected between two AC phases. For switch type converter, the STATCOM switch type valve is an arrangement of IGBTs connected in series and arranged to be switched simultaneously as a single function unit between one AC phase and one DC terminal of the DC capacitor energy storage.

Note 2 to entry: For convenience, the term "STATCOM valve" is shortened as "valve" in this document.

3.4.3
diode valve
semiconductor valve containing only diodes as the main semiconductor devices, which might be used in some STATCOM topologies

3.4.4
submodule
part of a valve comprising controllable switches and diodes connected in a half bridge or full bridge arrangement, together with their immediate auxiliaries, storage capacitor, if any, where each controllable switch consists of one or more switched valve device(s) connected in series

Note 1 to entry: This definition is only applicable for converters of controllable voltage source type.

3.4.5
switch type valve
arrangement of IGBT-diode pairs connected in series and arranged to be switched simultaneously as a single function unit

3.4.6
controllable voltage source type valve
complete controllable voltage source assembly, which is generally connected between AC phases or between one AC terminal and one DC terminal

3.4.7
modular multi-level converter
MMC
multi-level converter in which each VSC valve (see 3.4.5, 3.4.6) consists of a number of MMC building blocks (see 3.4.9) connected in series

3.4.8
cascaded two-level converter
CTL
modular multi-level converter in which each switch position consists of more than one IGBT-diode pair connected in series

3.4.9
MMC building block
self-contained, two-terminal controllable voltage source together with DC capacitor(s) and immediate auxiliaries, forming part of a MMC

3.4.10
STATCOM valve level
the smallest indivisible functional unit of valve

Note 1 to entry: For any valve in which switch devices are connected in series and operated simultaneously, one valve level is one IGBT including its auxiliaries. For modular multilevel converter (MMC) type without IGBT connected in series, one valve level is one submodule (cell) together with its auxiliaries.

3.4.11
diode valve level
part of a diode valve composed of a diode and associated circuits and components, if any

3.4.12
redundant valve levels
the maximum number of series connected valve levels or diode valve levels in a valve that may be short-circuited externally or internally without affecting the safe operation of the valve as demonstrated by type tests, and which if and when exceeded, would require shutdown of the valve to replace the failed levels or acceptance of increased risk of failures

Note 1 to entry: In valve designs which contain two or more conduction paths within each cell and have series-connected VSC valve levels in each path, redundant levels shall be counted only in one conduction path in each cell.

3.5 Valve structure terms

3.5.1
valve structure
physical structure holding the levels of a valve which is insulated to the appropriate voltage above earth potential

3.5.2
valve support
part of the valve which mechanically supports and electrically insulates the active part of the valve from earth

3.5.3
multiple valve unit
MVU
mechanical arrangement of two or more valves sharing a common valve support, where applicable

3.5.4
valve section
electrical assembly defined for test purposes, comprising a number of valve levels and other components, which exhibits pro-rated electrical properties of a complete valve

3.5.5
valve base electronics
electronic unit, at earth potential, which is the interface between the converter control system and the STATCOM valves

4 General requirements

4.1 Guidelines for the performance of type tests

4.1.1 General

The tests described apply to the valve (or valve sections), the valve structure and those parts of the coolant distribution system and firing and monitoring circuits which are contained within the valve structure (internal insulation) or connected between the valve structure and earth (external insulation). Other equipment, such as valve control and protection and valve base electronics, can be essential for demonstrating the correct function of the valve during the tests but are not in themselves the subject of the tests.

4.1.2 Dielectric tests

The purpose of these tests is to verify the valve design for voltage stresses under normal and abnormal repetitive conditions as well as under transient conditions.

In the interest of standardization with other equipment, lightning impulse tests between valve terminals and earth and between phases of a multiple valve unit (MVU) are included. For tests between valve terminals, the only impulse test specified is a switching impulse.

4.1.3 Operational tests

The purpose of these tests is to verify the valve design for combined voltage and current stresses under normal and abnormal repetitive conditions as well as under transient fault conditions.

4.1.4 Electromagnetic interference tests

The principal objective of these tests is to demonstrate the immunity of the valve to electromagnetic interference from within the valve and from outside the valve.

4.1.5 Evidence in lieu

Each design of valve shall be subjected to the type tests specified in this document. If the valve is demonstrably similar to one previously tested, the supplier may, in lieu of performing a type test or individual parts of it, submit a test report of a previous type test for consideration by the purchaser. This should be accompanied by a separate report detailing the differences in the design and demonstrating how the referenced type test satisfies the test objectives for the proposed design.