IEC 62954

Edition 1.0 2019-01

INTERNATIONAL STANDARD

NORME INTERNATIONALE

colour inside

Nuclear power plants – Control rooms – Requirements for emergency response facilities

Centrales nucléaires de puissance – Salles de commande – Exigences pour les moyens de réaction d'urgence



IEC 62954:2019-01(en-fr)



THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2019 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

Droits de reproduction réservés. Sauf indication contraire, aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de l'IEC ou du Comité national de l'IEC du pays du demandeur. Si vous avez des questions sur le copyright de l'IEC ou si vous désirez obtenir des droits supplémentaires sur cette publication, utilisez les coordonnées ci-après ou contactez le Comité national de l'IEC de votre pays de résidence.

IEC Central Office
3, rue de Varembé
CH-1211 Geneva 20
Switzerland

Tel.: +41 22 919 02 11
info@iec.ch
www.iec.ch

About the IEC
The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications
The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigendum or an amendment might have been published.

IEC publications search - webstore.iec.ch/advsearchform
The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee,…). It also gives information on projects, replaced and withdrawn publications.

IEC Just Published - webstore.iec.ch/justpublished
Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and once a month by email.

IEC Customer Service Centre - webstore.iec.ch/csc
If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: sales@iec.ch.

Electropedia - www.electropedia.org
The world's leading online dictionary on electrotechnology, containing more than 22 000 terminological entries in English and French, with equivalent terms in 16 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

IEC Glossary - std.iec.ch/glossary
67 000 electrotechnical terminology entries in English and French extracted from the Terms and Definitions clause of IEC publications issued since 2002. Some entries have been collected from earlier publications of IEC TC 37, 77, 86 and CISPR.

A propos de l'IEC
La Commission Electrotechnique Internationale (IEC) est la première organisation mondiale qui élabore et publie des Normes internationales pour tout ce qui a trait à l'électricité, à l'électronique et aux technologies apparentées.

A propos des publications IEC
Le contenu technique des publications IEC est constamment revu. Veuillez vous assurer que vous possédez l'édition la plus récente, un corrigendum ou amendement peut avoir été publié.

Recherche de publications IEC - webstore.iec.ch/advsearchform
La recherche avancée permet de trouver des publications IEC en utilisant différents critères (numéro de référence, texte, comité d'études,…). Elle donne aussi des informations sur les projets et les publications remplacées ou retirées.

IEC Just Published - webstore.iec.ch/justpublished
Restez informé sur les nouvelles publications IEC. Just Published détaille les nouvelles publications parues. Disponible en ligne et une fois par mois par email.

Service Clients - webstore.iec.ch/csc
Si vous désirez nous donner des commentaires sur cette publication ou si vous avez des questions contactez-nous: sales@iec.ch.

Electropedia - www.electropedia.org
Le premier dictionnaire d'électrotechnologie en ligne au monde, avec plus de 22 000 articles terminologiques en anglais et en français, ainsi que les termes équivalents dans 16 langues additionnelles. Egalement appelé Vocabulaire Electrotechnique International (IEV) en ligne.

Glossaire IEC - std.iec.ch/glossary
67 000 entrées terminologiques électrotechniques, en anglais et en français, extraites des articles Termes et Définitions des publications IEC parues depuis 2002. Plus certaines entrées antérieures extraites des publications des CE 37, 77, 86 et CISPR de l'IEC.

IEC 62954

Edition 1.0 2019-01

INTERNATIONAL STANDARD

NORME INTERNATIONALE

colour inside

Nuclear power plants – Control rooms – Requirements for emergency response facilities

Centrales nucléaires de puissance – Salles de commande – Exigences pour les moyens de réaction d'urgence

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

COMMISSION
ELECTROTECHNIQUE
INTERNATIONALE

ICS 27.120.20

ISBN 978-2-8322-6384-6

Warning! Make sure that you obtained this publication from an authorized distributor.
Attention! Veuillez vous assurer que vous avez obtenu cette publication via un distributeur agréé.

® Registered trademark of the International Electrotechnical Commission
Marque déposée de la Commission Electrotechnique Internationale

CONTENTS

FOREWORD 4
INTRODUCTION 6
1 Scope 9
2 Normative references 9
3 Terms and definitions 10
4 Symbols and abbreviated terms 12
5 ERF basis for design 12
5.1 General 12
5.2 Role and main features 12
5.2.1 General 12
5.2.2 Emergency Response Centre (ERC) 13
5.2.3 Technical Support Centre (TSC) 13
5.2.4 Operational Support Centre (OSC) 14
5.3 Availability and hazard withstand 14
5.4 Information to be available in ERF 15
6 ERF location and physical features 15
6.1 Location 15
6.2 Access routes 16
6.3 Access control 16
6.4 Environmental design 16
6.5 Other habitability aspects 16
6.6 Power supplies 17
6.7 Documentation 17
7 Principles of operation 18
7.1 Organisational aspects 18
7.2 Staffing 18
8 Human Machine Interface (HMI) 18
8.1 Room layout and workspace design 18
8.2 Hardware and software HMI design 18
9 Human Factors Engineering (HFE) 19
9.1 General 19
9.2 Operational experience 19
9.3 Functional analysis and assignment 19
9.4 Task analysis 19
9.5 Style guide 20
9.6 HFE verification and validation 20
10 Instrumentation and control equipment 20
10.1 Safety classification 20
10.2 Design of I&C equipment for ERF 20
10.3 I&C functions of the ERF 21
10.4 Testability 21
11 Equipment qualification 21
12 Communications 21
12.1 Communication principles 21
12.2 Nature of communications 21

12.3 Data communications 22
12.4 Verbal communications 22
12.5 Non-verbal communications 22
12.6 Communication confidentiality 22
13 Maintenance and training 23
13.1 Maintainability 23
13.2 Repairs 23
13.3 Periodic verification of equipment and perishable goods 23
13.4 Training and exercises 23
Annex A (informative) Extracts from IAEA Safety Guides relevant to ERF 24
Bibliography 26

Figure 1 – On-site and off-site ERFs and communicating entities 6

INTERNATIONAL ELECTROTECHNICAL COMMISSION

_____

NUCLEAR POWER PLANTS – CONTROL ROOMS – REQUIREMENTS FOR EMERGENCY RESPONSE FACILITIES

FOREWORD

1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
6) All users should ensure that they have the latest edition of this publication.
7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 62954 has been prepared by subcommittee 45A: Instrumentation, control and electrical power systems of nuclear facilities, of IEC technical committee 45: Nuclear instrumentation.

The text of this International Standard is based on the following documents:

FDIS	Report on voting
45A/1236/FDIS	45A/1251/RVD

Full information on the voting for the approval of this International Standard can be found in the report on voting indicated in the above table.

This document has been drafted in accordance with the ISO/IEC Directives, Part 2.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under "http://webstore.iec.ch" in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

INTRODUCTION

a) Technical background, main issues and organisation of the Standard

The Fukushima-Daiichi accident has shown that extremely severe hazards can occur for which a nuclear power plant has not been designed to resist. In such situations, the plant has possibly to cope with one or several damaged reactors, and associated radioactive releases, but also has to cope with the loss of a major part of the electrical sources, cooling functions and I&C, possibly including the Main Control Room (MCR), as well as with difficulties in accessing the site. Providing safe on-site facilities for managing such an emergency is hence a major issue.

An international consensus has emerged to promote the design and installation of a specific set of facilities aiming at coordinating the efforts of personnel charged with controlling the emergency activities and those of authorities external to the site charged with protecting the population and the environment. These facilities are called the Emergency Response Facilities (ERF).

Different countries, utilities and nuclear power plants have different geographical and infrastructure characteristics and different requirements under emergency situations. However, the same fundamentals apply in terms of both on-site and off-site requirements.

The IAEA requirements for emergency response are addressed in SSR-2/1 and GSR Part 7. Informative Annex A provides the more relevant extracts from these two IAEA publications.

Figure 1 below illustrates the most important control locations, emergency response facilities and other associated facilities on-site and off-site. Some of the on-site facilities could be combined to support close-communication or their functions could be dispersed across other on-site facilities. The level of hardening and autonomy of the individual on-site facilities could vary considerably.




Figure 1 – On-site and off-site ERFs and communicating entities

NOTE 1 No internationally standardized terminology has been established for the various on-site and off-site emergency response facilities. The terms used in Figure 1 indicate the ones that have been adopted in this document.

NOTE 2 Depending on local contexts, the “on-site” ERFs could be implemented close to the NPP and not inside it.

NOTE 3 The role and composition of the off-site civil authorities and emergency infrastructure are known to vary widely. These entries in Figure 1 are therefore considered as illustrative only.

As indicated in Figure 1 some functional services are already dealt with in IEC standards.

This standard was proposed after the Fukushima-Daiichi accident to take into account the lessons learned from those dramatic events. Several reports prepared after the accident, at national level (Japanese Government report) as well as at international level (IAEA fact finding mission) highlighted the role played by the Emergency Response Centre (ERC) during those events and identified the need to take into account the experience gained to strengthen the requirements for such a facility.

This led to the development of this standard, with the following principles:

- The scope should align with that of the relevant IAEA guidance, as given in SSR-2/1, Rev. 1 and GSR Part 7;
- The scope should address the three functional facilities related to Emergency Response that are addressed by the IAEA guidance (i.e. the ERC, TSC and OSC);
- The scope should be limited to such facilities that are on or near the NPP site. The scope should exclude activities in the scope of local response authorities;
- The requirements should be defined in terms of the functions that are to be performed;
- The standard should address the way in which the functions are invoked in response to different severities of incident / accident and any responsibilities that would be transferred from the MCR to the Emergency Response Facilities (ERFs);
- The scope should include consideration of the requirements for environment control, lighting, power supplies, access control of the ERFs, etc., as needed to enable the Emergency Response functions to be performed;
- The only “controls” that should be provided are those that relate to the services that provide the above mentioned environment control, lighting, power supplies, access control of the ERFs, etc.;
- The standard should recognize that a wide range of national or regional situations exist regarding the structure and arrangements for the off-site Emergency Response support.

This IEC standard specifically focuses on the issue of requirements relevant for the Emergency Response Facilities (ERFs).

It is intended that the Standard be used by designers and operators of NPPs (utilities), systems evaluators, vendors and subcontractors, and by licensors.

b) Situation of the current Standard in the structure of the IEC SC 45A standard series

IEC 62954 is at the third level of the IEC SC 45A standard series. It is to be considered as affiliated to IEC 60964, the top document on control rooms in the SC 45A standard series.

For a generic description of the structure of the IEC SC 45A standard series, see item d) of this introduction.

c) Recommendations and limitations regarding the application of the Standard

This standard establishes functional requirements for Emergency Response Facilities and clarifies the design and operation of the ERF systems to be used in case of incidents or accidents occurring on nuclear power plants (NPPs) and/or nuclear facilities.

It is recognized that this is an evolving area of regulatory requirements, due to ongoing analysis of the Fukushima lessons learned. Therefore, the goal of this project is to provide a standard, which defines the framework within which the evolving country or plant specific requirements may be developed and applied.

d) Description of the structure of the IEC SC 45A standard series and relationships with other IEC documents and other bodies documents (IAEA, ISO)

The top-level documents of the IEC SC 45A standard series are IEC 61513 and IEC 63046. IEC 61513 provides general requirements for I&C systems and equipment that are used to perform functions important to safety in NPPs. IEC 63046 provides general requirements for electrical power systems of NPPs; it covers power supply systems including the supply systems of the I&C systems. IEC 61513 and IEC 63046 are to be considered in conjunction and at the same level. IEC 61513 and IEC 63046 structure the IEC SC 45A standard series and shape a complete framework establishing general requirements for instrumentation, control and electrical systems for nuclear power plants.

IEC 61513 and IEC 63046 refer directly to other IEC SC 45A standards for general topics related to categorization of functions and classification of systems, qualification, separation, defence against common cause failure, control room design, electromagnetic compatibility, cybersecurity, software and hardware aspects for programmable digital systems, coordination of safety and security requirements and management of ageing. The standards referenced directly at this second level should be considered together with IEC 61513 and IEC 63046 as a consistent document set.

At a third level, IEC SC 45A standards not directly referenced by IEC 61513 or by IEC 63046 are standards related to specific equipment, technical methods, or specific activities. Usually these documents, which make reference to second-level documents for general topics, can be used on their own.

A fourth level extending the IEC SC 45 standard series, corresponds to the Technical Reports which are not normative.

The IEC SC 45A standards series consistently implements and details the safety and security principles and basic aspects provided in the relevant IAEA safety standards and in the relevant documents of the IAEA nuclear security series (NSS). In particular this includes the IAEA requirements SSR-2/1, establishing safety requirements related to the design of nuclear power plants (NPPs), the IAEA safety guide SSG-30 dealing with the safety classification of structures, systems and components in NPPs, the IAEA safety guide SSG-39 dealing with the design of instrumentation and control systems for NPPs, the IAEA safety guide SSG-34 dealing with the design of electrical power systems for NPPs and the implementing guide NSS17 for computer security at nuclear facilities. The safety and security terminology and definitions used by SC 45A standards are consistent with those used by the IAEA.

IEC 61513 and IEC 63046 have adopted a presentation format similar to the basic safety publication IEC 61508 with an overall life-cycle framework and a system life-cycle framework. Regarding nuclear safety, IEC 61513 and IEC 63046 provide the interpretation of the general requirements of IEC 61508-1, IEC 61508-2 and IEC 61508-4, for the nuclear application sector. In this framework IEC 60880, IEC 62138 and IEC 62566 correspond to IEC 61508-3 for the nuclear application sector. IEC 61513 and IEC 63046 refer to ISO as well as to IAEA GSR Part 2 and IAEA GS-G-3.1 and IAEA GS-G-3.5 for topics related to quality assurance (QA). At level 2, regarding nuclear security, IEC 62645 is the entry document for the IEC/SC 45A security standards. It builds upon the valid high level principles and main concepts of the generic security standards, in particular ISO/IEC 27001 and ISO/IEC 27002; it adapts them and completes them to fit the nuclear context and coordinates with the IEC 62443 series. At level 2, IEC 60964 is the entry document for the IEC/SC 45A control rooms standards and IEC 62342 is the entry document for the ageing management standards.

NOTE 1 It is assumed that for the design of I&C systems in NPPs that implement conventional safety functions (e.g. to address worker safety, asset protection, chemical hazards, process energy hazards) international or national standards would be applied.

NOTE 2 IEC/SC 45A domain was extended in 2013 to cover electrical systems. In 2014 and 2015 discussions were held in IEC/SC 45A to decide how and where general requirements for the design of electrical systems were to be considered. IEC/SC 45A experts recommended that an independent standard be developed at the same level as IEC 61513 to establish general requirements for electrical systems. Project IEC 63046 is now launched to cover this objective. When IEC 63046 is published this NOTE 2 of the introduction of IEC/SC 45A standards will be suppressed.

NUCLEAR POWER PLANTS – CONTROL ROOMS – REQUIREMENTS FOR EMERGENCY RESPONSE FACILITIES

1 Scope

This document presents the requirements for the on-site emergency response facilities (referred to hereinafter as the “ERF”) which are to be used in case of incidents or accidents occurring on the associated Nuclear Power Plant (NPP). The ERF consists of the Emergency Response Centre (ERC), the Technical Support Centre (TSC) and the Operational Support Centre (OSC), as shown in Figure 1.

It establishes requirements for the ERF features and ERF I&C equipment to:

- coordinate on-site operational efforts with respect to safety and radioprotection;
- optimize the design in terms of environment control, lighting, power supplies and access control of the ERF;
- enhance the identification and resolution of potential conflicts between the traditional operational means and emergency means (MCR/SCR and ERF, operating staff and emergency teams, operational procedures and emergency procedures);
- aid the identification and the enhancement of the potential synergies between the traditional operational means and emergency means.

This document is intended for application to new nuclear power plants whose conceptual design is initiated after the publication of this document, but it may also be used for designing and implementing ERF in existing nuclear power plants or in any other nuclear facility.

Detailed equipment design is outside the scope of this document.

This document does not define the situations (reactor plant conditions, hazards and magnitudes of hazards) leading to mobilisation of emergency response teams and activation / use of the ERF. These aspects are usually addressed in the NPP Emergency Plan. However, the need for consistency of the ERF design and operation with the NPP Emergency Plan is within scope.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC/IEEE 60780-323, *Nuclear facilities – Electrical equipment important to safety – Qualification*

IEC 61226:2009, *Nuclear power plants – Instrumentation and control important to safety – Classification of instrumentation and control functions*

IEC 61513, *Nuclear power plants – Instrumentation and control important to safety – General requirements for systems*

3 Terms and definitions

For the purposes of this document, the following terms and definitions apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- IEC Electropedia: available at http://www.electropedia.org/
- ISO Online browsing platform: available at http://www.iso.org/obp

3.1
Access Control Point
ACP
area (one or more) within the facility security boundary to control the entry and exit of off-site personnel, in particular emergency teams

3.2
assembly point
location (one or more) where non-essential personnel at the facility are assembled, accounted for and sheltered or evacuated

3.3
emergency
non-routine situation or event that necessitates prompt action, primarily to mitigate a hazard or adverse consequences for human life, health, property or the environment

Note 1 to entry: This includes nuclear and radiological emergencies and conventional emergencies such as fires, release of hazardous chemicals, storms or earthquakes.

Note 2 to entry: This includes situations for which prompt action is warranted to mitigate the effects of a perceived hazard.

[SOURCE: IAEA GSR Part 7, 2015]

3.4
emergency plan
description of the objectives, policy and concept of operations for the response to an emergency and of the structure, authorities and responsibilities for a systematic, coordinated and effective response

Note 1 to entry: The emergency plan serves as the basis for the development of other plans, procedures and checklists.

[SOURCE: IAEA GSR Part 7, 2015]

3.5
emergency response
performance of actions to mitigate the consequences of an emergency for human life, health, property and the environment

[SOURCE: IAEA GSR Part 7, 2015]

3.6
Emergency Response Centre
ERC
area set aside on or near to the NPP site for staff to manage the overall response to the emergency and to handle the off-site interfaces

3.7
Emergency Response Facility
ERF
facility or location needed for supporting an emergency response, for which specific functions are to be assigned at the preparedness stage, and which need to be usable under emergency conditions

[SOURCE: IAEA GSR Part 7, 2015]

3.8
function
specific purpose or objective to be accomplished, that can be specified or described without reference to the physical means of achieving it

3.9
functional analysis
examination of the functional goals of a system with respect to available manpower, technology, and other resources, to provide the basis for determining how the function may be assigned and executed

[SOURCE: IEC 60964:2018, 3.12]

3.10
functional goal
performance objectives that shall be satisfied to achieve the corresponding function

[SOURCE: IEC 60964: 2018, 3.13]

3.11
Nuclear Power Plant site
NPP site
geographical area that contains the NPP, circumscribed by the security perimeter fence or other designated property marker

[SOURCE: IAEA GSR Part 7, 2015]

3.12
Operational Support Centre
OSC
area separate from the main control room where NPP operations support staff will assemble in an emergency situation to be assigned to various duties (e.g. environmental monitoring, health physics, damage control and fire fighting)

3.13
task analysis
identification and description of an operator's task, in terms of its components, to specify the detailed human activities involved, and their functional and temporal relationships

Note 1 to entry: Frequently, task analysis in understood to also include the evaluation of the operator's tasks. In the frame of IEC 60964, this evaluation is described in terms of verification and validation of function assignment and verification and validation of the integrated control room system (which also covers the operator tasks).

[SOURCE: IEC 60964: 2018, 3.31]