IEC PAS 62953

Edition 1.0 2015-04

PUBLICLY AVAILABLE SPECIFICATION

PRE-STANDARD

Industrial communication networks – Fieldbus specifications

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

ICS 25.040.40; 35.100.01

ISBN 978-2-8322-2445-8

Warning! Make sure that you obtained this publication from an authorized distributor.

® Registered trademark of the International Electrotechnical Commission

CONTENTS

Industrial communication networks – Fieldbus specifications – Part 3-25: Data-link layer service definition – Type 25 elements 6

Industrial communication networks – Fieldbus specifications – Part 4-25: Data-link layer protocol specification – Type 25 elements 32

Industrial communication networks – Fieldbus specifications – Part 5-25: Application layer service definition – Type 25 elements 94

Industrial communication networks – Fieldbus specifications – Part 6-25: Application layer protocol specification – Type 25 elements 158

CPF20 input for IEC 61784-2: Industrial communication networks – Profiles – Part 2: Additional fieldbus profiles for real-time networks based on ISO/IEC 8802-3 270

INTERNATIONAL ELECTROTECHNICAL COMMISSION

INDUSTRIAL COMMUNICATION NETWORKS – FIELDBUS SPECIFICATIONS AND PROFILES – ADS-NET

FOREWORD

1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
6) All users should ensure that they have the latest edition of this publication.
7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

A PAS is a technical specification not fulfilling the requirements for a standard, but made available to the public.

IEC PAS 62953 has been processed by subcommittee 65C: Industrial networks, of IEC technical committee 65: Industrial-process measurement, control and automation.

The text of this PAS is based on the following document:	This PAS was approved for publication by the P-members of the committee concerned as indicated in the following document
Draft PAS	**Report on voting**
65C/787/PAS	65C/799/RVD

Following publication of this PAS, which is a pre-standard publication, the technical committee or subcommittee concerned may transform it into an International Standard.

This PAS shall remain valid for an initial maximum period of 3 years starting from the publication date. The validity may be extended for a single period up to a maximum of 3 years, at the end of which it shall be published as another type of normative document, or shall be withdrawn.

INTRODUCTION

This PAS contains the ADS-net fieldbus specifications and profiles (Communication profile CP 20/1 ADS-net/μΣNETWORK-1000, CP 20/2 ADS-net/NX) for inclusion in the IEC 61158 series as well as IEC 61784-2.

The intention is to make this technical content available immediately, while a corresponding new work item proposal (NP) has been launched. If the NP is accepted, this contents will be included in the next editions of the IEC 61158 series and of IEC 61784-2.

This PAS contains the relevant ADS-net (Type 25) elements for the DL and AL services and protocols and information with references to:

– IEC 61158-1:2014

– IEC 61158-2:2014

– IEC 61784-2:2014

The present IEC PAS is structured in the same way as the IEC 61158 series and IEC 61784-2:

– IEC PAS 62953-3-25 is intended to become a future IEC 61158-3-25;

– IEC PAS 62953-4-25 is intended to become a future IEC 61158-4-25;

– IEC PAS 62953-5-25 is intended to become a future IEC 61158-5-25;

– IEC PAS 62953-6-25 is intended to become a future IEC 61158-6-25;

– IEC PAS 62953-2 is intended to be merged into a revised version of IEC 61784-2:2014.

INCLUDED SUBPARTS

Industrial communication networks – Fieldbus specifications – Part 3-25: Data-link layer service definition – Type 25 elements

Industrial communication networks – Fieldbus specifications – Part 4-25: Data-link layer protocol specification – Type 25 elements

Industrial communication networks – Fieldbus specifications – Part 5-25: Application layer service definition – Type 25 elements

Industrial communication networks – Fieldbus specifications – Part 6-25: Application layer protocol specification – Type 25 elements

CPF20 input for IEC 61784-2: Industrial communication networks – Profiles – Part 2: Additional fieldbus profiles for real-time networks based on ISO/IEC 8802-3

CONTENTS

1 Scope 9
1.1 General 9
1.2 Specifications 9
1.3 Conformance 9
2 Normative references 10
3 Terms, definitions, symbols and abbreviations 10
3.1 Reference model terms and definitions 11
3.1.1 DL-address [ISO/IEC 7498-3] 11
3.1.2 DL-address-mapping [ISO/IEC 7498-1] 11
3.1.3 called-DL-address [ISO/IEC 7498-3] 11
3.1.4 calling-DL-address [ISO/IEC 7498-3] 11
3.1.5 centralized multi-end-point-connection [ISO/IEC 7498-1] 11
3.1.6 DL-connection [ISO/IEC 7498-1] 11
3.1.7 DL-connection-end-point [ISO/IEC 7498-1] 11
3.1.8 DL-connection-end-point-identifier [ISO/IEC 7498-1] 11
3.1.9 DL-connection-mode transmission [ISO/IEC 7498-1] 11
3.1.10 DL-connectionless-mode transmission [ISO/IEC 7498-1] 11
3.1.11 correspondent (N)-entities [ISO/IEC 7498-1] 11
3.1.12 DL-duplex-transmission [ISO/IEC 7498-1] 11
3.1.13 (N)-entity [ISO/IEC 7498-1] 11
3.1.14 DL-facility [ISO/IEC 7498-1] 11
3.1.15 flow control [ISO/IEC 7498-1] 11
3.1.16 (N)-layer [ISO/IEC 7498-1] 11
3.1.17 layer-management [ISO/IEC 7498-1] 12
3.1.18 DL-local-view [ISO/IEC 7498-3] 12
3.1.19 DL-name [ISO/IEC 7498-3] 12
3.1.20 naming-(addressing)-domain [ISO/IEC 7498-3] 12
3.1.21 peer-entities [ISO/IEC 7498-1] 12
3.1.22 primitive name [ISO/IEC 7498-3] 12
3.1.23 DL-protocol [ISO/IEC 7498-1] 12
3.1.24 DL-protocol-connection-identifier [ISO/IEC 7498-1] 12
3.1.25 DL-protocol-data-unit [ISO/IEC 7498-1] 12
3.1.26 DL-relay [ISO/IEC 7498-1] 12
3.1.27 reset [ISO/IEC 7498-1] 12
3.1.28 responding-DL-address [ISO/IEC 7498-3] 12
3.1.29 routing [ISO/IEC 7498-1] 12
3.1.30 segmenting [ISO/IEC 7498-1] 12
3.1.31 (N)-service [ISO/IEC 7498-1] 12
3.1.32 (N)-service-access-point [ISO/IEC 7498-1] 12
3.1.33 DL-service-access-point-address [ISO/IEC 7498-3] 12
3.1.34 DL-service-connection-identifier [ISO/IEC 7498-1] 12
3.1.35 DL-service-data-unit [ISO/IEC 7498-1] 12
3.1.36 DL-simplex-transmission [ISO/IEC 7498-1] 12
3.1.37 DL-subsystem [ISO/IEC 7498-1] 12
3.1.38 systems-management [ISO/IEC 7498-1] 12
3.1.39 DLS-user-data [ISO/IEC 7498-1] 12

3.2 Service convention terms and definitions 12
3.2.1 acceptor 12
3.2.2 asymmetrical service 12
3.2.3 confirm (primitive); 12
3.2.4 deliver (primitive) 13
3.2.5 DL-confirmed-facility 13
3.2.6 DL-facility 13
3.2.7 DL-local-view 13
3.2.8 DL-mandatory-facility 13
3.2.9 DL-non-confirmed-facility 13
3.2.10 DL-provider-initiated-facility 13
3.2.11 DL-provider-optional-facility 13
3.2.12 DL-service-primitive; 13
3.2.13 DL-service-provider 13
3.2.14 DL-service-user 13
3.2.15 DLS-user-optional-facility 13
3.2.16 indication (primitive); 13
3.2.17 multi-peer 13
3.2.18 request (primitive); 13
3.2.19 requestor 13
3.2.20 response (primitive); 13
3.2.21 submit (primitive) 13
3.2.22 symmetrical service 13
3.3 Terms and definitions 13
3.4 Symbols and abbreviations 16
3.5 Common conventions 17
3.6 Additional Type 25 conventions 18
4 DL services and concepts 18
4.1 Overview 18
4.2 Types of DLS 18
4.2.1 General 18
4.2.2 Primitive of the RCL communication and RT communication 18
4.3 Detailed description of the RCL communication service 19
4.3.1 Sequence of primitives 19
4.3.2 Transmit / Receive DLSDU 19
4.4 Detailed description of the RT communication service 21
4.4.1 Sequence of primitives 21
4.4.2 Transmit / Receive DLSDU 21
5 DL management services 22
5.1 General 22
5.2 Facilities of the DLMS 22
5.3 Service of the DL-management 22
5.3.1 Overview 22
5.3.2 Reset 23
5.3.3 Set value 23
5.3.4 Get value 23
5.3.5 RCL stop 23
5.3.6 RCL start 23
5.3.7 Node status 23

5.3.8 Event 23
5.4 Overview of interactions 23
5.5 Detail specification of service and interactions 24
5.5.1 Reset 24
5.5.2 Set value 25
5.5.3 Get value 26
5.5.4 RCL stop 26
5.5.5 RCL start 27
5.5.6 Event 28
Bibliography 30

Figure 1 – Relationships of DLSAPs, DLSAP-addresses and group DL-addresses 14
Figure 2 – Sequence diagram of RCL communication and RT communication services 19
Figure 3 – Reset, Set value, and Get value services 24
Figure 4 – Event service 24

Table 1 – Primitives and parameters used on the RCL communication service 19
Table 2 – Transmit DLSDU primitives and parameters 20
Table 3 – Primitives and parameters used on the RT communication service 21
Table 4 – Transmit DLSDU primitives and parameters 21
Table 5 – Transmit DLSDU primitives and parameters 23
Table 6 – DLM_Reset primitives and parameters 24
Table 7 – DLM_Set primitives and parameters 25
Table 8 – DLM_Get primitives and parameters 26
Table 9 – DLM_RCL_STOP primitives and parameters 27
Table 10 – DLM_RCL_START primitives and parameters 27
Table 11 – DLM_RCL_START primitives and parameters 28
Table 12 – DLM_Event primitives and parameters 29

INDUSTRIAL COMMUNICATION NETWORKS – FIELDBUS SPECIFICATIONS –

Part 3-25: Data-link layer service definition – Type 25 elements

1 Scope

1.1 General

This part of IEC PAS 62953 provides common elements for basic time-critical messaging communications between devices in an automation environment. The term “time-critical” is used to represent the presence of a time-window, within which one or more specified actions are required to be completed with some defined level of certainty. Failure to complete specified actions within the time window risks failure of the applications requesting the actions, with attendant risk to equipment, plant and possibly human life.

This standard defines in an abstract way the externally visible service provided by the Type 25 fieldbus data-link layer in terms of

a) the primitive actions and events of the service;

b) the parameters associated with each primitive action and event, and the form which they take; and

c) the interrelationship between these actions and events, and their valid sequences.

The purpose of this standard is to define the services provided to

- the Type 25 fieldbus application layer at the boundary between the application and data-link layers of the fieldbus reference model;
- systems management at the boundary between the data-link layer and systems management of the fieldbus reference model.

1.2 Specifications

The principal objective of this standard is to specify the characteristics of conceptual data-link layer services suitable for time-critical communications, and thus supplement the OSI Basic Reference Model in guiding the development of data-link protocols for time-critical communications. A secondary objective is to provide migration paths from previously-existing industrial communications protocols.

This specification may be used as the basis for formal DL-Programming-Interfaces. Nevertheless, it is not a formal programming interface, and any such interface will need to address implementation issues not covered by this specification, including

a) the sizes and octet ordering of various multi-octet service parameters, and

b) the correlation of paired request and confirm, or indication and response, primitives.

1.3 Conformance

This standard does not specify individual implementations or products, nor does it constrain the implementations of data-link entities within industrial automation systems.

There is no conformance of equipment to this data-link layer service definition standard. Instead, conformance is achieved through implementation of the corresponding data-link protocol that fulfills the Type 25 data-link layer services defined in this standard.

2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC PAS 62953-4-25, *Industrial communication networks – Fieldbus specifications – Part 4-25: Data-link layer protocol specification – Type 25 elements*

IEC PAS 62953-5-25, *Industrial communication networks – Fieldbus specifications – Part 5-25: Application layer service definition – Type 25 elements*

IEC PAS 62953-6-25, *Industrial communication networks – Fieldbus specifications – Part 6-25: Application layer protocol specification – Type 25 elements*

ISO/IEC 10731, *Information technology – Open Systems Interconnection – Basic Reference Model – Conventions for the definition of OSI services*

ISO/IEC 7498-1, *Information technology – Open Systems Interconnection – Basic Reference Model: The Basic Model*

ISO/IEC 7498-3, *Information technology – Open Systems Interconnection – Basic Reference Model: Naming and addressing*

ISO/IEC 8802-3:2000, *Information technology – Telecommunications and information exchange between systems – Local and metropolitan area networks – Specific requirements – Part 3: Carrier sense multiple access with collision detection (CSMA/CD) access method and Physical Layer specifications*

ISO/IEC 10731, *Information technology – Open Systems Interconnection – Basic Reference Model – Conventions for the definition of OSI services*

CONTENTS

1 Scope 36
1.1 General 36
1.2 Specifications 36
1.3 Procedures 36
1.4 Applicability 37
1.5 Conformance 37
2 Normative references 37
3 Terms, definitions, symbols and abbreviations 38
3.1 Reference model terms and definitions 38
3.1.1 DL-address [ISO/IEC 7498-3] 38
3.1.2 DL-address-mapping [ISO/IEC 7498-1] 38
3.1.3 called-DL-address [ISO/IEC 7498-3] 38
3.1.4 calling-DL-address [ISO/IEC 7498-3] 38
3.1.5 centralized multi-end-point-connection [ISO/IEC 7498-1] 38
3.1.6 DL-connection [ISO/IEC 7498-1] 38
3.1.7 DL-connection-end-point [ISO/IEC 7498-1] 38
3.1.8 DL-connection-end-point-identifier [ISO/IEC 7498-1] 38
3.1.9 DL-connection-mode transmission [ISO/IEC 7498-1] 38
3.1.10 DL-connectionless-mode transmission [ISO/IEC 7498-1] 38
3.1.11 correspondent (N)-entities [ISO/IEC 7498-1] 38
3.1.12 DL-duplex-transmission [ISO/IEC 7498-1] 38
3.1.13 (N)-entity [ISO/IEC 7498-1] 38
3.1.14 DL-facility [ISO/IEC 7498-1] 38
3.1.15 flow control [ISO/IEC 7498-1] 38
3.1.16 (N)-layer [ISO/IEC 7498-1] 38
3.1.17 layer-management [ISO/IEC 7498-1] 39
3.1.18 DL-local-view [ISO/IEC 7498-3] 39
3.1.19 DL-name [ISO/IEC 7498-3] 39
3.1.20 naming-(addressing)-domain [ISO/IEC 7498-3] 39
3.1.21 peer-entities [ISO/IEC 7498-1] 39
3.1.22 primitive name [ISO/IEC 7498-3] 39
3.1.23 DL-protocol [ISO/IEC 7498-1] 39
3.1.24 DL-protocol-connection-identifier [ISO/IEC 7498-1] 39
3.1.25 DL-protocol-data-unit [ISO/IEC 7498-1] 39
3.1.26 DL-relay [ISO/IEC 7498-1] 39
3.1.27 reset [ISO/IEC 7498-1] 39
3.1.28 responding-DL-address [ISO/IEC 7498-3] 39
3.1.29 routing [ISO/IEC 7498-1] 39
3.1.30 segmenting [ISO/IEC 7498-1] 39
3.1.31 (N)-service [ISO/IEC 7498-1] 39
3.1.32 (N)-service-access-point [ISO/IEC 7498-1] 39
3.1.33 DL-service-access-point-address [ISO/IEC 7498-3] 39
3.1.34 DL-service-connection-identifier [ISO/IEC 7498-1] 39
3.1.35 DL-service-data-unit [ISO/IEC 7498-1] 39
3.1.36 DL-simplex-transmission [ISO/IEC 7498-1] 39
3.1.37 DL-subsystem [ISO/IEC 7498-1] 39

3.1.38 systems-management [ISO/IEC 7498-1] 39
3.1.39 DLS-user-data [ISO/IEC 7498-1] 39
3.2 Service convention terms and definitions 39
3.2.1 acceptor 39
3.2.2 asymmetrical service 39
3.2.3 confirm (primitive); 39
3.2.4 deliver (primitive) 40
3.2.5 DL-confirmed-facility 40
3.2.6 DL-facility 40
3.2.7 DL-local-view 40
3.2.8 DL-mandatory-facility 40
3.2.9 DL-non-confirmed-facility 40
3.2.10 DL-provider-initiated-facility 40
3.2.11 DL-provider-optional-facility 40
3.2.12 DL-service-primitive; 40
3.2.13 DL-service-provider 40
3.2.14 DL-service-user 40
3.2.15 DLS-user-optional-facility 40
3.2.16 indication (primitive); 40
3.2.17 multi-peer 40
3.2.18 request (primitive); 40
3.2.19 requestor 40
3.2.20 submit (primitive) 40
3.2.21 symmetrical service 40
3.3 Terms and definitions 40
3.4 Symbols and abbreviations 43
3.5 Common conventions 44
3.6 Additional Type 25 conventions 45
3.6.1 Primitive conventions 45
3.6.2 State machine conventions 45
4 Overview of the DL-protocol 46
4.1 General 46
4.2 Overview of the medium access control 46
4.2.1 General 46
4.2.2 Network topology 46
4.2.3 Priority control with VLAN 48
4.2.4 The maximum delivery delay in Type 25 network 49
4.2.5 Traffic control for real-time communication 49
4.3 Service assumed from PhL 50
4.4 DL Layer architecture 50
4.5 Local parameters and variables 51
4.5.1 Overview 51
4.5.2 Variables, parameter, counter and timer 52
5 General structure and encoding of PhPDUs and DLPDU and related elements of procedure 53
5.1 Overview 53
5.2 Common MAC frame structure, encoding and elements of procedure 53
5.2.1 MAC frame structure 53
5.2.2 Elements of the MAC frame 53

6 DLPDU-specific structure, encoding and elements of procedure 55
6.1 General 55
6.2 Structure of the RCL DLPDU 55
6.2.1 RCL header 56
7 DLE elements of procedure 58
7.1 Overview 58
7.2 RCL communication control (RCLC) 58
7.2.1 General 58
7.2.2 Primitive definitions 58
7.2.3 RCLC state machine 61
7.2.4 Function of RCLC 79
7.3 Real-time communication control (RTC) 79
7.3.1 General 79
7.3.2 Primitive definitions 79
7.3.3 RTC state machine 81
7.3.4 Function of RTC 82
7.4 Transmit/Receive control (TRC) 82
7.4.1 General 82
7.4.2 Primitive definitions 83
7.4.3 TRC state machine 83
7.4.4 Function of TRC 87
7.5 DLL management protocol (DLM) 89
7.5.1 Overview 89
7.5.2 Primitive definitions 89
7.5.3 DLM state machine (DLM_SM) 90
7.5.4 Function of DLM 92
Bibliography 93

Figure 1 – Relationships of DLSAPs, DLSAP-addresses and group DL-addresses 41
Figure 2 – Ring control in Type 25 network 47
Figure 3 – Communication ranges of Type 25 frames 48
Figure 4 – Priority control with VLAN of Type 25 network 48
Figure 5 – The mechanism of transmission delay in a node 49
Figure 6 – The worst delay in Type 25 network 50
Figure 7 – Data-Link layer internal architecture 51
Figure 8 – Type 25 fieldbus DLPDU frame format 53
Figure 9 – RCL frame format 55
Figure 10 – State transition diagram of RHE_SM-A 62
Figure 11 – State transition diagram of RHE_SM-B 65
Figure 12 – The state diagram of RCLNode_SM 69
Figure 13 – The state diagram of RCLTR_SM 77
Figure 14 – The state diagram of RTTR_SM 81
Figure 15 – The state diagram of TRC_SM 83
Figure 16 – The state diagram of DLM_SM 90

Table 1 – State transition descriptions 45

Table 2 – Descriptions of state machine elements 45
Table 3 – Conventions used in state machine 46
Table 4 – Characteristics of the node states 47
Table 5 – Characteristic of the frame classes 48
Table 6 – Data-link layer components 51
Table 7 – Destination address format 54
Table 8 – VLAN tag format 54
Table 9 – Types and classes of RCL frames 56
Table 10 – Structure of RCL header 56
Table 11 – Class field format 57
Table 12 – Destination address field format 57
Table 13 –Source address field format 57
Table 14 – CMD field format 57
Table 15 – The primitives and parameters for DLS-user interface 58
Table 16 – Parameters used with primitives exchanged between RCLC and DLS-user 59
Table 17 – The primitives and parameters for TRC interface 59
Table 18 – Parameters used with primitives exchanged between RCLC and TRC 60
Table 19 – The primitives and parameters for DLM interface 60
Table 20 – Parameters used with primitives exchanged between RCLC and DLM 61
Table 21 – Transitions of RHE_SM-A at RCL communication 63
Table 22 – Transitions of RHE_SM-B at RCL communication 66
Table 23 – Transitions of RCLNode_SM at RCL communication 70
Table 24 – Transitions of RCLTR_SM at RCL communication 78
Table 25 – RCLC function table 79
Table 26 – The primitives and parameters for DLS-user interface 79
Table 27 – Parameters used with primitives exchanged between RTC and DLS-user 80
Table 28 – The primitives and parameters for TRC interface 80
Table 29 – Parameters used with primitives exchanged between RTC and TRC 80
Table 30 – The primitives and parameters for DLM interface 81
Table 31 – Parameters used with primitives exchanged between RTC and DLM 81
Table 32 – Transitions of RTTR_SM at RT communication 82
Table 33 – RTC function table 82
Table 34 – The primitives and parameters for DLM interface 83
Table 35 – Parameters used with primitives exchanged between TRC and DLM 83
Table 36 – Transitions of TRC_SM 84
Table 37 – TRC function table 88
Table 38 – Primitives exchanged between DLM and DLS-user 89
Table 39 – Parameters used with primitives exchanged between DLM and DLS-user 90
Table 40 – Transitions of DLM_SM 91
Table 41 – DLM function table 92

INDUSTRIAL COMMUNICATION NETWORKS - FIELDBUS SPECIFICATIONS –

Part 4-25: Data-link layer protocol specification - Type 25 elements

1 Scope

1.1 General

The data-link layer provides basic time-critical messaging communications between devices in an automation environment.

This protocol provides communication opportunities to all participating data-link entities

a) in a synchronously-starting cyclic manner, according to a pre-established schedule, and

b) in a cyclic or acyclic asynchronous manner, as requested each cycle by each of those data-link entities.

Thus this protocol can be characterized as one which provides cyclic and acyclic access asynchronously but with a synchronous restart of each cycle.

1.2 Specifications

This standard specifies

a) procedures for the timely transfer of data and control information from one data-link user entity to a peer user entity, and among the data-link entities forming the distributed datalink service provider;

b) procedures for giving communications opportunities to all participating DL-entities, sequentially and in a cyclic manner for deterministic and synchronized transfer at cyclic intervals up to one millisecond;

c) procedures for giving communication opportunities available for time-critical data transmission together with non-time-critical data transmission without prejudice to the time-critical data transmission;

d) procedures for giving cyclic and acyclic communication opportunities for time-critical data transmission with prioritized access;

e) procedures for giving communication opportunities based on standard ISO/IEC 8802-3 medium access control, with provisions for nodes to be added or removed during normal operation;

f) the structure of the fieldbus DLPDUs used for the transfer of data and control information by the protocol of this standard, and their representation as physical interface data units.

1.3 Procedures

The procedures are defined in terms of

a) the interactions between peer DL-entities (DLEs) through the exchange of fieldbus DLPDUs;

b) the interactions between a DL-service (DLS) provider and a DLS-user in the same system through the exchange of DLS primitives;

c) the interactions between a DLS-provider and a Ph-service provider in the same system through the exchange of Ph-service primitives.

1.4 Applicability

These procedures are applicable to instances of communication between systems which support time-critical communications services within the data-link layer of the OSI or fieldbus reference models, and which require the ability to interconnect in an open systems interconnection environment.

Profiles provide a simple multi-attribute means of summarizing an implementation's capabilities, and thus its applicability to various time-critical communications needs.

1.5 Conformance

This standard also specifies conformance requirements for systems implementing these procedures. This standard does not contain tests to demonstrate compliance with such requirements.

2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC PAS 62953-3-25, *Industrial communication networks – Fieldbus specifications – Part 3-25: Data-link layer service definition – Type 25 elements*

IEC PAS 62953-5-25, *Industrial communication networks – Fieldbus specifications – Part 5-25: Application layer service definition – Type 25 elements*

IEC PAS 62953-6-25, *Industrial communication networks – Fieldbus specifications – Part 6-25: Application layer protocol specification – Type 25 elements*

ISO/IEC 10731, *Information technology – Open Systems Interconnection – Basic Reference Model – Conventions for the definition of OSI services*

ISO/IEC 7498-1, *Information technology – Open Systems Interconnection – Basic Reference Model: The Basic Model*

ISO/IEC 7498-3, *Information technology – Open Systems Interconnection – Basic Reference Model: Naming and addressing*

ISO/IEC 8802-3:2000, *Information technology – Telecommunications and information exchange between systems – Local and metropolitan area networks – Specific requirements – Part 3: Carrier sense multiple access with collision detection (CSMA/CD) access method and Physical Layer specifications*

ISO/IEC 10731, *Information technology – Open Systems Interconnection – Basic Reference Model – Conventions for the definition of OSI services*

IEEE 802.1D-2004, IEEE Standard for Local and metropolitan area networks – Media access control (MAC) Bridges, available at <http://www.ieee.org>

IEEE 802.1Q-2005, IEEE Standard for Local and metropolitan area networks – Virtual Bridged Local Area Networks, available at <http://www.ieee.org>

CONTENTS

1 Scope 97
1.1 Overview 97
1.2 Specification 98
1.3 Conformance 98
2 Normative references 98
3 Terms, definitions, symbols and abbreviations 99
3.1 Referenced terms and definitions 99
3.1.1 ISO/IEC 7498-1 terms 99
3.1.2 ISO/IEC 8822 terms 99
3.1.3 ISO/IEC 9545 terms 99
3.1.4 ISO/IEC 8824 terms 100
3.1.5 IEC 61158 terms 100
3.2 Additional terms and definitions for this IEC PAS 62953-5-25 100
3.3 Symbols and abbreviations 102
3.4 Conventions 103
3.4.1 General conventions 103
3.4.2 Conventions for class definitions 103
3.4.3 Conventions for service definitions 104
4 Concept 105
5 Data type ASE 106
5.1 Overview 106
5.2 Fixed length types 106
5.2.1 Numeric types 106
5.3 String types 108
5.3.1 OctetString 108
6 Communication model specification 108
6.1 Communication model 108
6.1.1 General 108
6.1.2 Cyclic communication model 108
6.1.3 Acyclic communication model 109
6.2 ASE type S 110
6.2.1 Overview 110
6.2.2 Cyclic data type S 110
6.2.3 Acyclic data ASE type S 114
6.2.4 Management ASE type S 117
6.3 ASE type N 119
6.3.1 Overview type N 119
6.3.2 Cyclic data ASE type N 120
6.3.3 Acyclic data ASE type N 124
6.3.4 Management ASE type N 133
6.4 AR type S 135
6.4.1 Cyclic control type S 136
6.4.2 Remote control 140
6.4.3 RCL communication control 141
6.4.4 RT communication control 143

6.5 AR type N 146
6.5.1 Cyclic transmission control 147
6.5.2 Acyclic transmission control 149
6.5.3 RT communication control type N 154
Bibliography 157

Figure 1 – Cyclic communication model (n:n communication with shared memory) 109
Figure 2 – Acyclic communication model (client server model) 109
Figure 3 – Acyclic communication model (push model) 109
Figure 4 – Structure of ASE type S of FAL type 25 110
Figure 5 – Structure of ASE type N of FAL type 25 120
Figure 6 – Structure of AR type S of FAL type 25 136
Figure 7 – Structure of AR type N of FAL type 25 147

Table 1 – Put_cyclicdata service parameters 111
Table 2 – Get_cyclicdata service parameters 112
Table 3 – Ctl_cyclic service parameters 113
Table 4 – Send_ctldata service parameters 115
Table 5 – Send_infodata service parameters 116
Table 6 – Send_rmtctl service parameters 117
Table 7 – Set_attribute service parameters 118
Table 8 – Get_attribute service parameters 119
Table 9 – Put_cyclicdata service parameters 121
Table 10 – Get_cyclicdata service parameters 122
Table 11 – Control_cyclic service parameters 123
Table 12 – Put message service parameters 125
Table 13 – Get message service parameters 126
Table 14 – Put inquiry message service parameters 128
Table 15 – Put ninquiry message service parameters 129
Table 16 – Put reply message service parameters 130
Table 17 – Send aliveinfo service parameters 131
Table 18 – Receive aliveinfo service parameters 131
Table 19 – Control_acyclic service parameters 133
Table 20 – Get attribute service parameters 134
Table 21 – Set attribute service parameters 135
Table 22 – CYC_WRITE service parameters 137
Table 23 – CYC_READ service parameters 138
Table 24 – CTL_CYCLIC service parameters 139
Table 25 – SendRMTCTL service parameters 141
Table 26 – RCL_START service parameters 143
Table 27 – RCL_STOP service parameters 143
Table 28 – SendCTL service parameters 144
Table 29 – SendINFO service parameters 145
Table 30 – SendCTL_RMT service parameters 146

Table 31 – SendCYC service parameters 146
Table 32 – Write_cyclicdata service parameters 148
Table 33 – Ctl_cyclic service parameters 149
Table 34 – Transmit_acyclicdata1 service parameters 151
Table 35 – Transmit_acyclicdata2 service parameters 152
Table 36 – Ctl_acyclic service parameters 153
Table 37 – Send_cyclicdata service parameters 155
Table 38 – Send_acyclicdata service parameters 155

INDUSTRIAL COMMUNICATION NETWORKS – FIELDBUS SPECIFICATIONS –

Part 5-25: Application layer service definition – Type 25 elements

1 Scope

1.1 Overview

The fieldbus Application Layer (FAL) provides user programs with a means to access the fieldbus communication environment. In this respect, the FAL can be viewed as a “window between corresponding application programs.”

This standard provides common elements for basic time-critical and non-time-critical messaging communications between application programs in an automation environment and material specific to Type 25 fieldbus. The term “time-critical” is used to represent the presence of a time-window, within which one or more specified actions are required to be completed with some defined level of certainty. Failure to complete specified actions within the time window risks failure of the applications requesting the actions, with attendant risk to equipment, plant and possibly human life.

This standard defines in an abstract way the externally visible service provided by the different Types of the fieldbus Application Layer in terms of

a) an abstract model for defining application resources (objects) capable of being manipulated by users via the use of the FAL service,
b) the primitive actions and events of the service;
c) the parameters associated with each primitive action and event, and the form which they take; and
d) the interrelationship between these actions and events, and their valid sequences.

The purpose of this standard is to define the services provided to

a) the FAL user at the boundary between the user and the Application Layer of the Fieldbus Reference Model, and
b) Systems Management at the boundary between the Application Layer and Systems Management of the Fieldbus Reference Model.

This standard specifies the structure and services of the IEC fieldbus Application Layer, in conformance with the OSI Basic Reference Model (ISO/IEC 7498) and the OSI Application Layer Structure (ISO/IEC 9545).

FAL services and protocols are provided by FAL application-entities (AE) contained within the application processes. The FAL AE is composed of a set of object-oriented Application Service Elements (ASEs) and a Layer Management Entity (LME) that manages the AE. The ASEs provide communication services that operate on a set of related application process object (APO) classes. One of the FAL ASEs is a management ASE that provides a common set of services for the management of the instances of FAL classes.

Although these services specify, from the perspective of applications, how request and responses are issued and delivered, they do not include a specification of what the requesting and responding applications are to do with them. That is, the behavioral aspects of the applications are not specified; only a definition of what requests and responses they can

send/receive is specified. This permits greater flexibility to the FAL users in standardizing such object behavior. In addition to these services, some supporting services are also defined in this standard to provide access to the FAL to control certain aspects of its operation.

1.2 Specification

The principal objective of this standard is to specify the characteristics of conceptual application layer services suitable for time-critical communications, and thus supplement the OSI Basic Reference Model in guiding the development of application layer protocols for time-critical communications.

A secondary objective is to provide migration paths from previously-existing industrial communications protocols. It is this latter objective which gives rise to the diversity of services standardized as the various Types of IEC 61158, and the corresponding protocols standardized in subparts of IEC 61158-6.

This specification may be used as the basis for formal Application Programming-Interfaces. Nevertheless, it is not a formal programming interface, and any such interface will need to address implementation issues not covered by this specification, including

a) the sizes and octet ordering of various multi-octet service parameters, and

b) the correlation of paired request and confirm, or indication and response, primitives.

1.3 Conformance

This standard does not specify individual implementations or products, nor does it constrain the implementations of application layer entities within industrial automation systems.

There is no conformance of equipment to this application layer service definition standard. Instead, conformance is achieved through implementation of conforming application layer protocols that fulfill any given Type of application layer services as defined in this standard.

2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC PAS 62953-3-25, *Industrial communication networks – Fieldbus specifications – Part 3-25: Data-link layer service definition – Type 25 elements*

IEC PAS 62953-4-25, *Industrial communication networks – Fieldbus specifications – Part 4-25: Data-link layer protocol specification – Type 25 elements*

IEC PAS 62953-6-25, *Industrial communication networks – Fieldbus specifications – Part 6-25: Application layer protocol specification – Type 25 elements*

ISO/IEC 10731, *Information technology – Open Systems Interconnection – Basic ReferenceModel – Conventions for the definition of OSI services*

ISO/IEC 7498-1, *Information technology – Open Systems Interconnection – Basic ReferenceModel: The Basic Model*

ISO/IEC 7498-3, *Information technology – Open Systems Interconnection – Basic ReferenceModel: Naming and addressing*

ISO/IEC 8802-3:2000, *Information technology – Telecommunications and information exchange between systems – Local and metropolitan area networks – Specific requirements – Part 3: Carrier sense multiple access with collision detection (CSMA/CD) access method and Physical Layer specifications*

ISO/IEC 10731, *Information technology – Open Systems Interconnection – Basic Reference Model – Conventions for the definition of OSI services*

IEEE 802.1D-2004, *IEEE Standard for Local and metropolitan area networks – Media accesscontrol (MAC) Bridges,* available at <http://www.ieee.org>

IEEE 802.1Q-2005, *IEEE Standard for Local and metropolitan area networks – Virtual BridgedLocal Area Networks,* available at <http://www.ieee.org>

CONTENTS

1 Scope 163
1.1 General 163
1.2 Specification 164
1.3 Conformance 164
2 Normative references 164
3 Terms, definitions, symbols and abbreviations 165
3.1 Reference model terms and definitions 165
3.1.1 ISO/IEC 7498-1 terms 165
3.1.2 ISO/IEC 8822 terms 165
3.1.3 ISO/IEC 9545 terms 165
3.1.4 ISO/IEC 8824 terms 165
3.1.5 ISO/IEC 61158 terms 165
3.2 Additional terms and definitions for this IEC PAS 62953-6-25 166
3.3 Symbols and abbreviations 167
3.4 Conventions 169
3.4.1 General conventions 169
3.4.2 Conventions for class definitions 169
3.4.3 Conventions for bit description in octets 169
3.4.4 Conventions for state machine descriptions 170
4 FAL syntax description 170
4.1 FAL PDU type S abstract syntax 170
4.1.1 Basic abstract syntax 170
4.2 FAL PDU type N abstract syntax 174
4.2.1 Basic abstract syntax 174
4.2.2 CyclicData-PDU 175
4.2.3 MulticastData-PDU 175
4.2.4 PtoPData-PDU 175
4.2.5 Aliveinfo-PDU 175
4.2.6 Aliveinfo6-PDU 176
4.2.7 Inq-PDU 176
4.2.8 Ninq-PDU 177
4.2.9 Reply-PDU 177
4.2.10 RetransEnq-PDU 177
4.2.11 RetransConfirm-PDU 177
4.2.12 RetransNak-PDU 177
4.3 Data type assignments for type S 177
4.4 Data type assignments for type N 178
5 FAL transfer syntax 179
5.1 Encoding rules 179
5.1.1 Unsigned encoding 179
5.1.2 Octet string encoding 179
5.1.3 SEQUENCE encoding 179
5.2 FALPDU type S elements encoding 179
5.2.1 RCL_header 179
5.2.2 RHE-PDU 181
5.2.3 LCC-PDU 183

5.2.4 LCA-PDU 183
5.2.5 LCN-PDU 184
5.2.6 LNA-PDU 184
5.2.7 SCR-PDU 185
5.2.8 Cyclic_S-PDU 185
5.2.9 Cyclic_header 186
5.2.10 Control-PDU 186
5.2.11 RMTCTL-PDU 186
5.2.12 INFO-PDU 187
5.3 FALPDU type N elements encoding 187
5.3.1 General 187
5.3.2 FALAR-N Header 188
5.3.3 CyclicData-PDU 201
5.3.4 MulticastData-PDU 202
5.3.5 PtoP Data-PDU 202
5.3.6 Aliveinfo-PDU 202
5.3.7 Aliveinfo6-PDU 205
5.3.8 Inq-PDU 207
5.3.9 Ninq-PDU 207
5.3.10 Reply-PDU 208
5.3.11 RetransEnq-PDU 208
5.3.12 RetransConfirm-PDU 209
5.3.13 RetransNak-PDU 209
6 Structure of the FAL protocol state machine 210
7 FAL service protocol machine (FSPM) 211
7.1 Overview 211
7.2 FSPM type S 211
7.2.1 Overview 211
7.2.2 Interface of cyclic communication to FAL users 212
7.2.3 State machine of FSPM 213
7.3 FSPM type N 216
7.3.1 Overview 216
7.3.2 FSPM 217
8 Application relationship protocol machine (ARPM) 219
8.1 ARPM type S 219
8.1.1 Overview 219
8.1.2 Cyclic control 220
8.1.3 Remote control 223
8.1.4 RCL communication control 229
8.1.5 RT communication control 233
8.2 ARPM type N 236
8.2.1 Overview 236
8.2.2 General control 236
8.2.3 Cyclic transmission control 238
8.2.4 Acyclic transmission control 242
8.2.5 RT communication control 253
9 DLL mapping protocol machine (DMPM) 266
9.1 DMPM type S 266

9.2 DMPM type N 266
9.2.1 General 266
9.2.2 Communication port in transport layer 266
9.2.3 Quality of Service (Qos) for CP 20/2. 267
Bibliography 269

Figure 1 – Bit description in octets 169
Figure 2 – hd_sa 188
Figure 3 – hd_da 189
Figure 4 – Valid sequence number for reception message 192
Figure 5 – hd_m_ctl 192
Figure 6 – Valid reception packet sequence number 196
Figure 7 – Node-list 207
Figure 8 – Relationships between protocol machines 210
Figure 9 – Structure of FSPM type S 211
Figure 10 – Shared memory allocation in Type S network 213
Figure 11 – Structure of FSPM type N 216
Figure 12 – Structure of ARPM type S 220
Figure 13 – Sequence of cyclic communication 221
Figure 14 – The primitives for cyclic control 221
Figure 15 – The primitives for Remote control 224
Figure 16 – The primitives for RCL communication control 229
Figure 17 – The primitives for RT communication control 233
Figure 18 – Structure of ARPM type N 236
Figure 19 – Primitives of Cyclic transmission control 238
Figure 20 – Primitives of acyclic transmission control 243
Figure 21 – DSCP format 267
Figure 22 – IEEE 802.1Q tag frame format 267

Table 1 – State transition descriptions 170
Table 2 – Descriptions of state machine elements 170
Table 3 – Conventions used in state machine 170
Table 4 – Frame Class 180
Table 5 – DA_STaddress – DA_STaddress 180
Table 6 – DA_MACaddress 180
Table 7 – CMD field format 181
Table 8 – Send Direction 181
Table 9 – RHE ReceiveStatus 182
Table 10 – Physical Linkdown 182
Table 11 – RHE_pattern 1~4 183
Table 12 – LCC-Kind 183
Table 13 – RCL Status 183
Table 14 – hd_h_type 188
Table 15 – Usage of Mgn or Lnn 190

Table 16 – Detailed conditions for sequence number check of reception message 192
Table 17 – Valid bits of hd_m_ctl 193
Table 18 – Specified TCD 193
Table 19 – hd_pkind 194
Table 20 – PDU with an effective hd_pseq 194
Table 21 – Detailed conditions for sequence number check of reception packet (Multicast communication with retransmission) 196
Table 22 – Detailed conditions for packet sequence number check (One to one communication using a duplex LAN) 197
Table 23 – Relation between message transmission/reception 198
Table 24 – hd_mode 198
Table 25 – Message priority level 198
Table 26 – Value of α 199
Table 27 – Example of header information for a UDP message fragmentation 199
Table 28 – Example of header information for a TCP message fragmentation 200
Table 29 – inqid_inq_sa value 200
Table 30 – inqid_tr_adr value 201
Table 31 – inqid_inq_seq value 201
Table 32 – Relationship between inqid_id_seq and inqid_tr_adr 201
Table 33 – Type of an alive-message 203
Table 34 – Type of an alive-message protocol 203
Table 35 – Time of each al_mode 204
Table 36 – Status change of tasks 204
Table 37 – Change of tasks content 205
Table 38 – The threshold of transmission factor 212
Table 39 – Example of the traffic control configuration menu 213
Table 40 – Cyclic data state table 214
Table 41 – Acyclic data state table 215
Table 42 – Management state table 215
Table 43 – Cyclic data state table 217
Table 44 – Acyclic data state table 218
Table 45 – Management state table 219
Table 46 – Cyclic control state table 222
Table 47 – Cyclic control functions 223
Table 48 – Cyclic control variables 223
Table 49 – Remote control state table 225
Table 50 – Remote control functions 228
Table 51 – Remote control variables 228
Table 52 – RCL communication control state table 230
Table 53 – RCL communication control functions 231
Table 54 – RCL communication control variables 232
Table 55 – RT communication control state table 234
Table 56 – RT communication control functions 235
Table 57 – RT communication control variables 235

Table 58 – Cyclic transmission control state table 239
Table 59 – Cyclic transmission control functions 240
Table 60 – Cyclic transmission control variables 242
Table 61 – Acyclic transmission control state table 244
Table 62 – Acyclic transmission control functions 249
Table 63 – Acyclic transmission control variables 252
Table 64 – RT communication control state table 253
Table 65 – RT communication control functions 260
Table 66 – RT communication control variables 265
Table 67 – ARPM to DL mapping 266
Table 68 – Assignment policy of communication ports 267
Table 69 – Default DSCP and IEEE 802.1D/Q priority mapping for CP20/2 traffic 268

INDUSTRIAL COMMUNICATION NETWORKS – FIELDBUS SPECIFICATIONS –

Part 6-25: Application layer protocol specification – Type 25 elements

1 Scope

1.1 General

The Fieldbus Application Layer (FAL) provides user programs with a means to access the fieldbus communication environment. In this respect, the FAL can be viewed as a “window between corresponding application programs.”

This standard provides common elements for basic time-critical and non-time-critical messaging communications between application programs in an automation environment and material specific to Type 12 fieldbus. The term “time-critical” is used to represent the presence of a time-window, within which one or more specified actions are required to be completed with some defined level of certainty. Failure to complete specified actions within the time window risks failure of the applications requesting the actions, with attendant risk to equipment, plant and possibly human life.

This standard defines in an abstract way the externally visible behavior provided by the different Types of the fieldbus Application Layer in terms of

a) the abstract syntax defining the application layer protocol data units conveyed between communicating application entities,
b) the transfer syntax defining the application layer protocol data units conveyed between communicating application entities,
c) the application context state machine defining the application service behavior visible between communicating application entities; and
d) the application relationship state machines defining the communication behavior visible between communicating application entities; and.

The purpose of this standard is to define the protocol provided to

a) define the wire-representation of the service primitives defined in IEC PAS 62953-5-25, and
b) define the externally visible behavior associated with their transfer.

This standard specifies the protocol of the IEC fieldbus Application Layer, in conformance with the OSI Basic Reference Model (ISO/IEC 7498) and the OSI Application Layer Structure (ISO/IEC 9545).

FAL services and protocols are provided by FAL application-entities (AE) contained within the application processes. The FAL AE is composed of a set of object-oriented Application Service Elements (ASEs) and a Layer Management Entity (LME) that manages the AE. The ASEs provide communication services that operate on a set of related application process object (APO) classes. One of the FAL ASEs is a management ASE that provides a common set of services for the management of the instances of FAL classes.

Although these services specify, from the perspective of applications, how request and responses are issued and delivered, they do not include a specification of what the requesting and responding applications are to do with them. That is, the behavioral aspects of the

applications are not specified; only a definition of what requests and responses they can send/receive is specified. This permits greater flexibility to the FAL users in standardizing such object behavior. In addition to these services, some supporting services are also defined in this standard to provide access to the FAL to control certain aspects of its operation.

1.2 Specification

The principal objective of this standard is to specify the syntax and behavior of the application layer protocol that conveys the application layer services defined in IEC PAS 62953-5-25. A secondary objective is to provide migration paths from previously-existing industrial communications protocols. It is this latter objective which gives rise to the diversity of protocols standardized in subparts of IEC 61158-6.

1.3 Conformance

This standard does not specify individual implementations or products, nor does it constrain the implementations of application layer entities within industrial automation systems.

There is no conformance of equipment to the application layer service definition standard. Instead, conformance is achieved through implementation of this application layer protocol specification.

2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC PAS 62953-3-25, *Industrial communication networks – Fieldbus specifications – Part 3-25:Data-link layer service definition – Type 25 elements*

IEC PAS 62953-4-25, *Industrial communication networks – Fieldbus specifications – Part 4-25: Data-link layer protocol specification – Type 25 elements*

IEC PAS 62953-5-25, *Industrial communication networks – Fieldbus specifications – Part 5-25: Application layer service definition – Type 25 elements*

ISO/IEC 10731, *Information technology – Open Systems Interconnection – Basic Reference Model – Conventions for the definition of OSI services*

ISO/IEC 7498-1, *Information technology – Open Systems Interconnection – Basic Reference Model: The Basic Model*

ISO/IEC 7498-3, *Information technology – Open Systems Interconnection – Basic Reference Model: Naming and addressing*

ISO/IEC 8802-3:2000, *Information technology – Telecommunications and information exchange between systems – Local and metropolitan area networks – Specific requirements – Part 3: Carrier sense multiple access with collision detection (CSMA/CD) access method and Physical Layer specifications*

ISO/IEC 10731, *Information technology – Open Systems Interconnection – Basic Reference Model – Conventions for the definition of OSI services*

IEEE 802.1D-2004, *IEEE Standard for Local and metropolitan area networks – Media access control (MAC) Bridges,* available at <http://www.ieee.org>

IEEE 802.1Q-2005, *IEEE Standard for Local and metropolitan area networks – Virtual Bridged Local Area Networks,* available at <http://www.ieee.org>

CONTENTS

1 Scope 271
2 Normative references 271
3 Terms, definitions, symbols and abbreviations 271
3.1 Terms and definitions 271
3.2 Abbreviated terms and acronyms 271
3.3 Symbols 271
3.3.1 CPF 20 symbols 271
3.4 Conventions 272
4 Conformance to communication profiles 272
5 RTE performance indicators 272
6 Conformance tests 272
7 Communication Profile Family 20 (ADS-net) – RTE communication profiles 273
7.1 General overview 273
7.2 Profile 20/1 273
7.2.1 Physical layer 273
7.2.2 Data link layer 273
7.2.3 Application layer 273
7.2.4 Performance indicator selection 275
7.3 Profile 20/2 278
7.3.1 Physical layer 278
7.3.2 Data link layer 278
7.3.3 Application layer 278
7.3.4 Performance indicator selection 279
Annex A (informative) Performance Indicator calculation 283
A.1 CPF 20 – Performance indicator calculation 283
A.1.1 Profile 20/1 283
A.1.2 Profile 20/2 284
Bibliography 286

Table 1 – CP 20/1: DLL service selection 273
Table 2 – CP 20/1: DLL protocol selection 273
Table 3 – CP 20/1: AL service selection 274
Table 4 – CP 20/1: AL protocol selection 274
Table 5 – CP 20/1: performance indicator overview 275
Table 6 – CP 20/1: Performance indicator dependency matrix 275
Table 7 – CP 20/1: Consistent set of performance indicators 278
Table 8 – CP 20/2: AL service selection 278
Table 9 – CP 20/2: AL protocol selection 279
Table 10 – CP 20/2: Performance indicator overview 279
Table 11 – CP 20/2: Performance indicator dependency matrix 280
Table 12 – CP 20/2: Consistent set of performance indicators 282

INDUSTRIAL COMMUNICATION NETWORKS – PROFILES –

Part 2: Additional fieldbus profiles for real-time networks based on ISO/IEC 8802-3

1 Scope

Chapter is identical in form and content for all CPFs – see IEC 61784-2:2014

2 Normative references

Additional references for CPF 20

IEC PAS 62953-3-25, *Industrial communication networks – Fieldbus specifications – Part 3-25: Data-link layer service definition – Type 25 elements*

IEC PAS 62953-4-25, *Industrial communication networks – Fieldbus specifications – Part 4-25: Data-link layer protocol specification – Type 25 elements*

IEC PAS 62953-5-25, *Industrial communication networks – Fieldbus specifications – Part 5-25: Application layer service definition – Type 25 elements*

IEC PAS 62953-6-25, *Industrial communication networks – Fieldbus specifications – Part 6-25: Application layer protocol specification – Type 25 elements*