IEC TR 61850-90-7

Edition 2.0 2023-08

TECHNICAL REPORT

colour inside

Communication networks and systems for power utility automation – Part 90-7: Object models for power converters in distributed energy resources (DER) systems

INTERNATIONAL ELECTROTECHNICAL COMMISSION

ICS 33.200

ISBN 978-2-8322-7337-1

Warning! Make sure that you obtained this publication from an authorized distributor.

® Registered trademark of the International Electrotechnical Commission

CONTENTS

FOREWORD 5
1 Scope 7
2 Normative references 7
3 Terms, definitions, acronyms and abbreviated terms 7
3.1 Terms and definitions 8
3.2 Acronyms 10
3.3 Abbreviated terms 10
4 Overview of power converter-based DER functions 11
4.1 General 11
4.2 Power converter configurations and interactions 12
4.3 Power converter methods 14
4.4 Power converter functions 15
4.5 Differing DER architectures 16
4.5.1 Conceptual architecture: electrical coupling point (ECP) 16
4.5.2 Conceptual architecture: point of common coupling (PCC) 16
4.5.3 Utility interactions directly with power converters or indirectly via a customer EMS 17
4.5.4 Communication profiles 17
4.6 General sequence of information exchange interactions 18
5 Concepts and constructs for managing power converter functions 19
5.1 Basic settings of power converters 19
5.1.1 Nameplate values versus basic settings 19
5.1.2 Power factor and power converter quadrants 19
5.1.3 Maximum watts, vars, and volt-amp settings 21
5.1.4 Active power ramp rate settings 22
5.1.5 Voltage phase and correction settings 23
5.1.6 Charging settings 23
5.1.7 Example of basic settings 23
5.1.8 Basic setting process 24
5.2 Modes for managing autonomous behaviour 24
5.2.1 Benefits of modes to manage DER at ECPs 24
5.2.2 Modes using curves to describe behaviour 25
5.2.3 Paired arrays to describe mode curves 26
5.2.4 Percentages as size-neutral parameters: voltage and var calculations 27
5.2.5 Hysteresis as values cycle within mode curves 27
5.2.6 Low pass exponential time rate 28
5.2.7 Ramp rates 29
5.2.8 Randomized response times 29
5.2.9 Timeout period 30
5.2.10 Multiple curves for a mode 30
5.2.11 Multiple modes 30
5.2.12 Use of modes for loosely coupled, autonomous actions 30
5.3 Schedules for establishing time-based behaviour 30
5.3.1 Purpose of schedules 30
5.3.2 Schedule components 31
6 DER management functions for power converters 32
6.1 Immediate control functions for power converters 32

6.1.1 General 32
6.1.2 Function INV1: connect / disconnect from grid 33
6.1.3 Function INV2: adjust maximum generation level up/down 33
6.1.4 Function INV3: adjust power factor 34
6.1.5 Function INV4: request active power (charge or discharge storage) 34
6.1.6 Function INV5: pricing signal for charge/discharge action 35
6.2 Modes for volt-var management 36
6.2.1 VAr management modes using volt-var arrays 36
6.2.2 Example setting volt-var mode VV11: available var support mode with no impact on watts 37
6.2.3 Example setting volt-var mode VV12: maximum var support mode based on WMax 38
6.2.4 Example setting volt-var mode VV13: static power converter mode based on settings 40
6.2.5 Example setting volt-var mode VV14: passive mode with no var support 41
6.3 Modes for frequency-related behaviours 41
6.3.1 Frequency management modes 41
6.3.2 Frequency-watt mode FW21: high frequency reduces active power 42
6.3.3 Frequency-watt mode FW22: constraining generating/charging by frequency 44
6.4 Dynamic reactive current support during abnormally high or low voltage levels 47
6.4.1 Purpose of dynamic reactive current support 47
6.4.2 Dynamic reactive current support mode TV31: support during abnormally high or low voltage levels 47
6.5 Low/high voltage ride-through curves for “must disconnect” and “must remain connected” zones 51
6.5.1 Purpose of L/HVRT 51
6.5.2 “Must disconnect” (MD) and “must remain connected” (MRC) curves 51
6.6 Modes for watt-triggered behaviours 53
6.6.1 Watt-power factor mode WP41: feed-in power controls power factor 53
6.6.2 Alternative watt-power factor mode WP42: feed-in power controls power factor 53
6.7 Modes for voltage-watt management 54
6.7.1 Voltage-watt mode VW51: voltage-watt management: generating by voltage 54
6.7.2 Voltage-watt mode VW52: voltage-watt management: charging by voltage 54
6.8 Modes for behaviours triggered by non-power parameters 55
6.8.1 Temperature mode TMP 55
6.8.2 Pricing signal mode PS 55
6.9 Setting and reporting functions 56
6.9.1 Purpose of setting and reporting functions 56
6.9.2 Establishing settings DS91: modify power converter-based DER settings 56
6.9.3 Event logging DS92: log alarms and events, retrieve logs 56
6.9.4 Reporting status DS93: selecting status points, establishing reporting mechanisms 60
Bibliography 62

Figure 1 – DER management hierarchical interactions: autonomous, loosely-coupled, broadcast/multicast 14
Figure 2 – Electrical Connection Points (ECP) and Point of Common Coupling (PCC) 17
Figure 3 – Producer and Consumer Reference Frame conventions 20
Figure 4 – EEI power factor sign convention 21
Figure 5 – Working areas for different modes 22
Figure 6 – Example of voltage offsets (*VRef*Ofs) with respect to the reference voltage (*VRef*) 23
Figure 7 – Example of modes associated with different ECPs 25
Figure 8 – Example of a volt-var mode curve 26
Figure 9 – Example of hysteresis in volt-var curves 28
Figure 10 – Example of deadband in volt-var curves 28
Figure 11 – Local function block diagram 29
Figure 12 – Time domain response of first order low pass filter 29
Figure 13 – Interrelationships of schedule controllers, schedules, and schedule references 32
Figure 14 – Volt-var mode VV11 – available vars mode 37
Figure 15 – Power converter mode VV12 – Maximum var support mode based on WMax 39
Figure 16 – Power converter mode VV13 – Example: static var support mode based on *VArMax* 40
Figure 17 – Frequency-watt mode curves 42
Figure 18 – Frequency-based active power reduction 43
Figure 19 – Frequency-based active power modification with the use of an array 44
Figure 20 – Example of a basic frequency-watt mode configuration 45
Figure 21 – Example array settings with hysteresis 46
Figure 22 – Example of an asymmetrical hysteresis configuration 46
Figure 23 – Example array configuration for absorbed watts vs. frequency 47
Figure 24 – Basic concepts of the dynamic reactive current support function 48
Figure 25 – Calculation of delta voltage over the filter time window 48
Figure 26 – Activation zones for dynamic reactive current support 49
Figure 27 – Alternative gradient behaviour, selected by ArGraMod 50
Figure 28 – Settings to define a blocking zone 50
Figure 29 – Must disconnect and must remain connected zones 52
Figure 30 – Examples of “must remain connected” requirements for different regions 52
Figure 31 – Power factor controlled by feed-in power 53
Figure 32 – Example configuration curve for maximum watts vs. voltage 54
Figure 33 – Example configuration curve for maximum watts absorbed vs. voltage 55

Table 1 – Producer Reference Frame (PRF) conventions 19
Table 2 – Example basic settings for a storage DER unit 24
Table 3 – Events 58
Table 4 – Examples of status points 60

INTERNATIONAL ELECTROTECHNICAL COMMISSION

_____

COMMUNICATION NETWORKS AND SYSTEMS FOR POWER UTILITY AUTOMATION –

Part 90-7: Object models for power converters in distributed energy resources (DER) systems

FOREWORD

1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
6) All users should ensure that they have the latest edition of this publication.
7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

IEC TR 61850-90-7 has been prepared by IEC technical committee 57: Power systems management and associated information exchange. It is a Technical Report.

This second edition cancels and replaces the first edition published in 2013. This edition is primarily an editorial revision in order to be consistent with the publication of Edition 2 of IEC 61850-7-420:2021.

This edition includes the following significant changes with respect to the previous edition:

a) Clause 3 has been updated.
b) Clause 8 (IEC 61850 information models for power converter-based functions) has been deleted. This clause defined data models with the transitional namespace "(Tr) IEC 61850-90-7:2012". The data models are now defined in IEC 61850-7-420.

The text of this Technical Report is based on the following documents:

Draft	Report on voting
57/2558/DTR	57/2610/RVDTR

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

The language used for the development of this Technical Report is English.

This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available at www.iec.ch/members_experts/refdocs. The main document types developed by IEC are described in greater detail at www.iec.ch/publications.

A list of all parts of the IEC 61850 series, under the general title *Communication networks and systems for power utility automation*, can be found on the IEC website.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under webstore.iec.ch in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

COMMUNICATION NETWORKS AND SYSTEMS FOR POWER UTILITY AUTOMATION –

Part 90-7: Object models for power converters in distributed energy resources (DER) systems

1 Scope

This part of IEC 61850, which is a Technical Report, describes functions for power converter-based distributed energy resources (DER) systems, focused on DC-to-AC and AC-to-AC conversions and including photovoltaic systems (PV), battery storage systems, electric vehicle (EV) charging systems, and any other DER systems with a controllable power converter.

The functions defined in this document were used to help define the information models described in IEC 61850-7-420 and which can be used in the exchange of information between these power converter-based DER systems and the utilities, energy service providers (ESPs), or other entities which are tasked with managing the volt, var, and watt capabilities of these power converter-based systems.

These power converter-based DER systems can range from very small grid-connected systems at residential customer sites, to medium-sized systems configured as microgrids on campuses or communities, to very large systems in utility-operated power plants, and to many other configurations and ownership models. They may or may not combine different types of DER systems behind the power converter, such as a power converter-based DER system and a battery that are connected at the DC level.

NOTE The term power converter is being used in place of “inverter” since it covers more types of conversion from input to output power:

- AC to DC (rectifier)
- DC to AC (inverter)
- DC to DC (DC-to-DC converter)
- AC to AC (AC-to-AC converter)

2 Normative references

There are no normative references in this document.