IEC TR 62746-2

Edition 2.0 2025-11

TECHNICAL REPORT

Systems interface between customer energy management system and the power management system -
Part 2: Use cases

ICS 33.200

ISBN 978-2-8327-0814-9

IEC TR 62746-2:2025-11(en)

THIS PUBLICATION IS COPYRIGHT PROTECTED
Copyright © 2025 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

IEC Secretariat
3, rue de Varembé
CH-1211 Geneva 20
Switzerland

Tel.: +41 22 919 02 11
info@iec.ch
www.iec.ch

About the IEC
The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications
The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigendum or an amendment might have been published.

IEC publications search - webstore.iec.ch/advsearchform
The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee, …). It also gives information on projects, replaced and withdrawn publications.

IEC Just Published - webstore.iec.ch/justpublished
Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and once a month by email.

IEC Customer Service Centre - webstore.iec.ch/csc
If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: sales@iec.ch.

IEC Products & Services Portal - products.iec.ch
Discover our powerful search engine and read freely all the publications previews, graphical symbols and the glossary. With a subscription you will always have access to up to date content tailored to your needs.

Electropedia - www.electropedia.org
The world's leading online dictionary on electrotechnology, containing more than 22 500 terminological entries in English and French, with equivalent terms in 25 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

Warning! Make sure that you obtained this publication from an authorized distributor.

CONTENTS

FOREWORD....5
INTRODUCTION....7
1 Scope....10
2 Normative references....11
3 Terms, definitions and abbreviated terms....11
3.1 Terms and definitions....11
3.2 Abbreviated terms....17
4 Guidelines....18
4.1 Common architecture model – Architectural criteria....18
4.2 SG CP (Smart Grid Connection Point)....23
4.2.1 Overview....23
4.2.2 Definition of SG CP (Smart Grid Connection Point)....24
4.2.3 Purpose of definition of SG CP (Smart Grid Connection Point)....24
4.2.4 Target of demand / supply of power and information that is sent and received....25
4.2.5 Functional criteria of SG CP (Smart Grid Connection Point)....25
4.3 The Communication of the Smart Grid and the Smart Grid Connection Point (interface into the premises)....26
4.4 Common messages – information to be exchanged....27
4.4.1 General....27
4.4.2 Intention of user stories and use cases....27
4.4.3 Relationship of user stories and use cases....29
4.4.4 Criteria for information exchange....29
4.4.5 Energy management concepts....32
4.4.6 Function-specific profiles....34
4.4.7 Comfort, management and status information....40
4.4.8 Upcoming profiles for new service criteria....40
Annex A (informative) User stories and use cases collection....41
A.1 User stories....41
A.1.1 General....41
A.1.2 JWG1 Flex start washing machine....41
A.1.3 JWG2 Flex start EV charging....42
A.1.4 JWG3 Severe grid stability issues....43
A.1.5 JWG4 Power limitation PV....43
A.1.6 JWG5 CEM manages devices....44
A.1.7 JWG6 Customer sells flexibility....44
A.1.8 JWG7 Customer sells decentralized energy....45
A.1.9 JWG8 Grid-related emergency situations....45
A.1.10 JWG9 Customer connects new smart device....46
A.1.11 JWG10 Energy consumption information....46
A.1.12 JWG11 Unexpected disconnect....46
A.1.13 JWG12 Expected Yearly Costs of Smart Device....46
A.1.14 JWG13 Energy storage and feed in based on tariff....47
A.1.15 JWG14 Energy Consumption Management From External....47
A.1.16 JWG15 Manage in-premises battery system....48
A.1.17 JWG16 Manage DER....48
A.1.18 JWG17 Peak shift contribution by battery aggregation....49

A.1.19 JWG18 Control appliances based on price information 49
A.1.20 JWG19 Control appliances based on energy savings signal 50
A.1.21 JWG20 Control appliances before power cut 50
A.1.22 JWG21 Control appliances in case of natural disaster 51
A.1.23 JWG22 Bilateral DR-negawatt 51
A.1.24 JWG23 User story lighting 52
A.1.25 JWG24 Energy market flexibility management 53
A.1.26 Japanese building scenarios on energy management 54
A.2 User stories and use case mapping table 57
A.3 Use case descriptions 66
A.3.1 Overview 66
A.3.2 High level use case (JWG1100) Flexible start of a smart device (SD) 66
A.3.3 Specialized use case (JWG1110) Control of Smart home appliances based on price information by time slot 76
A.3.4 High level use case (JWG112x) Manage mixed energy system like heat pumps with PV, storage battery 82
A.3.5 High level use case (JWG113x) Log mixed energy system events of heat pumps with pv, storage battery 89
A.3.6 High level use case (JWG120x) Provide local power managing capabilities 96
A.3.7 High level use case (JWG121x) Provide local power managing capabilities 102
A.3.8 High level use case (JWG2002) District Energy Management 108
A.3.9 High level use case (WGSP 211x) Exchanging information on consumption, price device status, and warnings with external actors and within the home 118
A.3.10 High level use case (JWG212x, based on WGSP212x) Direct load-generation management (international) 137
A.3.11 high level use case (WGSP2140) Tariff synchronization 154
A.3.12 High level use case (JWG3000) Limitation of Power Consumption 165
A.3.13 High level use case (JWG3001) Limitation of Power Production 175
A.3.14 High level use case (JWG3002) Monitoring of Grid Connection Points 186
A.3.15 High level use case (JWG3003) Monitoring of power consumption 192
A.3.16 high level use case (JWG3004) Time of Use Tariff 197
A.3.17 high level use case (JWG3005) Power Demand Forecast 204
A.3.18 high level use case (JWG3006) Power Envelop 209
A.3.19 high level use case (JWG4000) Residential Home Energy Management integrating DER flexibility aggregation 224
Bibliography 229

Figure 1 – Examples of demand response capabilities 9
Figure 2 – Smart environment as of today 10
Figure 3 – Criteria for interoperability 10
Figure 4 – External actor definition 13
Figure 5 – Internal actor definition 14
Figure 6 – Smart Grid Functional Architecture Model 18
Figure 7 – Neutral interfaces 20
Figure 8 – Mapping Interface (I/F) structure 20
Figure 9 – Example of a mapping of messages 21

Figure 10 – Different CEM configurations see SG-CG/M490 [5] to [9] 21
Figure 11 – Physical combinations 22
Figure 12 – Examples of CEM architecture 23
Figure 13 – "Group of domains" and "Functional Architecture Model" 24
Figure 14 – Smart Grid Connection Point SG CP 26
Figure 15 – SG CP (in the case of interruption of electrical power supply from energy supplier) 26
Figure 16 – User stories and use cases process 28
Figure 17 – Relationship user stories and use cases 29
Figure 18 – Examples of information to be exchanged 30
Figure 19 – Traffic Light Concept 33
Figure 20 – Structure of a power profile 35
Figure 21 – Consumption and generation 35
Figure 22 – Structure of an easy power profile 36
Figure 23 – Structure of a price profile 37
Figure 24 – Structure of a load / generation management profile 38
Figure 25 – Structure of a temperature profile 39
Figure A.1 – Kinds of user stories 41
Figure A.2 – Use case and process 66
Figure A.3 – Flexible start of a smart device – High-level use case overview 67
Figure A.4 – Power sequence – Modelling with slots and time constraints 68
Figure A.5 – Workflow of the use case Flexible start of a smart device 69
Figure A.6 – Sequence diagram – Announcement of plan 74
Figure A.7 – Sequence diagram – Shift preferred power sequence 74
Figure A.8 – Sequence diagram – Select alternative power sequence 75
Figure A.9 – Sequence diagram – Configure current power sequence 76
Figure A.10 – District energy management – High-level use case overview 109
Figure A.11 – Exchanging information on consumption, price device status, and warnings with external actors and within the home – High-level use case overview 119
Figure A.12 – Load-generation management (international) – High-level use case overview 137
Figure A.13 – Tariff synchronization – High-level use case overview 155
Figure A.14 – Limitation of power consumption – High-level use case overview 166
Figure A.15 – Example for two instances of limitation of power consumption use case 170
Figure A.16 – Limitation of power consumption use case state machine 170
Figure A.17 – Limitation of power production – High-level use case overview 176
Figure A.18 – Example of permitted ranges for power, depending on the respective valid limit value 177
Figure A.19 – Example for two instances of limitation of power production use case 180
Figure A.20 – Limitation of power production use case state machine 181
Figure A.21 – Monitoring of grid connection point – High-level use case overview 186
Figure A.22 – Location of the grid connection point 187
Figure A.23 – Sequence diagram – Use case monitoring of grid connection point 188
Figure A.24 – Monitoring of power consumption – High-level use case overview 193

Figure A.25 – Sequence diagram – Use case monitoring of power consumption 194
Figure A.26 – Time of use tariff – High-level use case overview 198
Figure A.27 – Incentive table example for consumption 199
Figure A.28 – Unique tiers example for consumption and production 200
Figure A.29 – Power demand forecast – High-level use case overview 205
Figure A.30 – Power forecast example: power (P) curves over time (t) 206
Figure A.31 – Power over time limit curves 210
Figure A.32 – Power envelope – High-level use case overview 210
Figure A.33 – Example of permitted ranges for power limit curves 216
Figure A.34 – Example of active power consumption (hatched area) 217
Figure A.35 – Example of active power production (hatched area) 218
Figure A.36 – Residential home energy management integrating DER flexibility aggregation – High-level use case overview 227

Table 1 – Information criteria collection 30
Table 2 – Mapping user stories to categories 31
Table 3 – Mapping use cases to categories 32
Table 4 – Information guidelines for "Energy Profile" 36
Table 5 – Information guidelines "Price and Environment Profile" 37
Table 6 – Information guidelines "Direct Load / Generation Management Profile" 39
Table 7 – Information guidelines "Temperature Profile" 40
Table A.1 – User stories – Use case mapping table 58

INTERNATIONAL ELECTROTECHNICAL COMMISSION

_____

Systems interface between customer energy management system and the power management system - Part 2: Use cases

FOREWORD

1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
6) All users should ensure that they have the latest edition of this publication.
7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
9) IEC draws attention to the possibility that the implementation of this document may involve the use of (a) patent(s). IEC takes no position concerning the evidence, validity or applicability of any claimed patent rights in respect thereof. As of the date of publication of this document, IEC had not received notice of (a) patent(s), which may be required to implement this document. However, implementers are cautioned that this may not represent the latest information, which may be obtained from the patent database available at https://patents.iec.ch. IEC shall not be held responsible for identifying any or all such patent rights.

IEC TR 62746-2 has been prepared by IEC technical committee 57: Power systems management and associated information exchange. It is a Technical Report.

This second edition cancels and replaces the first edition published in 2015. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

a) The Architecture Model of the Smart Grid Coordination Group (Figure 6) has been replaced with the draft Architecture Model of TC57 in collaboration with SC23K and TC13;
b) The use cases from Edition 1 (2015) with the following IDs have been removed from the current document: JWG2000, JWG2001, JWG2010, JWG202x, JWG2041, JWG2042, JWG1111, WGSP2120, JWG30xx;

c) The use cases from Edition 1 (2015) with the following IDs: JWG1100, JWG1101, JWG-SPUC1102, and JWG1103 have been replaced with the use case JWG1100;

d) The following use cases have been added to the current document: JWG3000, JWG3001, JWG3002, JWG3003, JWG3004, JWG3005, JWG3006, JWG4000.

The text of this Technical Report is based on the following documents:

Draft	Report on voting
57/2803/DTR	57/2847/RVDTR

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

The language used for the development of this Technical Report is English.

This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available at www.iec.ch/members_experts/refdocs. The main document types developed by IEC are described in greater detail at www.iec.ch/publications.

A list of all parts in the IEC 62746 series, published under the general title *Systems interface between customer energy management system and the power management system*, can be found on the IEC website.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under webstore.iec.ch in the data related to the specific document. At this date, the document will be

– reconfirmed,

– withdrawn, or

– revised.

INTRODUCTION

Intelligent, integrated energy systems for smart environments

NOTE This Introduction is an extract from the "Demand – Response – White Paper, Siemens AG, 2010 [1][1].

In 2007, the number of people living in conurbations around the world surpassed that of those living in rural areas. Today, large cities worldwide account for 75 per cent of energy demand and generate a large percentage of total carbon dioxide emissions. For this reason, a number of cities and metropolitan areas have set themselves ambitious goals towards reducing emissions by increasing the efficiency of their infrastructures. These goals aim to have a positive impact on the environment, while continuing to enhance the quality of life of growing urban populations.

The transition to a new "electrical era" in which electricity is becoming the preferred energy source for most everyday applications is currently taking place. This is governed by three key factors: demographic change, scarcity of resources, and climate change. In the meantime, two development trends are of particular interest:

– the demand for electricity is continuing to grow.

– the energy system is subject to dramatic changes.

The experienced changes to the energy system can vary, based on whether they are nationally or cross-nationally observed. Some of the changes are caused by electricity production and fluctuating power supply sources.

Until recently, load dictated production, a method which influenced how interconnected power systems were designed. Power generation was centralized, controllable, and above all, reliable. The load was statistically predictable, and energy flow was unidirectional, that is from producer to consumer.

These aspects of power generation are changing. Firstly, the rising percentage of fluctuating production within the energy mix brought about by renewables reduces the level of power generation control available. Secondly, the energy flow is no longer unidirectionally sent from producer to consumer; now the consumer is slowly turning into a "prosumer," a term which denotes a person who produces and consumes energy. More and more consumers are installing their own renewable energy products to increase energy efficiency. These prosumers are cogenerating heat and power with their own solar panels or microCHPs, for example. This trend is set to continue, as government bodies continue to provide incentives to domestic users to become "prosumers" as part of their increased energy efficiency policies.

Managing reactive power in relation with power system voltage control will become more important in situation and regions where distributed generation and power storage is or will become a substantial part of the total power demand of that region. The total power demand in the region will be generated partly by the central power stations that are connected to the transmission system and the power generated locally by generators and storage facilities connected to the distribution networks in that region. It will not be sufficient to switch distributed generators and/or storage facilities of premises off during emergency situations in the power system. In future it will be thinkable, and it already happens that in certain regions distributed generation and storage will support power system restoration in emergency situations in the network. Voltage and frequency will not only be controlled by central power stations and dispatch centers, a more advanced control will be supported by appropriate energy market arrangements (contracts and transparent arrangements between different parties involved).

[1] Numbers in square brackets refer to the Bibliography.

Ultimately, the way of the future will have to be that, up to a certain extent, the load follows the energy availability.

The way in which loads (being demand or local generation) at the consumer side can be managed, is through the mechanisms of Demand Response and Demand Side Management.

When referring to Demand Response and Demand Side Management, within this technical report the following definition of EURELECTRIC [2] in its paper "EURELECTRIC Views on Demand-Side Participation" is used:

– "Demand Side Management (DSM) or Load Management has been used in the (mainly still vertically integrated as opposed to unbundled) power industry over the last thirty years with the aim "to reduce energy consumption and improve overall electricity usage efficiency through the implementation of policies and methods that control electricity demand. Demand Side Management (DSM) is usually a task for power companies / utilities to reduce or remove peak load, hence defer the installations of new capacities and distribution facilities. The commonly used methods by utilities for demand side management are combination of high efficiency generation units, peak-load shaving, load shifting, and operating practices facilitating efficient usage of electricity, etc." Demand Side Management (DSM) is therefore characterized by a 'top-down' approach: the utility decides to implement measures on the demand side to increase its efficiency.
– Demand Response (DR), on the contrary, implies a 'bottom-up' approach: the customer becomes active in managing his/her consumption – in order to achieve efficiency gains and by this means monetary/economic benefits. Demand Response (DR) can be defined as "the changes in electric usage by end-use customers from their normal consumption patterns in response to changes in the price of electricity over time. Further, DR can be also defined as the incentive payments designed to induce lower electricity use at times of high wholesale market prices or when system reliability is jeopardized. DR includes all intentional modifications to consumption patterns of electricity of end use customers that are intended to alter the timing, level of instantaneous demand, or the total electricity consumption". DR aims to reduce electricity consumption in times of high energy cost or network constraints by allowing customers to respond to price or quantity signals."

The intent of Demand Response and Demand Side Management programs is to motivate end users to make changes in electric use, lowering consumption when prices spike or when grid reliability is jeopardized. These concepts refer to all functions and processes applied to influence the behaviour of energy consumption or local production. This leads to a more efficient energy supply which enables the consumer to benefit from reduced overall energy costs.

In this context, the report focuses on the signals exchanged between the grid and the premise, which goes from simple signalling to integrated load management.

Since many components are integrated to interface within a demand response solution, a suitable communication infrastructure is of paramount importance.

There is a variety of equipment connected to the grid, which can be included in a demand response solution. Such devices can act as an energy source or load. Some devices can act as both an energy source and a load alternately, depending on the operation mode selected. In response to load peaks or shortages, selected generation sources can be switched on, loads switched off, and storages discharged. In addition, loads with buffer or storage capacity can be switched on to make use of preferred energy generation when available.

As shown in the examples in Figure 1, some device types provide storage or buffer capability for energy. A storage device can give back the energy in the same type as it was filled. An example of this is a battery. A buffer device, however, can store energy only in a converted form, in the way that a boiler stores energy by heating up water; it is only capable of load-shifting. Devices capable of storage, however, can be utilized fully for energy balancing within the electrical grid.

Table: Demand response communication infrastructure

Device type	Influenceable		Storage/ buffer	Comment
	Generation	Consumption		
Wind turbine	■			Only reduction of actual generation
Photovoltaic generation	■			Only reduction of actual generation
Backup generators	■			
Solar water radiators		■	B	Additional electrical heating in boiler required
Combined heat and power	■	■	B	Additional electrical heating in boiler required
Heat pump with boiler		■	B	
Electric radiators		■		
Central air-conditioning		■	B	
Decentral air-conditioning		■		
Drives for ventilation		■		
Drives for water pumps		■	B	Requires water tanks on top of buildings
Other drives		■		Elevators, escalators, etc.
Household appliances		■		Washing machines, tumble dryers, dishwashers, etc.
Industrial processes		■	S/B	Storage/buffer capability depends on process type
Batteries and supercaps	■	■	S	
E-cars (home charging)	■	■	S/B	Feedback is currently only future option
E-cars (public charging)		■		

SOURCE: Siemens AG [1]

Figure 1 – Examples of demand response capabilities

1 Scope

The success of the Smart Grid and Smart Home/Building/Industrial approach is very much related to interoperability, which means that Smart Grid and all smart devices in a Home/Building/Industrial environment have a common understanding of messages and data in a defined interoperability area (in a broader perspective, it does not matter if it has an energy related message, a management message or an informative message).

In contradiction, today's premises are covered by different networks and standalone devices (see Figure 2).




Figure 2 – Smart environment as of today

The scope of this part of IEC 62746, which is a technical report, is to describe the main pillars of interoperability to assist different IEC Technical Committees in defining their interfaces and messages covering the whole chain between a Smart Grid and Smart Home/Building/Industrial area (see Figure 3).




Figure 3 – Criteria for interoperability

The main topics of this document are:

– To describe an architecture model from a logical point of view;
– To describe a set of user stories that describe a number of situations related to energy flexibility and demand side management as well as an outline of potential upcoming Smart Building and Smart Home scenarios. The set of user stories does not have the ambition to list all home and building (energy) management possibilities, but is meant as a set of examples that are used as input in use cases and to check that the set of use cases is complete;
– To describe a set of use cases based on the user stories and architecture. The use cases describe scenarios in which the communication between elements of the architecture are identified;
– To further detail the communication, identified in the use cases, by describing the messages and information to be exchanged.

This document can also be used as a blueprint for further smart home solutions like remote control, remote monitoring, ambient assistant living and so forth.

This technical report will be regularly revised by introducing new use cases and updating the current use cases. The use cases presented in this document are not going to be included in the IEC Use Case Management Repository (UCMR). The data models of some use cases presented here are defined in the second edition of IEC 62746-4[2]. The smart grid architecture model presented in this document is created in coordination with IEC TC13, SC23, and TC57.

2 Normative references

There are no normative references in this document.

[2] Under consideration.