IEC TS 60695-5-2

Edition 3.0 2021-06
REDLINE VERSION

TECHNICAL SPECIFICATION

colour inside

Fire hazard testing –
Part 5-2: Corrosion damage effects of fire effluent – Summary and relevance of test methods

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

ICS 13.220.99; 19.020; 29.020

ISBN 978-2-8322-9866-4

Warning! Make sure that you obtained this publication from an authorized distributor.

® Registered trademark of the International Electrotechnical Commission

CONTENTS

FOREWORD 4
INTRODUCTION 2
1 Scope 9
2 Normative references 9
3 Terms and definitions 9
4 Classification of test methods 9
4.1 ~~Introduction~~ General 11
4.2 Test specimen 11
4.2.1 Product testing 11
4.2.2 Material or composite sample testing 11
4.3 The physical fire model 12
4.4 The nature of the corrosivity measurement 12
4.4.1 Product ~~testing~~ as target 12
4.4.2 Simulated product ~~testing~~ as target 12
4.4.3 Indirect assessment 14
5 Published test methods 14
5.1 ~~Introduction~~ General 14
5.2 Tests for the determination of halogen acid in combustion gases 14
5.2.1 Standards 14
5.2.2 Purpose and principle 14
5.2.3 Test specimen 15
5.2.4 Test method 15
5.2.5 Repeatability and reproducibility 15
5.2.6 Relevance of test data to corrosion hazard assessment 15
5.3 Tests for the determination of the acidity and conductivity of combustion gases dissolved in an aqueous solution 15
5.3.1 Standards 15
5.3.2 Purpose and principle 16
5.3.3 Test specimen 16
5.3.4 Test method 16
5.3.5 Repeatability and reproducibility 16
5.3.6 Relevance of test data to corrosion hazard assessment 16
5.4 Tests for the determination of corrosive gases by ~~using the copper mirror test in ASTM D 2671-00 [9]~~ evaluation of copper corrosion in ASTM D 2671 – Sections 89 to 95 0 16
5.4.1 Purpose and principle 16
5.4.2 Test specimen 16
5.4.3 Test methods 17
5.4.4 Special observations 17
5.4.5 Repeatability and reproducibility 17
5.4.6 Relevance of test data to corrosion hazard assessment 17
~~5.5 Static method (ISO 11907-2 [10]) .....~~
~~5.6 Travelling furnace method (ISO 11907-3 [11]) .....~~
5.5 Cone corrosimeter method 22
5.5.1 Standards 22
5.5.2 Purpose and principle 22

5.5.3 Test specimen 22
5.5.4 Corrosion target 22
5.5.5 Test method 22
5.5.6 Special observation 23
5.5.7 Repeatability and reproducibility 23
5.5.8 Relevance of test data to corrosion hazard assessment 23
~~6 Leakage current and metal loss (IEC 60695-5-3) .....~~
~~6.1 Purpose and principle .....~~
~~6.2 Test specimen .....~~
~~6.3 Corrosion targets .....~~
~~6.4 Test method .....~~
6 Overview of methods and relevance of data 25
Annex A (informative) Acidity and conductivity of aqueous solutions – Test methods 28
Annex B (informative) Determination of repeatability and reproducibility – Comparative tests of solutions of combustion gases 29
Bibliography 33

~~Figure – Schematic drawing of a serpentine-track resistance target .....~~
~~Figure – Interdigitated leakage current target .....~~
Figure 1 – Schematic drawing of a typical corrosion target of defined metal thickness 23

~~Table 1 – General classification of fire stages in accordance with ISO/TR 9122-1 .....~~
Table 1 – Characteristics of fire stages (from Table 1 in ISO 19706:2011) 13
Table 2 – Overview of corrosivity test methods 27
Table A.1 – Test methods for the measurement of acidity and conductivity of aqueous solutions obtained after bubbling combustion effluent through water 28
Table B.1 – Determination of repeatability and reproducibility – Comparative pH tests on solutions of combustion gases 30
Table B.2 – Determination of repeatability and reproducibility – Comparative resistivity tests on solutions of combustion gases 31
Table B.3 – Results obtained on brominated polycarbonate 32

INTERNATIONAL ELECTROTECHNICAL COMMISSION

_____

FIRE HAZARD TESTING –

Part 5-2: Corrosion damage effects of fire effluent – Summary and relevance of test methods

FOREWORD

1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
6) All users should ensure that they have the latest edition of this publication.
7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

This redline version of the official IEC Standard allows the user to identify the changes made to the previous edition IEC TS 60695-5-2:2002. A vertical bar appears in the margin wherever a change has been made. Additions are in green text, deletions are in strikethrough red text.

IEC 60695-5-2, which is a technical specification, has been prepared by IEC technical committee 89: Fire hazard testing.

This third edition cancels and replaces the second edition published in 2002.

The main changes with respect to the previous edition are listed below:

– References to IEC TS 60695-5-3 (withdrawn in 2014) have been removed.
– ISO/TR 9122-1 has been revised by ISO 19706.
– References to ISO 11907-2 and ISO 11907-3 have been removed.
– Terms and definitions have been updated.
– Text in 5.4 has been updated.
– Text in 5.5.8 (5.7.8 in Ed. 2) has been updated.
– Text in Clause 6 (7 in Ed. 2) has been updated.
– Bibliographic references have been updated.

It has the status of a basic safety publication in accordance with IEC Guide 104 and ISO/IEC Guide 51.

The text of this technical specification is based on the following documents:

Draft	Report on voting
89/1473/DTS	89/1506/RVDTS

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

The language used for the development of this Technical Specification is English.

This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available at www.iec.ch/members_experts/refdocs. The main document types developed by IEC are described in greater detail at www.iec.ch/standardsdev/publications.

In this technical specification, the following print types are used:

Arial bold: terms referred to in Clause 3

This technical specification is to be read in conjunction with IEC 60695-5-1.

A list of all parts in the IEC 60695 series, published under the general title *Fire hazard testing*, can be found on the IEC website.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under webstore.iec.ch in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

INTRODUCTION

~~The risk of fire should be considered in any electrical circuit. With regard to this risk, the circuit and equipment design, the selection of components and the choice of materials should contribute towards reducing the likelihood of fire even in the event of foreseeable abnormal use, malfunction or failure. The practical aim should be to prevent ignition caused by electrical malfunction but, if ignition and fire occur, to control the fire preferably within the bounds of the enclosure of the electrotechnical product.~~

In the design of an electrotechnical product the risk of fire and the potential hazards associated with fire need to be considered. In this respect the objective of component, circuit and equipment design, as well as the choice of materials, is to reduce the risk of fire to a tolerable level even in the event of reasonably foreseeable (mis)use, malfunction or failure. IEC 60695-1-10 [1][1], IEC 60695-1-11 [2], and IEC 60695-1-12 [3] provide guidance on how this is to be accomplished.

Fires involving electrotechnical products can also be initiated from external non-electrical sources. Considerations of this nature are dealt with in an overall fire hazard assessment.

The aim of the IEC 60695 series is to save lives and property by reducing the number of fires or reducing the consequences of the fire. This can be accomplished by:

- trying to prevent ignition caused by an electrically energised component part and, in the event of ignition, to confine any resulting fire within the bounds of the enclosure of the electrotechnical product.
- trying to minimise flame spread beyond the product's enclosure and to minimise the harmful effects of **fire effluent**s including heat, **smoke**, and toxic or corrosive combustion products.

All **fire effluent** is corrosive to some degree and the level of potential to corrode depends on the nature of the fire, the combination of combustible materials involved in the fire, the nature of the substrate under attack, and the temperature and relative humidity of the environment in which the corrosion is taking place. There is no evidence that **fire effluent** from electrotechnical products offers greater risk of **corrosion damage** than the **fire effluent** from other products such as furnishings, building materials, etc.

The performance of electrical and electronic components can be adversely affected by **corrosion damage** when subjected to **fire effluent**. A wide variety of combinations of small quantities of effluent gases, **smoke** particles, moisture and temperature may provide conditions for electrical component or system failures from breakage, overheating or shorting.

Evaluation of potential **corrosion damage** is particularly important for high value and safety-related electrotechnical products and installations.

Technical committees responsible for the products will choose the test(s) and specify the level of severity.

The study of **corrosion damage** requires an interdisciplinary approach involving chemistry, electricity, physics, mechanical engineering, metallurgy and electrochemistry. In the preparation of this part of IEC 60695, all of the above have been considered.

IEC 60695-5-1 defines the scope of the guidance and indicates the field of application.

IEC 60695-5-2 provides a summary of test methods including relevance and usefulness.

---

[1] Numbers in square brackets refer to the bibliography.

~~IEC 60695-5-3 gives details of a small-scale test method for the measurement of leakage current and metal loss caused by fire effluent.~~

FIRE HAZARD TESTING –

Part 5-2: Corrosion damage effects of fire effluent – Summary and relevance of test methods

1 Scope

This part of IEC 60695, which is a technical specification, gives a summary of the test methods that are used in the assessment of the corrosivity of **fire effluent**. It presents a brief summary of test methods in common use, either as international standards or national or industry standards. It includes special observations on their relevance, for electrotechnical products and their materials, to real **fire scenario**s and gives recommendations on their use.

One of the responsibilities of a technical committee is, wherever applicable, to make use of basic safety publications in the preparation of its publications. The requirements, test methods or test conditions of this publication will not apply unless specifically referred to or included in the relevant publications.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60695-4:~~1993~~2012, *Fire hazard testing – Part 4: Terminology concerning fire tests for electrotechnical products*

IEC 60695-5-1~~:2002~~, *Fire hazard testing – Part 5-1: Corrosion damage effects of fire effluent - General guidance*

~~IEC/TS 60695-5-3, *Fire hazard testing – Part 5-3: Corrosion damage effects of fire effluent – Leakage current and metal loss test method*[2]~~

IEC GUIDE 104~~:1997~~, *The preparation of safety publications and the use of basic safety publications and group safety publications*

ISO Guide 51, *Safety aspects – Guidelines for their inclusion in standards*

ISO~~/IEC~~ 13943:~~2000~~2017*, Fire safety – Vocabulary*

ISO 19706:2011*, Guidelines for assessing the fire threat to people*

~~ISO/TR 9122-1:1989, *Toxicity testing of fire effluents – Part 1: General*~~

~~[2] To be published.~~

IEC TS 60695-5-2

Edition 3.0 2021-06

TECHNICAL SPECIFICATION

Fire hazard testing –
Part 5-2: Corrosion damage effects of fire effluent – Summary and relevance of test methods



IEC TS 60695-5-2:2021-06(en)

CONTENTS

FOREWORD 4
INTRODUCTION 6
1 Scope 7
2 Normative references 7
3 Terms and definitions 7
4 Classification of test methods 9
4.1 General 9
4.2 Test specimen 9
4.2.1 Product testing 9
4.2.2 Material or composite sample testing 9
4.3 The physical fire model 9
4.4 The nature of the corrosivity measurement 9
4.4.1 Product as target 9
4.4.2 Simulated product as target 9
4.4.3 Indirect assessment 11
5 Published test methods 11
5.1 General 11
5.2 Tests for the determination of halogen acid in combustion gases 11
5.2.1 Standards 11
5.2.2 Purpose and principle 11
5.2.3 Test specimen 11
5.2.4 Test method 11
5.2.5 Repeatability and reproducibility 11
5.2.6 Relevance of test data to corrosion hazard assessment 12
5.3 Tests for the determination of the acidity and conductivity of combustion gases dissolved in an aqueous solution 12
5.3.1 Standards 12
5.3.2 Purpose and principle 12
5.3.3 Test specimen 12
5.3.4 Test method 12
5.3.5 Repeatability and reproducibility 12
5.3.6 Relevance of test data to corrosion hazard assessment 13
5.4 Tests for the determination of corrosive gases by evaluation of copper corrosion in ASTM D 2671 – Sections 89 to 95 [9] 13
5.4.1 Purpose and principle 13
5.4.2 Test specimen 13
5.4.3 Test methods 13
5.4.4 Special observations 13
5.4.5 Repeatability and reproducibility 13
5.4.6 Relevance of test data to corrosion hazard assessment 13
5.5 Cone corrosimeter method 14
5.5.1 Standards 14
5.5.2 Purpose and principle 14
5.5.3 Test specimen 14
5.5.4 Corrosion target 14
5.5.5 Test method 14

5.5.6 Special observation 15
5.5.7 Repeatability and reproducibility 15
5.5.8 Relevance of test data to corrosion hazard assessment 15
6 Overview of methods and relevance of data 15
Annex A (informative) Acidity and conductivity of aqueous solutions – Test methods 18
Annex B (informative) Determination of repeatability and reproducibility – Comparative tests of solutions of combustion gases 19
Bibliography 23

Figure 1 – Schematic drawing of a typical corrosion target of defined metal thickness 15

Table 1 – Characteristics of fire stages (from Table 1 in ISO 19706:2011) 10
Table 2 – Overview of corrosivity test methods 17
Table A.1 – Test methods for the measurement of acidity and conductivity of aqueous solutions obtained after bubbling combustion effluent through water 18
Table B.1 – Determination of repeatability and reproducibility – Comparative pH tests on solutions of combustion gases 20
Table B.2 – Determination of repeatability and reproducibility – Comparative resistivity tests on solutions of combustion gases 21
Table B.3 – Results obtained on brominated polycarbonate 22

INTERNATIONAL ELECTROTECHNICAL COMMISSION

_____

FIRE HAZARD TESTING –

Part 5-2: Corrosion damage effects of fire effluent – Summary and relevance of test methods

FOREWORD

1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
6) All users should ensure that they have the latest edition of this publication.
7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

IEC 60695-5-2, which is a technical specification, has been prepared by IEC technical committee 89: Fire hazard testing.

This third edition cancels and replaces the second edition published in 2002.

The main changes with respect to the previous edition are listed below:

– References to IEC TS 60695-5-3 (withdrawn in 2014) have been removed.
– ISO/TR 9122-1 has been revised by ISO 19706.
– References to ISO 11907-2 and ISO 11907-3 have been removed.
– Terms and definitions have been updated.
– Text in 5.4 has been updated.
– Text in 5.5.8 (5.7.8 in Ed. 2) has been updated.
– Text in Clause 6 (7 in Ed. 2) has been updated.

– Bibliographic references have been updated.

It has the status of a basic safety publication in accordance with IEC Guide 104 and ISO/IEC Guide 51.

The text of this technical specification is based on the following documents:

Draft	Report on voting
89/1473/DTS	89/1506/RVDTS

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

The language used for the development of this Technical Specification is English.

This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available at www.iec.ch/members_experts/refdocs. The main document types developed by IEC are described in greater detail at www.iec.ch/standardsdev/publications.

In this technical specification, the following print types are used:

Arial bold: terms referred to in Clause 3

This technical specification is to be read in conjunction with IEC 60695-5-1.

A list of all parts in the IEC 60695 series, published under the general title *Fire hazard testing*, can be found on the IEC website.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under webstore.iec.ch in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

INTRODUCTION

In the design of an electrotechnical product the risk of fire and the potential hazards associated with fire need to be considered. In this respect the objective of component, circuit and equipment design, as well as the choice of materials, is to reduce the risk of fire to a tolerable level even in the event of reasonably foreseeable (mis)use, malfunction or failure. IEC 60695-1-10 [1][1], IEC 60695-1-11 [2], and IEC 60695-1-12 [3] provide guidance on how this is to be accomplished.

Fires involving electrotechnical products can also be initiated from external non-electrical sources. Considerations of this nature are dealt with in an overall fire hazard assessment.

The aim of the IEC 60695 series is to save lives and property by reducing the number of fires or reducing the consequences of the fire. This can be accomplished by:

- trying to prevent ignition caused by an electrically energised component part and, in the event of ignition, to confine any resulting fire within the bounds of the enclosure of the electrotechnical product.
- trying to minimise flame spread beyond the product's enclosure and to minimise the harmful effects of **fire effluent**s including heat, **smoke**, and toxic or corrosive combustion products.

All **fire effluent** is corrosive to some degree and the level of potential to corrode depends on the nature of the fire, the combination of combustible materials involved in the fire, the nature of the substrate under attack, and the temperature and relative humidity of the environment in which the corrosion is taking place. There is no evidence that **fire effluent** from electrotechnical products offers greater risk of **corrosion damage** than the **fire effluent** from other products such as furnishings, building materials, etc.

The performance of electrical and electronic components can be adversely affected by **corrosion damage** when subjected to **fire effluent**. A wide variety of combinations of small quantities of effluent gases, **smoke** particles, moisture and temperature may provide conditions for electrical component or system failures from breakage, overheating or shorting.

Evaluation of potential **corrosion damage** is particularly important for high value and safety-related electrotechnical products and installations.

Technical committees responsible for the products will choose the test(s) and specify the level of severity.

The study of **corrosion damage** requires an interdisciplinary approach involving chemistry, electricity, physics, mechanical engineering, metallurgy and electrochemistry. In the preparation of this part of IEC 60695, all of the above have been considered.

IEC 60695-5-1 defines the scope of the guidance and indicates the field of application.

IEC 60695-5-2 provides a summary of test methods including relevance and usefulness.

---

1 Numbers in square brackets refer to the bibliography.

FIRE HAZARD TESTING –

Part 5-2: Corrosion damage effects of fire effluent – Summary and relevance of test methods

1 Scope

This part of IEC 60695, which is a technical specification, gives a summary of the test methods that are used in the assessment of the corrosivity of **fire effluent**. It presents a brief summary of test methods in common use, either as international standards or national or industry standards. It includes special observations on their relevance, for electrotechnical products and their materials, to real **fire scenario**s and gives recommendations on their use.

One of the responsibilities of a technical committee is, wherever applicable, to make use of basic safety publications in the preparation of its publications. The requirements, test methods or test conditions of this publication will not apply unless specifically referred to or included in the relevant publications.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60695-4:2012, *Fire hazard testing – Part 4: Terminology concerning fire tests for electrotechnical products*

IEC 60695-5-1, *Fire hazard testing – Part 5-1: Corrosion damage effects of fire effluent - General guidance*

IEC GUIDE 104, *The preparation of safety publications and the use of basic safety publications and group safety publications*

ISO Guide 51, *Safety aspects – Guidelines for their inclusion in standards*

ISO 13943:2017*, Fire safety – Vocabulary*

ISO 19706:2011*, Guidelines for assessing the fire threat to people*