IEC TS 62271-320

Edition 1.0 2025-03

TECHNICAL SPECIFICATION

High-voltage switchgear and controlgear – Part 320: Environmental aspects and life cycle assessment rules for high-voltage switchgear and controlgear

INTERNATIONAL ELECTROTECHNICAL COMMISSION

ICS 13.020.30; 29.130.10

ISBN 978-2-8327-0293-2

Warning! Make sure that you obtained this publication from an authorized distributor.

® Registered trademark of the International Electrotechnical Commission

CONTENTS

FOREWORD 5
INTRODUCTION 7
1 Scope 8
2 Normative references 9
3 Terms and definitions 9
3.1 Switchgear and controlgear 10
3.2 Environmental aspects 11
3.3 Index of definitions 21
3.4 Abbreviated terms 23
4 Description and classification of high-voltage switchgear and controlgear (SG&CG) 24
4.1 General 24
4.2 Description and classification of switching devices 24
4.3 Description and classification of assemblies 25
5 Environmentally conscious design 26
5.1 General 26
5.2 Life cycle thinking 29
5.3 Reference service life 31
5.3.1 General 31
5.3.2 Service use conditions 31
5.4 Material circularities 32
6 PSR for life cycle assessment 32
6.1 General 32
6.2 Product specific rules (PSR) 32
6.3 Inputs 33
6.4 Outputs 35
6.5 Qualitative and quantitative assessments 35
6.6 LCA functional unit (LCA-FU) 35
6.6.1 General 35
6.6.2 LCA functional unit(s) for switching devices 36
6.6.3 LCA standard functional unit for assemblies 47
6.7 System boundaries 56
6.7.1 General 56
6.7.2 Material circularities 58
6.7.3 Exclusions from system boundary 60
6.7.4 Cut-off rules for SG&CG 60
6.8 Life cycle inventory analysis 61
6.8.1 General 61
6.8.2 Manufacturing 61
6.8.3 Distribution 61
6.8.4 Installation 62
6.8.5 Use 62
6.8.6 End-of-life 62
6.9 Scenarios 63
6.9.1 General 63
6.9.2 Insulation and/or switching medium emissions aspects 63

6.9.3 Manufacturing and installation scenario 66
6.9.4 Distribution scenario 66
6.9.5 Use scenario 67
6.9.6 End-of-life scenarios 72
6.10 Impact categories 76
6.11 Guidance for extrapolation of LCA results within a homogenous product family 78
6.12 LCA comparison aspects 79
7 Information 79
7.1 General 79
7.2 Material declaration 80
7.2.1 General 80
7.2.2 Additional reporting recommendations 80
7.3 End-of-life information 81
7.3.1 General 81
7.3.2 End-of-life information provision 81
7.4 Digitization of high-voltage switchgear and controlgear and information related to LCA 81
7.5 LCA report 82
7.5.1 General 82
7.5.2 General information 82
7.5.3 Goal and scope of the study 83
7.5.4 Life cycle inventory analysis 83
7.5.5 Environmental impact assessment 83
7.5.6 Additional environmental information 84
Annex A (informative) Environmental aspects in environmentally conscious design 85
A.1 General 85
A.2 Inputs and outputs to be considered 85
A.2.1 General 85
A.2.2 Inputs 85
A.2.3 Outputs 86
A.3 Tools for including environmental impacts in high-voltage switchgear and controlgear design 86
Annex B (informative) Brief introduction to life cycle assessment (LCA) 88
B.1 General 88
B.2 Definition of the goal and scope of the LCA 88
B.3 Inventory analysis 89
B.4 Impact assessment 89
B.5 Interpretation 90
Annex C (informative) Environmental impact criteria 91
C.1 General 91
C.2 Sustainable development goals (SDGs) and environmental impact category 91
Annex D (informative) Equivalent energy mix – Example of calculation 101
D.1 Hypothesis 101
D.2 Example 101
Bibliography 105

Figure 1 – Overview of the defined product families SG&CG within the scope of this document 25

Figure 2 – General relationship between environmental aspects and associated impacts for SG&CG during their life cycle 27
Figure 3 – Example of system diagram of the whole life cycle for life cycle assessment of SG&CG 30
Figure 4 – Functional description for IEC 62271-109 AC by-pass switches > 52 kV 47
Figure 5 – Functional description for IEC/IEEE 62271-37-013 Generator circuit-breakers ≤ 38 kV 47
Figure 6 – Scheme of the analysed product system's boundaries, including the life cycle stages and unit processes, which separate it from the ecosphere (natural environment) (based on IEC 63366:—, Figure 2) 58
Figure 7 – Upstream and downstream product information 79
Figure C.1 – Life cycle impact assessment, from inventory to category endpoints 91
Figure C.2 – Life cycle impact assessment, from inventory to category midpoints 92
Figure C.3 – Relation between LCA impact categories (endpoints) and sustainable development goals 93

Table 1 – Abbreviated terms 23
Table 2 – Overview of the referenced standards, structure, content and the corresponding clauses/subclauses of this document 28
Table 3 – Examples of typical average environmental intended use conditions of SG&CG 31
Table 4 – Typical LCA-functional unit properties of switching devices 37
Table 5 – Typical LCA-functional unit properties of assemblies 49
Table 6 – Formulas for calculating the net benefits and loads beyond the system boundaries 59
Table 7 – Calculation of emissions during the use life cycle stage including refilling and maintenance, if applicable 64
Table 8 – Typical emissions factors in per unit SGCG and by life cycle stage 66
Table 9 – Recommended scenarios for IED for use phase 67
Table 10 – Typical scenarios for switchgear and controlgear switching devices 68
Table 11 – Typical use scenarios for calculating impacts of assemblies 69
Table 12 – Typical load conditions for assemblies 69
Table 13 – Further explanation of the generic EoL treatment scenario 74
Table 14 – Recommended impact categories in LCA studies or reported in environmental declarations for SG&CG 77
Table 15 – Additional parameters to be considered in the environmental declaration per functional/reference unit 77
Table C.1 – Detailed environmental impact criteria 94
Table D.1 – Energy mix by location 101
Table D.2 – Parts manufacturing mass ratio and use unit ratio 102
Table D.3 – Equivalent energy mixes for manufacturing 103
Table D.4 – Equivalent energy mixes for installation, use and EoL 104
Table D.5 – Equivalent energy mixes by life cycle stages 104

INTERNATIONAL ELECTROTECHNICAL COMMISSION

_____

HIGH-VOLTAGE SWITCHGEAR AND CONTROLGEAR –

Part 320: Environmental aspects and life cycle assessment rules for high-voltage switchgear and controlgear

FOREWORD

1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
6) All users should ensure that they have the latest edition of this publication.
7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
9) IEC draws attention to the possibility that the implementation of this document may involve the use of (a) patent(s). IEC takes no position concerning the evidence, validity or applicability of any claimed patent rights in respect thereof. As of the date of publication of this document, IEC had not received notice of (a) patent(s), which may be required to implement this document. However, implementers are cautioned that this may not represent the latest information, which may be obtained from the patent database available at https://patents.iec.ch. IEC shall not be held responsible for identifying any or all such patent rights.

IEC TS 62271-320 has been prepared by IEC technical committee 17: High-voltage switchgear and controlgear. It is a Technical Specification.

The text of this Technical Specification is based on the following documents:

Draft	Report on voting
17/1161/DTS	17/1169/RVDTS

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

The language used for the development of this Technical Specification is English.

This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available at www.iec.ch/members_experts/refdocs. The main document types developed by IEC are described in greater detail at www.iec.ch/publications.

A list of all parts in the IEC 62271 series, published under the general title *High-voltage switchgear and controlgear*, can be found on the IEC website.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under webstore.iec.ch in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn, or
- revised.

INTRODUCTION

Increasingly there is a focus on preserving the natural environment for the good of future generations. For this to be achieved, efficient use of energy and materials throughout the life cycle of every product when used in a system and process to conserve the world's finite natural resources is essential. In addition, it is essential that the release of substances and materials that might be harmful for the environment or induce climatic changes be avoided or minimized. From concept to end-of-life of a product, the environmental impact of all the relevant processes should be considered, including the circularities of materials for their future life such as how materials are disposed of or recovered.

In order to contribute to conserving natural resources, manufacturers of high-voltage switchgear and controlgear and their assemblies should ensure an environmentally conscious design (ECD) involving:

a) phasing-out or minimizing the use of hazardous substances or materials;

b) efficient use of energy and materials in the manufacture of products;

c) ensuring the lowest practical energy consumption by the products while they are in use;

d) ensuring a dependability performance consideration in relation to the reference service life and associated conditions;

e) at the end-of-product life, as far as practical, the design should enable recovery of materials for future use and sorting hazardous components requiring a specific treatment.

As this approach considers the use of high-voltage switchgear and controlgear in systems, this document contributes to conserving natural resources by users.

Declarations and ECD are increasingly required. This document recommends type III environmental declarations in accordance with ISO 14025 and material declarations (MD) in accordance with IEC 62474. In some businesses, green public procurement (GPP) is applicable and/or ECD is part of the ISO 14001 certification. Some countries and regions are also actively pushing for environmental conservation, for example, the European Union through its Ecodesign for Sustainable product regulations (ESPR, Regulation EU 2024/1781) and China through Ecodesign and life cycle assessment initiatives. Systematic demands for ECD will be required by most, if not all customers, in the medium term.

Assessing the environmental impact of high-voltage switchgear and controlgear and their assemblies is part of an ECD process. ECD requires the identification, measurement and reporting of particular impacts. IEC 62430 describes the basic principles of ECD, with the goal of reducing the potential environmental impacts of products.

Stakeholders met along the life cycle of the switchgear and controlgear (suppliers, manufacturers, carriers, contractors, users, recyclers) are continuing their efforts to reduce their environmental footprint and to assess it as targeted by this document. A simplified means of estimating the environmental impacts is essential together with readily available data to make the stakeholder's, i.e., manufacturer's, contractor's, installer's, end user's and recycler's, task of assessing environmental impacts at system level easier.

Product specific rules (PSR) for assessing the environmental impacts and providing appropriate data for high-voltage switchgear and controlgear and their assemblies are among the purposes of this document. These rules establish a common evaluation scheme of their environmental impacts in terms of characterized impact indicators (e.g. carbon dioxide equivalents, ozone depletion, etc.) over their whole life cycle.

The informative references are mentioned in bibliography. They are referred to in the text in such a way that some or all of their content constitutes the most useful references for this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

HIGH-VOLTAGE SWITCHGEAR AND CONTROLGEAR –

Part 320: Environmental aspects and life cycle assessment rules for high-voltage switchgear and controlgear

1 Scope

This part of IEC 62271 provides guidance to suppliers, manufacturers, users, and waste operators of high-voltage switchgear and controlgear as well as their assemblies having a rated voltage above 1 kV AC and 1,5 kV DC, together with their associated auxiliary equipment, on environmentally conscious design, and on assessing environmental impacts when used in systems. This document also gives guidance on effective communication of environmental information throughout the entire life cycle.

This document provides guidance on the process and general aspects to select UN sustainable development goals (UN sustainable development goals (SDG)), especially those dealing with health and environmental impacts and their assessments, represented respectively by:

- SDG 3-Good Health and Well-being;
- SDG 6-Clean Water and Sanitation;
- SDG 7-Affordable and Clean Energy;
- SDG 12-Responsible Consumption and Production;
- SDG 13-Climate Action;
- SDG 14-Life Below Water;
- SDG 15-Life on Land.

This document gives guidance on the process and general aspects to implement environmentally conscious product design (ECD) principles, as given in IEC 62430, essential for high-voltage electrical power equipment and power control equipment.

This document gives guidance on executing the life cycle assessment (LCA) based on product category rules (PCR) in accordance with IEC 63366, ISO 14040 and ISO 14044 and on applying the Type III environmental declaration in accordance with ISO 14025, both for high-voltage switchgear and controlgear. This guidance provides standardized product specific rules (PSR) summarized as follows:

1) Common rules for the LCA process describing functional units, system boundaries, life cycle inventory analysis, scenarios, environmental impact categories;
2) Common rules for communicating information about the presence of regulated substances and the materials contained in the product, according to IEC 62474;
3) Common rules for communicating information about the end-of-life treatment of the product including material efficiency.

This document does not address the environmental declaration programme, however it can be used by program operators.

This document focuses on describing the LCA process referring to the functional unit, system boundary, scenarios, etc.

Owing to variability of influencing factors, such as flows, allocations, not balanced and time-stable energy mix under different programmes, equipment customization, durability related to environmental conditions, it is not possible to compare two similar high-voltage switchgear and controlgear analysed in different contexts.

This document does not address by-products from arcing which are generated in sufficiently small quantities such that their environmental impact can be neglected. Any by-product generated by arcing during the use of equipment is strongly dependent on operating conditions and cannot a priori be qualified nor quantified. However, they are not expected to be released in air and will be managed at end-of-life by a dedicated process.

EXAMPLE

During the use of high-voltage switchgear and controlgear the handlings of normally arced gas are covered by IEC 62271-4. When the volume of gaseous by-product is below 1 % of normally arced gas, it is not considered compared to the cut-off rules specified in this document. The scenarios related to the system boundary do not take into account leakages from failures except if an agreement is reached on this between user and manufacturer (see Table 7, item h).

Power transformers, low-voltage switchgear and controlgear, and the interconnections with such equipment are not covered by this document. Therefore, assemblies according to IEC 62271-202 or IEC 62271-212 comprising any of the above equipment are not within the scope of this document.

This document supports material efficiency for circular economy. However, one of the major issues related to remanufacturing is the consideration of used parts and product(s) while regulatory requirements are applicable to new product. For high voltage switchgear and controlgear and for this document remanufacturing is not considered avoiding any misalignment for life cycle assessment.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 62271-1, *High-voltage switchgear and controlgear – Part 1: Common specifications for alternating current switchgear and controlgear*

IEC 62271-4:2022, *High-voltage switchgear and controlgear – Part 4: Handling procedures for gases for insulation and/or switching*