INTERNATIONAL STANDARD

ISO 10140-4

Second edition
2021-04

Acoustics — Laboratory measurement of sound insulation of building elements —

Part 4: Measurement procedures and requirements

Acoustique — Mesurage en laboratoire de l'isolation acoustique des éléments de construction —

Partie 4: Exigences et modes opératoires de mesurage

Reference number
ISO 10140-4:2021(E)

© ISO 2021



COPYRIGHT PROTECTED DOCUMENT

© ISO 2021

All rights reserved. Unless otherwise specified, or required in the context of its implementation, no part of this publication may be reproduced or utilized otherwise in any form or by any means, electronic or mechanical, including photocopying, or posting on the internet or an intranet, without prior written permission. Permission can be requested from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office
CP 401 • Ch. de Blandonnet 8
CH-1214 Vernier, Geneva
Phone: +41 22 749 01 11
Email: copyright@iso.org
Website: www.iso.org

Published in Switzerland

Contents

Page

Foreword ... **iv**
Introduction ... **v**
1 Scope ... **1**
2 Normative references ... **1**
3 Terms and definitions ... **1**
4 Measurement procedures and requirements ... **2**
4.1 Frequency range ... 2
4.2 Measurement of sound pressure levels ... 3
4.2.1 General ... 3
4.2.2 Minimum separation distances for microphone positions ... 3
4.2.3 Averaging times ... 3
4.2.4 Energy average sound pressure level ... 3
4.3 Correction for background noise level ... 4
4.4 Measurement of airborne sound insulation ... 4
4.4.1 General ... 4
4.4.2 Measurements with fixed microphone positions ... 5
4.4.3 Measurements with a continuously moving microphone ... 5
4.5 Measurement of impact sound insulation ... 5
4.5.1 General ... 5
4.5.2 Measurements with fixed microphone positions ... 5
4.5.3 Continuously moving microphone ... 5
4.6 Measurement of reverberation time and evaluation of the equivalent sound absorption area ... 6
4.6.1 General ... 6
4.6.2 Measurement of reverberation time ... 6
4.6.3 Equivalent sound absorption area ... 6
4.7 Measurement of structural reverberation time ... 7
4.8 Measurement of radiated sound power by surface velocity of elements ... 7
5 Sound insulation measurements ... **8**
5.1 General ... 8
5.2 General procedure for the determination of airborne sound insulation ... 8
5.2.1 General ... 8
5.2.2 Fixed microphone positions and multiple loudspeakers operating simultaneously or a moving loudspeaker ... 8
5.2.3 Fixed microphone positions and a single loudspeaker operated at more than one position ... 8
5.2.4 Continuously moving microphone and multiple loudspeakers operating simultaneously or a moving loudspeaker ... 9
5.2.5 Continuously moving microphone and a single loudspeaker operated at more than one position ... 9
5.3 General procedure for the determination of impact sound insulation of floors ... 9
5.3.1 General ... 9
5.3.2 Fixed microphone position ... 9
5.3.3 Continuously moving microphone ... 9
Annex A (informative) **Additional procedures for measurements at low frequencies** ... **10**
Bibliography ... **12**

© ISO 2021 – All rights reserved

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

The procedures used to develop this document and those intended for its further maintenance are described in the ISO/IEC Directives, Part 1. In particular the different approval criteria needed for the different types of ISO documents should be noted. This document was drafted in accordance with the editorial rules of the ISO/IEC Directives, Part 2 (see www.iso.org/directives).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights. Details of any patent rights identified during the development of the document will be in the Introduction and/or on the ISO list of patent declarations received (see www.iso.org/patents).

Any trade name used in this document is information given for the convenience of users and does not constitute an endorsement.

For an explanation of the voluntary nature of standards, the meaning of ISO specific terms and expressions related to conformity assessment, as well as information about ISO's adherence to the World Trade Organization (WTO) principles in the Technical Barriers to Trade (TBT) , see www.iso.org/iso/foreword.html.

This document was prepared by Technical Committee ISO/TC 43, *Acoustics*, Subcommittee SC 2, *Building acoustics,* in collaboration with the European Committee for Standardization (CEN) Technical Committee CEN/TC 126, *Acoustic properties of building elements and of buildings*, in accordance with the Agreement on technical cooperation between ISO and CEN (Vienna Agreement).

This second edition cancels and replaces the first edition (ISO 10140-4:2010), which has been technically revised.

The main changes compared to the previous edition are as follows:

— all references in the text have been updated;

— in Clause 2, the normative references have been updated;

— in Clause 3, the terms and definitions have been updated;

— in 4.8 first and last paragraph have been edited;

— in 5.3.3 the Note has been edited.

A list of all parts in the ISO 10140 series can be found on the ISO website.

Any feedback or questions on this document should be directed to the user’s national standards body. A complete listing of these bodies can be found at www.iso.org/members.html.

© ISO 2021 – All rights reserved

Introduction

ISO 10140 (all parts) concerns laboratory measurement of the sound insulation of building elements (see Table 1).

ISO 10140-1 specifies the application rules for specific elements and products, including specific requirements for the preparation and mounting of the test elements, and for the operating and test conditions. ISO 10140-2 and ISO 10140-3 contain the general procedures for airborne and impact sound insulation measurements, respectively, and refer to this document and ISO 10140-5 where appropriate. For elements and products without a specific application rule described in ISO 10140-1, it is possible to apply ISO 10140-2 and ISO 10140-3. This document contains basic measurement techniques and processes. ISO 10140-5 contains requirements for test facilities and equipment. For the structure of ISO 10140 (all parts), see Table 1.

ISO 10140 (all parts) was developed to improve the layout for laboratory measurements, ensure consistency and simplify future changes and additions regarding mounting conditions of test elements in laboratory and field measurements. ISO 10140 (all parts) aims at presenting a well-written and arranged format for laboratory measurements.

ISO 10140-1 is planned to be updated with application rules for other products.

Table 1 — Structure and contents of ISO 10140 (all parts)

Relevant part of ISO 10140	Main purpose, contents and use	Detailed content
ISO 10140-1	It indicates the appropriate test procedure for elements and products. For certain types of element/product, it can contain additional and more specific instructions about quantities and test element size and about preparation, mounting and operating conditions. Where no specific details are included, the general guidelines are according to ISO 10140-2 and ISO 10140-3.	Appropriate references to ISO 10140-2 and ISO 10140-3 and product-related, specific and additional instructions on: — specific quantities measured; — size of test element; — boundary and mounting conditions; — conditioning, testing and operating conditions; — additional specifics for test report.
ISO 10140-2	It gives a procedure for airborne sound insulation measurements according to ISO 10140-4 and ISO 10140-5. For products without specific application rules, it is sufficiently complete and general for the execution of measurements. However, for products with specific application rules, measurements are carried out according to ISO 10140-1, if available.	— Definitions of main quantities measured — General mounting and boundary conditions — General measurement procedure — Data processing — Test report (general points)
ISO 10140-3	It gives a procedure for impact sound insulation measurements according to ISO 10140-4 and ISO 10140-5. For products without specific application rules, it is sufficiently complete and general for the execution of measurements. However, for products with specific application rules, measurements are carried out according to ISO 10140-1, if available.	— Definitions of main quantities measured — General mounting and boundary conditions — General measurement procedure — Data processing — Test report (general points)

© ISO 2021 – All rights reserved

Table 1 *(continued)*

Relevant part of ISO 10140	Main purpose, contents and use	Detailed content
ISO 10140-4	It gives all the basic measurement techniques and processes for measurement according to ISO 10140-2 and ISO 10140-3 or facility qualifications according to ISO 10140-5. Much of the content is implemented in software.	— Definitions — Frequency range — Microphone positions — SPL measurements — Averaging, space and time — Correction for background noise — Reverberation time measurements — Loss factor measurements — Low-frequency measurements — Radiated sound power by velocity measurement
ISO 10140-5	It specifies all information needed to design, construct and qualify the laboratory facility, its additional accessories and measurement equipment (hardware).	Test facilities, design criteria: — volumes, dimensions; — flanking transmission; — laboratory loss factor; — maximum achievable sound reduction index; — reverberation time; — influence of lack of diffusivity in the laboratory. Test openings: — standard openings for walls and floors; — other openings (windows, doors, small technical elements); — filler walls in general. Requirements for equipment: — loudspeakers, number, positions; — tapping machine and other impact sources; — measurement equipment. Reference constructions: — basic elements for airborne and impact insulation improvement; — corresponding reference performance curves.

© ISO 2021 – All rights reserved

Acoustics — Laboratory measurement of sound insulation of building elements —

Part 4: Measurement procedures and requirements

1 Scope

This document specifies the basic measurement procedures for airborne and impact sound insulation of building elements in laboratory test facilities.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

ISO 3382-2, *Acoustics — Measurement of room acoustic parameters — Part 2: Reverberation time in ordinary rooms*

ISO 10140-1:2021, *Acoustics — Laboratory measurement of sound insulation of building elements — Part 1: Application rules for specific products*

ISO 10140-2, *Acoustics — Laboratory measurement of sound insulation of building elements — Part 2: Measurement of airborne sound insulation*

ISO 10140-3, *Acoustics — Laboratory measurement of sound insulation of building elements — Part 3: Measurement of impact sound insulation*

ISO 10140-5:2021, *Acoustics — Laboratory measurement of sound insulation of building elements — Part 5: Requirements for test facilities and equipment*

ISO 10848-1:2017, *Acoustics — Laboratory and field measurement of flanking transmission for airborne, impact and building service equipment sound between adjoining rooms — Part 1: Frame document*

ISO 18233, *Acoustics — Application of new measurement methods in building and room acoustics*

3 Terms and definitions

For the purposes of this document, the following terms and definitions apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

— ISO Online browsing platform: available at https://www.iso.org/obp

— IEC Electropedia: available at http://www.electropedia.org/

© ISO 2021 – All rights reserved

3.1
energy average sound pressure level in a room
L
ten times the common logarithm of the ratio of the space and time average of the squared sound pressure to the square of the reference sound pressure, the space average being taken over the entire room with the exception of those parts where the direct radiation of a sound source or the near field of the boundaries (walls, etc.) is of significant influence

Note 1 to entry: *L* is expressed in decibels.

3.2
reverberation time
T
time required for the sound pressure level in a room to decrease by 60 dB after the sound source has stopped

Note 1 to entry: The reverberation time is expressed in seconds.

Note 2 to entry: The reverberation time is usually calculated using linear extrapolation of much shorter evaluation ranges than 60 dB.

3.3
structural reverberation time
T_s
time required for the acceleration level in a structure to decrease by 60 dB after the structure-borne sound source has stopped

Note 1 to entry: The structural reverberation time is expressed in seconds.

Note 2 to entry: T_s is usually calculated using linear extrapolation of much shorter evaluation ranges than 60 dB, normally 15 dB or 20 dB.

3.4
background noise level
measured sound pressure level in the receiving room from all sources other than the loudspeaker or tapping machine in the source room

3.5
continuously moving microphone
microphone that, with respect to a fixed point,

a) moves with approximately constant speed in a circle, or

b) sweeps, over a fixed time period, to and fro along the arc of a circle, which is as large as possible, but is not to be less than 270°

4 Measurement procedures and requirements

4.1 Frequency range

All quantities shall be measured using one-third octave band filters having at least the following centre frequencies, in hertz:

100, 125, 160, 200, 250, 315, 400, 500, 630, 800, 1 000, 1 250, 1 600, 2 000, 2 500, 3 150, 4 000, 5 000.

If additional information in the low-frequency range is required, use one-third octave band filters with the following centre frequencies, in hertz:

50, 63, 80.

For additional measurements at low frequencies, guidance is given in Annex A.

© ISO 2021 – All rights reserved