INTERNATIONAL STANDARD

ISO 14520-12

Third edition
2015-02-15

Gaseous fire-extinguishing systems — Physical properties and system design —

Part 12: IG-01 extinguishant

Systèmes d'extinction d'incendie utilisant des agents gazeux — Propriétés physiques et conception des systèmes —

Partie 12: Agent extincteur IG-01

Reference number
ISO 14520-12:2015(E)

© ISO 2015



COPYRIGHT PROTECTED DOCUMENT

© ISO 2015

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized otherwise in any form or by any means, electronic or mechanical, including photocopying, or posting on the internet or an intranet, without prior written permission. Permission can be requested from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office
Case postale 56 • CH-1211 Geneva 20
Tel. + 41 22 749 01 11
Fax + 41 22 749 09 47
E-mail copyright@iso.org
Web www.iso.org

Published in Switzerland

Contents

Page

Foreword ..... **iv**

1 Scope **1**

2 Normative reference **1**

3 Terms and definitions **1**

4 Characteristics and uses **1**
4.1 General 1
4.2 Use of IG-01 systems 2

5 Safety of personnel **5**

6 System design **6**
6.1 Fill pressure 6
6.2 Superpressurization 6
6.3 Extinguishant quantity 6

7 Environmental properties **7**

© ISO 2015 – All rights reserved

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

The procedures used to develop this document and those intended for its further maintenance are described in the ISO/IEC Directives, Part 1. In particular the different approval criteria needed for the different types of ISO documents should be noted. This document was drafted in accordance with the editorial rules of the ISO/IEC Directives, Part 2 (see www.iso.org/directives).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights. Details of any patent rights identified during the development of the document will be in the Introduction and/or on the ISO list of patent declarations received (see www.iso.org/patents).

Any trade name used in this document is information given for the convenience of users and does not constitute an endorsement.

For an explanation on the meaning of ISO specific terms and expressions related to conformity assessment, as well as information about ISO's adherence to the WTO principles in the Technical Barriers to Trade (TBT), see the following URL: Foreword — Supplementary information.

The committee responsible for this document is ISO/TC 21, *Equipment for fire protection and fire fighting*, Subcommittee SC 8, *Gaseous media firefighting systems using gas*.

This third edition cancels and replaces the second edition (ISO 14520-12:2005), which has been technically revised.

ISO 14520 consists of the following parts, under the general title *Gaseous fire-extinguishing systems — Physical properties and system design*:

— *Part 1: General requirements*

— *Part 2: CF3I extinguishant*

— *Part 5: FK-5-1-12 extinguishant*

— *Part 6: HCFC Blend A extinguishant*

— *Part 8: HFC 125 extinguishant*

— *Part 9: HFC 227ea extinguishant*

— *Part 10: HFC 23 extinguishant*

— *Part 11: HFC 236fa extinguishant*

— *Part 12: IG-01 extinguishant*

— *Part 13: IG-100 extinguishant*

— *Part 14: IG-55 extinguishant*

— *Part 15: IG-541 extinguishant*

Parts 3, 4, and 7, which dealt with FC-2-1-8, FC-3-1-10, and HCFC 124 extinguishants, respectively, have been withdrawn, as these types are no longer manufactured.

© ISO 2015 – All rights reserved

Gaseous fire-extinguishing systems — Physical properties and system design —

Part 12: IG-01 extinguishant

1 Scope

This part of ISO 14520 contains specific requirements for gaseous fire-extinguishing systems, with respect to the IG-01 extinguishant. It includes details of physical properties, specification, usage, and safety aspects.

This part of ISO 14520 covers systems operating at nominal pressures of 160 bar, 200 bar, and 300 bar at 15 °C. This does not preclude the use of other systems, although design data for other pressures are not available at this time.

2 Normative reference

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

ISO 14520-1:2006, *Gaseous fire-extinguishing systems — Physical properties and system design — Part 1: General requirements*

3 Terms and definitions

For the purposes of this document, the terms and definitions given in ISO 14520-1 apply.

4 Characteristics and uses

4.1 General

Extinguishant IG-01 shall comply with the specification shown in Table 1.

IG-01 is a colourless, odourless, electrically non-conductive gas at ambient (20 °C) temperatures, with a density approximately 1,4 times that of air.

The physical properties are shown in Table 2.

IG-01 extinguishes fires mainly by a reduction of the oxygen concentration in the atmosphere of the hazard enclosure.

Table 1 — Specification for IG-01

Property	Requirement
Purity	99,9 % by volume, min.
Moisture	50×10^{-6} by mass, max.
Suspended matter or sediment	None visible

© ISO 2015 – All rights reserved