International Standard

ISO 16079-1

Condition monitoring and diagnostics of wind turbines —

Part 1: General guidelines

Surveillance et diagnostic d'état des éoliennes de production d'électricité —

Partie 1: Lignes directrices générales

Second edition
2026-06

Reference number
ISO 16079-1:2026(en)

© ISO 2026



COPYRIGHT PROTECTED DOCUMENT

© ISO 2026

All rights reserved. Unless otherwise specified, or required in the context of its implementation, no part of this publication may be reproduced or utilized otherwise in any form or by any means, electronic or mechanical, including photocopying, or posting on the internet or an intranet, without prior written permission. Permission can be requested from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office
CP 401 • Ch. de Blandonnet 8
CH-1214 Vernier, Geneva
Phone: +41 22 749 01 11
Email: copyright@iso.org
Website: www.iso.org

Published in Switzerland

Contents

Page

Foreword ..... **iv**

Introduction ..... **v**

1 Scope **1**

2 Normative references **1**

3 Terms and definitions **1**

4 Overview of a condition monitoring implementation — Set-up and diagnostic requirements **3**

4.1 General 3

4.2 Automatic diagnostic decision support and artificial intelligence (AI) 7

5 FMECA: Identification of failure modes, their effects and criticality **7**

5.1 Overview 7

5.2 Identification of wind turbine component criticality factor, f_{CR} 8

5.3 Identification of failure mode priority factor, f_{FMP} 9

5.4 Calculating the monitoring priority number, n_{MP} 11

Annex A (informative) **P-F interval, ETTF and RUL** **13**

Annex B (informative) **Example of FMECA for a wind turbine drive train** **15**

Annex C (informative) **List of wind turbine components and their failure modes** **18**

Annex D (informative) **Brief introduction to the concept of FMECA** **21**

Bibliography **23**

© ISO 2026 – All rights reserved

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

The procedures used to develop this document and those intended for its further maintenance are described in the ISO/IEC Directives, Part 1. In particular, the different approval criteria needed for the different types of ISO documents should be noted. This document was drafted in accordance with the editorial rules of the ISO/IEC Directives, Part 2 (see www.iso.org/directives).

ISO draws attention to the possibility that the implementation of this document may involve the use of (a) patent(s). ISO takes no position concerning the evidence, validity or applicability of any claimed patent rights in respect thereof. As of the date of publication of this document, ISO had not received notice of (a) patent(s) which may be required to implement this document. However, implementers are cautioned that this may not represent the latest information, which may be obtained from the patent database available at www.iso.org/patents. ISO are not be held responsible for identifying any or all such patent rights.

Any trade name used in this document is information given for the convenience of users and does not constitute an endorsement.

For an explanation of the voluntary nature of standards, the meaning of ISO specific terms and expressions related to conformity assessment, as well as information about ISO's adherence to the World Trade Organization (WTO) principles in the Technical Barriers to Trade (TBT), see www.iso.org/iso/foreword.html.

This document was prepared by Technical Committee ISO/TC 108, *Mechanical vibration, shock and condition monitoring*, Subcommittee SC 5, *Condition monitoring and diagnostics of machine systems*.

This second edition cancels and replaces the first edition (ISO 16079-1:2017), which has been editorially revised.

The main changes are as follows:

— editorial changes throughout the document.

A list of all parts in the ISO 16079 series can be found on the ISO website.

Any feedback or questions on this document should be directed to the user’s national standards body. A complete listing of these bodies can be found at https://www.iso.org/about/members.

© ISO 2026 – All rights reserved

Introduction

0.1 General

Power production from wind turbines represents a significant and growing part of the global energy market. As a consequence, predictability of the power production from wind power plants has become as crucial as the predictability of power production from conventional power plants. As for conventional power plants, an efficient maintenance programme for wind power plants adds significant value to the reliability and predictability of the supply of energy. This document is the first in a series of International Standards addressing the application of condition monitoring to wind turbines. It is an application of the recommendations and best practices described in the generic standards developed under ISO/TC 108.

0.2 Aims of the ISO 16079 series

This document and subsequent documents in the ISO 16079 enable manufacturers and operators of wind turbines, as well as developers of condition monitoring systems for these turbines to adopt shared concepts and terminology. Additionally, these provide a methodology enabling users of this document to prioritize and select which components to be monitored and which failure modes to be detected. This is intended to implement the most efficient condition monitoring system, taking into account cost, detection capability, complexity of the condition monitoring system and methods, as well as the available resources and qualification levels of the monitoring personnel.

It is not the intention of this document or subsequent documents in the ISO 16079 series to cover any aspects of safety monitoring systems.

0.3 Time-proven experience

The condition monitoring strategies presented in the ISO 16079 series are based on time-proven experience. Only conservative, well-proven methods and best practices are applied. This means that the detection of certain failure modes may be left out if their behaviour and their related symptoms are not well-documented. As new condition monitoring techniques mature, this document and subsequent documents in the ISO 16079 series will be updated accordingly, see Figure 1.




Figure 1 — Links between the wind turbine-specific International Standards and the general International Standards (relation to the generic standards of ISO/TC 108)

© ISO 2026 – All rights reserved

Condition monitoring and diagnostics of wind turbines —

Part 1:
General guidelines

1 Scope

This document establishes basic guidelines for choosing condition monitoring methods for failure mode detection, diagnostics and prognostics of wind power plant components.

This document does not specify IT systems used for condition monitoring of wind turbines.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

ISO 2041, *Mechanical vibration, shock and condition monitoring — Vocabulary*

ISO 13372, *Condition monitoring and diagnostics of machines — Vocabulary*

3 Terms and definitions

For the purposes of this document, the terms and definitions given in ISO 2041 and ISO 13372 and the following apply.

ISO and IEC maintain terminology databases for use in standardization at the following addresses:

— ISO Online browsing platform: available at https://www.iso.org/obp/ui

— IEC Electropedia: available at https://www.electropedia.org/

3.1
alarm
operational signal or message designed to notify personnel when a selected *anomaly* (3.2), or a logical combination of anomalies, which requires a corrective action, is encountered

[SOURCE: ISO 13372:2012, 4.2, modified — “requiring” has been replaced by “which requires”]

3.2
anomaly
irregularity or abnormality in a system

[SOURCE: ISO 13372:2012, 4.4]

© ISO 2026 – All rights reserved