INTERNATIONAL STANDARD

**ISO 16312-1**

Third edition
2016-11-15

# Guidance for assessing the validity of physical fire models for obtaining fire effluent toxicity data for fire hazard and risk assessment —

## Part 1: **Criteria**

*Lignes directrices pour évaluer la validité des modèles de feu physiques pour l'obtention de données sur les effluents du feu en vue de l'évaluation des risques et dangers —*

*Partie 1: Critères*

Reference number
ISO 16312-1:2016(E)

© ISO 2016



## COPYRIGHT PROTECTED DOCUMENT

© ISO 2016, Published in Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized otherwise in any form or by any means, electronic or mechanical, including photocopying, or posting on the internet or an intranet, without prior written permission. Permission can be requested from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office
Ch. de Blandonnet 8 • CP 401
CH-1214 Vernier, Geneva, Switzerland
Tel. +41 22 749 01 11
Fax +41 22 749 09 47
copyright@iso.org
www.iso.org

 © ISO 2016 – All rights reserved

# Contents

Page

**Foreword** ... **iv**
**Introduction** ... **v**
**1 Scope** ... **1**
**2 Normative references** ... **1**
**3 Terms and definitions** ... **1**
**4 General principles** ... **1**
4.1 Physical fire model ... 1
4.2 Model validity ... 1
4.3 Test specimens ... 2
4.4 Combustion conditions ... 2
4.5 Effluent characterization ... 2
**5 Significance and use** ... **2**
**6 The ideal fire effluent toxicity test method** ... **3**
6.1 Fire stages ... 3
6.2 Applicability ... 3
6.3 Apparatus independence ... 3
6.4 Operational efficiency ... 3
6.5 Data generated ... 3
6.6 Accuracy ... 4
6.7 Repeatability and reproducibility ... 4
**7 Characteristics of fire stages** ... **4**
**8 Characterization of physical fire models** ... **4**
8.1 Thermal environment in the test specimen ... 4
8.1.1 General ... 4
8.1.2 Smouldering ... 5
8.1.3 Pyrolysis ... 5
8.1.4 Flaming ... 5
8.2 Oxygen availability ... 5
8.2.1 General ... 5
8.2.2 Fuel/air equivalence ratio ... 5
8.2.3 Combustion efficiency ... 6
8.3 Test specimen ... 6
8.4 Yields of combustion products ... 6
8.5 Analytical instrumentation ... 6
8.6 Use of test animals ... 6
**9 Physical fire model accuracy** ... **7**
**Annex A** (informative) **Characteristics affecting combustion product yields** ... **9**
**Bibliography** ... **11**

© ISO 2016 – All rights reserved

# Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

The procedures used to develop this document and those intended for its further maintenance are described in the ISO/IEC Directives, Part 1. In particular the different approval criteria needed for the different types of ISO documents should be noted. This document was drafted in accordance with the editorial rules of the ISO/IEC Directives, Part 2 (see www.iso.org/directives).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights. Details of any patent rights identified during the development of the document will be in the Introduction and/or on the ISO list of patent declarations received (see www.iso.org/patents).

Any trade name used in this document is information given for the convenience of users and does not constitute an endorsement.

For an explanation on the meaning of ISO specific terms and expressions related to conformity assessment, as well as information about ISO's adherence to the World Trade Organization (WTO) principles in the Technical Barriers to Trade (TBT) see the following URL: www.iso.org/iso/foreword.html.

The committee responsible for this document is ISO/TC 92, *Fire safety*, Subcommittee SC 3, *Fire threat to people and environment*.

This third edition cancels and replaces the second edition (ISO 16312-1:2010), of which it constitutes a minor revision with the normative references and bibliography having been updated.

A list of all parts in the ISO 16312-series can be found on the ISO website.


© ISO 2016 – All rights reserved

# Introduction

Providing the desired degree of life safety for an occupancy increasingly involves an explicit fire hazard or risk assessment. This assessment includes such components as the following:

— information on the room/building properties;

— the nature of the occupancy;

— the nature of the occupants;

— the types of potential fires;

— the outcomes to be avoided, etc.

This type of determination also requires information on the potential for harm due to the effluent produced in the fire. Because of the prohibitive cost of real-scale product testing under the wide range of fire conditions, most estimates of the potential harm from the fire effluent depend on data generated from a physical fire model, a reduced-scale test apparatus and procedure for its use.

The role of a physical fire model for generating accurate toxic effluent composition is to recreate the essential features of the complex thermal and reactive chemical environment in full-scale fires. These environments vary with the physical characteristics of the fire scenario and with time during the course of the fire, and close representation of some phenomena occurring in full-scale fires can be difficult or even not possible on a small-scale. The accuracy of the physical fire model, then, depends on two features:

a) degree to which the combustion conditions in the bench-scale apparatus mirror those in the fire stage being replicated;

b) degree to which the yields of the important combustion products obtained from burning of the commercial product at full scale are replicated by the yields from burning specimens of the product in the small-scale model. This measure is generally performed for a small set of products, and the derived accuracy is then presumed to extend to other test subjects. At least one methodology for effecting this comparison has been developed.[11]

This document provides guidance for accuracy assessment with and without the use of laboratory animals. Generally, accurate estimation of the toxic potency of the effluent can be obtained from analysis of a small number of gases (the *N*-gas hypothesis), as described in ISO 13571. This is especially true for product formulations similar to those for which the *N*-gas model has been confirmed. There are, however, cases where unusual toxicants have been generated in bench-scale apparatus. Thus, for novel commercial product formulations, confidence in the accuracy of the toxic potency measurement in the bench-scale device can be improved by a confirming bioassay and correlation with real-scale fire tests.

© ISO 2016 – All rights reserved

# Guidance for assessing the validity of physical fire models for obtaining fire effluent toxicity data for fire hazard and risk assessment —

# Part 1: Criteria

## 1 Scope

This document provides technical criteria and guidance for evaluating physical fire models (i.e. laboratory combustion devices and operating protocols) used in effluent toxicity studies for obtaining data on the effluent from products and materials under fire conditions relevant to life safety.[9] Relevant analytical methods, calculation methods, bioassay procedures and prediction of the toxic effects of fire effluents can be referenced in ISO 19701, ISO 19702, ISO 19703, ISO 19706 and ISO 13344. Comparisons are detailed in ISO 29903. Prediction of the toxic effects of fire effluents can be referenced in ISO 13571 and ISO/TR 13571-2.

## 2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

ISO 13571:2012, *Life-threatening components of fire — Guidelines for the estimation of time to compromised tenability in fires*

## 3 Terms and definitions

For the purposes of this document, the terms and definitions given in ISO 13943 apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

— IEC Electropedia: available at http://www.electropedia.org/

— ISO Online browsing platform: available at http://www.iso.org/obp

## 4 General principles

### 4.1 Physical fire model

A physical fire model is characterized by the requirements placed on the form of the test specimen, the operational combustion conditions and the capability of analysing the products of combustion.

### 4.2 Model validity

For use in providing data for effluent toxicity assessment, the validity of a physical fire model is determined by the degree of accuracy with which it reproduces the yields of the principal toxic components in real-scale fires.

© ISO 2016 – All rights reserved