INTERNATIONAL STANDARD

ISO 17738-1

Second edition
2021-12

Thermal insulation products — Exterior insulation finish systems —

Part 1: Materials

Produits isolants thermiques — Systèmes de finition d'isolation externe —

Partie 1: Materiaux

Reference number
ISO 17738-1:2021(E)

© ISO 2021



COPYRIGHT PROTECTED DOCUMENT

© ISO 2021

All rights reserved. Unless otherwise specified, or required in the context of its implementation, no part of this publication may be reproduced or utilized otherwise in any form or by any means, electronic or mechanical, including photocopying, or posting on the internet or an intranet, without prior written permission. Permission can be requested from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office
CP 401 • Ch. de Blandonnet 8
CH-1214 Vernier, Geneva
Phone: +41 22 749 01 11
Email: copyright@iso.org
Website: www.iso.org

Published in Switzerland

© ISO 2021 – All rights reserved

Contents

Page

Foreword ... **v**

Introduction ... **vi**

1 Scope ... **1**

2 Normative references ... **1**

3 Terms definitions and symbols ... **2**
3.1 Terms and definitions ... 2
3.2 Symbols ... 5

4 Requirements ... **5**
4.1 EIFS constituent products ... 5
4.2 LA-WRB ... 5

5 Test methods ... **5**
5.1 Requirments ... 5
5.2 Sampling ... 6
5.3 Preparation of sample panels ... 6
5.4 EIFS material tests ... 7
5.4.1 Ash content ... 7
5.4.2 Infrared analysis ... 7
5.4.3 Bond strength tests ... 8
5.4.4 Water vapour permeance of the lamina ... 8
5.4.5 Base coat water impermeability test ... 8
5.4.6 Water absorption of the base coat ... 8
5.4.7 Finish coat fungus resistance test ... 9
5.4.8 Lamina salt resistance test ... 9
5.4.9 Lamina ultraviolet resistance test ... 9
5.4.10 Reinforcing mesh strength and alkalinity resistance ... 10
5.4.11 Dry thickness of the base coat ... 11
5.5 LA-WRB tests ... 11
5.5.1 Ash content ... 11
5.5.2 Infrared analysis ... 11
5.5.3 Bond strength test of the LA-WRB ... 11
5.5.4 Water absorption coefficient of the LA-WRB ... 12
5.5.5 Water vapour permeance of the LA-WRB ... 12
5.5.6 Accelerated weathering resistance test of the LA-WRB ... 12
5.5.7 LA-WRB joint durability test ... 13
5.5.8 Nail popping resistance test ... 13
5.5.9 Air flow rate ... 13
5.6 EIFS tests ... 13
5.6.1 EIFS impact resistance test ... 13
5.6.2 Durability under cyclic environmental conditions test ... 14
5.6.3 Drainage capacity test ... 15
5.6.4 Wind load testing ... 15
5.7 Reporting requirements ... 15

6 Marking, packaging and labelling ... **16**
6.1 Packaging ... 16
6.2 Labelling ... 16

Annex A (normative) **Bond strength testing (5.3.3 and 5.4.3)** ... **21**

Annex B (normative) **Water absorption coefficient of the LA-WRB (5.5.4)** ... **24**

Annex C (normative) **Joint durability test (5.5.7)** ... **31**

Annex D (normative) **Nail popping resistance test (5.5.8)** ... **38**

© ISO 2021 – All rights reserved

Annex E (normative) **Assessing durability of EIFS under cyclic environmental conditions (5.6.2)** **42**

Annex F (normative) **Assessing drainage performance of EIFS (5.6.3)** **54**

Annex G (normative) **Wind load testing (5.6.4)** **62**

Annex H (normative) **Test method for pull-off strength of adhered air and water resistive barriers using adhesion tester** **70**

Annex I (normative) **Test specimen preparation for infrared analysis** **74**

Bibliography **75**

© ISO 2021 – All rights reserved

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

The procedures used to develop this document and those intended for its further maintenance are described in the ISO/IEC Directives, Part 1. In particular, the different approval criteria needed for the different types of ISO documents should be noted. This document was drafted in accordance with the editorial rules of the ISO/IEC Directives, Part 2 (see www.iso.org/directives).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights. Details of any patent rights identified during the development of the document will be in the Introduction and/or on the ISO list of patent declarations received (see www.iso.org/patents).

Any trade name used in this document is information given for the convenience of users and does not constitute an endorsement.

For an explanation of the voluntary nature of standards, the meaning of ISO specific terms and expressions related to conformity assessment, as well as information about ISO's adherence to the World Trade Organization (WTO) principles in the Technical Barriers to Trade (TBT), see www.iso.org/iso/foreword.html.

This document was prepared by Technical Committee ISO/TC 163, *Thermal performance and energy use in the built environment*, Subcommittee SC 3, *Thermal insulation products, components and systems*.

This second edition cancels and replaces the first edition (ISO 17338-1:2017), which has been technically revised.

The main changes are as follows:

— The Introduction has been modified to include the three parts of the ISO 17738 series of standards, including ISO 17738-2 and ISO 17738-3.

— The definition of exterior insulation and finish systems (EIFS) has been clarified to include the function of the materials that comprise the system.

— The water resistive barrier definitions have been expanded to include the components that connect the EIFS water resistive barrier with adjacent componets that offer the same function but are part of a different cladding assembly.

— Testing to determine the air flow rate of the water resistive barrier has been added.

— Testing to demonstrate the ability of EIFS to withstand wind loading (Annex G) has been expanded and changed from informative to normative.

— A new Annex H (normative) test method for pull-off strength of adhered air and water resistive barriers using adhesion tester has been added.

A list of all parts in the ISO 17738 series can be found on the ISO website.

Any feedback or questions on this document should be directed to the user's national standards body. A complete listing of these bodies can be found at www.iso.org/members.html.

© ISO 2021 – All rights reserved

Introduction

Exterior insulation and finish systems (EIFS) is a wall cladding assembly consisting of six components:

— A water resistive barrier to protect the substrate; the substrate has a means for drainage to the exterior;

— a means of attaching the system to the substrate;

— a thermal insulation layer;

— a base coat material;

— a reinforcing mesh embedded into the base coat;

— a finish material to provide the aesthetic appearance of the cladding assembly.

The ISO 17738 series comprises three parts: ISO 17738-1 (this document) deals with the material performance of exterior insulation and finish systems (EIFS), ISO 17738-2 provides guidance on installation and ISO 17738-3 gives guidance on the design and detailing of a durable and resiliant EIFS system.

© ISO 2021 – All rights reserved

Thermal insulation products — Exterior insulation finish systems —

Part 1: Materials

WARNING — This document does not purport to address all the health and safety aspects associated with its use. Anyone using this document has the responsibility to establish health and safety practices for its use.

1 Scope

This document outlines requirements for exterior insulation and finish systems (EIFS), used in combination with a drained air space as an exterior wall cladding system. The document includes requirements for a water resistive barrier assembly that are used as part of EIFS.

This document outlines testing procedures with pass/fail criteria for an exterior insulation and finish system. The procedures cover the liquid applied water resistive barrier, which forms a second line of defense against water penetration, individual material components and the complete system to demonstrate durability.

The use of mechanical fasteners is outside the scope of this document.

In EIFS, the thermal insulation boards support the base coat with integral glass fibre reinforcing mesh. Systems where the reinforcement is the supporting element of the rendering, e.g. conventional stucco, are not covered by this document.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

ISO 846, *Plastics — Evaluation of the action of microorganisms*

ISO 1463, *Metallic and oxide coatings — Measurement of coating thickness — Microscopical method*

ISO 1663, *Rigid cellular plastics — Determination of water vapour transmission properties*

ISO 1926, *Rigid cellular plastics — Determination of tensile properties*

ISO 3451-1, *Plastics — Determination of ash — Part 1: General methods*

ISO 4606, *Textile glass — Woven fabric — Determination of tensile breaking force and elongation at break by the strip method*

ISO 4611, *Plastics — Determination of the effects of exposure to damp heat, water spray and salt mist*

ISO 4650, *Rubber — Identification — Infrared spectrometric methods*

ISO 4898, *Rigid cellular plastics — Thermal insulation products for buildings — Specifications*

ISO 6612, *Windows and door height windows — Wind resistance tests*

ISO 7345, *Thermal performance of buildings and building components — Physical quantities and definitions*

© ISO 2021 – All rights reserved

ISO 8145, *Thermal insulation — Mineral wool board for overdeck insulation of roofs — Specification*

ISO 9229, *Thermal insulation — Vocabulary*

ISO 12572, *Hygrothermal performance of building materials and products — Determination of water vapour transmission properties — Cup method*

ISO 14857:2014, *Thermal performance in the built environment — Determination of air permeance of building materials*

ISO 15821, *Doorsets and windows — Water-tightness test under dynamic pressure — Cyclonic aspects*

ISO 16474-3, *Paints and varnishes — Methods of exposure to laboratory light sources — Part 3: Fluorescent UV lamps*

ISO 16894, *Wood-based panels — Oriented strand board (OSB) — Definitions, classification and specifications*

ISO 17738-2, *Thermal insulation products — Exterior insulation and finish systems (EIFS) — Part 2: Installation*

ISO 29465, *Thermal insulating products for building applications — Determination of length and width*

ISO 29466, *Thermal insulating products for building applications — Determination of thickness*

ISO 29470, *Thermal insulating products for building applications — Determination of the apparent density*

3 Terms definitions and symbols

For the purposes of this document, the terms and definitions given in ISO 7345, ISO 9229 and the following apply.

ISO and IEC maintain terminology databases for use in standardization at the following addresses:

— ISO Online browsing platform: available at https://www.iso.org/obp

— IEC Electropedia: available at https://www.electropedia.org/

3.1 Terms and definitions

3.1.1
adhesive
product for adhering the *thermal insulation board* (3.1.22) to the *substrate* (3.1.19) or *water resistive barrier assembly* (3.1.24)

3.1.2
attachment method
means by which the *thermal insulation board* (3.1.22) or *thermal insulation board/base coat* (3.1.3) and *reinforcing mesh* (3.1.18) composite is secured to the substrate which provides the wind load resistance of the wall assembly

3.1.3
base coat
polymer-based coating, either *factory-blended* (3.1.11) or *field-mixed* (3.1.12), applied directly to the *thermal insulation board* (3.1.22), fully *embedding* (3.1.9) the *reinforcing mesh* (3.1.18) providing the primary barrier to water penetration

3.1.4
cure
develop the ultimate properties of an initial wet state material by a chemical process

© ISO 2021 – All rights reserved

3.1.5
drainage cavity
space between the water resistive barrier material (*WRB)* (3.1.26) and *thermal insulation board* (3.1.22) that allows for the free drainage of water that penetrates the exterior insulation and finish system *(EIFS)* (3.1.10)

3.1.6
dry
develop the ultimate properties of an initial wet state material solely by evaporation of volatile ingredients

3.1.7
durability
ability of a building or any of its components to perform its required functions in its service environment over a period of time without unforeseen cost for maintenance or repair

3.1.8
EIFS manufacturer
exterior insulation and finish system (EIFS) manufacturer
producer of the materials and components forming a proprietary *EIFS* (3.1.10)

3.1.9
embed
press into and encapsulate the *reinforcing mesh* (3.1.18) in the wet *base coat* (3.1.3)

3.1.10
EIFS
exterior insulation and finish system
exterior wall system with capacity to provide heat, air and moisture control functions, inclusive of a *water resistive barrier assembly* (3.1.24), *thermal insulation board* (3.1.22) and *attachment method* (3.1.2) for securing the system to the *substrate* (3.1.19), and protected by a *base coat* (3.1.3) material and glass fibre *reinforcing mesh* (3.1.18) installed over the face and termination surfaces of the thermal insulation board and completed with a *finish material* (3.1.13)

3.1.11
factory-blended
material that arrives from the manufacturer requiring no additions apart from water to produce the wet state material

3.1.12
field-mixed
materials that are mixed in the field by combining two or more materials, other than, or in addition to, water

3.1.13
finish material
outermost layer installed over the *base coat* (3.1.3) and forming part of the system, providing the exterior insulation and finish system *(EIFS)* (3.1.10) with its aesthetic while contributing to the system's exposure resistance

3.1.14
GDDC
geometrically defined drainage cavity
path created between the water resistive barrier material (*WRB)* (3.1.26) and *thermal insulation board* (3.1.22) using thermal insulation board that has a pattern cut into its back surface

3.1.15
lamina
composite of *base coat* (3.1.3), *reinforcing mesh* (3.1.18) and *finish material* (3.1.13)

© ISO 2021 – All rights reserved

3.1.16
LA-WRB
liquid-applied water resistive barrier
fluid applied material, that dries to a membrane possessing low water absorption properties becoming a component of the *water resistive barrier assembly* (3.1.24)

3.1.17
manufacturer's installation instruction
written installation instructions provided by the exterior insulation and finish system *(EIFS) manufacturer* (3.1.8) that include information that will assist in the correct use and installation of the materials and components that comprise their system

3.1.18
reinforcing mesh
woven or non-woven glass fibre fabric component of the exterior insulation and finish system *(EIFS)* (3.1.10) encapsulated in the *base coat* (3.1.3) to strengthen the system

3.1.19
substrate
structural component supporting the exterior insulation and finish system *(EIFS)* (3.1.10), which is resistant to deterioration caused by water or is protected by a *water resistive barrier assembly* (3.1.24)

3.1.20
test sample
prepared materials or systems from which *test specimens* (3.1.21) are taken

3.1.21
test specimen
portion of a *test sample* (3.1.20) taken for measurement of a material property or characteristic

3.1.22
thermal insulation board
material that reduces heat flow through itself and provides the surface for applying the *base coat* (3.1.3)

3.1.23
water resistive barrier accesssory
product designated to maintain *water resistive barrier assembly* (3.1.24) continuity between *water resistive barrier material(s)* (3.1.26) and other wall assembly components, or at joints and openings not bridged by the water resistive barrier material

3.1.24
WRBA
water resistive barrier assembly
combination of *water resistive barrier material(s)* (3.1.26) and *water resistive barrier accessories* (3.1.23) designed to create a continuous secondary barrier against water penetration to direct and/or deflect water to the exterior

3.1.25
water absorption coefficient
mass of water absorbed by a *test specimen* (3.1.21) under specified time and pressure, per unit area

3.1.26
WRB
water resistive barrier material
material designed to provide the secondary plane of protection against water penetration and forming part of the *water resistive barrier assembly* (3.1.24)

3.1.27
water retention ratio
weight of water retained in the *test specimen* (3.1.21) following the drainage capacity test divided by the area of wetted wall

© ISO 2021 – All rights reserved

3.1.28
wrap
extend the base coat and glass fibre *reinforcing mesh* (3.1.18) over the edge and back of the *thermal insulation board* (3.1.22) to protect the exposed edges of board

3.2 Symbols

Symbol	Description	Unit
A	face area	m^2
A_w	water absorption coefficient	$kg/(m^2 \cdot s^{0,5})$
A_{wt}	water absorption coefficient related to a specific time, t, in seconds	$kg/(m^2 \cdot s^{0,5})$
Δm_t	mass gain per face area after time t	kg/m^2
m_i	initial mass of specimen	kg
m_t	mass of specimen after time t	kg
t	time	s or h
W_w	water absorption coefficient	$kg/(m^2 \cdot h^{0,5})$
W_{wt}	water absorption coefficient related to a specific time, t, in hours	$kg/(m^2 \cdot h^{0,5})$

NOTE Water absorption coefficient is defined in terms of seconds in ISO 9346. The alternative definition in terms of hours is widely used.

4 Requirements

4.1 EIFS constituent products

4.1.1 The material that comprise EIFS shall meet the requirements listed in Table 1.

4.1.2 Rigid cellular plastic thermal insulation board shall meet the requirements of ISO 4898.

4.1.3 Semi-rigid mineral fibre thermal insulation board shall meet the requirements of ISO 8145.

4.2 LA-WRB

4.2.1 Type 1 - The LA-WRB shall meet the technical requirements listed in Table 2.

4.2.2 Type 2 - The LA-WRB shall meet the technical requirements listed in Table 2 except for:

a) joint durability test;

b) nail popping resistance test.

5 Test methods

5.1 Requirments

The EIFS shall be tested as an assembly as required in 5.5 and meet the requirements in Table 3.

© ISO 2021 – All rights reserved