INTERNATIONAL STANDARD

ISO 20890-1

First edition
2020-06

Guidelines for in-service inspections for primary coolant circuit components of light water reactors —

Part 1: Mechanized ultrasonic testing

Lignes directrices pour les contrôles périodiques des composants du circuit primaire des réacteurs à eau légère —

Partie 1: Contrôle mécanique par ultrasons

Reference number
ISO 20890-1:2020(E)

© ISO 2020



COPYRIGHT PROTECTED DOCUMENT

© ISO 2020

All rights reserved. Unless otherwise specified, or required in the context of its implementation, no part of this publication may be reproduced or utilized otherwise in any form or by any means, electronic or mechanical, including photocopying, or posting on the internet or an intranet, without prior written permission. Permission can be requested from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office
CP 401 • Ch. de Blandonnet 8
CH-1214 Vernier, Geneva
Phone: +41 22 749 01 11
Fax: +41 22 749 09 47
Email: copyright@iso.org
Website: www.iso.org

Published in Switzerland

Contents

Page

Foreword ..... **v**

1 Scope **1**

2 Normative references **1**

3 Terms and definitions **2**

4 Test systems **7**
4.1 Preliminary remark 7
4.2 General 7
4.3 Validation and localisation of reflectors 8
4.3.1 Pulse-echo technique (PE technique) 8
4.3.2 Transmitter-Receiver technique (TR-technique) 8
4.3.3 Tandem technique 8
4.3.4 Inspection technique with mode conversion 8
4.3.5 V-transmission technique 9
4.3.6 Phased-Array technique (PA) 9
4.3.7 Preferred angles of incidence and wave modes for search techniques 9

5 Requirements **10**
5.1 Test personnel 10
5.1.1 Task of NDT personnel 10
5.1.2 Personnel requirements 10
5.2 Test object 11
5.3 Ultrasonic test equipment 11
5.3.1 Preliminary remark 11
5.3.2 Test robot 11
5.3.3 Ultrasonic test device 12
5.3.4 Data acquisition and analysis 13
5.3.5 UT probe 13
5.3.6 UT probe holders 15
5.3.7 UT probe cable (ultrasonic cable) 16
5.4 Couplant 16
5.5 Reference reflectors 16
5.6 Calibration block and reference or test block 17
5.7 Data storage medium 17

6 Testing **17**
6.1 Preparation 17
6.1.1 General 17
6.1.2 Probe data sheets 17
6.1.3 Probe system 17
6.1.4 Test robot 18
6.1.5 Ultrasonic test device 18
6.1.6 Setting the test level 18
6.1.7 Data acquisition system (DAS) 19
6.1.8 Ultrasonic test equipment 19
6.2 Implementation 19
6.3 Visualisation of the digitized and saved measuring data 20
6.4 Analysis of indications 20
6.5 Final measures 20

7 Recording **21**
7.1 Recording the setup for the ultrasonic test equipment 21
7.2 Test record and test report 21
7.3 Indication list 21
7.4 Findings record 22

Annex A (informative) **Examples of test systems and transceiver probe arrangements** **23**

© ISO 2020 – All rights reserved

Annex B (informative) **Forms** **25**
Annex C (informative) **Findings record** **28**
Annex D (informative) **Amplification compensation** **29**
Annex E (informative) **Standard test procedures and test specifications** **32**
Bibliography **33**

 © ISO 2020 – All rights reserved

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

The procedures used to develop this document and those intended for its further maintenance are described in the ISO/IEC Directives, Part 1. In particular, the different approval criteria needed for the different types of ISO documents should be noted. This document was drafted in accordance with the editorial rules of the ISO/IEC Directives, Part 2 (see www.iso.org/directives).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights. Details of any patent rights identified during the development of the document will be in the Introduction and/or on the ISO list of patent declarations received (see www.iso.org/patents).

Any trade name used in this document is information given for the convenience of users and does not constitute an endorsement.

For an explanation of the voluntary nature of standards, the meaning of ISO specific terms and expressions related to conformity assessment, as well as information about ISO's adherence to the World Trade Organization (WTO) principles in the Technical Barriers to Trade (TBT) see www.iso.org/iso/foreword.html.

This document was prepared by Technical Committee ISO/TC 85, *Nuclear energy, nuclear technologies, and radiological protection*, Subcommittee SC 6, *Reactor technology.*

A list of all parts in the ISO 20890 series can be found on the ISO website.

Any feedback or questions on this document should be directed to the user's national standards body. A complete listing of these bodies can be found at www.iso.org/members.html.

© ISO 2020 – All rights reserved

Guidelines for in-service inspections for primary coolant circuit components of light water reactors —

Part 1:
Mechanized ultrasonic testing

1 Scope

This document gives guidelines for pre-service-inspections (PSI) and in-service inspections (ISI) with mechanized ultrasonic test (UT) devices on components of the reactor coolant circuit of light water reactors. This document is also applicable on other components of nuclear installations.

Mechanized ultrasonic inspections are carried out in order to enable an evaluation in case of

— fault indications (e.g. on austenitic weld seams or complex geometry),

— indications due to geometry (e.g. in case of root concavity),

— complex geometries (e.g. fitting weld seams), or

— if a reduction in the radiation exposure of the test personnel can be attained in this way.

Ultrasonic test methods are defined for the validation of discontinuities (volume or surface open), requirements for the ultrasonic test equipment, for the preparation of test and device systems, for the implementation of the test and for the recording.

This document is applicable for the detection of indications by UT using normal-beam probes and angle-beam probes both in contact technique. It is to be used for UT examination on ferritic and austenitic welds and base material as search techniques and for comparison with acceptance criteria by the national referencing nuclear safety standards. Immersion technique and techniques for sizing are not in the scope of this document and are independent qualified.

NOTE Data concerning the test section, test extent, inspection period, inspection interval and evaluation of indications is defined in the applicable national nuclear safety standards.

Unless otherwise specified in national nuclear safety standards the minimum requirements of this document are applicable. This document does not define:

— extent of examination and scanning plans;

— acceptance criteria;

— UT techniques for dissimilar metal welds and for sizing (have to be qualified separately);

— immersion techniques;

— time-of-flight diffraction technique (TOFD).

It is recommended that UT examinations are nearly related to the component, the type and size of defects to be considered and are reviewed in specific national inspection qualifications.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

© ISO 2020 – All rights reserved

ISO 5577, *Non-destructive testing — Ultrasonic testing — Vocabulary*

ISO 8596, *Ophthalmic optics — Visual acuity testing — Standard and clinical optotypes and their presentation*

ISO 9712, *Non-destructive testing — Qualification and certification of NDT personnel*

ISO 16811, *Non-destructive testing — Ultrasonic testing — Sensitivity and range setting*

ISO 18490, *Non-destructive testing — Evaluation of vision acuity of NDT personnel*

EN 12668-1, *Non-destructive testing — Characterization and verification of ultrasonic examination equipment — Part 1: Instruments*

EN 12668-2, *Non-destructive testing — Characterization and verification of ultrasonic examination equipment — Part 2: Probes*

ISO 18563-1, *Non-destructive testing — Characterization and verification of ultrasonic phased array equipment — Part 1: Instruments*

ISO 18563-2, *Non-destructive testing — Characterization and verification of ultrasonic phased array equipment — Part 2: Probes*

3 Terms and definitions

For the purposes of this document, the terms and definitions given in ISO 5577 and the following apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

— ISO Online browsing platform: available at https://www.iso.org/obp

— IEC Electropedia: available at http://www.electropedia.org/

3.1
analysis scan
test scan with adopted parameters that is required for more precise characterisation of an *indication* (3.3)

3.2
analysis technique
test technique that is applied for more precise characterisation of *indications* (3.3) subject to analysis

3.3
indication
representation or signal from a discontinuity in the format allowed by the NDT method used

[SOURCE: ISO/TS 18173:2005, 2.14]

Note 1 to entry: Signal that is initiated by operationally induced damage mechanisms, geometrical as well as, material or design induced influences

3.4
evaluation
assessment (3.5) of *indications* (3.3) revealed by NDT against a predefined level

Note 1 to entry: Inspection of the recorded measured data in respect to completeness and analysis capacity, localisation and registration of indications according to defined criteria, representation of the test results

[SOURCE: EN 1330-2:1998, 2.10]

3.5
assessment
comparison of the analysed measuring results with specified criteria

© ISO 2020 – All rights reserved

3.6
data storage medium
storage medium for storing digital media

3.7
focal length
focal distance
distance from the probe to the focal point

[SOURCE: ISO 5577:2017, 4.2.13]

3.8
focus range
focal zone
zone in sound beam of a probe in which the sound pressure remains above a defined level related to its maximum

[SOURCE: ISO 5577:2017, 4.2.14]

Note 1 to entry: During measurement with the electrodynamic probe in sound transmission, this value corresponds to a decrease in the signal level by 3 dB in comparison to the maximum value.

Note 2 to entry: In general limitation by the decline in the signal level by 6 dB.

3.9
focus depth
focal point
point where the sound pressure on the beam axis is at its maximum

[SOURCE: ISO 5577:2017, 4.2.12]

3.10
adjustment
setting the ultrasonic test device based on specified parameters

3.11
calibration
<ultrasonic testing> determination of the measuring value range of an ultrasonic test device in relation to a calibrated test standard

3.12
calibration block
<ultrasonic testing> piece of material of specified composition, surface finish, heat treatment and geometric form, by means of which *ultrasonic test equipment* (3.43) can be assessed and calibrated

[SOURCE: ISO 5577:2017, 5.4.1]

Note 1 to entry: The calibration blocks according to ISO 2400 and ISO 7963 can be used as calibration blocks according to this document.

3.13
calibration reflector
reflector of a known geometry and size in or on the *calibration block* (3.12), test *reference block* (3.15) on the test *calibration block*, for distance or sensitivity adjustment of the *ultrasonic test instrument* (3.44)

3.14
component
part of a system delimited according to structural or functional aspects, which can still implement independent sub-functions

© ISO 2020 – All rights reserved

3.15
reference block
block of material representative of the material to be tested with similar acoustic properties containing well-defined reflectors, used to adjust the sensitivity and/or time base of the *ultrasonic instrument* (3.44) in order to compare detected discontinuity *indications* (3.3) with those arising from the known reflectors

[SOURCE: ISO 5577:2017, 5.4.2]

3.16
time of flight
time it takes an ultrasonic pulse to travel from the transmitter probe through the *test object* (3.27) to the receiver probe

[SOURCE: ISO 5577:2017, 3.2.6]

Note 1 to entry: This comprises the lead time in the UT probe and the time of flight in the component; it is the time that an ultrasonic pulse requires from the oscillator to a reflector and back to the oscillator.

3.17
LLL technique
test technique based on the reflection of the sound package at the back wall and at a planar reflector in the inspection volume using /utilizing longitudinal waves

Note 1 to entry: See Annex A, no. 7.

3.18
LLT technique
test technique based on reflection of the sound bundle at the back wall and at a planar reflector in the inspection volume using/utilizing the mode conversion of longitudinal waves and transversal waves

Note 1 to entry: See Annex A, no. 7.

3.19
measurement scan
movement of the UT probes with simultaneous recording of measured data

3.20
raw data
all measured data and setting parameters saved by the ultrasonic test equipment during the measurement run (recorded and saved data)

Note 1 to entry: Examples of raw data include amplitude, time of flight, and coordinates.

3.21
test section
part of the *test area* (3.23)

3.22
test supervisor
responsible for application of the test method and for the individual details of the test implementation including monitoring of the activities for preparation and implementation of the test as well as analysis of the *test results* (3.24)

3.23
test area
defined area on the *test object* (3.27) over which the tests are to be conducted

[SOURCE: ISO 5577:2017, 6.2.2]

© ISO 2020 – All rights reserved

3.24
test result
summarising evaluation of all measured data and comparison with the previous test

3.25
test scan
measuring run with the characteristics specified in the test specifications

3.26
test function
test task assigned to a UT probe or UT probe combination, e.g. coupling check

3.27
test object
object to be tested; object under test or examination; part of a component to be tested

3.28
test robots
scanner
mechanical device with control for guiding the UT probes

3.29
noise level
amplitudes of background noise in an ultrasonic system

Note 1 to entry: 95 % value of the sum frequency of the amplitudes, measured during the reference run or test run in an indication-free range

[SOURCE: ISO 5577:2017, 6.5.16]

3.30
signal to noise ratio
ratio of the amplitude of a signal arising from a discontinuity in a material to the amplitude of the average background *noise level* (3.29)

[SOURCE: EN 1330-2:1998, 2.16]

3.31
reference scan
measuring run for the functional control and functional adaptation of the ultrasonic test equipment

3.32
hysteresis correction
correction to the decrease in the calibration level resulting during the tandem test or during the test with a comparable test system, if the planar reflectors are not oriented vertically to the surface or vertically to the sound incidence level

3.33
transmitter-receiver technique (TR-technique)
pitch and catch technique
double probe technique
ultrasonic testing technique involving the use of two probes both of which can be used as transmitter and receiver

3.34
track offset correction
correction to the decrease in the calibration level of planar reflectors in the middle between two tracks

3.35
tandem zone correction
correction to the decrease in the calibration level of the calibration reflector to the tandem zone edges

© ISO 2020 – All rights reserved

3.36
test block
defined piece of material which allows tests for the accuracy and/or performance of an *ultrasonic test system* (3.43)

[SOURCE: ISO 5577:2017, 5.4.3]

Note 1 to entry: Specimen for examining properties of a test method, an ultrasonic test instrument or a test system.

3.37
depth zone
sub-range of the wall thicknesses to be tested

3.38
transfer correction
correction of the gain setting of the *ultrasonic test instrument* (3.44) when transferring the probe from a *calibration* (3.12) or *reference block* (3.15) to the test object

[SOURCE: ISO 5577:2017, 5.4.5]

3.39
trigger distance
path that the UT probes travels between two test cycles of the same test function following in succession

3.40
scan without couplant
measurement scan (3.19) without coupling between the UT probe and *test object* (3.27)

3.41
TTT technique
test technique based on reflection of the sound bundle at the back wall and at a planar reflector in the test volume using / utilizing shear waves

Note 1 to entry: See Annex A, no. 7.

3.42
ultrasonic test equipment
equipment consisting of an *ultrasonic instrument* (3.44), probes, cables and all devices connected to the instrument during testing

[SOURCE: ISO 5577:2017, 5.3.1]

Note 1 to entry: Connected devices consist also test robot and analysis unit including software, digitalisation unit and, if necessary, operating PC including software.

3.43
ultrasonic test instrument
instrument used together with the probe or probes, which transmits, receives, processes and displays ultrasonic signals for NDT purposes

[SOURCE: ISO 5577:2017, 5.1.1]

3.44
ultrasonic test technique
application-relevant technique for the localisation of discontinuities (internal or surface open)

Note 1 to entry: In relation to the application, requirements result for these ultrasonic test techniques in respect to the test parameters such as oscillation variable, beam angle, wave type and frequency.

Note 2 to entry: Test techniques are e.g. pulse-echo system (PE), transmitter-receiver system (TR), tandem system, phased-array system (PA).

© ISO 2020 – All rights reserved