TECHNICAL REPORT

ISO/TR 12470-2

First edition
2017-11

Fire-resistance tests — Guidance on the application and extension of results from tests conducted on fire containment assemblies and products —

Part 2: Non-loadbearing elements

Essais de résistance au feu — Recommandations pour l'application et l'extrapolation des résultats d'essais réalisés sur les produits et assemblages d'endiguement du feu —

Partie 2: Éléments non porteurs

Reference number
ISO/TR 12470-2:2017(E)

© ISO 2017



COPYRIGHT PROTECTED DOCUMENT

© ISO 2017, Published in Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized otherwise in any form or by any means, electronic or mechanical, including photocopying, or posting on the internet or an intranet, without prior written permission. Permission can be requested from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office
Ch. de Blandonnet 8 • CP 401
CH-1214 Vernier, Geneva, Switzerland
Tel. +41 22 749 01 11
Fax +41 22 749 09 47
copyright@iso.org
www.iso.org

Contents

Page

Foreword ..... **v**
Introduction ..... **vi**
1 Scope **1**
2 Normative references **2**
3 Terms and definitions **2**
4 Principles of the field of application **4**
4.1 General 4
4.2 Direct application 4
4.3 Extended application 5
4.3.1 General 5
4.3.2 Rules of extended application 5
4.3.3 Calculations and computer programs used in extended applications 5
4.3.4 Judgements in extended applications 5
4.4 Project specific application 6
5 Common factors which influence the field of application of all elements **6**
5.1 General 6
5.2 Manufacture and materials 6
5.2.1 General 6
5.2.2 Direct application 6
6 Fire resisting door assemblies **7**
6.1 General 7
6.2 Direct application 7
6.2.1 General 7
6.2.2 Leaves 7
6.2.3 Openings in the leaf 8
6.2.4 Frames 8
6.2.5 Door hardware (ironmongery) 8
6.2.6 Fire seals 8
6.3 Extended application 9
6.3.1 General 9
6.3.2 Rules 9
6.3.3 Fire engineering calculations 10
6.3.4 Expert judgements 10
6.3.5 Opening in the leaf or leaves 22
7 Fixed vertical fire resisting glazed elements **28**
7.1 General 28
7.2 Direct application 28
7.2.1 General 28
7.2.2 Common parameters of all forms of fixed glazed elements 28
7.2.3 Framing members (timber) 28
7.2.4 Framing members (metal) 29
7.2.5 Glass retention system 29
7.2.6 Glass 29
7.3 Extended application 30
7.3.1 General 30
7.3.2 Rules 30
7.3.3 Fire engineering calculations 30
7.3.4 Expert judgements 30
8 Linear gap sealing systems **33**
8.1 General 33
8.2 Direct application 34

© ISO 2017 – All rights reserved

8.2.1 General ... 34
8.2.2 Common parameters for all applications ... 34
8.3 Extended applications ... 35
8.3.1 General ... 35
8.3.2 Rules ... 35
8.3.3 Fire engineering calculations ... 35
8.3.4 Expert judgement ... 36
9 Service penetration sealing systems ... 47
9.1 General ... 47
9.2 Direct application ... 48
9.2.1 General ... 48
9.2.2 Common parameters ... 48
9.3 Extended applications ... 49
9.3.1 General ... 49
9.3.2 Rules ... 49
9.3.3 Fire engineering calculations ... 50
9.3.4 Expert judgement ... 50
10 Improvements in the design of test specimens and modelling to generate fields of application ... 56
10.1 General ... 56
10.2 Expert system based upon the use of performance coefficients ... 57
10.2.1 Concept ... 57
10.2.2 Expert system applied to doors ... 57
Annex A (informative) **Principles of using expert judgement to establishing the extended field of application ... 62**
Bibliography ... 69

 © ISO 2017 – All rights reserved

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

The procedures used to develop this document and those intended for its further maintenance are described in the ISO/IEC Directives, Part 1. In particular the different approval criteria needed for the different types of ISO documents should be noted. This document was drafted in accordance with the editorial rules of the ISO/IEC Directives, Part 2 (see www.iso.org/directives).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights. Details of any patent rights identified during the development of the document will be in the Introduction and/or on the ISO list of patent declarations received (see www.iso.org/patents).

Any trade name used in this document is information given for the convenience of users and does not constitute an endorsement.

For an explanation on the voluntary nature of standards, the meaning of ISO specific terms and expressions related to conformity assessment, as well as information about ISO's adherence to the World Trade Organization (WTO) principles in the Technical Barriers to Trade (TBT) see the following URL: www.iso.org/iso/foreword.html.

This document was prepared by Technical Committee ISO/TC 92, *Fire safety*, Subcommittee SC 2, *Fire containment*.

A list of all parts in the ISO/TR 12470 series can be found on the ISO website.

© ISO 2017 – All rights reserved

Introduction

Fire resistance tests on building components are necessary to establish their behaviour against pre-determined criteria when exposed to a representative fully developed fire and to provide information that may be used in determining the fire safety of buildings. For several decades, people have accepted, by means of test results only, the possibility of grading the components. Now, due to the enhancement of our knowledge and the complexity of buildings, it is necessary to be able to give a more accurate assessment of the components used in buildings, particularly with the growth of the use of functional approaches to designing fire safe structures.

The need to understand how the element will perform at a different size, with different levels of restraint, etc., is vital when applying the results of the fire tests in a life safety situation, especially those where the fire safe solution has been generated using fire safety engineering techniques rather than code compliant solutions. This does not negate the need to predict any changes that may result from changes to the test construction when complying with building code solutions, but these codes may themselves provide solutions that take into account the influence or impact of changes, and indeed, the guidance given in this document may be used by the code writers to produce such guidance.

Even with the knowledge available to assess the behaviour of a given constructional element, whatever its design or its size, we will still be some distance away from establishing the complete behaviour of a building in a real fire.

The philosophy of only grading elements into different fire resistance categories may not give any indication about how the element actually behaves when heated. By studying and assessing the data from fire resistance tests, it will be possible, using the guidance within this document, to obtain a basic understanding of the influence of the main parameters on the element performance during fire resistance tests.

In practice, tests give much useful information which can be used for interpolation and extrapolation of the results.

The original version of ISO/TR 12470 was published by ISO/TC 92 in 1998. This Technical Report provided a methodology in identifying how the results of fire resistance tests carried out in the standard furnaces could be modified to apply to the elements as they may be used in practice. In some cases, the results of the test may need to be reduced to reflect any increases in the degree of difficulty that the final application represents, or alternatively, modifications/enhancements may need to be made to the construction in order to maintain the performance level(s).

In the intervening years since the original Technical Report was prepared, a greater understanding has developed as to what the changes are likely to be and how they may be quantified. Some of the work in CEN (Committee European Normalisation) has aided this process and in particular, the principles given in Annex A remained unpublished by CEN but were developed in one of the technical Work Groups of CEN/TC 127. This revision represents the current state-of-art with respect to the objectives of the original 1998 version of ISO/TR 12470.

In this document, all the assessments of extended application are based, on the one hand, on the standard time/temperature conditions and, on the other hand, on isolated elements with no interaction with the adjacent elements.

Ageing and weathering are not covered here.

This document is divided into two parts.

The first part provides the methodology for defining the field of application for loadbearing members, both separating and non-separating. It also includes a review of the state-of-the-art and possible improvement in the methods of testing which would make it easier to establish the field of application for an element.

© ISO 2017 – All rights reserved

Guidance on direct and extended application of test results for specific non-loadbearing elements used in buildings, and the major parameters, which would be assessed by calculation or by expert judgements based upon the principles and discipline given in Annex A, are discussed

This document suggests expert systems which could take into account the interaction of various factors in an assessment of the fire resistance of doors, glazing, services, service penetrations and linear gap seals

© ISO 2017 – All rights reserved

Fire-resistance tests — Guidance on the application and extension of results from tests conducted on fire containment assemblies and products —

Part 2: Non-loadbearing elements

1 Scope

This document explains a methodology to determine the applicability of the results of fire resistance tests to actual applications.

It is applicable to those non-loadbearing elements for which there is an ISO standard test procedure based upon the ISO 834 series for determining the fire resistance of a representative sample of the construction proposed for use in a specific building or just for general use. These elements are:

— fire resisting door assemblies (excluding lift landing doorsets):

  — timber;

  — steel;

— fire resisting vertical glazing – metal framed:

  NOTE The rheology of glass is such that gravity has a disproportional influence on fire glass when it is heated to high temperatures and as a consequence, it is not possible to provide generic guidance on the extended application of horizontal glazed elements.

  — timber framed;

— linear gap sealing;

— service penetration sealing.

Fire resistance testing furnaces have fairly restricted size limitations and as a consequence, there is little confidence that the result obtained on an element of construction tested in accordance with the standard methods will behave in a similar manner when installed in the final building.

Direct and extended applications of test results are the two possible ways to ensure that an element that is not identical to the tested construction will have an acceptable probability of obtaining the same fire rating as that of the original tested specimen. In both cases, these applications generally refer only to the fire rating that the building element can expect to reach if it, or a representative sample of it, were to be tested in a furnace according to the standard fire test conditions used in the reference test.

The criteria and methodology used in evaluating ductwork and dampers is significantly different from those used to evaluate conventional separating elements and for this reason, these forms of construction are not included in the scope of this document. It is planned that a subsequent part of this document may include guidance on these elements.

© ISO 2017 – All rights reserved

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

ISO 834 (all parts), *Fire-resistance tests — Elements of building construction*

ISO/TR 10295 (all parts), *Fire tests for building elements and components — Fire testing of service installations*

ISO 13943, *Fire safety — Vocabulary*

3 Terms and definitions

For the purposes of this document, the terms and definitions given in ISO 834 (all parts), ISO/TR 10295 (all parts) and ISO 13943 and the following apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

— IEC Electropedia: available at https://www.electropedia.org/

— ISO Online browsing platform: available at https://www.iso.org/obp

3.1
direct application
application that identifies the modifications that can be made to the design of the tested element without reducing its fire rating

Note 1 to entry: These possible modifications are based on obvious knowledge and do not need further evaluation. In every case it is, at least, assumed that the basic material(s) used for the construction of the tested sample will not be changed.

Note 2 to entry: Direct application defines the variation(s) in the construction and the limits of use for the element which, without further analysis, are covered by the result of a test in accordance with ISO 834 (all parts). Direct application is arrived at by the application of simple *rules* (3.4) that are known, or considered by the fire community, to give equal fire resistance performance by the users. The rules can be applied by non- fire experts.

Note 3 to entry: Only results from one test report can be used when considering a change of an element. Any combination and use of two or more tests reports or other technical sources should be regarded as *extended application* (3.2) and hence dealt with accordingly.

3.2
extended application
application that is arrived at by the application of calculation or assessment *rules* (3.4) that are known, or considered by the fire community, to give equal or improved fire resistance performance by the users

Note 1 to entry: The rules are applied by fire experts.

Note 2 to entry: This will generally require an assessment by a fire expert either in developing rules of application for more general application by others or evaluating the results of fire engineering calculations or for making a judgement in specific cases. In every case, it will be taken into consideration that extended application may take into account the difference between the result of the original test and the fire resistance required for the untested element.

© ISO 2017 – All rights reserved

Note 3 to entry: Extended application defines and specifies the variations in the construction and establishes the limits of use for an element that has been tested according to the appropriate EN standard based upon an analysis by fire experts. The extended application can use the results from one or more test reports and can be based upon rules, calculations and expert judgement. As a result of the extended application, the fire resistance classification of an element with respect to defined performance characteristics may be maintained, increased or decreased when used in practice.

3.3
project specific application
application that uses a mixture of established validated calculations/computer models (if they exist and are appropriate) together with judgements made by suitably qualified persons (normally a professional badged engineer or a corporate member of a learned professional body)

Note 1 to entry: Because the application will, in these circumstances, require an understanding of both the structural response and the fire dynamics of the building in question, it is inevitable that the solution will involve an element of fire safety engineering.

3.4
rule
quantitative *factor* (3.9) that can be applied to the result of tests when defining the limits of application for which justification exists as a result of research and testing

Note 1 to entry: Rules are primarily used in determining the *direct application* (3.1) of the result as their application do not generally require specialist knowledge.

Note 2 to entry: It is anticipated that these rules be established by the specialist (or ad-hoc) groups preparing the specific standards based upon public domain knowledge and developed by industry consortia or trade associations for specific elements for which the members have appropriate interest and knowledge, particularly in Europe initially. After some experience, the results of calculations and judgements may become rules.

3.5
calculation in support of extended application
calculation method that can be applied to one or more parameters of a tested construction and which are based on existing physical laws or which have been empirically validated and which form part of the process of defining the *extended application* (3.2)

Note 1 to entry: If this term has a definition elsewhere, then it should be used but possibly modified to include this specific use.

3.6
expert judgement
qualitative process performed by fire experts when the complexity of the influence is beyond the scope of *rules* (3.4), to establish the resultant effect of a variation in one or more parameters, on the classification awarded

3.7
construction parameter
aspect of the design and construction of an element that may be varied and which may result in a change in the fire resistance performance, e.g. a change in one or more of the dimensions of a stud in a stud-framed separating elements

3.8
thermal and mechanical parameter
aspect of the conditions of a test that may vary in practice and influence the classification system given, e.g. the pressure differential that will exist at the top of a larger element than existed at the top of the specimen when tested

3.9
factor
one of the possible variations that may be applied to a parameter, e.g. a change in the stiffness as a result of a dimensional change in the member or a component within the element

© ISO 2017 – All rights reserved

3.10
factor influence
one of the potential causes of a change in the fire resistance recorded by test, with respect to one or more of the criteria, when a *factor* (3.9) is changed, e.g. an increase in the loadbearing capacity, *R*, as a result of an increase in stiffness

4 Principles of the field of application

4.1 General

The field of application from the result of a fire resistance test has at least 3 possible components: a) direct application, b) extended application and c) project specific application.

The process of determining the Direct Application and Extended Application of the fire resistance rating of a tested construction normally assumes that the performance is evaluated against the temperature/time and differential pressure conditions given in the appropriate ISO fire resistance testing standard [based upon ISO 834 (all parts) or the national, regional equivalent], as this is generally what is referenced in national prescriptive legislation. The variations between the tested specimen and the "as-built" construction will therefore be restricted to

— variations in the size of the construction,

— variations in the materials and methods of construction,

— variations in the restraint and fixity, and

— variations in the load carried (if any).

In this situation, only the constructional parameters given in A.2.2 need to be taken into account.

In practice there will be a need to predict the performance of a structure when it is exposed to different fire exposure conditions, in terms of the temperatures reached after certain durations and with greater, or lesser pressure differentials. Generally, the parameters will be analysed by means of a fire engineering analysis which is outside of the scope of this document, but the parameters listed in A.2.1 may be appropriate for use in an expert judgement analysis of these characteristics.

For each type of element of construction, the application of test results will be considered under three conditions: a) direct application, b) extended application and c) project specific fields of application.

Changes in materials and methods of construction can have significant influences on the fire resistance. Because the advice and recommendations are common to all elements, those aspects are dealt with separately under 5.1 to avoid repetition. The user of this document should consider these aspects in all applications of results whether direct applications, extended applications, or project specific applications.

4.2 Direct application

The direct application will normally involve the application of "rules" that are given as part of the test standard or in a document directly associated with the test standard. It requires no knowledge of the process of determining the fire resistance other than an understanding of the criteria and the general terminology.

Where there is more than one change in any proposed construction/installation, two "direct application" rules should not be applied automatically and the two should be compared as part of an extended application.

© ISO 2017 – All rights reserved