UL 1741

STANDARD FOR SAFETY

Inverters, Converters, Controllers and Interconnection System Equipment for Use With Distributed Energy Resources

ULSE INC. COPYRIGHTED MATERIAL – NOT AUTHORIZED FOR FURTHER
REPRODUCTION OR DISTRIBUTION WITHOUT PERMISSION FROM ULSE INC.

UL Standard for Safety for Inverters, Converters, Controllers and Interconnection System Equipment for Use With Distributed Energy Resources, UL 1741

Third Edition, Dated September 28, 2021

Summary of Topics:

This revision of UL 1741 dated August 14, 2026 includes the following changes in requirements:

– Expansion of Medium Voltage Requirements; 7.1.7, Section 7.2A, Section 7.2B, 15.3.8, 19A.4, 25.2.5, Section 47A (title), Table 47A.1, Section 47B, 67.8A, 67.8B, and 68.2.9.

– Addition of Applicable Battery and Energy Storage Standard References, UL 1973 and UL 9540; 32.4.5, 32.4.6, and Annex A

– Editorial corrections to table numbers and their references to reflect the section they appear in, Tables 5.4 – 5.9 updated to Table 7.4 – Table 7.9, 7.7.5, 7.7.8, 7.8.2.1, 7.8.5.1, and 7.9.14

– Editorial corrections to figure numbers and their references to reflect the section they appear in, Figures 5.1 – 5.3 updated to Figure 7.1 – Figure 7.3, 7.8.2.1 and 7.8.3.1.

Text that has been changed in any manner or impacted by ULSE's electronic publishing system is marked with a vertical line in the margin.

The new and revised requirements are substantially in accordance with Proposal(s) on this subject dated March 12, 2026 and July 14, 2026.

All rights reserved. No part of this publication may be reproduced, stored in a retrieval system, or transmitted in any form by any means, electronic, mechanical photocopying, recording, or otherwise without prior permission of ULSE Inc. (ULSE).

ULSE provides this Standard "as is" without warranty of any kind, either expressed or implied, including but not limited to, the implied warranties of merchantability or fitness for any purpose.

In no event will ULSE be liable for any special, incidental, consequential, indirect or similar damages, including loss of profits, lost savings, loss of data, or any other damages arising out of the use of or the inability to use this Standard, even if ULSE or an authorized ULSE representative has been advised of the possibility of such damage. In no event shall ULSE's liability for any damage ever exceed the price paid for this Standard, regardless of the form of the claim.

Users of the electronic versions of UL's Standards for Safety agree to defend, indemnify, and hold ULSE harmless from and against any loss, expense, liability, damage, claim, or judgment (including reasonable attorney's fees) resulting from any error or deviation introduced while purchaser is storing an electronic Standard on the purchaser's computer system.

ULSE INC. COPYRIGHTED MATERIAL – NOT AUTHORIZED FOR FURTHER REPRODUCTION OR DISTRIBUTION WITHOUT PERMISSION FROM ULSE INC.

No Text on This Page

ULSE INC. COPYRIGHTED MATERIAL – NOT AUTHORIZED FOR FURTHER REPRODUCTION OR DISTRIBUTION WITHOUT PERMISSION FROM ULSE INC.

SEPTEMBER 28, 2021
(Title Page Reprinted: August 14, 2026)

UL 1741

Standard for Inverters, Converters, Controllers and Interconnection System Equipment for Use With Distributed Energy Resources

First Edition – May, 1999
Second Edition – January, 2010

Third Edition

September 28, 2021

This UL Standard for Safety consists of the Third edition including revisions through August 14, 2026.

Comments or proposals for revisions on any part of the Standard may be submitted to ULSE at any time. Proposals should be submitted via a Proposal Request in the Collaborative Standards Development System (CSDS) at https://csds.ul.com.

Our Standards for Safety are copyrighted by ULSE Inc. Neither a printed nor electronic copy of a Standard should be altered in any way. All of our Standards and all copyrights, ownerships, and rights regarding those Standards shall remain the sole and exclusive property of ULSE Inc.

NOTE – The user's attention is called to the possibility that compliance with this Standard may require use of an invention covered by patent rights.

By publication of this Standard, no position is taken with respect to the validity of this claim or of any such claim(s) or of patent rights in connection therewith. If a patent holder has filed a statement of willingness to grant a license under these rights on reasonable and nondiscriminatory terms and conditions to applicants desiring to obtain such a license, then details may be obtained from ULSE.

© 2026 ULSE Inc. All rights reserved.

ULSE INC. COPYRIGHTED MATERIAL – NOT AUTHORIZED FOR FURTHER REPRODUCTION OR DISTRIBUTION WITHOUT PERMISSION FROM ULSE INC.

No Text on This Page

ULSE INC. COPYRIGHTED MATERIAL – NOT AUTHORIZED FOR FURTHER REPRODUCTION OR DISTRIBUTION WITHOUT PERMISSION FROM ULSE INC.

CONTENTS

INTRODUCTION

1 Scope 11
2 Glossary 11
2.1 General 11
2.2 PV rapid shutdown equipment and systems 16
3 Components 17
4 Units of measurement 18
5 References 18

CONSTRUCTION

6 General 18
7 Frame and Enclosure 18
7.1 General 18
7.2 Access covers 19
7.2A Doors and covers for medium voltage equipment 19
7.2B Viewing panes 20
7.3 Cast metal enclosures 20
7.4 Sheet metal enclosures 21
7.5 Nonmetallic enclosures 23
7.6 Openings covered by glass 24
7.7 Openings for wiring system connections 24
7.8 Openings for ventilation 26
7.9 Environmental rated enclosures 31
8 Protection Against Corrosion 34
9 Mechanical Assembly 34
10 Mounting 35
11 Protection of Users – Accessibility of Uninsulated Live Parts 35
12 Protection of Service Personnel 38
13 Electric Shock 40
13.1 Voltage 40
13.2 Stored energy 42
14 Switches and Controls 44
15 Disconnect Devices 46
15.1 General 46
15.2 Provision for locking 46
15.3 Medium voltage disconnect devices (isolating means) 46
15A Interlocking of Medium Voltage Equipment 48
16 AC Output Connections 50
16.1 Stand-alone inverters 50
16.2 Utility-interactive inverters 51
17 Receptacles for Low Voltage Output Circuits 51
18 Supply Connections 51
18.1 General 51
18.2 Wiring terminals 52
18.3 Wiring leads for low voltage field conductors 54
18.4 Wiring compartments for low voltage field conductors 54
18.5 Openings for conduit or cable connection 55
18.6 Openings for class 2 circuit conductors 55
19 Wire-Bending Space for Low Voltage Field Conductors 55
19A Wire-bending Space for Medium Voltage Field Conductors 61
20 Equipment Grounding 62

ULSE INC. COPYRIGHTED MATERIAL – NOT AUTHORIZED FOR FURTHER REPRODUCTION OR DISTRIBUTION WITHOUT PERMISSION FROM ULSE INC.

20.1 General....62
20.2 Grounding electrode terminal....64
21 AC Output Circuit Grounded Conductor....64
22 Internal Bonding for Grounding....66
22A Connection of Medium Voltage Conductor Shields....68
22B Grounding of Medium Voltage Drawout Elements....68
22C Ground Bus for Medium Voltage Equipment....68
23 Internal Wiring....68
23.1 General....68
23.2 Protection of wiring....69
23.3 Electrical connections....70
24 Live Parts....71
25 Separation of Circuits....71
25.1 Factory wiring....71
25.2 Field wiring....72
25.3 Separation barriers....72
26 Spacings....73
26.1 General....73
26.2 Insulating liners and barriers for low voltage circuits....75
26.3 Insulating liners and barriers for medium voltage circuits....76
27 Alternate Spacings – Clearances and Creepage Distances for Low Voltage Circuits....76
28 Insulating Materials....77
28.1 General....77
28.2 Barriers for low voltage circuits....78
29 Capacitors....78
30 Isolated Accessible Signal Circuits....79
31 Control Circuits....80
32 Low Voltage Overcurrent Protection....82
32.1 General....82
32.2 Low voltage Control circuit overcurrent protection....83
32.3 Low voltage output ac power circuit overcurrent protection....84
32.4 Battery circuits....85
32A Medium Voltage Overcurrent Protection....85
32A.1 General....85
32A.2 Medium voltage switch gear control circuit overcurrent protection....86
32A.3 Medium voltage output ac power circuit overcurrent protection....86
33 Panelboard Features....86
34 DC Ground Fault Detector/Interrupter....86
34A PV DC Arc-Fault Protection....88
35 Printed-Wiring Boards....88
36 External Transformers....89
36A Voltage Dividers....89

PROTECTION AGAINST RISKS OF INJURY TO PERSONS

37 General....90
38 Enclosures and Guards....90
39 Moving Parts....91
40 Switches and Controls....91
41 Mounting....91

OUTPUT POWER CHARACTERISTICS AND INTERACTIVE COMPATIBILITY

42 General....91
43 Interactive Equipment....91

ULSE INC. COPYRIGHTED MATERIAL – NOT AUTHORIZED FOR FURTHER REPRODUCTION OR DISTRIBUTION WITHOUT PERMISSION FROM ULSE INC.

43A Cybersecurity (Optional) 93

PERFORMANCE

44 General 93
45 Maximum-Voltage Measurements 94
46 Temperature 94
47 Dielectric Voltage-Withstand Test on Low Voltage Circuits 99
47A Power Frequency Withstand and Impulse Tests on Medium Voltage Circuits 99
47B Mechanical Tests of Viewing Panes 100
47B.1 General 100
47B.2 Pressure test 100
47B.3 Impact test 101
48 Output Power Characteristics 101
48.1 General 101
48.2 Output ratings 101
48.3 Input range 101
48.4 Harmonic distortion 101
49 Utility Compatibility 102
50 Abnormal Tests 102
50.1 General 102
50.2 Output overload test 104
50.3 Short-circuit test 104
50.4 DC input miswiring test 105
50.5 Ventilation test 105
50.6 Component short- and open-circuit 105
50.7 Load transfer test 106
50.8 Loss of control circuit 106
51 Grounding Impedance Test 106
52 Overcurrent Protection Calibration Test 106
53 Strain Relief Test 107
54 Reduced Spacings Tests for Low Voltage Printed Wiring Boards 107
54.1 General 107
54.2 Dielectric voltage-withstand test 107
54.3 Shorted trace test 108
55 Bonding Conductor Test 108
56 Voltage Surge Test 109
57 Calibration Test 109
58 Overvoltage Test 111
59 Current Withstand Test 111
60 Capacitor Voltage Determination Test 111
61 Stability 111
62 Static Load 112
63 Compression Test 112
64 Rain and Sprinkler Tests 112
64.1 General 112
64.2 Rain test 113
64.3 Sprinkler test 116
64.4 Driven rain test 118
64A Rod Entry Test 119
64B Medium Voltage Shutter Integrity Test 119
64C Impulse Withstand Tests 119
64C.1 General 119
64C.2 Evaluation 120

ULSE INC. COPYRIGHTED MATERIAL – NOT AUTHORIZED FOR FURTHER REPRODUCTION OR DISTRIBUTION WITHOUT PERMISSION FROM ULSE INC.

RATING

65 Details 121

MARKING

66 Details 123
67 Cautionary Markings 130
68 Equipment Information and Instructions 132
68.1 Separation of information 132
68.2 Operating and installation instructions 132
69 Important Safety Instructions 134

MANUFACTURING AND PRODUCTION TESTS

70 Dielectric Voltage-Withstand Test – Low Voltage Circuits 138
70A Power Frequency Voltage Withstand Test – Medium Voltage Circuits 140
71 Production Tests for Interactive Equipment 140

CHARGE CONTROLLERS

INTRODUCTION

72 General 140

CONSTRUCTION

73 General 141

PERFORMANCE

74 General 141
75 Sources and Loads 142
76 Normal Operations 143
77 Temperature 144
78 Temperature Compensation 144
79 Connection Sequence 144
80 Abnormal Tests 144
80.1 General 144
80.2 Input and output faults 144
80.3 Charge controller miswiring 145
80.4 Low-voltage disconnect 145

MARKING

81 Cautionary Markings 146
82 Details 146
83 Important Safety Instructions 146

AC MODULES AND PV MODULES WITH INTEGRATED ELECTRONICS

INTRODUCTION

84 General 147

ULSE INC. COPYRIGHTED MATERIAL – NOT AUTHORIZED FOR FURTHER REPRODUCTION OR DISTRIBUTION WITHOUT PERMISSION FROM ULSE INC.

CONSTRUCTION

85 General 147

PERFORMANCE

86 General 149
87 PV Module Mounted Equipment Securement Test 150
88 Module to Electronics Bonding 150

RATING

89 General 151

MARKING

90 Details 151
91 Important Safety Instructions 152

RAPID SHUTDOWN EQUIPMENT AND SYSTEMS

INTRODUCTION

92 General 152

CONSTRUCTION

93 Protection of Emergency Personnel 153
94 Electrical Isolation Systems (EIS) 157
95 Initiators 157
96 PVRSS that Includes Disconnect Functionality 158
97 PVRSS and PVRSE Functional Safety 158
97.1 General 158
97.2 Conditions to be addressed for a PVRSS/PVRSE 160

PERFORMANCE

98 General 161
98.1 Operational tests for PVRSS/PVRSE verification of levels – controlled conductors 161
98.2 Verification testing of PVRSS at rated extremes 161
98.3 Power supply grid support ride through 162
98.4 Inverters rated as PVRSE 163
98.5 Other equipment rated as PVRSE 164
99 Functional Safety Evaluation and Environmental Stress Testing For PVRSS/PVRSE 164

RATINGS

100 General 174

MARKING

101 Details 174
102 Installation Instructions 175

ULSE INC. COPYRIGHTED MATERIAL – NOT AUTHORIZED FOR FURTHER REPRODUCTION OR DISTRIBUTION WITHOUT PERMISSION FROM ULSE INC.

POWER CONTROL SYSTEMS

103 General 176

SUPPLEMENT SA – GRID SUPPORT UTILITY INTERACTIVE EQUIPMENT

PART 1 – GENERAL

SA1 Scope 177
SA2 Acronyms 178
SA3 Definitions 179
SA4 Construction 181
SA5 Performance – Grid Support Utility Interactive 181
SA5.1 General 181
SA5.2 Grid support utility interconnection protection performance 181
SA5.3 Test parameter tolerances 182
SA5.4 Representative testing 183
SA5.5 Abnormal tests 183
SA6 Ratings, Markings and Instructions 183
SA7 Manufacturing and Production Line Testing for Grid Support Utility Interactive Inverters 184

PART 2 – SPECIFIC REQUIREMENTS AND TESTS FOR GRID SUPPORT UTILITY INTERACTIVE INVERTERS

SA8 Anti-islanding Protection – Unintentional Islanding with Grid Support Functions Enabled 184
SA8.1 General 184
SA8.2 Test procedure 185
SA8.3 Tests requirements 186
SA9 L/HVRT Low and High Voltage Ride-Through 190
SA9.1 Function L/HVRT – low and high voltage ride-through 190
SA9.2 Must trip magnitude and duration 195
SA10 L/HFRT Low and High Frequency Ride-Through 196
SA10.1 General 196
SA10.2 Test requirements 197
SA10.3 Test procedure 197
SA10.4 Ride-through test signal (step function) 199
SA10.5 Must trip magnitude and duration 201
SA11 RR – Normal Ramp Rate and SS – Soft-Start Ramp Rate 201
SA11.1 General 201
SA11.2 Procedure for normal ramp rate test 202
SA11.3 Test requirements 202
SA11.4 Procedure for soft-start ramp rate test 203
SA11.5 Test requirements 204
SA11.6 Ramp rate test profiles 204
SA12 SPF – Specified Power Factor 206
SA12.1 General 206
SA12.2 Procedure for specified power factor test 206
SA12.3 Test requirements 208
SA13 Volt/VAr Mode [Q(V)] 208
SA13.1 General 208
SA13.2 Procedure for Volt-VAr "Q(V)" test 208
SA13.3 Test requirements 213
SA14 Frequency-Watt (FW) – Optional 213
SA14.1 General 213
SA14.2 EUT Specified Parameters 214
SA14.3 Test procedure 215

ULSE INC. COPYRIGHTED MATERIAL – NOT AUTHORIZED FOR FURTHER REPRODUCTION OR DISTRIBUTION WITHOUT PERMISSION FROM ULSE INC.

SA14.4 Test requirements 217
SA15 Volt-Watt (VW) – Optional 218
SA15.1 General 218
SA15.2 EUT specified parameters 218
SA15.3 Test procedure 220
SA15.4 Test requirements 224
SA16 Ratings for Grid Support Utility Interactive Inverters, Converters 224
SA17 Disable Permit Service (Optional) 224
SA17.1 General 224
SA17.2 Test procedures 224
SA17.3 Criteria 225
SA18 Limit Active Power (Optional) 225
SA18.1 General 225
SA18.2 Test procedures 226

SUPPLEMENT SB – GRID SUPPORT UTILITY-INTERACTIVE INVERTERS AND CONVERTERS BASED UPON IEEE 1547-2018 and IEEE 1547.1-2020

SB1 Scope 227
SB2 Definitions 227
SB3 Construction 227
SB4 Performance – Grid Support Interactive 228
SB4.1 General 228
SB4.2 Grid support utility interconnection performance 228
SB4.2A Performance Categories 228
SB4.3 Additional requirements for testing according to IEEE 1547.1-2020 229
SB5 Ratings, Markings and Instructions 256
SB6 Manufacturing and Production Line Testing 257
SB7 Type Testing Results Reporting 257

SUPPLEMENT SC – AC BIDIRECTIONAL ELECTRIC VEHICLE SUPPLY EQUIPMENT (BEVSE) / INTERCONNECTION SYSTEMS EQUIPMENT (ISE) FOR EVs WITH SAE J3072 BIDIRECTIONAL ONBOARD INVERTERS

SC1 Scope 259
SC2 Referenced Publications 260
SC3 Definitions 262
SC4 Construction and Functionality 263
SC5 BEVID Interrupting Device 264
SC6 Line to Neutral Overvoltage Protection 265
SC7 EV Export Over Current Oversight and Protection 266
SC8 BEVSE/ISE Testable Communications Requirements 266
SC8.1 General 266
SC8.2 Downstream BEVSE/ISE communications 267
SC8.3 Upstream BEVSE/ISE communications 268
SC8.4 Upstream communications testing 268
SC8.5 SAE J3072 bridging to other authorized DER managing entities (DME) (Optional) 269
SC8.6 Charging, absorption or export of power communications relationships 269
SC9 BEVSE/ISE General Considerations and Oversight Requirements 269
SC9.1 BEVSE/ISE oversight scope 269
SC9.2 General considerations and requirements for test equipment 270
SC9.3 General considerations and requirements of the BEVSE/ISE 271
SC9.4 BEVSE/ISE oversight response and redundancy of SAE J3072 EV functions 274
SC9.5 Continuation of prohibit export (disable permit service) following a BEVSE/ISE power cycle 276
SC10 Performance – Grid Support Interactive 276

ULSE INC. COPYRIGHTED MATERIAL – NOT AUTHORIZED FOR FURTHER REPRODUCTION OR DISTRIBUTION WITHOUT PERMISSION FROM ULSE INC.

SC10.1 General 276
SC10.2 Grid support utility interconnection performance 277
SC10.3 BEVID safety isolation device or paralleling device 278
SC10.4 Tests on BEVSE/ISE BEVID interrupting device 278
SC10.5 Test for voltage disturbance oversight 278
SC10.6 Test for frequency disturbance oversight 278
SC10.7 BEVSE/ISE withstand tests 279
SC10.8 Interconnection integrity 279
SC10.9 Rate of change of frequency (ROCOF) susceptibility test 279
SC10.10 Phase change ride through (PCRT) susceptibility test 279
SC10.11 Power supply grid support ride through test (PSGSRT) 279
SC11 Ratings, Markings and Instructions 280
SC12 Manufacturing and Production Line Testing 281

Annex A

Standards for Components 282

ULSE INC. COPYRIGHTED MATERIAL – NOT AUTHORIZED FOR FURTHER REPRODUCTION OR DISTRIBUTION WITHOUT PERMISSION FROM ULSE INC.

INTRODUCTION

1 Scope

1.1 These requirements cover inverters, converters, charge controllers, and interconnection system equipment (ISE) intended for use in stand-alone (not grid-connected) or interactive (grid-connected) power systems. Interactive inverters, converters, and ISE are intended to be operated in parallel with an electric power system (EPS) to supply power to common loads.

1.2 For interactive equipment, these requirements are intended to supplement and be used in conjunction with the Standard for Interconnecting Distributed Resources With Electric Power Systems, IEEE 1547, and the Standard for Conformance Test Procedures for Equipment Interconnecting Distributed Resources with Electric Power Systems, IEEE 1547.1.

1.3 These requirements cover AC modules that combine flat-plate photovoltaic modules and inverters to provide AC output power for stand-alone use or interaction with the electric power system (EPS), commonly the electric utility grid, and power systems that combine other alternative energy sources with inverters, converters, charge controllers, and interconnection system equipment (ISE), in system specific combinations.

1.4 These requirements also cover power systems that combine independent power sources with inverters, converters, charge controllers, and interconnection system equipment (ISE) in system specific combinations.

1.5 The products covered by these requirements are intended to be installed in accordance with the National Electrical Code, NFPA 70.

1.6 These requirements also cover rapid shutdown equipment and systems.

2 Glossary

2.1 General

2.1.1 In the text of this standard, the term "unit" refers to any product covered by this Standard. For the purpose of this Standard, the definitions in 2.1.2 – 2.1.54 apply.

2.1.2 AC MODULE – The smallest complete unit that includes solar cells, optics, inverters, and other components, excluding tracking devices, intended to generate ac power from sunlight.

2.1.3 BARRIER – A part inside an enclosure that reduces access to a part that involves a risk of fire, electric shock, injury to persons, or electrical energy-high current levels.

2.1.4 BRANCH CIRCUIT – The portion of the building wiring system beyond the final overcurrent protective device in the power-distribution panel that protects the ac output of the field-wiring terminals in a permanently connected unit.

2.1.5 BYPASS SOURCE – A branch circuit or generator to which the load is connected when the power conversion portion of the inverter is not supplying power to the load.

2.1.6 CHARGE CONTROLLER – A device intended to control the charging process of storage batteries used in photovoltaic power systems.

ULSE INC. COPYRIGHTED MATERIAL – NOT AUTHORIZED FOR FURTHER REPRODUCTION OR DISTRIBUTION WITHOUT PERMISSION FROM ULSE INC.