UL 248-19

STANDARD FOR SAFETY

Low-Voltage Fuses – Part 19:
Photovoltaic Fuses

ULSE INC. COPYRIGHTED MATERIAL – NOT AUTHORIZED FOR FURTHER
REPRODUCTION OR DISTRIBUTION WITHOUT PERMISSION FROM ULSE INC.

UL Standard for Safety for Low-Voltage Fuses – Part 19: Photovoltaic Fuses, UL 248-19

First Edition, Dated November 13, 2015

Summary of Topics

This revision of ANSI/UL 248-19 dated November 25, 2024 includes changes to the Scope to increase the maximum votage rating for PV systems: 1.1 and 3.2.1.

As noted in the Commitment for Amendments statement located on the back side of the title page, UL, CSA, and ANCE are committed to updating this harmonized standard jointly.

Text that has been changed in any manner or impacted by ULSE's electronic publishing system is marked with a vertical line in the margin.

The revised requirements are substantially in accordance with Proposal(s) on this subject dated March 29, 2024 and August 13, 2024.

All rights reserved. No part of this publication may be reproduced, stored in a retrieval system, or transmitted in any form by any means, electronic, mechanical photocopying, recording, or otherwise without prior permission of ULSE Inc. (ULSE).

ULSE provides this Standard "as is" without warranty of any kind, either expressed or implied, including but not limited to, the implied warranties of merchantability or fitness for any purpose.

In no event will ULSE be liable for any special, incidental, consequential, indirect or similar damages, including loss of profits, lost savings, loss of data, or any other damages arising out of the use of or the inability to use this Standard, even if ULSE or an authorized ULSE representative has been advised of the possibility of such damage. In no event shall ULSE's liability for any damage ever exceed the price paid for this Standard, regardless of the form of the claim.

Users of the electronic versions of UL's Standards for Safety agree to defend, indemnify, and hold ULSE harmless from and against any loss, expense, liability, damage, claim, or judgment (including reasonable attorney's fees) resulting from any error or deviation introduced while purchaser is storing an electronic Standard on the purchaser's computer system.

ULSE INC. COPYRIGHTED MATERIAL – NOT AUTHORIZED FOR FURTHER REPRODUCTION OR DISTRIBUTION WITHOUT PERMISSION FROM ULSE INC.

No Text on This Page

ULSE INC. COPYRIGHTED MATERIAL – NOT AUTHORIZED FOR FURTHER REPRODUCTION OR DISTRIBUTION WITHOUT PERMISSION FROM ULSE INC.



Association of Standardization and Certification
NMX-J-009/248/19-ANCE
First Edition



CSA Group
CSA C22.2 No. 248.19
First Edition



ULSE Inc.
UL 248-19
First Edition

Low-Voltage Fuses – Part 19: Photovoltaic Fuses

November 13, 2015

(Title Page Reprinted: November 25, 2024)



ANSI/UL 248-19-2024

ULSE INC. COPYRIGHTED MATERIAL – NOT AUTHORIZED FOR FURTHER REPRODUCTION OR DISTRIBUTION WITHOUT PERMISSION FROM ULSE INC.

Commitment for Amendments

This standard is issued jointly by the Association of Standardization and Certification (ANCE), the Canadian Standards Association (operating as “CSA Group”), and ULSE Inc. (ULSE). Comments or proposals for revisions on any part of the standard may be submitted to ANCE, CSA Group, or ULSE at anytime. Revisions to this standard will be made only after processing according to the standards development procedures of ANCE, CSA Group, and ULSE. CSA Group and ULSE will issue revisions to this standard by means of a new edition or revised or additional pages bearing their date of issue. ANCE will incorporate the same revisions into a new edition of the standard bearing the same date of issue as the CSA Group and ULSE pages.

© 2015 ANCE

Rights reserved in favor of ANCE.

ISBN 978-1-77139-677-6 © 2015 Canadian Standards Association

All rights reserved. No part of this publication may be reproduced in any form whatsoever without the prior permission of the publisher.

This Standard is subject to review within five years from the date of publication, and suggestions for its improvement will be referred to the appropriate committee. To submit a proposal for change, please send the following information to inquiries@csagroup.org and include "Proposal for change" in the subject line: Standard designation (number); relevant clause, table, and/or figure number; wording of the proposed change; and rationale for the change.

To purchase CSA Group Standards and related publications, visit CSA Group's Online Store at www.csagroup.org/store/ or call toll-free 1-800-463-6727 or 416-747-4044.

© 2024 ULSE Inc. All rights reserved.

Our Standards for Safety are copyrighted by ULSE Inc. Neither a printed nor electronic copy of a Standard should be altered in any way. All of our Standards and all copyrights, ownerships, and rights regarding those Standards shall remain the sole and exclusive property of ULSE Inc.

This ANSI/UL Standard for Safety consists of the First Edition including revisions through November 25, 2024. The most recent designation of ANSI/UL 248-19 as an American National Standard (ANSI) occurred on November 25, 2024. ANSI approval for a standard does not include the Cover Page, Transmittal Pages, Title Page (front and back), or the Preface.

Comments or proposals for revisions on any part of the Standard may be submitted to ULSE at any time. Proposals should be submitted via a Proposal Request in the Collaborative Standards Development System (CSDS) at https://csds.ul.com.

For information on ULSE Standards, visit http://www.shopulstandards.com, call toll free 1-888-853-3503 or email us at ClientService@shopULStandards.com.

ULSE INC. COPYRIGHTED MATERIAL – NOT AUTHORIZED FOR FURTHER REPRODUCTION OR DISTRIBUTION WITHOUT PERMISSION FROM ULSE INC.

CONTENTS

PREFACE 5

1 Scope 7
2 General 7
3 Characteristics 7
3.1 Classification 7
3.2 Voltage rating 7
3.3 Frequency 7
3.4 Interrupting rating 7
3.5 Peak let-through current and clearing I^2t characteristics 7
4 Markings 8
5 Construction 8
6 Tests 8
6.1 General 8
6.2 Verification of temperature rise and current-carrying capacity 9
6.3 Verification of overload operation 9
6.4 Verification of operation at rated voltage 9
6.5 Verification of peak let-through characteristics and I^2t 10
6.6 Special environment conditions 10
6.7 Current cycling 10

ULSE INC. COPYRIGHTED MATERIAL – NOT AUTHORIZED FOR FURTHER REPRODUCTION OR DISTRIBUTION WITHOUT PERMISSION FROM ULSE INC.

No Text on This Page

ULSE INC. COPYRIGHTED MATERIAL – NOT AUTHORIZED FOR FURTHER REPRODUCTION OR DISTRIBUTION WITHOUT PERMISSION FROM ULSE INC.

PREFACE

This is the harmonized ANCE, CSA Group, and ULSE Standard for Fuses – Part 19: Photovoltaic Fuses. It is the first edition of NMX-J-009/248/19-ANCE , the first edition of CAN/CSA-C22.2 No 248.19, and the first edition of UL 248-19. This harmonized standard has been jointly revised on November 25, 2024. For this purpose, CSA Group and UL are issuing revision pages dated November 25, 2024, and ANCE is issuing a new edition dated November 25, 2024.

This harmonized standard was prepared by the Association of Standardization and Certification, (ANCE), CSA Group and ULSE Inc. (ULSE). The efforts and support of the Technical Harmonization Subcommittee, THC 32B under CANENA on the Harmonization of Electrotechnical Standards of the Nations of the Americas (CANENA), are gratefully acknowledged.

The present Mexican standard was developed by the CT 32 “Fusibles” from the Comite de Normalizacion de la Asociacion de Normalizacion y Certificacion, A.C., CONANCE, with the collaboration of the manufacturers and users of fuses.

This standard was reviewed by the CSA Subcommittee on Fuses and Fuseholders, under the jurisdiction of the CSA Technical Committee on Industrial Products and the CSA Strategic Steering Committee on requirements for Electrical Safety, and has been formally approved by the CSA Technical Committee.

Application of Standard

Where reference is made to a specific number of samples to be tested, the specified number is to be considered a minimum quantity.

Note: Although the intended primary application of this standard is stated in its scope, it is important to note that it remains the responsibility of the users of the standard to judge its suitability for their particular purpose.

Interpretations

The interpretation by the standards development organization of an identical or equivalent standard is based on the literal text to determine compliance with the standard in accordance with the procedural rules of the standards development organization. If more than one interpretation of the literal text has been identified, a revision is to be proposed as soon as possible to each of the standards development organizations to more accurately reflect the intent.

ULSE INC. COPYRIGHTED MATERIAL – NOT AUTHORIZED FOR FURTHER REPRODUCTION OR DISTRIBUTION WITHOUT PERMISSION FROM ULSE INC.

No Text on This Page

ULSE INC. COPYRIGHTED MATERIAL – NOT AUTHORIZED FOR FURTHER REPRODUCTION OR DISTRIBUTION WITHOUT PERMISSION FROM ULSE INC.

Low-Voltage Fuses – Part 19: Photovoltaic Fuses

1 Scope

1.1 This Part applies to fuses for photovoltaic (PV) systems rated up to 2000 Vdc.

1.2 Fuses for photovoltaic (PV) systems are intended to be used for the protection of photovoltaic strings or arrays and their associated wiring to provide protection against overloads or short circuits within the marked electrical ratings in accordance with the Canadian Electrical Code (CSA C22.1 Canadian Electrical Code Part I) in Canada, the Standard for Electrical Installations, NOM-001-SEDE, in Mexico and the National Electrical Code NEC), NFPA-70, in the United States of America.

1.3 These types of fuses are not intended to protect downstream inverter components, such as capacitors and against the discharge of such capacitors back into the arrays.

2 General

2.1 This Part is intended to be read together with the Standard for Low-Voltage Fuses – Part 1: General Requirements, NMX-J-009/248/1-ANCE ♦ CAN/CSA C22.2 No. 248.1-11 ♦ UL 248-1, hereafter referred to as Part 1. The requirements of Part 1 apply unless modified by this Part.

2.2 For products intended for use in Canada, general requirements are given in CAN/CSA-C22.2 No. 0, General Requirements – Canadian Electrical Code, Part II.

3 Characteristics

3.1 Classification

3.1.1 Fuses for photovoltaic (PV) systems shall:

a) Be non-renewable; and

b) Have an minimum interrupting rating of 10 kA minimum.

3.2 Voltage rating

3.2.1 The voltage rating may be up to 2000 Vdc. Preferred ratings are 600 V, 750 V, 1000 V, 1250 V, 1500 V, and 2000 V.

3.3 Frequency

3.3.1 Not applicable.

3.4 Interrupting rating

3.4.1 The interrupting rating shall be 10 kA minimum.

3.5 Peak let-through current and clearing I^2t characteristics

3.5.1 Not applicable.

ULSE INC. COPYRIGHTED MATERIAL – NOT AUTHORIZED FOR FURTHER REPRODUCTION OR DISTRIBUTION WITHOUT PERMISSION FROM ULSE INC.