UL 60730-1

STANDARD FOR SAFETY

Automatic Electrical Controls – Part 1: General Requirements

ULSE INC. COPYRIGHTED MATERIAL – NOT AUTHORIZED FOR FURTHER
REPRODUCTION OR DISTRIBUTION WITHOUT PERMISSION FROM ULSE INC.

UL Standard for Safety for Automatic Electrical Controls – Part 1: General Requirements, UL 60730-1

Sixth Edition, Dated October 31, 2024

Summary of Topics

Adoption of IEC 60730-1, Automatic electrical controls – Part 1: General requirements, (Edition 6.0, issued by the IEC September 2022) as a new Sixth Edition IEC-based UL Standard, UL 60730-1, dated October 31, 2024 with US National Differences. Please note that the national difference document incorporates all of the U.S. National Differences for UL 60730-1.

The new and revised requirements are substantially in accordance with Proposal(s) on this subject dated January 26, 2024 and April 19, 2024.

All rights reserved. No part of this publication may be reproduced, stored in a retrieval system, or transmitted in any form by any means, electronic, mechanical photocopying, recording, or otherwise without prior permission of ULSE Inc. (ULSE).

ULSE provides this Standard "as is" without warranty of any kind, either expressed or implied, including but not limited to, the implied warranties of merchantability or fitness for any purpose.

In no event will ULSE be liable for any special, incidental, consequential, indirect or similar damages, including loss of profits, lost savings, loss of data, or any other damages arising out of the use of or the inability to use this Standard, even if ULSE or an authorized ULSE representative has been advised of the possibility of such damage. In no event shall ULSE's liability for any damage ever exceed the price paid for this Standard, regardless of the form of the claim.

Users of the electronic versions of UL's Standards for Safety agree to defend, indemnify, and hold ULSE harmless from and against any loss, expense, liability, damage, claim, or judgment (including reasonable attorney's fees) resulting from any error or deviation introduced while purchaser is storing an electronic Standard on the purchaser's computer system.

ULSE INC. COPYRIGHTED MATERIAL – NOT AUTHORIZED FOR FURTHER REPRODUCTION OR DISTRIBUTION WITHOUT PERMISSION FROM ULSE INC.

No Text on This Page

ULSE INC. COPYRIGHTED MATERIAL – NOT AUTHORIZED FOR FURTHER REPRODUCTION OR DISTRIBUTION WITHOUT PERMISSION FROM ULSE INC.

OCTOBER 31, 2024

ANSI/UL 60730-1-2024

UL 60730-1

Automatic Electrical Controls – Part 1: General Requirements

First Edition – Not Printed
Second Edition – Not Printed
Third Edition – January, 2002
Fourth Edition – October, 2009
Fifth Edition – August, 2016

Sixth Edition

October 31, 2024

This ANSI/UL Standard for Safety consists of the Sixth Edition.

The most recent designation of ANSI/UL 60730-1 as an American National Standard (ANSI) occurred on October 31, 2024. ANSI approval for a standard does not include the Cover Page, Transmittal Pages, Title Page, or Preface. The National Difference Page and IEC Foreword are also excluded from the ANSI approval of IEC-based standards.

Comments or proposals for revisions on any part of the Standard may be submitted to ULSE at any time. Proposals should be submitted via a Proposal Request in the Collaborative Standards Development System (CSDS) at https://csds.ul.com.

Our Standards for Safety are copyrighted by ULSE Inc. Neither a printed nor electronic copy of a Standard should be altered in any way. All of our Standards and all copyrights, ownerships, and rights regarding those Standards shall remain the sole and exclusive property of ULSE Inc.

© 2024 ULSE Inc. All rights reserved.

ULSE INC. COPYRIGHTED MATERIAL – NOT AUTHORIZED FOR FURTHER REPRODUCTION OR DISTRIBUTION WITHOUT PERMISSION FROM ULSE INC.

No Text on This Page

ULSE INC. COPYRIGHTED MATERIAL – NOT AUTHORIZED FOR FURTHER REPRODUCTION OR DISTRIBUTION WITHOUT PERMISSION FROM ULSE INC.

CONTENTS

Preface **11**

NATIONAL DIFFERENCES **13**

FOREWORD **15**

1 Scope 19
1DV.1 Modification of Clause 1 by adding the following text: 20
2 Normative references 20
2DV Modification of Clause 2 to add the following: 24
3 Terms and definitions 25
3.1 Definitions relating to ratings, voltages, currents, frequencies, and wattages 26
3.1.5DV Modification of Clause 3.1.5 NOTE 2 as follows: 27
3.1.6DV Modification of 3.1.6 to add the following NOTE: 27
3.2 Definitions of types of control according to purpose 28
3.3 Definitions relating to the function of controls 30
3.4 Definitions relating to disconnection and interruption 34
3.4.5DV Modification of Clause 3.4.5 definition as follows: 34
3.5 Definitions of types of control according to construction 35
3.5.3DV Modification of Clause 3.5.3 NOTE 1 as follows: 35
3.6 Definitions of type of automatic action of a control 36
3.7 Definitions relating to protection against electric shock and type of insulation 37
3.7.4DV Modification of Clause 3.7.4 by adding the following text after NOTE 1: 37
3.7.9DV Modification of Clause 3.7.9 as follows: 39
3.7.12.1DV Modification of Clause 3.7.12.1 to replace Note 1 with the following: 40
3.7.21DV Add the following definitions to Clause 3: 41
3.8 Definitions relating to component parts of controls 42
3.9 Definitions of types of terminals and terminations of controls 43
3.10 Definitions relating to the connections to controls 45
3.11 Definitions relating to the performance of type 2 actions 46
3.12 Definitions relating to the requirements for creepage distances and clearances 47
3.13 Miscellaneous definitions 47
3.14 Definitions relating to manufacturer and user 49
3.14.2DV Modification of Clause 3.14.2 to add the following NOTE: 49
3.15 Definitions pertaining to thermistors 50
3.16 Definitions relating to the structure of controls using software 50
3.17 Definitions relating to error avoidance in controls using software 50
3.18 Definitions relating to fault/error control techniques for controls using software 50
3.19 Definitions relating to memory tests for controls using software 50
3.20 Definitions of software terminology – General 50
3.21 Definitions relating to classes of control functions 50
3.22 Definitions relating to functional safety 50
3.23 Definitions related to access to data exchange 50
3.24 Definitions related to EMC performance 50
4 General 53
4.1 General structure of the document 53
4.2 General requirements 55
4.2DV Modification of Clause 4.2 by adding the following after "the appropriate part 2, if any.": 55
4.3 General notes on tests 55
5 Required technical information 59
5.1 General requirements 59
5.2 Methods of providing technical information 59

ULSE INC. COPYRIGHTED MATERIAL – NOT AUTHORIZED FOR FURTHER REPRODUCTION OR DISTRIBUTION WITHOUT PERMISSION FROM ULSE INC.

5.2.10DV.1 Modification of Clause 5.2.10 by adding the following to the list of symbols:.....61
5.2.10DV.2 Modification of Clause 5.2.10 by adding the following paragraphs:.....61
Table 1DV.1 Modification of Table 1 as follows:.....67
5.3 Class II symbol.....68
5.4 Additional requirements for marking.....69
5.5 Warning or cautionary markings.....71
6 Protection against electric shock.....71
6.1 General requirements.....71
6.1.2DV Modification of Clause 6.1.2 to add the following:.....72
6.1.8DV Modification of Clause 6.1.8 to add the following:.....73
6.2 Actuating members and actuating means.....74
6.3 Capacitors.....74
6.4 Covers and uninsulated live or hazardous parts.....75
6.4DV Modification of Clause 6.4 to add the following NOTES:.....75
6.5 Battery operated controls provided with a user accessible mains supply input connector.....75
7 Provision for protective earthing.....75
7.1 Class 0I and Class I controls.....75
7.1.1DV.1 Modification of Clause 7.1.1 to add the following:.....76
7.1.1DV.2 Modification of Clause 7.1.1 to add paragraphs 7.1.1DV.2.1 – 7.1.1DV.2.3 as follows:.....76
7.1.2DV Modification of Clause 7.1.2 to add the following:.....76
7.2 Class II and class III controls.....76
7.3 Adequacy of earth connections.....77
7.4 Corrosion resistance.....81
7.5 Other requirements.....81
7.6 Protective equipotential bonding.....82
8 Terminals and terminations.....82
8.1 Terminals and terminations for external copper conductors.....82
8.1.1DV Modification of Clause 8.1.1 to add paragraphs 8.1.1DV.1 and 8.1.1DV.2 as follows:.....82
Table 2DV Modification of Table 2 to replace with the following text:.....84
8.1.9DV Modification of Clause 8.1.9 item (a) to replace with the following:.....85
8.1.15DV.1 Modification of Clause 8.1.15 to add a NOTE 1DV and 8.1.15DV.1.1 as follows:.....87
8.1.16DV Modification of Clause 8.1.16 to add 8.1.16DV.1 and 8.1.16DV.2 as follows:.....87
8.2 Terminals and terminations for internal conductors.....88
8.3 Terminals and terminations for integrated conductors.....90
9 Constructional requirements.....90
9.1 Materials.....90
9.2 Protection against electric shock.....91
9.3 Actuation and operation.....94
9.4 Actions.....98
9.5 Openings in enclosures.....101
9.5DV Modification of Clause 9.5 to add 9.5DV.1 to 9.5DV.3 as follows:.....101
9.6 Mounting of controls.....101
9.7 Attachment of cords.....102
9.8 Size of cords – non-detachable.....104
9.8.2DV Modification of Clause 9.8.2 to add the following:.....104
9.9 Inlet openings.....105
9.9DV Modification of Clause 9.9 to add Clause 9.9DV.1 as follows:.....105
9.9.5DV Modification of Clause 9.9.5 to add the following:.....106
9.9.6DV.1 Modification of Clause 9.9.6 as follows:.....106
9.9.6DV.2 Modification of Clause 9.9.6 to add the following:.....106
9.10 Equipment inlets and socket-outlets.....106
9.10.3DV Modification of Clause 9.10.3 to add the following:.....107

ULSE INC. COPYRIGHTED MATERIAL – NOT AUTHORIZED FOR FURTHER REPRODUCTION OR DISTRIBUTION WITHOUT PERMISSION FROM ULSE INC.

9.11 Requirements during mounting, use, maintenance and servicing 107
9.12 Controls using software 111
9.13 Protective controls and components of protective control systems 114
10 Threaded parts and connections 117
10.1 Threaded parts moved during mounting or servicing 117
10.1.10DV Modification of Clause 10.1.10 to add the following: 118
10.2 Current-carrying connections and connections providing protective earthing continuity 119
10.2.4DV Modification of Clause 10.2.4 to add the following NOTE: 120
10.2.5DV Modification of Clause 10.2.5 to add the following NOTE: 120
11 Creepage distances, clearances and distances through solid insulation 120
11.1 General 120
11.2 Clearances 121
11.2.9DV Modification of Clause 11.2.9 to add the following: 124
11.3 Creepage distances 126
11.3.1DV Modification of Clause 11.3.1 to replace second, third and fourth paragraphs with the following: 126
11.4 Solid insulation 129
11.4.5DV Modification of Clause 11.4.5 by replacing the second paragraph with the following: 130
12 Components 130
12.1 Transformers 130
12.1.1DV Modification of Clause 12.1.1 by adding the following: 130
12.2 Switch mode power supplies and converters 130
12.3 Capacitors 131
12.4 Fuses 131
12.4DV Modification of Clause 12.4 by adding the following: 132
12.5 Varistors 132
12.5.2DV Modification of Clause 12.5.2 by adding the following: 132
12.6 Thermistors 132
12.7 Relays 132
12.8 Other components 132
12.8.2DV Modification of Clause 12.8.2 by adding 12.8.2DV.1 as follows: 133
13 Fault assessment on electronic circuits 133
13.1 Fault assessment for inherent safety 133
13.2 Fault assessment to ensure functional safety 141
14 Moisture and dust resistance 141
14.1 Protection against ingress of water and dust 141
14.1.1DV Modification of Clause 14.1.1 by adding the following: 141
14.1.6DV.1 Modification of Clause 14.1.6 by adding the following: 141
14.1.6DV.2 Modification of Clause 14.1.6 to add the following: 142
14.2 Protection against humid conditions 143
14.3 Touch current test for in-line cord controls and free-standing controls 143
15 Electric strength and insulation resistance 145
15.1 Insulation resistance 145
15.2 Electric strength 145
15.3 Additional tests for in-line cord and free-standing controls 147
15.3.5DV Modification of Clause 15.3.5 to add the following NOTE: 148
16 Heating 148
Table 17DV Modification of Table 17 to replace with the following: 153
17 Manufacturing deviation and drift 157
17DV Modification of Clause 17 to add the following NOTE: 157
18 Environmental stress 157
18.1 Transportation and storage 157
18.2 Environmental stress of temperature 157
19 Endurance 157

ULSE INC. COPYRIGHTED MATERIAL – NOT AUTHORIZED FOR FURTHER REPRODUCTION OR DISTRIBUTION WITHOUT PERMISSION FROM ULSE INC.

19.1 General requirements 157
19.2 Electrical conditions for the tests 159
Table 19DV Modification of Table 19 to add the following: 164
Table 20DV Modification of Table 20 to add the following: 167
19.3 Thermal conditions for the tests 169
19.3.2DV Modification of Clause 19.3.2 by adding the following: 169
19.4 Manual and mechanical conditions for the tests 169
19.5 Dielectric strength requirements 170
19.5DV Modification of Clause 19.5 to replace the last sentence as follows: 170
19.6 Ageing test 170
19.7 Overvoltage test or overload test in all countries using an overload test of automatic action at accelerated rate 171
19.7.6DV Modification of Clause 19.7.6 to replace with the following: 171
19.8 Test of automatic action at accelerated rate 171
19.8.4DV Modification of Clause 19.8.4 to replace the last paragraph with the following: 172
19.9 Test of automatic action at slow rate 172
19.10 Overvoltage test or overload test in all countries that use the overload test of manual action at accelerated speed 172
19.10.3DV Modification of Clause 19.10.3 second sentence as follows: 172
19.11 Test of manual action at slow speed 173
19.11.4DV Modification of Clause 19.11.4 by adding the following: 173
19.12 Test of manual action at high speed which has multiple poles, and where polarity reversal occurs during the action 173
19.12.4DV Modification of Clause 19.12.4 by replacing the first sentence with the following: 173
19.13 Test of manual action at accelerated speed 173
19.14 Evaluation of compliance 174
19.14.2DV Modification of Clause 19.14.2 to add the following dashed item: 174
19.15 Test for particular purpose controls 174
19.18DV Add the following section titled, "Electronic Ballasts, CFLs and LED driver rated controls" 175
20 Mechanical strength 178
20.1 General requirements 178
20.1.5DV Modification of Clause 20.1.5 to add 20.1.5DV.1 – 20.1.5DV.4 and Table 20.1.5DV.1 as follows: 179
20.2 Impact resistance 180
20.2.1DV Modification of Clause 20.2.1 by adding the following: 180
20.2.7DV Modification of Clause 20.2 to add the following new clause: 180
20.3 Free-standing controls 183
20.4 In-line cord controls 183
20.5 Pull-cord actuated controls 184
20.6 Foot actuated controls 184
20.7 Actuating member and actuating means 185
20.7.4DV Modification of Clause 20.7 to add 20.7.4DV.1 – 20.7.4DV.7 as follows: 185
20.8 Flexing – test 186
20.9 Cord anchorages – test 186
20.9.3DV Modification of Clause 20.9.3 to replace with the following: 187
20.9.4DV Modification of Clause 20.9.4 to add the following: 187
21 Resistance to heat, fire and tracking 188
21.1 General requirements 188
21.1DV Modification of Clause 21.1 by replacing the last sentence with the following and adding 21.1DV.1 and 21.1DV.2: 188
21.2 Integrated, incorporated and in-line cord controls 188
21.3 Independently mounted, free-standing controls 190
21.3.4DV Modification of Clause 21.3 to add the following: 190
22 Resistance to corrosion 191

ULSE INC. COPYRIGHTED MATERIAL – NOT AUTHORIZED FOR FURTHER REPRODUCTION OR DISTRIBUTION WITHOUT PERMISSION FROM ULSE INC.

22.1 Resistance to rusting 191
23 Electromagnetic compatibility (EMC) requirements – Emission 191
23.1 General requirement 191
23.1DV Modification of Clause 23.1 to add the following: 191
23.2 High frequency emission 192
23.3 Low frequency emission 196
24 Normal operation 196
24.1 Output waveform of electronic controls 196
24.2 Operation within the voltage range 196
25 Electromagnetic compatibility (EMC) requirements – Immunity 196
25.1 General 196
25.1DV Modification of Clause 25.1 to add the following NOTE: 197
25.2 EMC test plan and report 197
25.3 Immunity requirements 199
25.4 Performance criteria 202
25.5 Surge immunity test 203
25.6 Electrical fast transient immunity test 203
25.7 Radio-frequency electromagnetic field immunity 204
25.8 Electrostatic discharge 204
25.9 Immunity to power-frequency magnetic fields 204
25.10 Test of the influence of voltage dips and voltage interruption in the power supply network 204
26 Abnormal operation tests 205
26.1 Abnormal temperature test 205
26.2 Overload tests 206
26.3 Battery short-circuit test 207
Figure 5DV Modification of Figure 5 to replace with the following: 210

Annex A (normative) Indelibility of markings

A.1 Requirements for indelibility 231
A.2 Test procedure for markings classified to A.1.3 232
A.3 Test procedure for markings classified to A.1.4 232

Annex B (normative) Measurement of creepage distances and clearances in air

Annex C (informative) Nominal voltages of supply systems for different modes of overvoltage control

Annex D (normative) Overvoltage categories

Annex E (informative) Typical usage of controls and related overvoltage categories

Annex F (normative) Pollution degrees

F.1 Pollution 245
F.2 Degrees of pollution in the micro-environment 245

Annex G (normative) Resistance to heat, fire and tracking tests

ULSE INC. COPYRIGHTED MATERIAL – NOT AUTHORIZED FOR FURTHER REPRODUCTION OR DISTRIBUTION WITHOUT PERMISSION FROM ULSE INC.

G.1 Glow-wire test 246
G.2 Proof tracking test 246
G.3 Ball pressure test 246
G.3.1 Ball pressure tests 246
G.3.2 Ball pressure test 1 246
G.3.3 Ball pressure test 2 246

Annex H (normative) Requirements related to functional safety

H.3 Terms and definitions 248
H.3.16 Definitions relating to the structure of controls using software 248
H.3.17 Definitions relating to error avoidance in controls using software 248
H.3.18 Definitions relating to fault/error control techniques for controls using software 250
H.3.19 Definitions relating to memory tests for controls using software 253
H.3.20 Definitions of software terminology – General 255
H.3.21 Definitions relating to classes of control functions 256
H.3.22 Definitions relating to functional safety 256
H.3.23 Definitions related to access to data exchange 258
H.5 Information 259
H.9 Constructional requirements 260
H.9.12 Controls using software 260
H.13 Fault assessment on electronic circuits 279
H.13.2 Fault assessment to ensure functional safety 279
H.17 Manufacturing deviation and drift 283
H.17.7 Calibration tests for PTC thermistors 284
H.17.8 Calibration tests for NTC thermistors 284
H.19 Endurance 285
H.19.1 General requirements 285
H.25 Electromagnetic compatibility (EMC) requirements – Immunity 285
H.25.1 General requirements 285
H.25.2 Particular requirements for integrated and incorporated controls with type 2 action 286
H.25.3 Sample requirement 286
H.25.4 Harmonics and interharmonics including mains signalling at AC power port, low frequency immunity tests 287
H.25.5 Voltage dips, voltage interruptions and voltage variations in the power supply network 287
H.25.6 Test of influence of voltage unbalance 289
H.25.7 Test of the influence of DC in AC networks 290
H.25.8 Surge immunity test 290
H.25.9 Electrical fast transient/burst immunity test 292
H.25.10 Electrostatic discharge test 293
H.25.11 Radio-frequency electromagnetic field immunity 293
H.25.12 Test of influence of supply frequency variations 296
H.25.13 Power frequency magnetic field immunity test 296
H.25.14 Evaluation of compliance 297

Annex I (normative) Requirements for certain types of DC supplied controls

I.2 Scope 298
I.25.8 Surge immunity tests 298
I.25.9 Electrical fast transient/burst 298
I.25.11.2 Immunity to conducted disturbances 298
I.25.12 Supply frequency variations 299

Annex J (normative) Requirements for thermistor elements and controls using thermistors

ULSE INC. COPYRIGHTED MATERIAL – NOT AUTHORIZED FOR FURTHER REPRODUCTION OR DISTRIBUTION WITHOUT PERMISSION FROM ULSE INC.

J.1 Scope 300
J.3 Terms and definitions 300
J.3.15 Definitions pertaining to thermistors 300
J.4 General 304
J.4.3 General notes on tests 304
J.5 Information 306
J.9 Constructional requirements 306
J.12 Components 306
J.12.8.2DV Modification of Clause J.12.8.2 to replace with the following: 307
J.15 Electric strength and insulation resistance 307
J.15.2 Electric strength 307
J.17 Manufacturing deviation and drift 307
J.17.1 Calibration tests for PTC thermistors 307
J.17.2 Calibration tests for NTC thermistors 309
J.19 Endurance 311
J.19.17 Conditioning tests 312

Annex K (normative) Circuit for measuring touch current

Annex L (normative) Printed circuit board coating performance test

Annex L Modification of Annex L as follows: 318

Annex M (normative) Printed circuit board protection

Annex N (informative) Explanatory notes for surge immunity test

N.1 Different source impedances 323
N.2 Application of the tests 323
N.2.1 General 323
N.2.2 Equipment level immunity 323
N.2.3 System level immunity 323
N.3 Installation classification 324
N.3.1 General 324
N.3.2 Equipment level immunity of ports connected to the power supply network 325
N.3.3 Equipment level immunity of ports connected to interconnection lines 325

Annex O (informative) Guidance for applying Clause 11

Annex P (normative) Requirements for SELV and PELV

P.1 Overview of the requirements for SELV and PELV 330
P.1.1 Protection by SELV 330
P.1.2 Protection by PELV 330
P.2 Protection against electric shock by SELV system or PELV system 330
P.2.1 SELV system 330
P.2.2 PELV system 331
P.3 Protective measures for SELV system and PELV system 331
P.3.1 Limitation of voltage 331
P.3.2 Protective separation 331
P.3.3 Protective screening 332

ULSE INC. COPYRIGHTED MATERIAL – NOT AUTHORIZED FOR FURTHER REPRODUCTION OR DISTRIBUTION WITHOUT PERMISSION FROM ULSE INC.

P.3.4 Simple-separation 332
P.3.5 Functional earthing 332

Annex Q (informative) Regional differences relevant for the member countries of Cenelec

Q.3.7.3 Class 0 control (see 3.7.3) 333
Q.3.7.4 Class II control (see 3.7.4) 333
Q.3.7.6.3 Class II control (see 3.7.6.3) 333
Q.4.2 General requirements (see 4.2) 333
Q.4.3.4.3 According to protection against electric shock (see 4.3.4.3.1) 333
Q.5.4.2 Marking of terminals for external connections (see 5.4.2) 333
Q.7.5.2 Incorporated control (see 7.5.2) 334
Q.15.2 Electric strength (see 15.2, Table 16) 334
Q.16 Heating (see Clause 16) 334
Q.19.7 Overvoltage test or overload test in all countries using an overload test of automatic action at accelerated rate (see 19.7) 335
Q.19.10 Overvoltage test or overload test in all countries using an overload test of automatic action at accelerated rate (see 19.10) 335
Q.25 Electromagnetic compatibility (EMC) requirements – Immunity (see Clause 25) 335
Q.25.1 General 335
Q.30 – Annex ZB (normative) – Special national conditions 335
Q.31 – Annex ZC (informative) – A-deviations 336

Annex R (informative) National differences relevant in the United States of America

R.2 Normative references 338
R30DV Addition to Annex R to add the following: 338

Annex S (informative) National differences relevant in Japan

S.2 Normative references 351

Annex T (informative) National differences relevant in Canada

T.2 Normative references 352

Bibliography

ULSE INC. COPYRIGHTED MATERIAL – NOT AUTHORIZED FOR FURTHER REPRODUCTION OR DISTRIBUTION WITHOUT PERMISSION FROM ULSE INC.

Preface

This UL Standard is based on IEC Publication 60730-1: sixth edition, Automatic electrical controls – Part 1: General requirements. IEC publication 60730-1 is copyrighted by the IEC.

^^This edition has been issued to satisfy ULSE Standards policy [or state other reason, including an administrative new edition, or out of necessity to incorporate extensive revisions].

This is the UL Standard for Automatic electrical controls – Part 1: General requirements. This UL Part 1 is to be used in conjunction with the appropriate UL Part 2's , which contains clauses to supplement or modify the corresponding clauses in the Part 1, to provide relevant requirements for each type of product.

These materials are subject to copyright claims of IEC and UL. No part of this publication may be reproduced in any form, including an electronic retrieval system, without the prior written permission of ULSE. All requests pertaining to the Automatic electrical controls – Part 1: General requirements, UL 60730-1 Standard should be submitted to ULSE.

Note – Although the intended primary application of this Standard is stated in its Scope, it is important to note that it remains the responsibility of the users of the Standard to judge its suitability for their particular purpose.

ULSE INC. COPYRIGHTED MATERIAL – NOT AUTHORIZED FOR FURTHER REPRODUCTION OR DISTRIBUTION WITHOUT PERMISSION FROM ULSE INC.

No Text on This Page

ULSE INC. COPYRIGHTED MATERIAL – NOT AUTHORIZED FOR FURTHER REPRODUCTION OR DISTRIBUTION WITHOUT PERMISSION FROM ULSE INC.

NATIONAL DIFFERENCES

National Differences from the text of International Electrotechnical Commission (IEC) Publication 60730-1, Automatic Electrical Controls, Part 1: General Requirements, copyright 2022 are indicated by notations (differences) and are presented in bold text.

There are five types of National Differences as noted below. The difference type is noted on the first line of the National Difference in the standard. The standard may not include all types of these National Differences.

DR – These are National Differences based on the **national regulatory requirements**.

D1 – These are National Differences which are based on **basic safety principles and requirements**, elimination of which would compromise safety for consumers and users of products.

D2 – These are National Differences from IEC requirements based on existing **safety practices**. These requirements reflect national safety practices, where empirical substantiation (for the IEC or national requirement) is not available or the text has not been included in the IEC standard.

DC – These are National Differences based on the **component standards** and will not be deleted until a particular component standard is harmonized with the IEC component standard.

DE – These are National Differences based on **editorial comments or corrections**.

Each national difference contains a description of what the national difference entails. Typically one of the following words is used to explain how the text of the national difference is to be applied to the base IEC text:

Addition / Add - An addition entails adding a complete new numbered clause, subclause, table, figure, or annex. Addition is not meant to include adding select words to the base IEC text.

Modification / Modify - A modification is an altering of the existing base IEC text such as the addition, replacement or deletion of certain words or the replacement of an entire clause, subclause, table, figure, or annex of the base IEC text.

Deletion / Delete - A deletion entails complete deletion of an entire numbered clause, subclause, table, figure, or annex without any replacement text.

ULSE INC. COPYRIGHTED MATERIAL – NOT AUTHORIZED FOR FURTHER REPRODUCTION OR DISTRIBUTION WITHOUT PERMISSION FROM ULSE INC.

No Text on This Page

ULSE INC. COPYRIGHTED MATERIAL – NOT AUTHORIZED FOR FURTHER REPRODUCTION OR DISTRIBUTION WITHOUT PERMISSION FROM ULSE INC.

FOREWORD

INTERNATIONAL ELECTROTECHNICAL COMMISSION

AUTOMATIC ELECTRICAL CONTROLS – Part 1: General requirements

1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as “IEC Publication(s)”). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.

2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.

3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.

4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.

5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.

6) All users should ensure that they have the latest edition of this publication.

7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.

8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.

9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

IEC 60730-1 has been prepared by IEC technical committee 72: Automatic electrical controls. It is an International Standard.

This sixth edition cancels and replaces the fifth edition published in 2013, Amendment 1:2015 and Amendment 2:2020. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

a) Structure of the main clauses — The clauses of the standard are grouped into two sections of requirements, where

• the first section consists of the Clauses 5 to 13 that, in general, addresses the construction of the product. It is noted that certain construction requirements may have verification requirements integrated within the clause to facilitate usage of the standard, and

ULSE INC. COPYRIGHTED MATERIAL – NOT AUTHORIZED FOR FURTHER REPRODUCTION OR DISTRIBUTION WITHOUT PERMISSION FROM ULSE INC.

	• the second section consists of Clauses 14 to 26 that addresses the verification requirements;
b) Scope	Relocated and deleted clauses to better reflect the products covered under the part 1 and for easier reading;
c) Normative references	Updated references;
d) Terms and definitions	Revised text in certain clauses and relocated relevant Clause H.3 subclauses into Clause 3;
e) General requirements	General structure of the standard explained along with a figure to depict the intent;
f) General notes on tests	Reduced sample size from 3 to 1, yet requiring analysis; order of tests more flexible; relocation of battery requirements from Annex V;
g) Rating	Deleted – covered under the scope;
h) Classification	Deleted – covered under information;
i) Information	Updated Table 1 to reflect entries from the classification clause, and all cross-references;
j) Protection against electric shock	Revised Clause 8 to include Clause H.8 and Clause V.8 subclauses, revised clauses as appropriate to distinguish between a live part and a hazardous live part;
k) Provision for protective earthing	
l) Construction requirements	One Y1 capacitor allowed; relocated relevant requirements of Clause H.11 and Clause V.11 into Subclause 9.2.5 and Subclause 9.13.4.4 respectively;
m) Moisture and dust	Relocated IP table from classification to Clause 14; updated references;
n) Manufacturing deviation and drift	All clauses moved to Annex H since the requirements pertain to functional safety of controls;
o) EMC-Emissions	Moved Clause H.23 into Clause 23;
p) EMC-Immunity	New EMC requirements (performance) for all controls except incorporated/integrated controls with Class A control functions. Products intended for HBES/BACS are also subjected to these requirements;
q) Fault assessment on electronic circuits	Fault assessment moved from Annex H to Clause 13; deleted test abnormal voltage for electronic disconnection;
r) Annex H	Relocated all relevant requirements for electronics to the respective clauses within the body of the standard and retained requirements related to functional safety in this annex;
s) Annex T	Revised clauses for clarity in Annex P;
t) Annex U	Removed, the necessity of the annex was not seen anymore;
u) Annex V	Included in the main part of the standard.

The text of this International Standard is based on the following documents:

Draft	Report on voting
72/1307/FDIS	72/1320/RVD

ULSE INC. COPYRIGHTED MATERIAL – NOT AUTHORIZED FOR FURTHER REPRODUCTION OR DISTRIBUTION WITHOUT PERMISSION FROM ULSE INC.

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

The language used for the development of this International Standard is English.

This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available at www.iec.ch/members_experts/refdocs. The main document types developed by IEC are described in greater detail at https//www.iec.ch/publications.

A list of all parts of the IEC 60730 series, under the general title: *Automatic electrical controls*, can be found on the IEC website.

In the development of a fully international standard to cover automatic electrical controls, it has been necessary to take into consideration the differing requirements resulting from practical experience in various parts of the world and to recognize the variation in national electrical systems and wiring rules.

The "in some countries" clauses have been moved to the regional respectively national differences in Annex Q to Annex T.

It is envisaged that in the next edition of this document, it will be found possible to remove those differences that are covered by new IEC standards now being prepared by other technical committees.

This part 1 is to be used in conjunction with the appropriate part 2 for a particular type of control, or for controls for particular applications. This part 1 may also be applied, so far as reasonable, to controls not mentioned in a part 2, and to controls designed on new principles, in which cases additional requirements may be considered to be necessary.

Where, for a particular clause or subclause, the text of part 2 indicates:

Addition:	the part 1 text applies with the additional requirement indicated in a part 2;
Modification:	the part 1 text applies with a minor change as indicated in a part 2;
Replacement:	the part 2 text contains a change which replaces the part 1 text in its entirety.

Where no change is necessary, the part 2 indicates that the relevant clause or subclause applies.

NOTE In this document the following print types are used:

– Requirements proper: in roman type;

– *Test specifications: in italic type;*

– Explanatory matter: in smaller roman type;

– Defined terms: **bold type**.

The committee has decided that the contents of the base publication and its amendment will remain unchanged until the stability date indicated on the IEC web site under "http://webstore.iec.ch" in the data related to the specific publication. At this date, the publication will be

ULSE INC. COPYRIGHTED MATERIAL – NOT AUTHORIZED FOR FURTHER REPRODUCTION OR DISTRIBUTION WITHOUT PERMISSION FROM ULSE INC.

• reconfirmed,

• withdrawn,

• replaced by a revised edition, or

• amended.

IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

DV.1 ***Modification to the Notes:***

– Words in SMALL ROMAN CAPITALS in the text are defined in Clause 3.

DV.2 ***Addition:***

The numbering system in the standard uses a space instead of a comma to indicate thousands and uses a comma instead of a period to indicate a decimal point. For example, 1 000 means 1,000 and 1,01 means 1.01.

ULSE INC. COPYRIGHTED MATERIAL – NOT AUTHORIZED FOR FURTHER REPRODUCTION OR DISTRIBUTION WITHOUT PERMISSION FROM ULSE INC.

AUTOMATIC ELECTRICAL CONTROLS – Part 1: General requirements

1 Scope

This document applies to automatic electrical controls

• for use in, on, or in association with equipment for household appliance and similar use;

NOTE 1 Throughout this document, the word "equipment" means "appliance and equipment".

• for building automation within the scope of ISO 16484 series and IEC 63044 series (HBES/BACS);

EXAMPLE 1 Independently mounted water valves, controls in smart grid systems and controls for building automation systems within the scope of ISO 16484–2.

• for equipment that is used by the public, such as equipment intended to be used in shops, offices, hospitals, farms and commercial and industrial applications;

EXAMPLE 2 Controls for commercial catering, heating and air-conditioning equipment.

• that are SMART ENABLED CONTROLS;

EXAMPLE 3 Smart grid control, remote interfaces/control of energy-consuming equipment including computer or smart phone.

• that are AC or DC powered controls with a rated voltage not exceeding 690 V AC or 600 V DC where the DC source is provided by primary or secondary batteries;

• used in, on, or in association with equipment that use electricity, gas, oil, solid fuel, solar thermal energy, etc., or a combination thereof;

• utilized as part of a control system or controls which are mechanically integral with multifunctional controls having non-electrical outputs;

• using NTC or PTC THERMISTORS and to discrete THERMISTORS, requirements for which are contained in Annex J;

• that are mechanically or electrically operated, responsive to or controlling such characteristics as temperature, pressure, passage of time, humidity, light, electrostatic effects, flow, or liquid level, current, voltage, acceleration, or combinations thereof;

• as well as manual controls when such are electrically and/or mechanically integral with automatic controls.

NOTE 2 Requirements for manually actuated mechanical switches not forming part of an automatic control are contained in IEC 61058-1-1.

This document applies to

– the inherent safety of automatic electrical controls, and

– functional safety of automatic electrical controls and safety related systems,

ULSE INC. COPYRIGHTED MATERIAL – NOT AUTHORIZED FOR FURTHER REPRODUCTION OR DISTRIBUTION WITHOUT PERMISSION FROM ULSE INC.

– controls where the performance (for example the effect of EMC phenomena) of the product can impair the overall safety and performance of the controlled system,

– the operating values, operating times, and operating sequences where such are associated with equipment safety.

This document specifies the requirements for construction, operation and testing of automatic electrical controls used in, on, or in association with an equipment.

This document does not

• apply to automatic ELECTRONIC CONTROLS intended exclusively for industrial process applications unless explicitly mentioned in the relevant part 2 or the equipment standard. However, this document can be applied to evaluate automatic electrical controls intended specifically for industrial applications in cases where no relevant safety standard exists.

• take into account the response value of an automatic action of a control, if such a response value is dependent upon the method of mounting the control in the equipment. Where a response value is of significant purpose for the protection of the user, or surroundings, the value defined in the appropriate equipment standard or as determined by the manufacturer will apply.

• address the integrity of the output signal to the network devices, such as interoperability with other devices unless it has been evaluated as part of the control system.

1DV.1 D2 ***Modification of Clause 1 by adding the following text:***

CONTROLS intended to be installed in air handling spaces or in other environmental air space (plenums) are covered under the scope of this standard.

CONTROLS intended to manage (monitor and/or control) energy consumption of components/systems (load management) or power sources are covered under the scope of this standard.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60038, *IEC standard voltages*

IEC 60065:2014, *Audio, video and similar electronic apparatus – Safety requirements*

IEC 60068-2-75, *Environmental testing – Part 2-75: Tests – Test Eh: Hammer tests*

IEC 60085, *Electrical insulation – Thermal evaluation and designation*

IEC 60099-1:1991, *Surge arresters – Part 1: Non-linear resistor type gapped surge arresters for a.c. systems*[1]

[1] Withdrawn.

ULSE INC. COPYRIGHTED MATERIAL – NOT AUTHORIZED FOR FURTHER REPRODUCTION OR DISTRIBUTION WITHOUT PERMISSION FROM ULSE INC.

IEC 60112:2020, *Method for the determination of the proof and the comparative tracking indices of solid insulating materials*

IEC 60127 (all parts), *Miniature fuses*

IEC 60227-1, *Polyvinyl chloride insulated cables of rated voltages up to and including 450/750 V – Part 1: General requirements*

IEC 60245-1, *Rubber insulated cables – Rated voltages up to and including 450/750 V – Part 1: General requirements*

IEC 60269 (all parts), *Low-voltage fuses*

IEC 60335-1:2020, *Household and similar electrical appliances – Safety – Part 1: General requirements*

IEC 60384-14, *Fixed capacitors for use in electronic equipment – Part 14: Sectional specification – Fixed capacitors for electromagnetic interference suppression and connection to the supply mains*

IEC 60384-16, *Fixed capacitors for use in electronic equipment – Part 16: Sectional specification – Fixed metallized polypropylene film dielectric DC capacitors*

IEC 60384-17, *Fixed capacitors for use in electronic equipment – Part 17: Sectional specification – Fixed metallized polypropylene film dielectric AC and pulse capacitors*

IEC 60417, *Graphical symbols for use on equipment*

IEC 60423, *Conduit systems for cable management – Outside diameters of conduits for electrical installations and threads for conduits and fittings*

IEC 60529:1989, *Degrees of protection provided by enclosures (IP code)*
IEC 60529:1989/AMD1:1999
IEC 60529:1989/AMD2:2013

IEC 60539 (all parts), *Directly heated negative temperature coefficient thermistors*

IEC 60664-1:2007[2], *Insulation coordination for equipment within low-voltage systems – Part 1: Principles, requirements and tests*

[2] Withdrawn.

IEC TR 60664-2 (all parts), *Insulation coordination for equipment within low-voltage systems*

IEC 60664-3:2016, *Insulation coordination for equipment within low-voltage systems – Part 3: Use of coating, potting or moulding for protection against pollution*

IEC 60664-4, *Insulation coordination for equipment within low-voltage systems – Part 4: Consideration of high-frequency voltage stress*

IEC 60695-2-10, *Fire hazard testing – Part 2-10: Glowing/hot-wire based test methods – Glow-wire apparatus and common test procedure*

ULSE INC. COPYRIGHTED MATERIAL – NOT AUTHORIZED FOR FURTHER REPRODUCTION OR DISTRIBUTION WITHOUT PERMISSION FROM ULSE INC.

IEC 60695-2-11:2021, *Fire hazard testing – Part 2-11: Glowing/hot-wire based test methods – Glow-wire flammability test method for end-products (GWEPT)*

IEC 60695-10-2, *Fire hazard testing – Part 10-2: Abnormal heat – Ball pressure test method*

IEC 60738 (all parts), *Thermistors – Directly heated positive temperature coefficient*

IEC 60747-5-5, *Semiconductor devices – Part 5-5: Optoelectronic devices – Photocouplers*

IEC 60884-1, *Plugs and socket-outlets for household and similar purposes – Part 1: General requirements*

IEC 60884-2-5:2017, *Plugs and socket-outlets for household and similar purposes – Part 2-5: Particular requirements for adaptors*

IEC 60998-2-2, *Connecting devices for low-voltage circuits for household and similar purposes – Part 2-2: Particular requirements for connecting devices as separate entities with screwless-type clamping units*

IEC 60998-2-3, *Connecting devices for low-voltage circuits for household and similar purposes – Part 2-3: Particular requirements for connecting devices as separate entities with insulation-piercing clamping units*

IEC 60999-1, *Connecting devices – Electrical copper conductors – Safety requirements for screw-type and screwless-type clamping units – Part 1: General requirements and particular requirements for clamping units for conductors from 0,2 mm^2 up to 35 mm^2 (included)*

IEC 61000-3-2, *Electromagnetic compatibility (EMC) – Part 3-2: Limits – Limits for harmonic current emissions (equipment input current ≤ 16 A per phase)*

IEC 61000-3-3, *Electromagnetic compatibility (EMC) – Part 3-3: Limits – Limitation of voltage changes, voltage fluctuations and flicker in public low-voltage supply systems, for equipment with rated current ≤16 A per phase and not subject to conditional connection*

IEC 61000-3-11, *Electromagnetic compatibility (EMC) – Part 3-11: Limits – Limitation of voltage changes, voltage fluctuations and flicker in public low-voltage supply systems – Equipment with rated current ≤ 75 A and subject to conditional connection*

IEC 61000-3-12, *Electromagnetic compatibility (EMC) – Part 3-12: Limits – Limits for harmonic currents produced by equipment connected to public low-voltage systems with input current >16 A and ≤ 75 A per phase*

IEC 61000-4-2:2008, *Electromagnetic compatibility (EMC) – Part 4-2: Testing and measurement techniques – Electrostatic discharge immunity test*

IEC 61000-4-3, *Electromagnetic compatibility (EMC) – Part 4-3: Testing and measurement techniques – Radiated, radio-frequency, electromagnetic field immunity test*

IEC 61000-4-4, *Electromagnetic compatibility (EMC) – Part 4-4: Testing and measurement techniques – Electrical fast transient/burst immunity test*

IEC 61000-4-5:2014, *Electromagnetic compatibility (EMC) – Part 4-5: Testing and measurement techniques – Surge immunity test*
IEC 61000-4-5:2014/AMD1:2017

ULSE INC. COPYRIGHTED MATERIAL – NOT AUTHORIZED FOR FURTHER REPRODUCTION OR DISTRIBUTION WITHOUT PERMISSION FROM ULSE INC.

IEC 61000-4-6, *Electromagnetic compatibility (EMC) – Part 4-6: Testing and measurement techniques – Immunity to conducted disturbances, induced by radio-frequency fields*

IEC 61000-4-8, *Electromagnetic compatibility (EMC) – Part 4-8: Testing and measurement techniques – Power frequency magnetic field immunity test*

IEC 61000-4-11, *Electromagnetic compatibility (EMC) – Part 4-11: Testing and measurement techniques – Voltage dips, short interruptions and voltage variations immunity tests for equipment with current up to 16 A per phase*

IEC 61000-4-13:2002, *Electromagnetic compatibility (EMC) – Part 4-13: Testing and measurement techniques – Harmonics and interharmonics including mains signalling at a.c. power port, low frequency immunity tests*
IEC 61000-4-13:2002 /AMD1:2009
IEC 61000-4-13:2002 /AMD2:2015

IEC 61000-4-20, *Electromagnetic compatibility (EMC) – Part 4-20: Testing and measurement techniques – Emission and immunity testing in transverse electromagnetic (TEM) waveguides*

IEC 61000-4-21, *Electromagnetic compatibility (EMC) – Part 4-21: Testing and measurement techniques – Reverberation chamber test methods*

IEC 61000-4-22, *Electromagnetic compatibility (EMC) – Part 4-22: Testing and measurement techniques – Radiated emissions and immunity measurements in fully anechoic rooms (FARs)*

IEC 61000-4-28, *Electromagnetic compatibility (EMC) – Part 4-28: Testing and measurement techniques – Variation of power frequency, immunity test for equipment with input current not exceeding 16A per phase*

IEC 61000-6-1:2016, *Electromagnetic compatibility (EMC) – Part 6-1: Generic standards – Immunity standard for residential, commercial and light-industrial environments*

IEC 61000-6-2:2016, *Electromagnetic compatibility (EMC) – Part 6-2: Generic standards – Immunity standard for industrial environments*

IEC 61000-6-3:2020, *Electromagnetic compatibility (EMC) – Part 6-3: Generic standards – Emission standard for equipment in residential environments*

IEC 61000-6-4:2018, *Electromagnetic compatibility (EMC) – Part 6-4: Generic standards – Emission standard for industrial environments*

IEC 61051-1, *Varistors for use in electronic equipment – Part 1: Generic specification*

IEC 61051-2, *Varistors for use in electronic equipment – Part 2: Sectional specification for surge suppression varistors*

IEC 61051-2-2, *Varistors for use in electronic equipment – Part 2: Blank detail specification for zinc oxide surge suppression varistors. Assessment level E*

IEC 61210, *Connecting devices – Flat quick-connect terminations for electrical copper conductors – Safety requirements*

IEC 61249 (all parts), *Materials for printed boards and other interconnecting structures*

ULSE INC. COPYRIGHTED MATERIAL – NOT AUTHORIZED FOR FURTHER REPRODUCTION OR DISTRIBUTION WITHOUT PERMISSION FROM ULSE INC.

IEC 61558-2-6, *Safety of transformers, reactors, power supply units and combinations thereof – Part 2-6: Particular requirements and tests for safety isolating transformers and power supply units incorporating safety isolating transformers for general applications*

IEC 61558-2-16, *Safety of transformers, reactors, power supply units and combinations thereof – Part 2-16: Particular requirements and tests for switch mode power supply units and transformers for switch mode power supply units for general applications*

IEC 61810-3, *Electromechanical elementary relays – Part 3: Replays with forcibly guided (mechanically linked) contacts*

IEC 62151, *Safety of equipment electrically connected to a telecommunication network*

IEC 62319 (all parts), *Polymeric thermistors – Directly heated positive step function temperature coefficient*

IEC 62326 (all parts), *Printed boards*

IEC 62368-1, *Audio/video, information and communication technology equipment – Part 1: Safety requirements*

IEC 63044 (all parts), *Home and Building Electronic Systems (HBES) and Building Automation and Control Systems (BACS)*

CISPR 11, *Industrial, scientific and medical equipment – Radio-frequency disturbance characteristics – Limits and methods of measurement*

CISPR 14-1:2020, *Electromagnetic compatibility – Requirements for household appliances, electric tools and similar apparatus – Part 1: Emission*

CISPR 32:2015, *Electromagnetic compatibility of multimedia equipment – Emission requirements*
CISPR 32:2015/AMD1:2019

ISO 4046-4:2016, *Paper, board, pulps and related terms − Vocabulary – Part 4: Paper and board grades and converted products*

ISO 7637-2:2011, *Road vehicles – Electrical disturbances from conduction and coupling – Part 2: Electrical transient conduction along supply lines only*

ISO 7637-3:2016, *Road vehicles – Electrical disturbances from conduction and coupling – Part 3: Electrical transient transmission by capacitive and inductive coupling via lines other than supply lines*

ISO 16484 (all parts), *Building automation and control systems (BACS)*

2DV D2 *Modification of Clause 2 to add the following:*

The following UL Standards are referenced in this Standard:

UL 50, *Enclosures for Electrical Equipment, Non-Environmental Considerations*

UL 50E, *Enclosures for Electrical Equipment, Environmental Considerations*

UL 62, *Flexible Cords and Cables*

ULSE INC. COPYRIGHTED MATERIAL – NOT AUTHORIZED FOR FURTHER REPRODUCTION OR DISTRIBUTION WITHOUT PERMISSION FROM ULSE INC.

UL 94, *Tests for Flammability of Plastic Materials for Parts in Devices and Appliances*

UL 157, *Gaskets and Seals*

UL 248-14, *Low-Voltage Fuses – Part 14: Supplemental Fuses*

UL 310, *Electrical Quick-Connect Terminals*

UL 508, *Industrial Control Equipment*

UL 514A, *Metallic Outlet Boxes*

UL 514B, *Conduit, Tubing, and Cable Fittings*

UL 514C, *Nonmetallic Outlet Boxes, Flush-Device Boxes, and Covers*

UL 635, *Insulating Bushings*

UL 746C, *Polymeric Materials – Use in Electrical Equipment Evaluations*

UL 796, *Printed Wiring Boards*

UL 969, *Marking and Labeling Systems*

UL 1059, *Terminal Blocks*

UL 1434, *Thermistor-type Devices*

UL 4200A, *Products Incorporating Button Batteries or Coin Cell Batteries* (First edition including revisions through August 30, 2023)

UL 4248, *Fuseholders series*

UL 5085-1, *Low Voltage Transformers – Part 1: General Requirements*

UL 5085-2, *Low Voltage Transformers – Part 2: General Purpose Transformers*

UL 5085-3, *Low Voltage Transformers – Part 3: Class 2 and Class 3 Transformers*

3 Terms and definitions

For the purposes of this document, the following terms and definitions apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

• IEC Electropedia: available at http://www.electropedia.org/

• ISO Online browsing platform: available at http://www.iso.org/obp

NOTE Where the terms "voltage" and "current" are used, they imply the RMS values, unless otherwise specified.

ULSE INC. COPYRIGHTED MATERIAL – NOT AUTHORIZED FOR FURTHER REPRODUCTION OR DISTRIBUTION WITHOUT PERMISSION FROM ULSE INC.